Lead in Water Test Results Summary: Rosemont Middle School

Notes:

- **The lead in water Action Level is 15 parts per billion (ppb).**
  Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "**ND**" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[#] ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are **highlighted in red and precede an "Action Req." (Action Required) value** in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are **highlighted in orange and precede a "High" value** in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are **highlighted in yellow and precede a "Moderate" value** in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are **not highlighted and precede a "Low" value** in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
A109- Health Room Nurses Office Sink	19221000-001NS	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A107- Health Room Single User Bathroom Sink	19221000-002BF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A108-Bathroom Faucet. Single user staff restroom	19221000-003BF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A104 - Staff Faucet. Staff room sink	19221000-004SF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A104-Staff Facucet. Staff room sprayer	19221000-005SF	2/3/2026	3.1	Low	N/A	N/A	3.1
A105- Workroom Faucet	19221000-159SF	2/3/2026	0.82	Low	N/A	N/A	0.82
A119-Classroom Faucet	19221000-006CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
C101- Patio Classroom Faucet	19221000-007CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
C-106 Bathroom Faucet	19221000-008BF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
C101-Drinking water-left	19221000-009DW	2/3/2026	ND	Non-Detect	N/A	N/A	ND
C101-Drinking water-right	19221000-010DW	2/3/2026	ND	Non-Detect	N/A	N/A	ND
C107-Bathroom Faucet	19221000-011BF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
C105-Classroom Faucet Left	19221000-012CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
C105-Classroom Faucet Right	19221000-013CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
C105-Classroom Faucet Sprayer	19221000-014CF	2/3/2026	0.59	Low	N/A	N/A	0.59
C103-Classroom Faucet	19221000-015CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
C104-Classroom Faucet	19221000-016CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B121-Classroom Faucet	19221000-017CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B120-Classroom Faucet	19221000-018CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B116-Classroom Faucet	19221000-019CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B117-Classroom Faucet	19221000-020CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B119-Classroom Faucet	19221000-021CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B118- Science Classroom Faucet middle of room	19221000-022CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B118- Science Classroom Faucet East wall Right	19221000-023CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B118- Science Classroom Faucet East wall center	19221000-024CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B118- Science Classroom Faucet East wall Left	19221000-025CF	2/3/2026	0.57	Low	N/A	N/A	0.57
B118- Science Classroom Faucet North wall right	19221000-026CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B118- Science Classroom Faucet North wall left	19221000-027CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B118- Science Classroom Faucet West wall right	19221000-028CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B118- Science Classroom Faucet West wall center	19221000-029CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B118- Science Classroom Faucet west wall left	19221000-030CF	2/3/2026	0.77	Low	N/A	N/A	0.77
B114-Science Prep Staff Faucet	19221000-031SF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B107- Staff Faucet	19221000-032SF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B110-Hallway Drinking Faucet	19221000-033DF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B110 -Hallway Bottle Filler	19221000-034WF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B113- Boys Bathroom Left Faucet	19221000-035BF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B113- Boys Bathroom Right Faucet	19221000-036BF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B111-Single User Bathroom Faucet	19221000-037BF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B112- Girls Bathroom Left Faucet	19221000-038BF	2/3/2026	ND	Non-Detect	N/A	N/A	ND

B112- Girls Bathroom Right Faucet	19221000-039BF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B105- Classroom Faucet	19221000-040CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B106- Classroom Faucet	19221000-041CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B101- Classroom Faucet	19221000-042CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B102 -Classroom Faucet	19221000-043CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B103- Classroom Faucet	19221000-044CF	2/3/2026	0.61	Low	N/A	N/A	0.61
B104- Science Classroom Faucet middle of room	19221000-045CF	2/3/2026	1.6	Low	N/A	N/A	1.6
B104- Science Classroom Faucet East wall right	19221000-046CF	2/3/2026	0.72	Low	N/A	N/A	0.72
B104- Science Classroom Faucet East wall center	19221000-047CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B104- Science Classroom Faucet East wall left	19221000-048CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B104- Science Classroom Faucet North wall right	19221000-049CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B104- Science Classroom Faucet North wall left	19221000-050CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B104- Science Classroom Faucet West wall right	19221000-051CF	2/3/2026	0.77	Low	N/A	N/A	0.77
B104- Science Classroom Faucet West wall center	19221000-052CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
B104- Science Classroom Faucet West wall left	19221000-053CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A142- Classroom Faucet	19221000-054CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A139- Classroom Faucet	19221000-055CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A140- Classroom Faucet	19221000-056CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A143- Classroom Faucet	19221000-057CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A138- Classroom Faucet	19221000-058CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A144-Science Classroom Faucet middle of room	19221000-060CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A144-Science Classroom Faucet East wall left	19221000-061CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A144-Science Classroom Faucet East wall center	19221000-062CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A144-Science Classroom Faucet East wall right	19221000-063CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A144-Science Classroom Faucet South wall left	19221000-064CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A144-Science Classroom Faucet South wall right	19221000-065CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A144-Science Classroom Faucet West wall left	19221000-066CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A144-Science Classroom Faucet West wall center	19221000-067CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A144-Science Classroom Faucet West wall right	19221000-068CF	2/3/2026	1.3	Low	N/A	N/A	1.3
A136-Girls Bathroom Left Faucet	19221000-069BF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A136-Girls Bathroom Right Faucet	19221000-070BF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A134-Single User Bathroom Faucet	19221000-071BF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A128- Hallway Drinking Fountain	19221000-072DW	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A128- Water Bottle Filler	19221000-073WF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A135- Boys Bathroom Left Faucet	19221000-074BF	2/3/2026	0.56	Low	N/A	N/A	0.56
A135- Boys Bathroom Right Faucet	19221000-075BF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A131- Classroom Faucet	19221000-076CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A127- Classroom Faucet	19221000-077CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A126- Classroom Faucet	19221000-078CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A124- Classroom Faucet	19221000-079CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A125- Classroom Faucet	19221000-080CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A129-Science Classroom Faucet middle of room	19221000-081CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A129-Science Classroom Faucet East wall left	19221000-083CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A129- Science Classroom Faucet East wall center	19221000-084CF	2/3/2026	1.8	Low	N/A	N/A	1.8
A129- Science Classroom Faucet East wall right	19221000-085CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A137- Science Prep Faucet (staff)	19221000-087SF	2/3/2026	0.98	Low	N/A	N/A	0.98

A129- Science Classroom Faucet South wall left	19221000-088CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A129- Science Classroom Faucet South wall right	19221000-089CF	2/3/2026	1.2	Low	N/A	N/A	1.2
A129- Science Classroom Faucet West wall left	19221000-090CF	2/3/2026	0.78	Low	N/A	N/A	0.78
A129- Science Classroom Faucet West wall center	19221000-091CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A129- Science Classroom Faucet West wall right	19221000-092CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
A130- Classroom Faucet	19221000-093CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
D108- Girls Bathroom Faucet Left	19221000-094BF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
D108- Girls Bathroom Faucet Right	19221000-095BF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
D109- Boys Bathroom Faucet Left	19221000-096BF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
D109- Boys Bathroom Faucet Right	19221000-097BF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
D107- Hallway Drinking Fountain	19221000-098DW	2/3/2026	ND	Non-Detect	N/A	N/A	ND
D107- Hallway Bottle Filler	19221000-099WF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
D113- Main Gym Drinking Fountain Left	19221000-100DW	2/3/2026	0.62	Low	N/A	N/A	0.62
D113- Main Gym Drinking Fountain Right	19221000-101DW	2/3/2026	ND	Non-Detect	N/A	N/A	ND
D114B- Single User Bathroom Faucet Kitchen	19221000-102BF	2/3/2026	0.97	Low	N/A	N/A	0.97
D114- Kichen Faucet. Dishwashing sink left	19221000-103KF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
D114- Kichen Faucet. Dishwashing sink sprayer	19221000-148KF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
D114- Kitchen Faucet. Dishwasing sink right	19221000-104KF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
D114- Kitchen Faucet. Handwashing sink right	19221000-105KF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
D114- Kitchen Faucet. Food prep sink	19221000-106KF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
D118- Boys Locker Room Faucet Left	19221000-107BF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
D118- Boys Locker Room Faucet Center	19221000-108BF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
D118- Boys Locker Room Faucet Right	19221000-109BF	2/3/2026	4.5	Low	N/A	N/A	4.5
D122- Girls Locker Room Faucet Left	19221000-119BF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
D122- Girls Locker Room Faucet Center	19221000-120BF	2/3/2026	0.6	Low	N/A	N/A	0.6
D122- Girls Locker Room Faucet Right	19221000-121BF	2/3/2026	0.52	Low	N/A	N/A	0.52
D107- Hallway Drinking Fountain Left	19221000-131DW	2/3/2026	ND	Non-Detect	N/A	N/A	ND
D107- Hallway Drinking Fountain Right	19221000-132DW	2/3/2026	ND	Non-Detect	N/A	N/A	ND
E104- Classroom Faucet	19221000-133CF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
Concessions- Men's Bathroom Faucet	19221002-151BF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
Concessions- Outside Drinking Water Fountain Left	19221002-152DW	2/3/2026	1.4	Low	N/A	N/A	1.4
Concessions- Outside Bottle Filler	19221002-153WF	2/3/2026	0.87	Low	N/A	N/A	0.87
Concessions- Outside Drinking Water Fountain Right	19221002-154DW	2/3/2026	ND	Non-Detect	N/A	N/A	ND
Concessions- Women's Bathroom Faucet	19221002-155BF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
Concessions - Prep Sink	19221002-156KF	2/3/2026	ND	Non-Detect	N/A	N/A	ND
Concessions - Prep Sink Sprayer	19221002-157KF	2/3/2026	1.5	Low	N/A	N/A	1.5
Concessions - Ice Machine	19221002-158IM	2/3/2026	ND	Non-Detect	N/A	N/A	ND