

PO Box 733  
Marlboro, NY 12542  
Phone 845-236-7823  
Fax 845-236-3911  
NYSDOH #10824

## **ENVIRONMENTAL LABWORKS, INC.**

---

February 11, 2026

Millbrook Central School District  
43 Alden Place  
Millbrook, NY 12545

Dear John,


The following are results of the analyses performed on water samples from **Millbrook Middle School - 43 Alden Place, Millbrook, NY** received at the laboratory on 01/22/26.

Date/Time Collected: 01/13/26 8:30am  
Collected By: MCSD  
Project ID: 01222604  
Secondary ID: MB260402-03

| LOCATION/<br>SAMPLE ID        | PARAMETER         | RESULTS       | ACTION LEVEL | ANALYZED |
|-------------------------------|-------------------|---------------|--------------|----------|
| MS Room 44 Cold<br>01222604-1 | EPA 200.8<br>Lead | <0.00040 mg/L | 0.005 mg/L   | 01/30/26 |
| MS Room 44 Hot<br>01222604-2  | EPA 200.8<br>Lead | 0.00320 mg/L  | 0.005 mg/L   | 01/30/26 |

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #12150. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi  
Laboratory Director