Addendum 02

PROJECT:

MCSD Bid No.: 2025-6
26th Street MARS/ELO-P Facility
Increments No. 1 & No. 2

Date: February 12, 2026
TETER Project No.: 23-13084

CLIENT:

Merced City School District
444 W. 23rd St.
Merced, CA 95340

Client Project No.: Bid 2025-6
DSA Application No.: 02-123377
DSA File No.: 24-35

The following additions, deletions and revisions to the plans, specifications and Addenda shall become a part of the plans and specifications. It is the responsibility of the General Contractor to submit the information contained in this addendum to all subcontractors and suppliers. The Bidder shall acknowledge receipt of the Addendum in the Bid Proposal.
*(Addendum number of pages: **12** pages + **61** attachment = **73** total pages).*

PROCEDURAL:

2 - 01: **DOCUMENT ACCESS,** in addition to the Exchanges listed on the Notice to Bidders, Bidding documents can be access at the following link: https://ftp.teterae.com/f/3f7723220bb2df7e

CONSTRUCTION DOCUMENTS:

2 - 02: **A100-02 OVERALL PROPOSED SITE PLAN, PG&E GAS METER ENCLOSURE,** Merced City School District is in communication with PG&E for new electrical and gas services. Gas meter will be placed in a CMU enclosure on the southeast corner of the site. Designs are still in negotiations. A meeting with PG&E will be set once the NTP is issued. Please refer to attached sheet A100-02 for enclosure location. Please provide enclosure in your bid. (1 pages combined):

REQUEST FOR INFORMATION (RFI):

2 - 03: **RFI #1 –** 1/15/26
QUESTION: License requirements for the project.
RESPONSE: Requirement will be Class "B" license.
Attachment (0 pages)

2 - 04: **RFI #2 –** 1/19/26
QUESTION: Does Merced City School District have a PLA (public labor agreement) or a STW (skilled and trained workforce) requirement.
RESPONSE: This project does not have a PLA (public labor agreement) or STW (skilled and trained workforce) requirements.
Attachment (0 pages)

2 - 05: **RFI #3 –** 1/20/26
QUESTION: Please provide information on the manufactures kit-of-parts building provided by the district.
RESPONSE: Information provided in addenda 1 issued 1/29/26.
Attachment (0 pages)

2 - 06: **RFI #4 –** 1/23/26
QUESTION: The Notice to Bidders issued for the above project makes mention of an “Instruction to Bidders” outline (see extracted below), however we cannot find one in any of the documents so far provided. Please provide.
RESPONSE: Instruction to bidders was issued with addenda 1 issued 1/29/26.
Attachment (0 pages)

2 - 07: **RFI #5 –** 1/23/26
QUESTION: Do we need to be prequalified with the Merced City School District?
RESPONSE: Only prime contractors are required to be qualified with the school district through Quality bidders. See instructions for qualifications in instruction to bidders.
Attachment (0 pages)

2 - 08: **RFI #6 –** 1/27/26
QUESTION: The Notice to Bidders infers that the Owners will be furnishing a “kit-of-parts” main building and storage building for the GC to erect. Could scope clarification be provided by the district as to what the exactly the “kit-of-parts” includes and what it excludes material wise and fabrication-wise thus establishing clear-cut responsibilities for all parties involved.
RESPONSE: Please refer to specification section 110113 Owner Furnished Contractor items issued with addenda 1 on 1/29/26.
Attachment (0 pages)

2 - 09: **RFI #7 –** 1/27/26
QUESTION: Are existing grades beneath the AC/AB available? If not, what is the depth of the existing AC/AB? Info requested to quantify earthwork for final grades.
RESPONSE: Refer to the geotechnical report, based on the boring logs, the existing asphaltic concrete section is 3" of asphalt with no aggregate base.
Attachment (15 pages)

2 - 10: **RFI #8 –** 1/28/26
QUESTION: Does the underground gas piping located under the bldgs need to be sleeved? See detail 1/P301-02.
RESPONSE: Underground natural gas piping routed beneath the building shall be installed in accordance with CPC 1212 and project details. Where gas piping passes beneath the building slab, piping shall be installed within a sleeve or conduit, continuous to daylight and sized to allow movement and inspection, unless otherwise detailed. Refer to Detail 1/P301-02 and Gas Riser Detail 8/P401-02 for sleeving, tracer wire, warning tape, and transition requirements.
Attachment (0 pages)

2 - 11: **RFI #9 –** 1/28/26
QUESTION: Section 221316, 2.2 has a heading of 'ABS Pipe and PVC Pipe Fittings' but with no further specification. Are ABS pipe and fittings ok to use for the below and above grade sanitary waste and vent piping?
RESPONSE: Yes, ABS pipe and fittings are acceptable for both below-grade and above-grade sanitary waste and vent piping, subject to compliance with CPC and local jurisdiction requirements. Installation shall comply with section 221316 and applicable CPC standards.
Attachment (0 pages)

2 - 12: **RFI #10 –** 1/28/26
QUESTION: Please provide a specification for the below and above grade grease waste and vent piping.
RESPONSE: Below-grade grease waste piping shall be heavy-duty no-hub cast iron, installed in accordance with CPC requirements and manufacturer recommendations, Above-grade frease waste and vent piping shall be no-hub cast iron unless noted otherwise, PVC and ABS is not permitted for grease waste piping.
Attachment (0 pages)

2 - 13: **RFI #11 –** 1/28/26
QUESTION: Please provide a specification for the above grade gas piping.
RESPONSE: Above-grade natural gas piping shall be Schedule 30 black steel pipe with threaded fittings, installed in accordance with CPC and NFPA 54. Piping shall be properly supported, labeled, and tested per code. Alternate approved materials may be submitted for review where permitted by the Authority Having Jurisdiction.
Attachment (0 pages)

2 - 14: **RFI #12 –** 1/30/26
QUESTION: Provide a specification for the water hammer arrestor described in note 44, sheet P001-02.
RESPONSE: Provide WHA-1 per J.R. Smith Model M#5005, 3/4-inch, at all quick-closing valves and solenoid-operated fixture per CPC 604.9, installed in accordance with the manufacturer's recommendations.
Attachment (0 pages)

2 - 15: **RFI #13 –** 2/3/26
QUESTION: Please advise when the deadline is to submit pre-bid RFI's
RESPONSE: Per pre-id job walk, Pre-bid RFI's last day 02/04/26 – RFI's can be answered within 72 hours prior to bid.
Attachment (0 pages)

2 - 16: **RFI #14 –** 2/4/26
QUESTION: Is the contractor responsible for providing SWPPP? This is mentioned on the civils, but is looks like we are disturbing less than an acre.
RESPONSE: No SWPPP, site is under an acre.
Attachment (0 pages)

2 - 17: **RFI #15 –** 2/4/26
QUESTION: Please provide the geotechnical report prepared by Krazan and Associates per 023000.
RESPONSE: Please refer to bid specifications appendix.
Attachment (0 pages)

2 - 18: **RFI #16 –** 2/4/26
QUESTION: There are currently two different plan sets for increment one available - please clarify which is correct.
RESPONSE: Both sets are identical. Mistake in upload.
Attachment (0 pages)

2 - 19: **RFI #17 –** 2/4/26
QUESTION: Is there a hazardous materials report available for the building that is to be demolished, per E100?
RESPONSE: Existing building previously removed prior demolition phase.
Attachment (0 pages)

2 - 20: **RFI #18 –** 2/4/26
QUESTION: Are there demolition plans available for the building that is to be demolished, per E100?
RESPONSE: Existing building previously removed prior demolition phase - E100 provided for overhead powerline scope of work**.**
Attachment (0 pages)

2 - 21: **RFI #19**
QUESTION: Is the modular elevator owner-furnished?
RESPONSE: Elevator to be contractor provide and contractor installed. Refer to specifications section 110113 provided with Addenda 1.
Attachment (0 pages)

2 - 22: **RFI #20 –** 2/4/26
QUESTION: Will phoenix provide the site-built machine room?
RESPONSE: Refer to construction drawings. to be site-built by general contractor.
Attachment (0 pages)

2 - 23: **RFI #21 –** 2/4/26
QUESTION: Please confirm that the notes indicating "by others" in the Phoenix drawings are to be interpreted "by the general contractor"
RESPONSE: Items noted as by others are to be provided by the general contractor.
Attachment (0 pages)

2 - 24: **RFI #22 –** 2/4/26
QUESTION: Will the contractor be responsible for utility use charges?
RESPONSE: Yes, contractor to be responsible for all new utility connections and services until site it turned over to owner.
Attachment (0 pages)

2 - 25: **RFI #23 –** 2/4/26
QUESTION: Will the contractor be responsible for any building permit fees?
RESPONSE: Please refer to General conditions provided in addenda 1, see 3.7.
Attachment (0 pages)

2 - 26: **RFI #24 –** 2/4/26
QUESTION: Will the contractor be responsible for providing a separate office trailer for the inspector of record?
RESPONSE: Please refer to General conditions provided in addenda 1. see 4.3.4.
Attachment (0 pages)

2 - 27: **RFI #25 –** 2/4/26
QUESTION: Are subcontractors subject to prequalification? Or only the prime contractor? The policy is unclear in the bid documents.
RESPONSE: Only the prime contractor is required to be pre-qualified with the district through quality bidders.
Attachment (0 pages)

2 - 28: **RFI #26 –** 2/4/26
QUESTION: Would the owner consider moving the bid date? Having a bid after a union holiday poses bid constraints.
RESPONSE: Bid date to remain 2/17/26.
Attachment (0 pages)

2 - 29: **RFI #27 –** 2/4/26
QUESTION: The sub list is currently asking for email, phone number, etc. Can this be submitted 24 hours post-bid? Publix contract code requires license, location, name, and trade.
RESPONSE: Refer to Division 00 Designation of Subcontractors section. His document must be executed and submitted with the bid.
Attachment (0 pages)

2 - 30: **RFI #28 –** 2/4/26
QUESTION: Please confirm that the project requires earthquake and flood endorsements for builder's risk policy-this increases the premium significantly.
RESPONSE: Please refer to Division 00 General requirements provided with addenda 1 for Course of Construction insurance requirements.
Attachment (0 pages)

2 - 31: **RFI #29 –** 2/4/26
QUESTION: Is the contractor responsible for providing the AED's?
RESPONSE: AED's cabinets to be contractor furnished and installed. AED to be provided by owner.
Attachment (0 pages)

2 - 32: **RFI #30 –** 2/4/26
QUESTION: Please clarify the pre-bid RFI deadline.
RESPONSE: No RFI can be responded to within 72 hours of the bid date and time. We would appreciate RFIs to be submitted prior to Wednesday 2/11/26 @ 2pm.
Attachment (0 pages)

2 - 33: **RFI #31 –** 2/4/26
QUESTION: When is the DVBE paperwork due? The documents indicate post-bid, but I want to confirm.
RESPONSE: DVBE forms must be submitted at time of bid. No exceptions
Attachment (0 pages)

2 - 34: **RFI #32 –** 2/4/26
QUESTION: Please clarify the project duration. There is conflicting information in the documents - both 180 days and 120 days are mentioned.
RESPONSE: Project duration will be 180 days from notice to proceed.
Attachment (0 pages)

2 - 35: **RFI #33 –** 2/4/26
QUESTION: Please confirm that this project is not subject to a PLA or Skilled and Trained Workforce requirements.
RESPONSE: No PLA required. Refer to Division 00 for all skilled and trained workforce requirements.
Attachment (0 pages)

2 - 36: **RFI #34 –** 2/4/26
QUESTION: Please confirm that there are no self-performance requirements (ie. The contractor must perform _% of the contract value with their own forces).
RESPONSE: Please refer to Division 00 documents for all contractor performance requirements.
Attachment (0 pages)

2 - 37: **RFI #35 –** 2/4/26
QUESTION: Has the owner confirmed the lead times for the PG&E work? This may be problematic on a tight construction schedule.
RESPONSE: Coordination with PG&E are underway, a meeting will be scheduled in the first week after the notice of award.
Attachment (0 pages)

2 - 38: **RFI #36 –** 2/4/26
QUESTION: Is there an estimated start date on this project?
RESPONSE: project will be awarded at the March 10 board meeting, NTP will be issued week of.
Attachment (0 pages)

2 - 39: **RFI #37 –** 2/4/26
QUESTION: Are the lead times known on the owner-furnished items?
RESPONSE: Owner furnished items are on order and will coordinate lead times with awarded contractor.
Attachment (0 pages)

2 - 40: **RFI #38 –** 2/4/26
QUESTION: Please confirm that there are no allowances to be included in our bid.
RESPONSE: No allowances at this time.
Attachment (0 pages)

2 - 41: **RFI #39 –** 2/4/26
QUESTION: Is the contractor responsible for the washer/dryer shown in the storage building?
RESPONSE: Washer/dry to be owner furnished owner installed.
Attachment (0 pages)

2 - 42: **RFI #40 –** 2/4/26
QUESTION: Please confirm that the turf shown on sheet A100 is sod turf, rather than synthetic turf**.**
RESPONSE: Refer to sheet L201-02 for all planting requirements.
Attachment (0 pages)

2 - 43: **RFI #41 –** 2/4/26
QUESTION: Would the district consider waiving the AISC certification requirement if the subcontractor can demonstrate they follow AISC specifications?
RESPONSE: Contractors may be LA City Certified as an alternate to AISC. Contractor must comply with one of the two requirements.
Attachment (0 pages)

2 - 44: **RFI #42 –** 2/4/26
QUESTION: What will the metal decking be filled with? There are conflicting notes, including acoustic insulation, lightweight concrete, normal weight concrete, and rigid insulation throughout the plans.
RESPONSE: The 2nd floor deck used on sheet S201-02 uses 3.25" of lightweight concrete over 3" deck type D1 on 1/S006-02. All other metal decks on the roof are bare decks, no concrete.
Attachment (0 pages)

2 - 45: **RFI #43 –** 2/4/26
QUESTION: Is the contractor truly responsible for the sideplate license fee? See S901.
RESPONSE: Yes, the steel fabricator is responsible Licensing fees as noted on S901-02, Note 1a.
Attachment (0 pages)

2 - 46: **RFI #44 –** 2/4/26
QUESTION: We noticed that there is an AISC certification program/designation or IAS Fabricator Inspection Program requirement in place for the fabricator and a designated AISC Certified Erector, Category ASCE for the erector. We would like to see if we could have those requirements waived and the wording changed to be, "fabrication and erection in accordance/conformance with AISC specifications for structural steel and erection", or similar.
RESPONSE: Contractors may be LA City Certified as an alternate to AISC. Contractor must comply with one of the two requirements.
Attachment (0 pages)

2 - 47: **RFI #45 –** 2/4/26
QUESTION: Provide depth of continuous grade beam for Storage Building.
RESPONSE: The footing is 18" thick per detail 1/S701-02.
Attachment (0 pages)

2 - 48: **RFI #46 –** 2/4/26
QUESTION: The specs state that the GC will be responsible for receiving, unloading, handling, storing, protecting and installing the Owner-furnished items per the Operational Responsibility Matrix. Due to constrained possible storage/laydown area available on site, how will these OFCI items be delivered to the site? Will the delivery of OFCI's be on a phased "Just-in Time" basis or all at one time with the GC expected to store on-site.
RESPONSE: Due to limited site space. Owner will work with the contractor on storage and delivery of owner furnished items.
Attachment (0 pages)

2 - 49: **RFI #47 –** 2/4/26
QUESTION: Kitchen Equipment Schedule item KE-9, Kratos self-contained ice machine 69K-908, has been discontinued. Please provide an alternate ice machine.
RESPONSE: I was able to find Kratos 69K-908 still in stock. 69K-909 model is an acceptable alternate.
Attachment (0 pages)

2 - 50: **RFI #48 –** 2/4/26
QUESTION: Provide details (height) and locations of the wall protection required per spec section 1026000.
RESPONSE: 48″ height per specification. Recommend at all outside corners and end walls with drywall finish. Please refer to attached marked floor plan for locations.
Attachment (2 pages)

2 - 51: **RFI #49 –** 2/4/26
QUESTION: On page (SR 167399) 7 on the Instruction to Bidders, the time of completion for the Project states completion "shall be One Hundred and Eighty (180) calendar days". However on page (SR 167398) 1 on the Agreement Between Owner and Contractors Form, it stated that the time of completion for the Project "shall be One Hundred and Twenty (120) calendar days". Please clarify as to which is correct and amend the documentation accordingly.
RESPONSE: Construction duration to be (180) calendar days from notice to proceed.
Attachment (0 pages)

2 - 52: **RFI #50 –** 2/4/26
QUESTION: The toilet partition spec is conflicting for material as it is labeled Reinforced Composite Toilet Compartment but then it lists Scranton solid-polymer plastic toilet compartment. Please confirm the material.
RESPONSE: The specification section is mislabeled. Should just be "Toilet Compartments". The spec number and contents remain unchanged.
Attachment (0 pages)

2 - 53: **RFI #51 –** 2/4/26
QUESTION: Please confirm the address of which sealed bids will be received as none is explicitly listed for the receiving of bids.
RESPONSE: Bids will be publicly opened and read aloud at 2:01pm on the 17th day of February 2026 at the Merced City School District, Facilities Services Department Operational Center (OC), 2111 Wardrobe Avenue, Merced, CA. 95341
Attachment (0 pages)

2 - 54: **RFI #52 –** 1/28/26
QUESTION: Please provide specs for the grease waste piping, we are not finding any.
RESPONSE: Provide allowance for grease waste piping. Will coordinate prior to start of construction.
Attachment (0 pages)

2 - 55: **RFI #53 –** 2/5/26
QUESTION: The toilet partition spec is conflicting for material as it is labeled Reinforced Composite Toilet Compartment but then it lists Scranton solid-polymer plastic toilet compartment. Please confirm the material.
RESPONSE: The specification section is mislabeled. Should just be "Toilet Compartments". The spec number and contents remain unchanged.
Attachment (0 pages)

2 – 56: **RFI #54 –** 2/5/26
QUESTION: Please provide a responsibility matrix on the owner provided Kit of Parts.
RESPONSE: Please refer to Addenda No. 1 and specification 110113 "Owner Furnished Contractor Installed Items" for the responsibility matrix for owner provided items.
Attachment (0 pages)

2 - 57: **RFI #55 –** 2/6/26
QUESTION: Is the prequalification application to MEP's or only GC's? idf so, please provide a list of approved contractors.
RESPONSE: Only the Prime general contractor will be required to be prequalified with the district through Quality bidders. Prequalified bidders can be found through Quality bidders website @ www.qualitybiders.com. Please find attached latest list as of 2/11 @8am.
Attachment (37 pages)

2 - 58: **RFI #56 –** 2/6/26
QUESTION: The specification does not list dollar value for the insurance limits. Please provide.
RESPONSE: Please refer to Division 00 issued in Addenda 1. See instructions to bidders for bond requirements and Agreement Between Owner and Contractor for insurance limits.
Attachment (0 pages)

2 - 59: **RFI #57 –** 2/6/26
QUESTION: Section 051200, 1.6.A requires AISC certification for the steel fabricator. Can an LA City approved fabricator be used in place of AISC certification?
RESPONSE: Contractors may be LA City Certified as an alternate to AISC. Contractor must comply with one of the two requirements.
Attachment (0 pages)

2 - 60: **RFI #58 –** 2/6/26
QUESTION: The toilet partition spec is conflicting for material as it is labeled Reinforced Composite Toilet Compartment but then it lists Scranton solid-polymer plastic toilet compartment. Please confirm the material.
RESPONSE: The specification section is mislabeled. Should just be "Toilet Compartments". The spec number and contents remain unchanged.
Attachment (0 pages)

2 - 61: **RFI #59 –** 2/6/26
QUESTION: Please confirm that the list of owner-furnished items provided in addendum one applies to both buildings.
RESPONSE: Yes, this applies to both buildings.
Attachment (0 pages)

2 - 62: **RFI #60 –** 2/6/26
QUESTION: Can you confirm that you will be taking solar bids at this time or if it is deferred to a later time?
RESPONSE: No deferred items. Solar will be included in this bid and included in the bidding contractors scope per construction documents. Please refer to the pre-bid job walk list provided in addenda 1 for the list of bidding contractors.
Attachment (0 pages)

2 - 63: **RFI #61 –** 2/9/26
QUESTION: Please provide a specification for the custom stainless-steel counters.
RESPONSE: Refer to attached marked sheet K200-02 for information of (2) custom stainless steel counter tops. Omit one counter top in kitchen and replace with riser table.
Attachment (6 pages)

2 - 64: **RFI #62 –** 2/9/26
QUESTION: There is an unidentified rectangle in detail 14/k200-02, to the left of the call out "5.44". Please clarify what this is.
RESPONSE: This is a storage shelf. Refer to attached marked sheet K200-02 for product information.
Attachment (6 pages)

2 - 65: **RFI #63 –** 2/9/26
QUESTION: Please provide a legend for unidentified references, such as the "302" in a diamond above the cabinets in detail 2/K200-02.
RESPONSE: 302 refers to the Woodwork Institute casework (W.I.C.) cabinet number, Omit this upper cabinet and replace with BK stainless steel shelf., See attached marked drawing for reference.
Attachment (6 pages)

2 - 66: **RFI #64 –** 2/9/26
QUESTION: Is this a pre-vailing wage job?
RESPONSE: No project labor agreement, refer to the Division 00 specifications for all skilled and trained workforce requirements, OCIP and/or WRAP-UP fees along with Prevailing wage requirements.
Attachment (0 pages)

2 - 67: **RFI #65 –** 2/10/26
QUESTION: I keep seeing the abbreviation "C.O." on the electrical plans does this abbreviation also stand for conduit just like "C"?
RESPONSE: C.O. is conduit only. We have many locations where we put in conduit only infrastructure for the district to come in and add cables in the future.
Attachment (0 pages)

2 - 68: **RFI #66 –** 2/10/26
QUESTION: Can the license type and phone number be submitted within 24 hours? This save time and reduces errors on bid day.
RESPONSE: Sublists are due at the time of the bid and filled out per Division 00 requirements. No exceptions.
Attachment (0 pages)

2 - 69: **RFI #67 –** 2/11/26
QUESTION: Please clarify if the railing at the northeast side of bldg A should be a 6' Ornamental fence (sheet A100-02 for reference).
RESPONSE: All fencing to be decorative metal. Refer to Civil drawings C301-02 for all fencing locations and details**.**
Attachment (0 pages)

2 - 70: **RFI #68 –** 2/11/26
QUESTION: Please clarify if the gate in between bldgs A&B is to be an ornamental gate or chain-link fence (sheet A100-02).
RESPONSE: All fencing & gates to be decorative metal. Refer to Civil drawings C301-02 for all fencing locations and details.
Attachment (0 pages)

2 - 71: **RFI #69 –** 2/11/26
QUESTION: Would the district consider extending the deadline for our DVBE good-faith effort paperwork to 48 hours post-bid? This helps tremendously in ensuring accurate records of solicited vs received DVBE bids.
RESPONSE: All DVBE documents must be submitted at the time of the bid per requirements set forth in Division 00 specifications. No exceptions.
Attachment (0 pages)

2 - 72: **RFI #70 –** 2/11/26
QUESTION: Please clarify the DIR classification line item on the bid form - what is this classification referring to?
RESPONSE: California Department of Industrial Relations (DIR) requires that contractors and subcontractors biding or performing work on a public project be registered and provide their unique 10 digit number at bid time.
Attachment (0 pages)

2 - 73: **RFI #71 –** 2/11/26
QUESTION: Part 7 of the pavement specifications (appendix C) of the Geotechnical Report calls for a Fog Seal Coat to be applied. The project drawings and the asphalt paving spec make no reference to this requirement with call outs or identified areas. Please confirm that a seal coat is required for the project.
RESPONSE: Seal coat is not required for this project.
Attachment (0 pages)

2 - 74: **RFI #72 –** 2/11/26
QUESTION: There is a note on the plan saying "cap existing utility line" is this part of the project as no legend number and is not bolded out. Please confirm if this part of the scope of the project.
RESPONSE: Since the old sewer line that ran into the site has already been demo'd in the demolition phase of the project, it is safe to assume the sewer line was capped off. The caps shown on sheet C601-01 with Keynote 4 are only shown as caps because the on-site utilities were not shown in the Inc1 drawings. Contractor will not need to cap any of the new services assuming they will be doing the Inc1 & Inc2 work all at the same time.
Attachment (0 pages)

2 - 75: **RFI #73 –** 2/11/26
QUESTION: 1. Ref M002-02 - The VRF equipment schedule does not indicate a box controller. Is one required? 2. Ref M200-02 - The plan does not indicate BRF location of box controller, pipe size or routing inside the building. Will a Daikin LATS diagram be provided?
RESPONSE: Provide allowance for controller. Clarification will be provided prior to start of construction.
Attachment (0 pages)

2 - 76: **RFI #73 –** 2/11/26
QUESTION: Does the school district have a preferred or existing controls platform that this project is intended to match (e.g. Johnson Controls Metasys, Honeywell WEBs, Niagara-based system, etc.)? Additionally, is there a requirement for an open control protocol framework, or would a proprietary Johnson Controls Metasys system be more favorable? We want to make sure our proposed system architecture is consistent with the owner's integration and maintenance approach, particularity if this facility will be tied into an existing district-wide EMS. Any additional direction you can provide beyond what is shown in the drawings and Division 23 specifications would be greatly appreciated.
RESPONSE: he districts standard is Trane Controls. HVAC system shall tie into the current BAS system to ensure smooth operation and support across all sites.
Attachment (0 pages)

END OF ADDENDUM NO. 02

Robert Ingalls
Senior Project Manager

Attachment(s): [61 pages]

Sheet A100-02 Overall Proposed Site Plan, added for clarification of PG&E gas enclosure (1 page)

RFI #7 Response, Civil Street Plans (13 pages)

RFI #7 Response, Civil Street Topo Plans (2 pages)


RFI #48 Response, Wall protection marked floor plans (2 pages)

RFI #55 Response, Contractors Prequalified list, (37 pages)

RFI #61, 62, & 63 Response, Kitchen Equipment (6 pages)

ADDENDUM NO. 2

\\tetr-file1\Users\cesar.silva_TETR\Documents\13084-A-MCSD-260 K ST.IT WAREHOUSE_cesar.sil.rvt



SITE INFORMATION

OWNER:	MERCED CITY SCHOOL DISTRICT
ASMT:	030022008000
GIS ACRES:	0.69
GIS SQDT:	30,000.00
APN:	030022008
PARCEL:	088
PARCEL NUMBER:	030-022-008

KEYNOTES (30.00)

2.06	EXISTING OVERHEAD UTILITY LINES TO REMAIN
2.11	EXISTING UTILITY POLE TO REMAIN
3.07	CONCRETE BOLLARDS, SEE CIVIL
10.11	PARKING LOT TOW AWAY SIGN, SEE DETAIL 6/A110-02
10.16	NEW ACCESSIBLE PARKING SIGNAGE
10.17	"DO NOT ENTER" SIGN
10.19	PROVIDE SIGNAGE MOUNTED TO GATE, SIGN TO READ "PARKING LOT IS NOT A PASS-THROUGH FOR FIRE TRUCK", SEE DETAIL 5/A110-02
10.61	SURFACE MOUNTED KNOX BOX EMERGENCY SERVICES KEY STORAGE. COORDINATE SIZE, LOCATION, AND MOUNTING WITH LOCAL FIRE AUTHORITY AND DISTRICT
10.83	FLAGPOLE, SEE DETAIL 5/A110-02
21.04	PAINT TOP AND FACE OF CURB RED WITH 4" HIGH LETTERING "NO PARKING - FIRE LANE" AT 30' ON CENTER OF FACE OF CURB
26.11	NEW EV CHARGING STATION
28.12	GATE CONTROL AND PEDESTAL
32.24	CONCRETE STEPS
32.34	DETECTABLE WARNING SURFACE
32.41	ANGLED PARKING PER MERCED CITY STANDARDS 18.38.070
32.42	BUS TURNOUT PER CITY STANDARD TC-12
32.54	22' - 0" MOTORIZED DECORATIVE METAL ROLLING GATE
32.55	18' - 0" MOTORIZED DECORATIVE METAL ROLLING GATE
32.75	BICYCLE RACK, SEE DETAIL 3/A110-02

LEGEND

- (N) PROPOSED BUILDING
- (E) AC PAVING TO REMAIN, AT ALLEY WAY
- (E) CONC. PAVING TO REMAIN
- (N) CONC. PAVING
- (N) HEAVY DUTY CONC. PAVING
- (N) AC PAVING
- (N) TURF
- (N) LANDSCAPING - MATERIAL TO BE DETERMINE
- (N) COBBLE IMPROVEMENTS
- (N) CHAINLINK FENCE
- (N) DECORATIVE METAL FENCE
- (E) TREE TO REMAIN
- (N) TREE
- (N) CONCRETE MASONRY WALL (C.M.U.)
- (B) (N) ACCESSIBLE BOYS TOILET ROOM (1ST FLOOR) (THIS DSA APPLICATION NUMBER)
- (G) (N) ACCESSIBLE GIRLS TOILET ROOM (1ST FLOOR) (THIS DSA APPLICATION NUMBER)
- (S) (N) ACCESSIBLE STAFF TOILET ROOM (2ND FLOOR) (THIS DSA APPLICATION NUMBER)
- (DF) (N) ACCESSIBLE DRINKING FOUNTAIN (THIS DSA APPLICATION NUMBER)
- (E) F.H. EXISTING FIRE HYDRANT
- ASSUMED PROPERTY LINE
- ACCESSIBLE ROUTE, 2% MAX SLOPE ALL DIRECTIONS UNLESS RAMP OR SLOPED WALK DESIGNATES OTHER COMPLIANCE PER (2022 C.B.C. SECTION 11B - 206)

GATE SCHEDULE

MARK	CLEAR WIDTH	HEIGHT	MATERIAL	REMARKS
G-1	20' - 0"	6' - 0"	DECORATIVE/ ROLLING GATE	B
G-2	20' - 0"	6' - 0"	DECORATIVE/ ROLLING GATE	B
G-3	4' - 0"	6' - 0"	DECORATIVE	A,C
G-4	4' - 0"	6' - 0"	DECORATIVE	A,C
G-5	8' - 0"	6' - 0"	DECORATIVE	A
G-6	10' - 0"	6' - 0"	DECORATIVE	B
G-7	4' - 0"	6' - 0"	DECORATIVE	B
G-8	4' - 0"	6' - 0"	DECORATIVE	B
G-9	4' - 0"	6' - 0"	SOLID UTILITY YARD GATE	B
G-10	4' - 0"	6' - 0"	SOLID TRASH ENCLOSURE GATE	B
G-11	3' - 0"	6' - 0"	DECORATIVE	B
G-12	6' - 4"	3' - 0"	STEEL PIPE POST	B

REMARKS:
A. EGGRESS GATE, PROVIDE PANIC HARDWARE, ACCESSIBLE
B. MAINTENANCE SERVICE GATE
C. ALL GATES TO HAVE LEVEL LANDINGS, 5'-0" PULL SIDE & 4'-0" PUSH SIDE, SEE 4/A110-02 FOR ACCESSIBLE MANUVERING CLEARANCES

PARKING INFORMATION:

TOTAL NUMBER OF SPACES PROVIDED: 34

ACCESSIBLE PARKING SPACES
- REQUIRED: 2: 26-50 (CBC TABLE 11B-208.2)
- PROVIDED (TOTAL): 2
  - STANDARD ACCESSIBLE: 1
  - VAN ACCESSIBLE: 1
- NOTE: THE NUMBER OF SPACES WITH EV CHARGING EQUIPMENT MAY BE DEDUCTED FROM THE TOTAL NUMBER OF SPACES FOR THE PURPOSE OF DETERMINING THE NUMBER OF ACCESSINBLE PARKING SPACES REQUIRED (CBC 11B-208.1)

EV CAPABLE SPACES
- REQUIRED: 8: 26-50
  - 2 OF 8 TO BE PROVIDED WITH CHARGING EQUIPMENT (CGBSC TABLE 5.106.5.6.1)
- PROVIDED:
  - EV CAPABLE W/O EQUIP.:
  - EV WITH CHARGING EQUIP: 2

ACCESSIBLE EV CHARGING SPACES
- (CBC TABLE 11B-228.3.2.1)
- VAN ACCESSIBLE
  - REQUIRED: 1
  - PROVIDED: 1
- STANDARD ACCESSIBLE
  - REQUIRED: 1
    - (NOTE: 1 STD ACCESSIBLE REQUIRED WHEN 5 OR MORE EV CHARGING STATIONS PROVIDED)
  - PROVIDED: 1
- AMBULATORY
  - REQUIRED: 0
  - PROVIDED: 0

NOTE:

SHEET NOT REVIEWED FOR DSA ACCESS COMPLIANCE AS PART OF THIS DSA INCREMENT 1 APPLICATION. SHEET TO BE REVIEWED AS PART OF THE DSA INCREMENT 2 APPLICATION

OVERALL PROPOSED SITE PLAN — 1" = 10'-0" — 8

PLOT DATE: 12/19/2025 11:10:46 AM

IDENTIFICATION STAMP
DIV. OF THE STATE ARCHITECT
APP: 02-123377 INC: 02
REVIEWED FOR
SS ☑ FLS ☑ ACS ☑
DATE: 01/08/2026

Teter, Inc. expressly reserves its common law copyright and other property rights in these plans. This document, the ideas and designs incorporated herein, as an instrument of professional service, is not to be used in whole or in part, for any other project without prior written authorization.

MARK	DATE	DESCRIPTION
	12/22/25	INC. 02 DSA SUBMITTAL

LICENSED ARCHITECT CHRISTOPHER NIKKEL C 39563 STATE OF CALIFORNIA

TETER, INC.
ARCHITECTS ENGINEERS CONNECTED
FRESNO HEADQUARTERS
VISALIA | BAKERSFIELD | MODESTO | SAN LUIS OBISPO

TETER

26TH STREET MARS/ELO-P FACILITY
MERCED CITY SCHOOL DISTRICT
2600 K STREET INCREMENT 02
MERCED, CA 95348

DRAWING TITLE: OVERALL PROPOSED SITE PLAN


PROJECT NO. 24-13084.00

DRAWING A100-02

MERCED CITY SCHOOL DISTRICT
PLANS FOR THE IMPROVEMENTS OF
26TH STREET MARS/ ELO-P FACILITY
2600 K STREET MERCED, CA. 95348


NOT TO BE INCLUDED IN CONSTRUCTION DRAWINGS

"FOR REFERENCE ONLY"



VICINITY MAP

NOT TO SCALE



LOCATION MAP

SCALE: 1"=30'

GENERAL NOTES:

1) RESTORATION REQUIREMENTS
   a. ARTERIAL STREET - AC 5.5" MIN OR 1" THICKER THAN EXISTING, WHICHEVER IS GREATER. AB 20.5" MIN COMPACTED TO 95%, AB CALTRANS CLASS II - SUBMIT CERT OF COMPLIANCE.
   b. COLLECTOR STREET - AC 4.0" MIN OR 1" THICKER THAN EXISTING, WHICHEVER IS GREATER. AB 15.5" MIN COMPACTED TO 95%, AB CALTRANS CLASS II - SUBMIT CERT OF COMPLIANCE.
   c. LOAL STREET - AC 2.5" MIN OR 1" THICKER THAN EXISTING, WHICHEVER IS GREATER. AB 11" MIN COMPACTED TO 95% ,AB CALTRANS CLASS II - SUBMIT CERT OF COMPLIANCE.
   d. SIDEWALK - FULL FLAG REMOVAL FOR ALL AFFECTED FLAGS, DOWELED UPON REPLACMENT
   e. CURB RAMPS - FULL COMPLETE REPLACEMENT OF CURB RAMP IF AFFECTED AT ANY SECTION INCLUDING CURB RETURNS
   f. CURB AND GUTTER - REPLACE ANY AFFECTED CURB/GUTTER TO SCORE LINES AND MAINTAIN FLOW LINES
   g. LANDSCAPE - REPLACE TO KIND OR BETTER. RE-SOD GRASS AREA.
   h. CROSSWALKS & BIKE LANES - RESTORATION WITHIN BIKE LANES AND CROSSWALKS TO BE FLUSH WITH EXISTING PAVEMENT. ANY DAMAGED STRIPING TO BE REPLACED TO BETTER. “BIKE LANE” OR SYMBOLS WITHIN THE BIKE LANE (NOT INCLUDING BOUNDARY LINE STRIPING FOR BIKE LANE) WILL REQUIRE FULL VERBAGE OR SYMBOL TO BE REPAINTED WITH A GREEN ANTI SKID THERMAL PLASTIC. CROSSWALKS WILL REQUIRE BOTH SIDES FULLY REPAINTED. STOP LOCATIONS WILL REQUIRE COMPLETE REPAINT OF “STOP” AND STOP BAR IF IMPEDED.
2) WORKING NEAR TRAFFIC SIGNALS - IF PAVEMENT HAS NO DAMAGE, CRACKING AND IS IN PRISTINE SHAPE, WORK TO STAY AT LEAST 1FT FROM TRAFFIC LOOP. IF PAVEMENT HAS DAMAGE OR ALLIGATOR CRACKS, WORK TO STAY AT LEAST 3 FT FROM TRAFFIC LOOP. FAILURE TO WORK WITHIN THESE GUIDELINES WILL RESULT IN THE REPLACEMENT OF TRAFFIC LOOP AT THE COST OF THE CONTRACTOR.
3) ALL WORK THAT REQUIRES TEMPORARY PLATING OF BELLHOLE/TRENCH SHALL BE ANCHORED TO PREVENT MOVEMENT
4) ALL UTILITIES SHALL BE INSTALLED AT A 42 INCH MINIMUM DEPTH AND TO LATEST CITY OF MERCED STANDARDS OF DESIGN
5) POST-CONSTRUCTION MONUMENT PRESERVATION REQUIRED IF PRE-CONSTRUCTION MONUMENT PRESERVATION WAS PRESENTED OR REQUIRED.
6) THE FOLLOWING REQUIREMENTS INCLUDE STRUCTURAL SECTIONS, INCLUDING BUT NOT LIMITED TO, SIDEWALKS, RAMPS, DRIVEWAYS, STREETS, CURB AND GUTTER
   a. SLURRY IS NOT AN ACCEPTABLE BACKFILL EXCEPT WITHIN A FULL DEPTH RECLAMATION (FDR) ROAD SECTION. THE USE OF SLURRY SHALL BE APPROVED IN WRITING BY THE CITY ENGINEER PRIOR TO PLACEMENT. ALL SLURRY IN FDR SECTIONS SHALL BE 500PSI AND SHALL BE TESTED AT THE CONTRACTORS EXPENSE.
   b. ASPHALT CONCRETE (AC), OVER 1 FOOT BY 1 FOOT (POTHOLE) WILL REQUIRE COMPACTION TESTING.
   c. IF COMPACTION IS REQUIRED, THE AC SHALL BE SAWCUT TO A MINIMUM OF 2 FEET BY 2 FEET TO ALLOW FOR PROPER COMPACTION AND TESTING.
   d. AC SHALL BE FLUSH WITH SURROUNDING STREETS
   e. CRUSHED ROCK SHALL NOT BE USED FOR ANY TYPE OF BACKFILL.
   f. POTHOLES SHALL BE BACKFILLED AND CAPPED IN A MANNER SUCH THAT IT REMAINS FLUSH WITH THE EXISTING STREET, AT LEAST 3 INCH THICK COLD PATCH
   g. DEPRESSIONS OR PROTRUSION (HUMP) WILL NOT BE ACCEPTED, EVEN AFTER FINAL INSPECTION HAS BEEN GIVEN.
7) POLES NEED TO BE REPLACED IN A TIMELY MANNER. VARIES BY PROJECT WILL NEED TO CHECK WITH CITY ENGINEER.
8) SHOULD WORK EXCEED THE ORIGINAL AGREED PLAN, CITY OF MERCED RESERVES THE RIGHT TO CHANGE THE REQUIREMENTS OF THE RESTORATION OR PERMIT OBLIGATIONS.
9) ALL WORK TO BE DONE TO CITY OF MERCED STANDARDS OF DESIGN AND ANY LATEST ADA REQUIREMENTS

PROJECT DIRECTORY:

OWNER: ADMINISTRATION OFFICE	MERCED CITY SCHOOL DISTRICT 2105 WARDROBE AVE MERCED, CA 95340
CONTACT:	BRYAN BEHN
PHONE:	(209) 385-6332
CIVIL ENGINEER:	BLAIR, CHURCH & FLYNN CONSULTING ENGINEERS 451 CLOVIS AVE., SUITE 200 CLOVIS, CA 93612
CONTACT:	ZACH HOCKETT
PHONE:	(559) 326-1400
LANDSCAPE ARCHITECT:	BLAIR, CHURCH & FLYNN CONSULTING ENGINEERS 451 CLOVIS AVE., SUITE 200 CLOVIS, CA 93612
CONTACT:	CATO HESKETT
PHONE:	(559) 326-1400

TABLE OF CONTENTS

SHEET NUMBER	SHEET TITLE
C100	COVER SHEET
C200	DEMOLITON PLAN
C300	STREET PLANS
C400	EROSION & SEDIMENT CONTROL PLAN
X100	SECTIONS
X101	DETAILS
X102	DETAILS
L100	IRRIGATION PLAN
L101	IRRIGATION DETAILS
L102	IRRIGATION DETAILS
L103	IRRIGATION DETAILS
L200	PLANTING PLAN
L201	PLANTING DETAILS
TOTAL SHEET COUNT: 13	

Know what's below. Call before you dig.

Blair, Church & Flynn
CONSULTING ENGINEERS

REGISTERED PROFESSIONAL ENGINEER — ZACHARY D. HOCKETT — No. 87,218 — CIVIL — STATE OF CALIFORNIA

08/29/2025
Date Signed:

CONSULTANT

Blair, Church & Flynn
Consulting Engineers
451 Clovis Avenue,
Suite 200
Clovis, California 93612
Tel (559) 326-1400
Fax (559) 326-1500

REF. & REV.

MERCED CITY SCHOOL DISTRICT


26TH STREET MARS/ELO-P FACILITY
2600 K STREET MERCED, CA 95348
COVER SHEET

DR. BY: AR
CH. BY: ZH
DATE: XX/XX/XX
SCALE AS NOTED


C100

Drawing: P:\224\224-0395\Site\productiondrawings\Off Site\224395co-offsite.dwg; Layout1 - BCF.ctb
Plot by: jfelix Feb 05, 2026 - 1:59pm


Loaded Xrefs



A / C200 26TH STREET ENLARGED DEMOLITION PLAN



B / C200 K STREET ENLARGED DEMOLITION PLAN



C / C200 ALLEY ENLARGED DEMOLITION PLAN

DEMOLITION LEGEND:

- REMOVE EXISTING IMPROVEMENTS AS NECESSARY TO CONSTRUCT NEW IMPROVEMENTS SHOWN ON THESE PLANS UNLESS OTHERWISE NOTED ON THE PLAN. THE REMOVAL OF IMPROVEMENTS MUST BE COORDINATED WITH ALL PLAN SHEETS. CONTRACTOR MUST ALSO COORDINATE REMOVAL OF IMPROVEMENTS WITH UTILITY AGENCIES. PROTECT ALL IMPROVEMENTS NOT DESIGNATED FOR REMOVAL. SEE NOTE 1
- LIMITS OF VEGETATION REMOVAL. 4" MINIMUM DEPTH
- LIMITS OF CONCRETE IMPROVEMENT REMOVAL
- LIMITS OF ASPHALTIC CONCRETE IMPROVEMENT REMOVAL
- DE — DISCONNECT ELECTRICAL SERVICE; COORDINATE WITH ELECTRICAL UTILITY PROVIDER
- PA — PROTECT ASPHALT CONCRETE PAVEMENT TO REMAIN
- PC — PROTECT CONCRETE IMPROVEMENTS TO REMAIN
- PS — PROTECT SIGN TO REMAIN
- PU — PROTECT UTILITY TO REMAIN
- PV — PROTECT SHRUBS TO REMAIN
- RA — REMOVE ASPHALT CONCRETE PAVEMENT STRUCTURAL SECTION
- RC — REMOVE CONCRETE IMPROVEMENTS
- RT — REMOVE TREE AND ROOT BALL, SEE NOTE 11
- RU — REMOVE UTILITY
- RV — STRIP AND REMOVE VEGETATION
- SC — SAWCUT
- CURB REMOVAL
- OE — EXISTING ELECTRICAL SERVICE TO BE DISCONNECTED
- G — LIMIT OF GAS LINE REMOVAL
- SD — LIMIT OF STORM DRAIN LINE REMOVAL
- S — LIMIT OF SEWER LINE REMOVAL
- W — LIMIT OF WATER LINE REMOVAL
- CAP EXISTING UTILITY
- REMOVE TREE

GENERAL DEMOLITION NOTES:

1. THE "LIMIT OF DEMOLITION" SHOWN IS APPROXIMATE AND IS GENERALLY CONSIDERED TO BE THE MINIMUM REMOVAL REQUIREMENTS. CONTRACTOR MUST COORDINATE AS NOTED IN THE LEGEND.
2. CONTRACTOR SHALL LEGALLY DISPOSE OF ALL DEMOLISHED MATERIALS OFF SITE.
3. CONTRACTOR SHALL PROTECT ALL EXISTING UTILITY IMPROVEMENTS NOT SPECIFICALLY DESIGNATED FOR REMOVAL.
4. THE ON-SITE UNDERGROUND UTILITIES SHOWN ON THIS SHEET ARE AT APPROXIMATE LOCATIONS. THE EXTENT, LOCATIONS AND SIZES ARE UNKNOWN. THE CONTRACTOR SHALL POTHOLE TO LOCATE AND VERIFY THE UNDERGROUND UTILITY LINES PRIOR TO REMOVAL.
5. CONTRACTOR TO PROTECT AND PRESERVE IN PLACE ANY FOUND SURVEY MONUMENTS. ANY MONUMENTS DISTURBED SHALL BE RESET BY A CALIFORNIA LICENSED SURVEYOR AND THE APPROPRIATE PAPERWORK FILED WITH THE CITY OR COUNTY, AT CONTRACTOR'S EXPENSE.
6. ALL HAZARDOUS MATERIALS ENCOUNTERED DURING SITE DEMOLITION SHALL BE REMEDIATED AND DISPOSED OF PER STATE AND EPA REQUIREMENTS.
7. CONTRACTOR SHALL CONTACT AND COORDINATE WITH ALL UTILITY AGENCIES PRIOR TO THE START OF ANY DEMOLITION OR CONSTRUCTION.
8. ANY EXISTING UTILITIES AND/OR IMPROVEMENTS WHICH ARE TO REMAIN, THAT BECOME DAMAGED DURING CONSTRUCTION SHALL BE COMPLETELY RESTORED TO THE SATISFACTION OF THE OWNER AND AGENCY HAVING AUTHORITY, AT THE CONTRACTOR'S SOLE EXPENSE.
9. REMOVE EXISTING IMPROVEMENTS AS NECESSARY TO CONSTRUCT NEW IMPROVEMENTS SHOWN ON THESE PLANS.
   a) FOR CONCRETE REMOVAL, REMOVE TO THE NEXT NEAREST TOOLED JOINT OR EXPANSION JOINT OF IMPROVEMENTS DESIGNATED TO REMAIN.
   b) FOR ASPHALTIC PAVEMENT REMOVAL. SAWCUT TO A STRAIGHT, CLEAN EDGE AT LOCATIONS INDICATED ON THE PLANS.
10. COMPLIANCE WITH FIRE SAFETY DURING CONSTRUCTION WILL BE ENFORCED.
11. WHERE TO BE REMOVED, EXISTING TREES SHALL BE REMOVED AND THE ROOT SYSTEM THOROUGHLY CLEARED OF ROOT BALLS AND ISOLATED ROOTS GREATER THAN 1/2 INCH IN DIAMETER. WHERE ROOTS ARE WITHIN ANY STRUCTURAL SECTIONS OF SIDEWALK, ROADWAY, OR CURB AND GUTTER, THE AREA SHALL BE THOROUGHLY CLEARED OF ROOT BALLS AND ISOLATED ROOTS GREATER THAN 1/2 INCH IN DIAMETER .

NOT TO BE INCLUDED IN CONSTRUCTION DRAWINGS

"FOR REFERENCE ONLY"

811 Know what's below. Call before you dig.

Blair, Church & Flynn
CONSULTING ENGINEERS


ZACHARY D. HOLT No. 87218 CIVIL STATE OF CALIFORNIA
08/29/2025
Date Signed:


CONSULTANT	REF. & REV.	MERCED CITY SCHOOL DISTRICT	
Blair, Church & Flynn Consulting Engineers 451 Clovis Avenue, Suite 200 Clovis, California 93612 Tel (559) 326-1400 Fax (559) 326-1500		26TH STREET MARS/ELO-P FACILITY 2600 K STREET MERCED, CA 95348 DEMOLITON PLAN	DR. BY: AR CH. BY: ZH DATE: XX/XX/XX SCALE AS NOTED
			C200

Drawing: P:\224\224-0395\Site\productiondrawings\Off Site\224395_de01-offsite.dwg; layout1 - BCF.ctb
Plot by: jfelix Feb 05, 2026 - 1:59pm


Loaded Xrefs


ADDENDUM NO. 2







A / C300 26TH STREET PLAN





B / C300 K STREET PLAN





C / C300 ALLEY STREET PLAN

CONSTRUCTION LEGEND:

- (A / C300) — DETAIL DESIGNATION / DETAIL REFERENCE / SHEET LOCATION
- [A/C300] — [DETAIL DESIGNATION / SHEET LOCATION]
- (shaded) — LIMITS OF ASPHALTIC CONCRETE PAVEMENT STRUCTURAL SECTION. MIN. 4" AC OR 1" THICKER THAN EXISTING, WHICHEVER IS GREATER OVER MIN. 15.5" OF CLASS II AGGREGATE BASE COMPACTED TO 95%.
- (stippled) — LIMITS OF CONCRETE IMPROVEMENTS
- C — CONCRETE
- G — GUTTER
- MS — MOWSTRIP
- P — PAVEMENT
- TC — TOP OF CURB
- (line) — EXISTING RIGHT-OF-WAY
- G.B. — GRADE BREAK
- S=0.0020 → — FLOWLINE SLOPE AND DIRECTION OF FLOW
- 4"S — SEWER MAIN, SIZE AS NOTED ON PLANS. PIPE BEDDING AND BACKFILL PER CITY OF MERCED CITY STD. T-1, SEE [A/X102]
- 3"W — WATER MAIN, SIZE AS NOTED ON PLANS. PIPE BEDDING AND BACKFILL PER CITY OF MERCED CITY STD. T-1, SEE [A/X102]
- 6"F — FIRE MAIN, SIZE AS NOTED ON PLANS. PIPE BEDDING AND BACKFILL PER CITY OF MERCED CITY STD. T-1, SEE [A/X102]
- (symbol) — DOUBLE CHECK VALVE BACKFLOW PREVENTER PER CITY OF MERCED CITY STD. W-8, SEE [C/X102]
- W — WATER METER PER CITY OF MERCED CITY STD. W-4, SEE [D/X102]
- S=0.0050 → — PIPE FLOWLINE SLOPE AND DIRECTION OF FLOW

SITE BENCHMARK:

CHISELED 'X' ON THE TOP OF THE CONCRETE CURB ON THE WESTERN SIDE OF K STREET, APPROXIMATELY 56'+/- NORTH OF THE INTERSECTION OF K AND 26TH.

ELEV.= 172.94' NAVD88 DATUM

SURVEY NOTES:

1. THIS TOPOGRAPHIC SURVEY LOCATES SPECIFIC PHYSICAL FEATURES OF THE SITE AND THEIR ELEVATION AS DETERMINED NECESSARY BY THE PROJECT ENGINEER. IT IS NOT A COMPLETE TOPOGRAPHIC SURVEY OF THE SITE. THE INFORMATION SHOWN REFLECTS THE DATA OBTAINED BY FIELD SURVEY CONDUCTED ON JANUARY 30, 2025.
2. UTILITY INFORMATION SHOWN HEREON IS BASED ON RECORD INFORMATION SUPPLIED TO THE ENGINEER BY UTILITY COMPANIES, PUBLIC AGENCIES AND THE PROPERTY OWNER, TOGETHER WITH OBSERVATION OF VISIBLE EVIDENCE BY A FIELD SURVEY. THE ENGINEER CAN MAKE NO GUARANTEE AS TO THE ACCURACY OR COMPLETENESS OF THE UNDERGROUND UTILITY FACILITIES SHOWN. PRIOR TO ANY SITE EXCAVATIONS, THE CONTRACTOR SHALL CONTACT THE OWNER AND UNDERGROUND SERVICE ALERT (USA) AND REQUEST THAT THEY IDENTIFY THE LOCATION OF ALL UNDERGROUND UTILITIES AT THE SITE.

NOT TO BE INCLUDED IN CONSTRUCTION DRAWINGS

"FOR REFERENCE ONLY"

811 Know what's below. Call before you dig.

Blair, Church & Flynn CONSULTING ENGINEERS

REGISTERED PROFESSIONAL ENGINEER ZACHARY D. HOLT No. 87218 CIVIL STATE OF CALIFORNIA

08/29/2025 Date Signed:

CONSULTANT: Blair, Church & Flynn Consulting Engineers, 451 Clovis Avenue, Suite 200, Clovis, California 93612, Tel (559) 326-1400, Fax (559) 326-1500

REF. & REV.

MERCED CITY SCHOOL DISTRICT


26TH STREET MARS/ELO-P FACILITY
2600 K STREET MERCED, CA 95348
STREET PLANS

DR. BY: AR
CH. BY: ZH
DATE: XX/XX/XX
SCALE AS NOTED

C300

Drawing: P:\224\224-0395\Site\productiondrawings\Off Site\224395_si01-offsite.dwg: layout1 - BCF.ctb
Plot by: jfelix Feb 05, 2026 - 1:59pm

Loaded Xrefs



NOT TO BE INCLUDED IN CONSTRUCTION DRAWINGS "FOR REFERENCE ONLY"

SITE LEGEND:


- LIMITS OF CONCRETE IMPROVEMENTS PER[A/X100-02]
- LIMITS OF HEAVY DUTY CONCRETE IMPROVEMENTS PER [A/X100-02]
- LIMITS OF ASPHALTIC CONCRETE PAVEMENT STRUCTURAL SECTION PER [B/X100-02]
- LIMITS OF COBBLE IMPROVEMENTS
- DETECTABLE WARNINGS
- DECORATIVE METAL FENCE
- PL — PLANTER
- (1) CONCRETE IMPROVEMENTS PER [A/X100-02]
- (2) CONCRETE CURB PER [E/X100-02]
- (3) CONCRETE CURB AND GUTTER PER [F/X100-02]
- (4) CONCRETE MOWSTRIP PER [G/X100-02]

EROSION & SEDIMENT CONTROL LEGEND


- PROJECT BOUNDARY/LIMITS OF SOIL DISTURBANCE
- PROTECT PROPOSED DRAIN INLETPER CASQA SE-10 AND DETAIL SE-10a AND SE-10b
- PROTECT EXISTING DRAIN INLET (TO BE DEMOLISHED) PER CASQA SE-10 AND DETAIL SE-10a AND SE-10b
- INSTALL FIBER ROLL OR SILT FENCE PER CASQA SE-5 AND SE-1
- INSTALL CHECK DAMS PER CASQA SE-4
- EXISTING STORM DRAIN PIPELINE
- PROPOSED STORM DRAIN PIPELINE
- PROPOSED PERFORATED STORM DRAIN PIPELINE
- INSTALL MINIMUM ONE TRACKOUT CONTROL PER CASQA TC-1 AND DETAIL TC-1A
- 1 CONCRETE WASHOUT LOCATION PER CASQA WM-08
- 2 LOCATION OF JOB TRAILER CONTAINING SPILL KIT
- 3 MATERIAL STORAGE LOCATION PER CASQA WM-01
- 4 OVERNIGHT EQUIPMENT/VEHICLE STORAGE AND MAINTENANCE PER CASQA NS-8, NS-9 AND NS-10
- 5 RESTROOMS AND SANITARY FACILITIES PER CASQA WM-09
- 6 SOLID WASTE STORAGE LOCATION PER CASQA WM-05
- 7 STOCKPILE STORAGE LOCATION PER CASQW WM-03

EROSION AND SEDIMENT CONTROL NOTES TO CONTRACTOR:


1. STREET SURFACES SHALL BE SWEPT BY THE CONTRACTOR PER CASQA SE-7. VISIBLE SEDIMENT TRACKING SHALL BE SWEPT OR VACUUMED ON A DAILY BASIS.
2. DUST CONTROL PRACTICES SHALL CONFORM WITH THE LOCAL AIR DISTRICT AND CASQA WE-1.
3. IF CONSTRUCTION IS PHASED, BMPS MAY BE INSTALLED ONLY WITHIN ACTIVE AREAS OF CONSTRUCTION. ONCE EACH PHASE OF CONSTRUCTION IS COMPLETE AND PROJECT AREA IS STABILIZED, BMPS MAY BE REMOVED WITHIN THE STABILIZED AREA.
4. THE INDICATED STAGING AREAS ARE ASSUMED FOR SCHEMATIC PURPOSES ONLY, CONTRACTOR MAY STORE MATERIALS AROUND THE SITE AS LONG AS MATERIALS ARE STORED IN ACCORDANCE WITH CASQA GUIDANCE.
5. CONTRACTOR SHALL COMPLY WITH CURRENT CALGREEN CODE SECTION 5.106 FOR PROJECTS THAT DISTURB LESS THAN ONE ACRE.



SE 10a LEVEL GRADE DRAIN INLET PROTECTION
NOT TO SCALE



SE 10b CURB & GUTTER DRAIN INLET PROTECTION
NOT TO SCALE



NOTES:
1. CONSTRUCTION EXIT SHALL BE KEPT IN GOOD CONDITION BY OCCASIONAL TOP DRESSING AND/OR ROUGHENING.
2. "RUMBLE PLATES" MAY BE ADDED AND COUNT TOWARDS 50' FT REQUIREMENT.
3. CONTRACTOR SHALL INSPECT EXIT WEEKLY AND DURING RAIN EVENTS.
4. CONTRACTOR SHALL SWEEP TRACKOUT WEEKLY AND PRIOR TO RAIN EVENTS PER CASQA SE-7 AND PER SJVAPCD DUST CONTROL REQUIREMENTS

TC 1 STABILIZED CONSTRUCTION EXIT
NOT TO SCALE

SCALE: 1"=10'

0 5 10 20 SCALE IN FEET

AREA OF SOIL DISTURBANCE = 0.92 ACRES

Know what's below. Call before you dig.

Blair, Church & Flynn CONSULTING ENGINEERS

REGISTERED PROFESSIONAL ENGINEER ZACHARY D. HOLT No. 87218 CIVIL STATE OF CALIFORNIA
08/29/2025 Date Signed:

CONSULTANT
Blair, Church & Flynn Consulting Engineers
451 Clovis Avenue, Suite 200
Clovis, California 93612
Tel (559) 326-1400
Fax (559) 326-1500

REF. & REV.

MERCED CITY SCHOOL DISTRICT

26TH STREET MARS/ELO-P FACILITY
2600 K STREET MERCED, CA 95348
EROSION & SEDIMENT CONTROL PLAN

DR. BY: AR
CH. BY: ZH
DATE: XX/XX/XX
SCALE AS NOTED

C400


Loaded Xrefs

Drawing: P:\224\224-0395\Site\productiondrawings\Off Site\224395_ec01-offsite.dwg; Layout1 - BCF.ctb
Plot by: jfelix Feb 05, 2026 - 1:59pm


ADDENDUM NO. 2

NOT TO BE INCLUDED IN CONSTRUCTION DRAWINGS


"FOR REFERENCE ONLY"




A / X100 — 26TH STREET BUS TURNOUT SECTION
NOT TO SCALE



B / X100 — 26TH STREET TYPICAL SECTION
NOT TO SCALE



C / X100 — K STREET TYPICAL SECTION
NOT TO SCALE



D / X100 — ALLEY TYPICAL SECTION
NOT TO SCALE

Blair, Church & Flynn
CONSULTING ENGINEERS

REGISTERED PROFESSIONAL ENGINEER — ZACHARY D. HOLT — No. 87,218 — CIVIL — STATE OF CALIFORNIA
08/29/2025
Date Signed:


CONSULTANT	REF. & REV.	MERCED CITY SCHOOL DISTRICT
Blair, Church & Flynn Consulting Engineers 451 Clovis Avenue, Suite 200 Clovis, California 93612 Tel (559) 326-1400 Fax (559) 326-1500		26TH STREET MARS/ELO-P FACILITY 2600 K STREET MERCED, CA 95348 SECTIONS

DR. BY: AR
CH. BY: ZH
DATE: XX/XX/XX
SCALE AS NOTED


X100

Loaded Xrefs


Drawing: P:\224\224-0395\Site\productiondrawings\Off Site\224395_dt01-offsite.dwg: layout1 (2) - BCF.ctb
Plot by: jfelix Feb 05, 2026 - 1:59pm




A / X101 — SIDEWALK, CURB AND GUTTER
NOT TO SCALE




B / X101 — CURB DRAIN DETAIL
NOT TO SCALE




C / X101 — BUS TURNOUT DETAIL
NOT TO SCALE



D / X101 — REFUSE ENCLOSURE DETAIL
NOT TO SCALE



E / X101 — REFUSE ENCLOSURE GATE DETAIL
NOT TO SCALE



PLAN
NO SCALE

NOTES


1. SEE CITY STANDARD R-1 FOR ADDITIONAL REQUIREMENTS.
2. MIRROR PLAN WHERE APPLICABLE.
3. ADDITIONAL REFUSE CONTAINER REQUIRED BY PLAN CHECK SHALL HAVE SEPARATE ENCLOSURES.
4. SEE CITY STANDARD R-3 FOR REFUSE ENCLOSURE DETAIL.
5. ANGLE OF ENCLOSURE VARIES. FOUNDATION SHALL NOT BE POURED UNTIL FIELD VERIFICATION OF ENCLOSURE ANGLE IS MADE BY REFUSE DIVISION PERSONNEL.

FRONT END LOADER - ANGLED SERVICE	CITY OF MERCED, CA.
APPROVED BY: CITY ENGINEER DATE	STANDARD DETAIL R-1A

F / X101 — FRONT END LOADER - ANGLED SERVICE
NOT TO SCALE

NOTES:

1. *THE DETECTABLE WARNING SURFACE SHALL BE YELLOW AND APPROXIMATE FS 33538 OF SAE AMSSTD-595A.*
2. *WHERE DETECTABLE WARNING SURFACE DOES NOT PROVIDE A 70% CONTRAST WITH ADJACENT WALKING SURFACES, A 1-INCH WIDE MINIMUM VISUALLY CONTRASTING SURFACE SHALL SEPARATE THE DETECTABLE WARNING FROM THE ADJACENT SURFACE.*
3. *THE DOMES SHALL BE MANUFACTURED BY ARMOR TILE INC. OR APPROVED EQUAL.*
4. *ONLY APPROVED DSA/AC DETECTABLE WARNING PRODUCTS AND DIRECTIONAL SURFACES SHALL BE INSTALLED AS PROVIDED IN THE CALIFORNIA CODE OF REGULATIONS (CCR), TITLE 24, PART 1, CHAPTER 5, ARTICLES 2, 3 AND 4.*



G / X101 — DETECTABLE WARNINGS
NOT TO SCALE

NOT TO BE INCLUDED IN CONSTRUCTION DRAWINGS

"FOR REFERENCE ONLY"

Blair, Church & Flynn
CONSULTING ENGINEERS

REGISTERED PROFESSIONAL ENGINEER ZACHARY D. HOLT No. 87,218 CIVIL STATE OF CALIFORNIA
08/29/2025
Date Signed:

CONSULTANT
Blair, Church & Flynn Consulting Engineers
451 Clovis Avenue, Suite 200
Clovis, California 93612
Tel (559) 326-1400
Fax (559) 326-1500

REF. & REV.

MERCED CITY SCHOOL DISTRICT

26TH STREET MARS/ELO-P FACILITY
2600 K STREET MERCED, CA 95348
DETAILS


DR. BY: AR
CH. BY: ZH
DATE: XX/XX/XX
SCALE AS NOTED

X101


Loaded Xrefs

Drawing: P:\224\224-0395\Site\productiondrawings\Off Site\224395_dt01-offsite.dwg; layout1 - BCF.ctb
Plot by: jfelix Feb 05, 2026 - 1:59pm

ADDENDUM NO. 2




A / X102 TRENCH EXCAVATION AND BACKFILL DETAIL
NOT TO SCALE




B / X102 SEWER LATERAL DETAIL
NOT TO SCALE

NOT TO BE INCLUDED IN
CONSTRUCTION DRAWINGS
"FOR REFERENCE ONLY"



C / X102 DOUBLE CHECK VALVE BACKFLOW PREVENTER
NOT TO SCALE




D / X102 2" WATER SERVICE CONNECTIONS
NOT TO SCALE

Blair, Church & Flynn CONSULTING ENGINEERS	REGISTERED PROFESSIONAL ENGINEER ZACHARY D. HOLT No. 87218 CIVIL STATE OF CALIFORNIA 08/29/2025 Date Signed:	CONSULTANT Blair, Church & Flynn Consulting Engineers 451 Clovis Avenue, Suite 200 Clovis, California 93612 Tel (559) 326-1400 Fax (559) 326-1500	REF. & REV.	MERCED CITY SCHOOL DISTRICT 26TH STREET MARS/ELO-P FACILITY 2600 K STREET MERCED, CA 95348 DETAILS DR. BY: AR CH. BY: ZH DATE: XX/XX/XX SCALE AS NOTED X102

Drawing: P:\224\224-0395\Site\productiondrawings\Off Site\224395_dt01-offsite.dwg: layout1 (3) - BCF.ctb
Plot by: jfelix Feb 05, 2026 - 1:59pm

Loaded Xrefs

NOT TO BE INCLUDED IN CONSTRUCTION DRAWINGS
"FOR REFERENCE ONLY"



POINT OF CONNECTION

WATER SERVICE SIZE: 2"

WATER METER SIZE/75% MAX FLOW: 2" / 120 GPM

MAXIMUM STATION FLOW: 9.53 GPM

IRRIGATION BACKFLOW SIZE: 2"

IRRIGATION WATER SOURCE: CITY OF MERCED, POTABLE
EXISTING STATIC PRESSURE: 47.7 PSI

SEE IRRIGATION GENERAL NOTE #3

DESIGN OPERATING PRESSURE:
30 PSI BUBBLERS
30 PSI DRIPLINE

WATER CONSERVATION COMPLIANCE STATEMENT:

I HAVE COMPLIED WITH THE PERFORMANCE COMPLIANCE OPTION CRITERIA OF THE MODEL WATER EFFICIENT LANDSCAPE ORDINANCE (MWELO) AND APPLIED THEM ACCORDINGLY FOR THE EFFICIENT USE OF WATER IN THE IRRIGATION DESIGN PLAN.

CATO H. HESKETT, PLA 6932

IRRIGATION SYSTEM OBSERVATION LOG:

ITEM NO.	WORK ITEM DESCRIPTION	REVIEWED & ACCEPTED BY OWNER'S REPRESENTATIVE: PRINT NAME	SIGNATURE	DATE
IR-1	EXISTING SYSTEM OPERATION & PRESSURE CHECK			
IR-2	PIPING/WIRE SLEEVES UNDER PAVEMENT			
IR-3	MAIN LINE INSTALLATION & PRESSURE TEST			
IR-4	VALVE INSTALLATIONS			
IR-5	IRRIGATION COVERAGE PRIOR TO PLANTING			
IR-6	CONTROL EQUIPMENT INSTALLATION			
IR-7	BOOSTER PUMP INSTALLATION & START-UP (MANUF.)			
IR-8	FINAL SYSTEM OPERATION REVIEW			

NOTES: THE ORIGINAL VERSION OF THIS LOG SHALL BE MAINTAINED ON THE AS-BUILT RECORD DRAWING SET.

WORK ITEMS MAY NOT BE REVIEWED IF PRIOR WORK ITEMS HAVE NOT BEEN ACCEPTED.

IT IS THE CONTRACTOR'S RESPONSIBILITY TO ENSURE THAT THE OWNER'S REPRESENTATIVE IS NOTIFIED OF THESE MILESTONE WITNESS POINTS.

CONTRACTOR SPECIAL IRRIGATION NOTES:

1. THE CONTRACTOR SHALL PERFORM AN OPERATIONAL ASSESSMENT OF THE EXISTING IRRIGATION SYSTEM WITHIN THE AREA OF WORK WITH THE OWNER'S REPRESENTATIVE PRIOR TO THE START OF CONSTRUCTION OPERATIONS.
2. THE CONTRACTOR SHALL ENSURE THAT ALL EXISTING PLANTING SCHEDULED TO REMAIN SHALL CONTINUE TO BE IRRIGATED THROUGHOUT THE COURSE OF CONSTRUCTION OPERATIONS. ANY DAMAGE TO THE EXISTING IRRIGATION SYSTEM THAT IMPACTS EXISTING PLANTING TO REMAIN SHALL BE IMMEDIATELY REPAIRED TO THE OWNER'S SATISFACTION.
3. PRIOR TO THE START OF ANY SHRUB, GROUND COVER, AND/OR TURFGRASS PLANTING, AN OPERATIONAL REVIEW OF THE IRRIGATION SYSTEM SHALL BE PERFORMED FOR PROPER COVERAGE AND SOIL MOISTURE DEPTH BY THE OWNER'S REPRESENTATIVE. ALL CORRECTIONS AND/OR ADJUSTMENTS SHALL BE COMPLETED AND VERIFIED BY THE OWNER'S REPRESENTATIVE BEFORE GROUND LEVEL PLANTING MAY COMMENCE.
4. THE ORIGINAL IRRIGATION SYSTEM OBSERVATION LOG SHALL BE MAINTAINED ON THE AS-BUILT RECORD DRAWING SET.
5. THE AS-BUILT RECORD DRAWING SET AND OTHER CLOSE-OUT ITEMS SHALL BE SUBMITTED AND ACCEPTED PRIOR TO THE SCHEDULING OF A FINAL ACCEPTANCE REVIEW.
6. UNLESS NOTED OTHERWISE, SALVAGE AND RETURN TO THE OWNER ALL IRRIGATION VALVES, HEADS AND OTHER EQUIPMENT COMPONENTS REMOVED AS PART OF THE WORK. SALVAGED COMPONENTS SHALL BE CLEAN AND IN WORKING CONDITION UNLESS NOTED AS NON-OPERATIONAL DURING THE OPERATIONAL ASSESSMENT.

WATER EFFICIENT LANDSCAPE WORKSHEET
Educational - DSA PR 15-03

Project: 26th Street MARS/ELO-P Facility (Offsite)
Location: 2600 K St, Merced, CA 95348
ETo Reference (MWELO-Apdx. A): Merced

MAWA = MAXIMUM APPLIED WATER ALLOWANCE (1,000 GALLONS)

TOTAL LANDSCAPE AREA (LA)	3,451	SF	(500 sf is threshold for inclusion)
SPECIAL LANDSCAPE AREA (SLA)	0	SF	(SLA is included in the total LA)
REGULAR LANDSCAPE AREA	3,451	SF	(<2,500 sf can use checklist)

NORMAL YEAR REFERENCE	ANNUAL
EVAPOTRANSPIRATION (ETo)	55.7
EFFECTIVE PRECIPITATION (25% OF ANNUAL)	0.0
ADJUSTED EVAPOTRANSPIRATION	55.7

MAWA=(ETo) x (0.62) [(0.45 x LA)+(0.55 x SLA)]	ANNUAL		2015 DWR Update
MAX. APPLIED WATER ALLOWANCE	**77.5**	K Gallons	
TOTAL IN ACRE/FT	0.2		
TOTAL IN CCF	104		

ETWU = ESTIMATED TOTAL WATER USE (1,000 GALLONS)

LANDSCAPE HYDROZONE TYPES	3,451	HA	PF	IE	ETAF
MIXED PLANTING (L)	3,451	SF	0.3	0.81	0.37
MIXED PLANTING (M)	0	SF	0.5	0.81	0.62
WARM-SEASON TURFGRASS (MH)	0	SF	0.6	0.75	0.80
SLA - RECREATIONAL/RECYCED WATER USE	0	SF	0.6	0.75	0.80
				AVERAGE REGULAR ETAF:	0.37
				MAXIMUM AVERAGE REGULAR ETAF:	**0.45**
				AVERAGE SITEWIDE ETAF:	0.37

ETWU=(ETo) x (0.62)x [(HA x PF/IE) + SLA]	ANNUAL		typical IE coeficients	
MIXED PLANTING (L)	44		0.75	overhead sprinklers
MIXED PLANTING (M)	0		0.81	drip & bubblers
WARM-SEASON TURFGRASS (M)	0			
SLA - RECREATIONAL/RECYCED WATER USE	0			
ESTIMATED TOTAL WATER USE	**44**	K Gallons		
TOTAL IN ACRE/FT	0.1			
TOTAL IN CCF	59			

ETWU AS A PERCENT OF MAWA: 57%

SEE SHEET L101 FOR IRRIGATION LEGEND

SEE SHEET L102 & L103 FOR IRRIGATION NOTES AND DETAILS

SCALE: N 1"=10'

0 5 10 20
SCALE IN FEET

Know what's below. Call before you dig. 811

Blair, Church & Flynn
CONSULTING ENGINEERS

LICENSED LANDSCAPE ARCHITECT, CATO H. HESKETT, 6932, Signature, 7/31/27 Renewal Date, 08/29/2025 Date, STATE OF CALIFORNIA

CONSULTANT
Blair, Church & Flynn Consulting Engineers
451 Clovis Avenue, Suite 200
Clovis, California 93612
Tel (559) 326-1400
Fax (559) 326-1500

REF. & REV.


MERCED CITY SCHOOL DISTRICT

26TH STREET MARS/ELO-P FACILITY
2600 K STREET MERCED, CA 95348
IRRIGATION PLAN

DR. BY: CH
CH. BY: DB
DATE: XX/XX/XX
SCALE AS NOTED


Drawing: P:\224\224-0395\Site\productiondrawings\Off Site\224395_ir01-offsite.dwg; layout1 - BCF.ctb
Plot by: jfelix Feb 05, 2026 - 1:59pm
Loaded Xrefs

NOT TO BE INCLUDED IN CONSTRUCTION DRAWINGS
"FOR REFERENCE ONLY"



TYPICAL TRENCH SHOWN IN PLANTING AREA

A / L102 IRRIGATION TRENCH BACKFILL
NOT TO SCALE




NOTE: CONCRETE PER SPECIFICATIONS. THRUST BLOCKS NOT REQUIRED WITH LESS THAN 2" MAIN LINE

TABLE OF BEARING AREAS REQUIRED (IN SQUARE FEET)

PIPE DIAMETER	≦4"	6"	8"	10"	12"
CROSS, TEE, 90° BEND, PLUG, FIRE HYDRANT	1	3	5	8	11
45° BEND	1	2	3	4	6
22-1/2° BEND	0.5	1	2	2	3
11-1/4° BEND	0	0	1	1	2
GATE VALVE (IN-LINE)	0	1	2.5	4	9

B / L102 CONCRETE THRUST BLOCKS
NOT TO SCALE




C / L102 SOLVENT WELD PIPE
NOT TO SCALE

CONDUIT/SLEEVE FOR CONTROL WIRE

CONDUIT/SLEEVE SIZE	QTY. 14 GA. WIRE
1"	8 OR LESS
1-1/4"	15
1-1/2"	20
2"	32
2-1/2"	45
3"	70
4"	120


NOTE: SLEEVE FOR PIPE IS 2X THE PIPE DIAMETER



NOTE:
IF CONTROL WIRES ARE ROUTED IN CONDUIT, SLEEVE FOR WIRES IS NOT REQUIRED

D / L102 IRRIGATION SLEEVE/CONDUIT
NOT TO SCALE


NOTE:
ALL TWO-WIRE CONTROL CABLE SHALL BE INSTALLED IN CONDUIT



NOTES:


1. TWO-WIRE UNDER PAVEMENT OR WALKS SHALL BE INSTALLED WITHIN A CONDUIT PVC SCH. 40 TYPE II PIPE CONDUIT.
2. SPLICES ARE ALLOWED ONLY WITH DBRY-6 CONNECTORS.
3. A VALVE BOX MUST BE PROVIDED AT ALL UNDERGROUND SPLICE CONNECTIONS.
4. SEE TWO-WIRE DECIDER SYSTEM NOTES.

E / L102 TWO-WIRE CONTROL CABLE
NOT TO SCALE




F / L102 2" AND LARGER GATE VALVE
NOT TO SCALE

NOTE:
PROVIDE A TRAFFIC RATED CONCRETE BOX AND LID FOR ANY BOX LOCATED IN HARDSCAPE PAVEMENT AND SET FLUSH TO FINISHED SURFACE. PROVIDE A 6"X6" CONCRETE COLLAR AROUND THE BOX IF LOCATED IN ASPHALTIC CONCRETE.



G / L102 IRRIGATION VALVE BOX
NOT TO SCALE




NOTE:
RISER PIPE SIZE AT MINIMUM SHALL MATCH THE LARGEST LATERAL PIPE SIZE

H / L102 REMOTE CONTROL VALVE WITH BALL VALVE - GLOBE
NOT TO SCALE


* NOTE: FLOW SENSOR MUST BE INSTALLED WITH INSERT (TOP) POSITIONED VERTICALLY AND BODY (TEE) POSITIONED HORIZONTALLY.

* NOTE: FLOW SENSOR CABLE MUST BE RUN IN 1" PVC CONDUIT FROM FLOW SENSOR TO CONTROLLER ENCLOSURE.




I / L102 FLOW SENSOR AND MASTER VALVE
NOT TO SCALE

PROVIDE:
FOUR (4) QUICK COUPLER KEYS AND HOSE SWIVEL "L" PER SPECIFICATIONS



J / L102 QUICK COUPLER VALVE
NOT TO SCALE




NOTE:

1. ALL CABLES & ELECTRICAL WIRES MUST BE RUN IN PLASTIC CONDUITS AND SWEEPS
2. PROVIDE GROUNDING PER MANUFACTURER'S SPECIFICATIONS AND A MINIMUM OF ONE GROUND ROD OR PLATE. INSTALL PER ASIC 100-2002 GUIDELINES
3. PROVIDE RECYCLED WATER DECAL ON ENCLOSURE PER CITY STANDARDS

K / L102 PEDESTAL CONTROLLER ASSEMBLY
NOT TO SCALE

Blair, Church & Flynn
CONSULTING ENGINEERS



CONSULTANT
Blair, Church & Flynn Consulting Engineers
451 Clovis Avenue, Suite 200
Clovis, California 93612
Tel (559) 326-1400
Fax (559) 326-1500

REF. & REV.

MERCED CITY SCHOOL DISTRICT
26TH STREET MARS/ELO-P FACILITY
2600 K STREET MERCED, CA 95348
IRRIGATION DETAILS


DR. BY: CH
CH. BY: DB
DATE: XX/XX/XX
SCALE AS NOTED

L102


Drawing: P:\224\224-0395\Site\productiondrawings\Off Site\224395_irdt01-offsite.dwg; layout1 (2) - BCF.ctb
Plot by: jfelix Feb 05, 2026 - 1:59pm

Loaded Xrefs


NOT TO BE INCLUDED IN CONSTRUCTION DRAWINGS
"FOR REFERENCE ONLY"




A / L103 — DRIP ZONE ASSEMBLY
NOT TO SCALE




LEGEND:
1. FINISH GRADE
2. DEPTH OF TUBING BELOW FINISHED GRADE - SEE LEGEND
3. MIN. 12" DEPTH OF PVC SUPPLY / FLUSH MANIFOLD BELOW FINISHED GRADE
4. ELBOW
5. DRIPLINE LATERAL, SEE PLAN
6. POLY TUBING, LENGTH AS NECESSARY
7. MALE ADAPTER
8. SCH 40 PVC TEE (SxSxT) WITH 1/2" FPT OUTLET
9. SCH 40 PVC SUPPLY MANIFOLD FROM DRIP ZONE KIT
10. TEE




B / L103 — DRIPLINE MANIFOLD
NOT TO SCALE




C / L103 — DRIPLINE LAYOUT SCHEMATIC
NOT TO SCALE




D / L103 — HUNTER ECO-INDICATOR
NOT TO SCALE




H / L104-02 — FEBCO MODEL 826YA BACKFLOW PREVENTER
NOT TO SCALE




E / L103 — DRIPLINE FLUSH VALVE
NOT TO SCALE




F / L103 — TREE BUBBLERS
NOT TO SCALE




G / L103 — HUNTER SOLAR SYNC
NOT TO SCALE




L / L104-02 — BACKFLOW PREVENTER ENCLOSURE
NOT TO SCALE



K / L103 — MASTER VALVE
NOT TO SCALE



I / L103 — VALVE BOX LAYOUT
NOT TO SCALE



LEGEND:
1. COVER GROUNDING ROD WITH 10-INCH ROUND VALVE BOX AS SHOWN
2. 5/8-INCH X 10 FT COPPER CLAD GROUNDING ROD OR GROUNDING PLATE. INSTALL RODS IN SOIL IN A TRIAGULAR PATTERN SPACED A MINIMUM OF 16FT APART FROM EACH OTHER. GROUNDING GRID TO HAVE A RESISTANCE OF TEN (10) OHMS OR LESS
3. BARE COPPER WIRE (#6 AWG MIN.) BETWEEN GROUNDING ROD AND GROUND PLATE
4. GROUND ROD CLAMP OR WELDS
5. COPPER GROUNDING PLATE
6. GROUND ENHANCEMENT MATERIAL (IF REQUIRED)
7. FINISH GRADE

J / L103 — GROUNDING ROD
NOT TO SCALE

Blair, Church & Flynn
CONSULTING ENGINEERS

LICENSED LANDSCAPE ARCHITECT — STATE OF CALIFORNIA
Signature
7/31/27
Renewal Date
08/29/2025
Date

CONSULTANT
Blair, Church & Flynn Consulting Engineers
451 Clovis Avenue, Suite 200
Clovis, California 93612
Tel (559) 326-1400
Fax (559) 326-1500

REF. & REV.

MERCED CITY SCHOOL DISTRICT
26TH STREET MARS/ELO-P FACILITY
2600 K STREET MERCED, CA 95348
IRRIGATION DETAILS

DR. BY: CH
CH. BY: DB
DATE: XX/XX/XX
SCALE AS NOTED

L103

Drawing: P:\224\224-0395\Site\production\drawings\Off Site\224395_irdt01-offsite.dwg; layout1 (3) - BCF.ctb
Plot by: jfelix Feb 05, 2026 - 1:59pm

GENERAL IRRIGATION NOTES:

1. ALL ITEMS IN THE LEGEND ARE TO BE FURNISHED AND INSTALLED, UNLESS NOTED OTHERWISE. THE CONTRACTOR SHALL FURNISH THE ARTICLES, EQUIPMENT, MATERIALS OR PROCESSES SPECIFIED BY NAME. NO SUBSTITUTION WILL BE ALLOWED WITHOUT PRIOR WRITTEN APPROVAL OF THE DESIGN ENGINEER. (ALL MATERIAL REQUIRED SHALL BE NEW AND OF THE BEST QUALITY AVAILABLE)
2. THE DESIGN ENGINEER RESERVES THE RIGHT TO REJECT ANY MATERIAL OR WORK WHICH DOES NOT CONFORM TO THE CONTRACT PLANS AND SPECIFICATIONS WITHOUT THE PRIOR WRITTEN APPROVAL OF THE DESIGN ENGINEER.
3. PRIOR TO STARTING WORK, THE CONTRACTOR SHALL VERIFY THE EXISTING SYSTEM COMPONENTS' LOCATION, SIZES AND ROUTING FOR BACKFLOW PREVENTERS, CONTROLLERS, MAIN AND LATERAL PIPING, VALVES, SPRINKLER HEADS AND CONTROL WIRE; AND SHALL CONFIRM THEIR OPERATIONAL STATUS IN THE PRESENCE OF THE OWNER'S REPRESENTATIVE. THE CONTRACTOR SHALL ALSO VERIFY THE AVAILABLE STATIC PRESSURE AT THE POINT-OF-CONNECTION. FAILURE TO NOTIFY THE OWNER'S REPRESENTATIVE BEFORE STARTING WORK OF ANY DEVIATION FROM THE INFORMATION SHOWN ON THE CONTRACT DOCUMENTS, OR NECESSARY REPAIRS TO THE EXISTING SYSTEM, SHALL MAKE THE CONTRACTOR RESPONSIBLE TO PROVIDE, AT HIS OWN EXPENSE, ANY CORRECTIVE WORK OR COMPONENTS NECESSARY FOR A FULLY FUNCTIONAL SYSTEM WITH FULL COVERAGE.
4. THE CONTRACTOR IS RESPONSIBLE TO PROTECT AND KEEP ANY EXISTING IRRIGATION SYSTEM SCHEDULED TO REMAIN OPERATIONAL AT ALL TIMES DURING THE COURSE OF THIS WORK. THE CONTRACTOR SHALL REPLACE ANY PLANTS DEAD OR DISTRESSED DUE TO INTERRUPTION OF EXISTING IRRIGATION SCHEDULES AND SHALL PERFORM ALL WORK NECESSARY TO MAINTAIN THE EXISTING SYSTEM'S OPERATIONAL.
5. THE CONTRACTOR IS RESPONSIBLE TO LOCATE AND PROTECT ALL EXISTING UTILITIES. UTILITIES SHOWN ARE FOR THE CONTRACTOR'S AWARENESS AND NO SURVEY HAS BEEN COMPLETE TO VERIFY THE ACCURACY OF THE UTILITIES SHOWN. IT IS THE CONTRACTORS RESPONSIBILITY TO REPAIR ANY DAMAGED UTILITIES CAUSED BY CONSTRUCTION ACTIVITIES.
6. THE CONTRACTOR SHALL BE RESPONSIBLE TO VERIFY ALL DIMENSIONS SHOWN AND TO ADJUST SAID DIMENSIONS TO FIT SITE CONDITIONS AND ACTUAL EQUIPMENT INSTALLED.
7. THE CONTRACTOR SHALL NOT WILLFULLY INSTALL THE IRRIGATION FACILITIES AS INDICATED ON THE DRAWINGS WHEN IT IS OBVIOUS IN THE FIELD THAT UNKNOWN OBSTRUCTIONS MIGHT NOT HAVE BEEN CONSIDERED IN THE DESIGN. SUCH OBSTRUCTIONS OR DIFFERENCES SHALL BE BROUGHT TO THE ATTENTION OF THE DESIGN ENGINEER.
8. THE IRRIGATION PLAN IS DIAGRAMMATIC. ALL PIPING, VALVES, AND HEADS SHALL BE LOCATED IN PLANTING AREAS WHENEVER POSSIBLE.
9. THE CONTRACTOR SHALL PROVIDE ADEQUATE SAFETY MEASURES TO WARN AND PROTECT THE PUBLIC, OTHER SITE CONTRACTORS AND HIS WORKERS FROM POSSIBLE INJURY DUE TO HIS CONSTRUCTION EQUIPMENT AND OPERATIONS.
10. DUE TO THE SCALE OF THE DRAWINGS, IT IS NOT POSSIBLE TO INDICATE ALL OFFSETS, FITTINGS, ETC. WHICH MAY BE REQUIRED. THE CONTRACTOR SHALL CAREFULLY INVESTIGATE THE STRUCTURAL AND FINISHED CONDITIONS AFFECTING ALL HIS WORK, AND PLAN HIS WORK ACCORDINGLY, FURNISHING SUCH FITTINGS, ETC., AS MAY BE REQUIRED TO INSTALL THE PROPOSED FACILITIES AND ACCOMMODATE THE SITE CONDITIONS. DRAWINGS ARE GENERALLY DIAGRAMMATIC AND INDICATIVE OF THE WORK TO BE DONE TO PROVIDE A COMPLETE AND OPERATIONAL IRRIGATION SYSTEM. ALL WORK TO BE DONE IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS, LOCAL CODES AND ORDINANCES.
11. VALVES SHALL BE LOCATED IN SHRUB/GROUND COVER AREAS INSTEAD OF IN TURFGRASS AREAS WHENEVER POSSIBLE. VALVES IN ATHLETIC SPORTS FIELDS SHALL BE LOCATED OUTSIDE OF THE FIELD-OF-PLAY TO THE GREATEST EXTENT POSSIBLE.
12. THE CONTRACTOR SHALL REPLACE ANY EXISTING PLANTS SCHEDULED TO REMAIN (SEE LANDSCAPE PLANS) THAT ARE DAMAGED BY THIS WORK WITH NEW PLANTS OF THE SAME SPECIES/VARIETY AND SIZE AS THE ORIGINAL.
13. ANY EXISTING TURFGRASS REMOVED FOR THIS WORK SHALL BE REPLANTED IF VIABLE, OR NEW SOD OF THE SAME SPECIES/VARIETY INSTALLED. THE UPPER 6 INCHES OF THE COMPACTED TRENCH BACKFILL SHALL BE CONDITIONED PER LANDSCAPE SPECIFICATIONS PRIOR TO SOD INSTALLATION. THE NEW SOD SURFACE SHALL BE FLUSH TO THE ADJACENT TURFGRASS WITHOUT HUMPS OR DEPRESSIONS.
14. INSTALL SLEEVES UNDER ALL ASPHALT/CONCRETE IMPROVEMENTS. SLEEVES SHALL BE PVC SCH. 40 PVC OR SDR 35 AND TWICE THE DIAMETER OF THE PIPE UNLESS OTHERWISE NOTED. CONTROL WIRING SHALL BE SLEEVED IN 2" SCH 40 PVC UNLESS OTHERWISE NOTED. MINIMUM DEPTH OF SLEEVES UNDER ALL ASPHALT/CONCRETE IMPROVEMENTS IS 18" BELOW SUBGRADE OR 24" BELOW FINISHED GRADE, WHICHEVER IS GREATER.
15. CONTRACTOR SHALL SAWCUT TO EXISTING JOINTS. REMOVE AND REPLACE SURFACING (CONCRETE, ASPHALT) AS NECESSARY TO INSTALL THE IRRIGATION SYSTEM.
16. THE CONTRACTOR SHALL PROVIDE AND KEEP AN UP-TO-DATE "RECORD DRAWING" SHOWING ALL CHANGES TO THE ORIGINAL DRAWINGS AND EXACT LOCATIONS OF THE FACILITIES INSTALLED. BEFORE FINAL INSPECTION, THE CONTRACTOR SHALL FURNISH MARKED "RECORD DRAWINGS" TO THE INSPECTOR.
17. THE CONTRACTOR SHALL PROVIDE ADJUSTMENT OF NOZZLE ARC AND RADIUS, INCLUDING ANY ALTERNATE NOZZLE TYPES, NECESSARY TO PROVIDE COMPLETE COVERAGE, TO SUIT ACTUAL SITE CONDITIONS, AND TO MINIMIZE OVERSPRAY ONTO HARDSCAPE, PAVEMENT AND/OR STRUCTURES.
18. CONCRETE ANCHORS OR THRUST BLOCKS SHALL BE PROVIDED ON ALL MAIN LINE PIPING. THEY ARE TO BE LOCATED AT ALL ABRUPT CHANGES IN PIPELINE GRADE, CHANGES IN HORIZONTAL ALIGNMENT, REDUCTION IN PIPE SIZES, END OF LINE AND IN-LINE VALVES TO ABSORB ANY AXIAL THRUST OF THE PIPE. THE PIPE MANUFACTURER'S RECOMMENDATIONS FOR THRUST CONTROL SHALL BE FOLLOWED. THRUST BLOCKS MUST BE FORMED AGAINST UNDISTURBED EARTH.
19. ALL MAIN LINE AND LATERAL LINE PIPES UNDER PAVEMENT SHALL BE PRESSURE TESTED WITH THE VALVES INSTALLED. THE CONTRACTOR SHALL PROVIDE ALL EQUIPMENT NEEDED. IF ANY LEAKS DEVELOP, THE REPAIRS ARE TO BE MADE AND THE TEST REPEATED UNTIL THE SYSTEM IS PROVEN WATERTIGHT. THE CONTRACTOR IS TO CENTER LOAD THE PIPE AND LEAVE ALL JOINTS EXPOSED FOR INSPECTION. THE PRESSURE TEST SHALL BE OBSERVED AND APPROVED BY THE OWNER'S REPRESENTATIVE. WHEN THE PIPE IS PROVEN WATERTIGHT AND ONLY THEN MAY THE LINE BE BACKFILLED.
20. WIRED CONNECTIONS BETWEEN THE CONTROLLER AND REMOTE CONTROL VALVES SHALL BE MADE WITH ONE CONTINUOUS DIRECT BURIAL WIRE RUN. A VALVE BOX MUST BE PROVIDED AT THE CONTRACTOR'S EXPENSE AT ALL UNDERGROUND SPLICES.
21. ONLY TEFLON TAPE OR AN APPROVED TEFLON PASTE MAY BE USED AS THE SEALING MATERIAL TO MAKE ALL THREADED CONNECTIONS. A MINIMUM OF TWO (2) WRAPS IN THE DIRECTION OF THE THREADS TO BE USED FOR TAPE. NO OTHER PIPE JOINT MATERIAL WILL BE ALLOWED WITHOUT THE WRITTEN AUTHORIZATION FROM THE DESIGN ENGINEER.
22. THE CONTRACTOR SHALL PROVIDE TWO (2) INDIVIDUALLY BOUND SETS OF OPERATION AND MAINTENANCE MANUALS. THE MANUAL SHALL CONTAIN THE FOLLOWING INFORMATION:
    - A. CONTRACTOR'S ADDRESS AND PHONE NUMBER.
    - B. DURATION OF GUARANTEE PERIOD (ONE YEAR AFTER FINAL ACCEPTANCE).
    - C. NAMES, ADDRESSES AND PHONE NUMBERS OF LOCAL MANUFACTURER REPRESENTATIVES.
    - D. COMPLETE SET OF MANUFACTURER'S LITERATURE AND SPECIFICATIONS.
    - E. COMPLETE OPERATING AND MAINTENANCE INSTRUCTIONS ON ALL MAJOR EQUIPMENT.
    - F. ISSUE A "CERTIFICATE OF CONSTRUCTION COMPLIANCE" WHICH STATES THAT ALL WORK DONE AND MATERIALS AND EQUIPMENT USED ARE IN CONFORMANCE WITH THE APPROVED PLANS, SPECIFICATIONS AND ALL AUTHORIZED REVISIONS.
    - G. INITIAL ELECTRICAL DATA ON EACH VALVE:
      - (1) OHMMS READING FOR EACH VALVE TAKEN AT THE CONTROLLER.
      - (2) VOLTAGE READING FOR EACH VALVE TAKEN BOTH AT THE CONTROLLER AND AT THE VALVE.
23. THE CONTRACTOR SHALL PROVIDE TWO SETS OF CONTROLLER CHARTS. THE CHARTS TO BE A REDUCED DRAWING OF THE ACTUAL PLANS. THE CHARTS SHALL BE COLORED WITH A DIFFERENT COLOR FOR EACH IRRIGATION CIRCUIT. THE CHARTS SHALL BE COVERED IN A WATERTIGHT ENVELOPE.
24. IRRIGATION LINE TRENCHING AND PIPE INSTALLATION LOCATED WITHIN THE CANOPY DRIP LINE OF EXISTING TREES SHALL BE PERFORMED BY HAND OR BY AIR SPADE WITHOUT CUTTING OR DAMAGING EXISTING ROOTS GREATER THAN ONE INCH IN DIAMETER. SEE EXISTING LANDSCAPE PROTECTION SECTION FOR ADDITIONAL REQUIREMENTS.
25. REPLACE ALL DAMAGED EXISTING VALVE BOXES AND/OR LIDS WITHIN THE AREA OF WORK. ADJUST THE ELEVATION OF ALL EXISTING VALVE BOXES WITHIN THE AREA OF WORK TO FINISH GRADE AS NECESSARY TO COMPLY WITH THE VALVE BOX DETAIL.

DRIP SYSTEM IRRIGATION NOTES:

1. ALL ITEMS, ACCESSORIES, FITTINGS, ETC. NECESSARY FOR A COMPLETE AND PROPERLY FUNCTIONING SUB-SURFACE DRIP SYSTEM ARE TO BE FURNISHED AND INSTALLED BY THE CONTRACTOR, UNLESS NOTED OTHERWISE.
2. THE EQUIPMENT AND COMPONENTS CALLED OUT ON THE DRAWING LEGEND ARE THE PREFERENCE OF THE OWNER AND ARE SELECTED TO MATCH EQUIPMENT AND COMPONENTS IN USE IN OTHER SIMILAR IRRIGATION SYSTEMS OF THE OWNER.
3. PRIOR TO STARTING WORK, THE CONTRACTOR SHALL VERIFY ANY EXISTING SYSTEM COMPONENTS' LOCATION, SIZES AND ROUTING FOR BACKFLOW PREVENTERS, CONTROLLERS, MAIN AND LATERAL PIPING, VALVES, SPRINKLER HEADS AND CONTROL WIRE; AND SHALL CONFIRM THEIR OPERATIONAL STATUS IN THE PRESENCE OF THE OWNER'S REPRESENTATIVE. THE CONTRACTOR SHALL ALSO VERIFY THE AVAILABLE STATIC PRESSURE AND AVAILABLE SAFE FLOW AT THE POINT-OF-CONNECTION. FAILURE TO NOTIFY THE OWNER'S REPRESENTATIVE AND THE ENGINEER BEFORE STARTING WORK, OF ANY DEVIATION FROM THE INFORMATION SHOWN ON THE CONTRACT DOCUMENTS OR NECESSARY REPAIRS TO THE EXISTING SYSTEM, SHALL MAKE THE CONTRACTOR RESPONSIBLE TO PROVIDE, AT HIS OWN EXPENSE, ANY CORRECTIVE WORK OR COMPONENTS NECESSARY FOR A FULLY FUNCTIONAL SYSTEM WITH FULL COVERAGE.
4. THE IRRIGATION PLAN IS DIAGRAMMATIC. ALL PIPING, VALVES, AND COMPONENTS SHALL BE LOCATED IN PLANTING AREAS, UNLESS NOTED OTHERWISE. VALVES SHALL BE LOCATED IN SHRUB/GROUND COVER AREAS INSTEAD OF IN TURFGRASS AREAS WHENEVER POSSIBLE.
5. INSTALL DRIP EMITTERS IN A TRIANGULAR OR STAGGERED PATTERN AND AT A CONSISTENT DEPTH BELOW GRADE AS SHOWN OR INDICATED IN THE DRAWINGS.
6. STAKE THE EMITTER TUBING USING THE MANUFACTURER'S RECOMMENDED STAKES DIRECTLY OVER EVERY OTHER EMITTER. FOR EXAMPLE, IF THE EMITTERS ARE SPACED AT 18 INCHES O.C., THEN STAKE AT 36 INCHES O.C.
7. PRIOR TO BACKFILLING THE DRIP TUBING AND THE START OF PLANTING OPERATIONS, THE SYSTEM SHALL BE REVIEWED FOR PROPER OPERATION BY THE OWNER'S REPRESENTATIVE.
8. PROGRAM THE CONTROLLER TO OPERATE THE CONTROL VALVE(S) FOR THE DRIP SYSTEM USING THE CONTROLLER'S "CYCLE AND SOAK" FEATURE IN ORDER TO APPLY THE REQUIRED WATER AMOUNT IN THREE EQUAL CYCLES.
9. PRIOR TO THE START OF PLANTING OPERATIONS, THE DRIP SYSTEM SHALL BE OPERATED FOR A FREQUENCY AND DURATION TO ADEQUATELY MOISTEN THE TOPSOIL TO A MINIMIM DEPTH OF 12 INCHES AT ANY LOCATION WITHIN THE PLANTING AREA .
10. THE CONTRACTOR SHALL PROVIDE ONE HUNDRED (100) FEET OF IN-LINE EMITTER TUBING OF THE SAME MODEL AS SPECIFIED, ENOUGH STAKES FOR THE 100 FEET, AND TEN (10) OF EACH TYPE OF FITTINGS USED ON THE PROJECT FOR THE OWNER'S USE AS SPARE PARTS.
11. IT IS THE CONTRACTOR'S RESPONSIBILITY TO KEEP ANY EXISTING IRRIGATION SYSTEM SCHEDULED TO REMAIN OPERATIONAL AT ALL TIMES DURING THE COURSE OF THIS WORK. THE CONTRACTOR SHALL REPLACE ANY PLANTS DEAD OR DISTRESSED DUE TO THE INTERRUPTION OF EXISTING IRRIGATION SCHEDULES, AND SHALL PERFORM ALL WORK NECESSARY TO MAINTAIN THE EXISTING SYSTEM'S OPERATION.
12. THE CONTRACTOR SHALL REPLACE ANY EXISTING PLANTS SCHEDULED TO REMAIN THAT ARE DAMAGED BY THIS WORK WITH NEW PLANTS OF THE SAME SPECIES/VARIETY AND SIZE AS THE ORIGINAL PRIOR TO THE START OF WORK. ANY EXISTING TURFGRASS REMOVED FOR THIS WORK SHALL BE REPLANTED IF VIABLE, OR NEW SOD OF THE SAME SPECIES/VARIETY INSTALLED. THE UPPER 6 INCHES OF THE COMPACTED TRENCH BACKFILL SHALL BE CONDITIONED PER THE PLANTING SPECIFICATIONS PRIOR TO SOD INSTALLATION. THE NEW SOD SURFACE SHALL BE FLUSH TO THE ADJACENT TURFGRASS WITHOUT HUMPS OR DEPRESSIONS.

TWO-WIRE DECODER SYSTEM NOTES:

1. ALL DECODERS, CONTROL WIRE, ACCESSORIES, CONNECTORS, GROUNDING AND INSTALLATION SHALL COMPLY WITH THE CONTROLLER/DECODER MANUFACTURER'S SPECIFICATIONS AND REQUIREMENTS.
2. THE IRRIGATION CONTROLLER SHALL HAVE A DEDICATED EARTH GROUND, BY MEANS OF BOTH A TEN FOOT LONG STEEL COPPER CLAD GROUND ROD, AND BY A PAIGE GROUNDING PLATE. THE GROUND ROD OR PLATE SHALL BE LOCATED AT LEAST 8 FEET AWAY FROM THE CONTROLLER, AND THE PLATE SHALL BE ORIENTED PERPENDICULAR FROM THE WIRE RUN AND SHALL BE AT LEAST 36 INCHES BELOW GRADE. GROUNDING CIRCUIT RESISTANCE SHALL BE LESS THAN OR EQUAL TO 10 OHMS.
3. EARTH GROUNDING SHALL BE INSTALLED ALONG THE WIRE PATH AT EVERY 12TH DECODER, OR 1,000 FEET OF CABLE RUN, WHICHEVER IS SHORTER. THE LAST DECODER ON A WIRE RUN SHALL BE EARTH GROUNDED. THE GROUNDING PLATE SHALL BE ORIENTED PERPENDICULAR FROM THE CABLE RUN AND SHALL BE AT LEAST 36 INCHES BELOW GRADE.
4. TWO-WIRE CABLE SHALL BE A JACKETED, TWISTED PAIR OF 14 AWG SOLID-CORE WIRE FOR UP TO 10,000 FEET OF RUN. WIRE CONNECTORS SHALL BE DBRY-6, OR EQUAL. EACH SEPARATE WIRE PATH FROM THE CONTROLLER SHALL HAVE A DIFFERENT COLOR CABLE MARKING.
5. CABLE PATH BRANCHES SHALL BE MADE WITH A PAIGE DCFC SPLITTER. INSTALL THE SPITTER WITH DBRY-6 CONNECTORS. PROVIDE A MINIMUM OF 5 FEET OF SLACK CABLE ON EACH SIDE OF THE CONNECTION, AND INSTALL IN A RECTANGULAR VALVE BOX PER THE SPECIFICATIONS.
6. USE ONE DECODER STATION TO OPERATE ONE CONTROL VALVE. GROUPED VALVES MAY USE MULTIPLE STATION DECODERS (2, 4, OR 6 OUTPUTS IN ONE DECODER). FLOW AND/OR CLICK TYPE SENSORS SHALL USE AN APPROPRIATE SENSOR DECODER. USE A SINGLE STATION DECODER FOR ANY PUMP START OR MASTER VALVE PURPOSE.
7. INSTALL THE DECODER INSIDE THE CONTROL VALVE BOX. PROVIDE ADEQUATE SLACK WIRE FOR ABOVE-GROUND INSPECTION AND MAINTENANCE. USE TWISTED WIRE CABLE FOR DECODER TO SOLENOID RUNS GREATER THAN 20 FEET UP TO 150 FEET, OTHERWISE USE 14 AWG IRRIGATION CONTROL WIRE. DECODER TO SOLENOID CONNECTIONS SHALL BE MADE WITH DBY-6 CONNECTORS OR EQUAL.

IRRIGATION LEGEND:

SYMBOL	MANUFACTURER/MODEL/DESCRIPTION	ARC	PSI	GPM	RADIUS	DETAIL
	HUNTER MSBN-25Q 25Q ON A HUNTER PROS-04-PRS30-CV BODY	90	30	0.25	1'	F/L103
	HUNTER RZWS-18-CV 50 18IN. LONG RZWS WITH INSTALLED .50 GPM BUBBLER OPTIONS, CHECK VALVE, 1/2IN. SWING JOINT	360	25	0.5	3'	F/L103

SYMBOL	MANUFACTURER/MODEL/DESCRIPTION	DETAIL
	HUNTER ICZ-101-40-LF DRIP CONTROL ZONE KIT. 1IN. ICV GLOBE VALVE WITH 1IN. HY100 FILTER SYSTEM. PRESSURE REGULATION: 40 PSI. FLOW RANGE: .5 GPM - 15 GPM. 150 MESH STAINLESS STEEL SCREEN.	A/L103
F	FLUSH VALVE MANUAL ASSEMBLY	E/L103
	AREA TO RECEIVE DRIPLINE NETAFIM TLCV-04-18 (18) TECHLINE PRESSURE COMPENSATING LANDSCAPE 17MM DRIPLINE WITH CHECK VALVE. 0.4GPH EMITTERS AT 18" O.C. DRIPLINE LATERALS SPACED AT ±18" APART, WITH EMITTERS OFFSET FOR TRIANGULAR PATTERN. 3" MINIMUM COVERAGE OVER TUBES	C/L103

SYMBOL	MANUFACTURER/MODEL/DESCRIPTION	DETAIL
	HUNTER ICV-G	H/L102
	QUICK COUPLER HUNTER HQ-44LRC	J/L102
	NIBCO F-619-RW-SON CAST IRON RESILIENT WEDGE GATE VALVE W/ 2" OPERATING NUT SIZE EQUAL TO MAINLINE	F/L102
MV	SUPERIOR 3000 2" NORMALLY CLOSED BRASS MASTER VALVE THAT PROVIDES DIRTY WATER PROTECTION AND 3-WAY SOLENOID DESIGN.	K/L103
	FEBCO 825YA 2" REDUCED PRESSURE BACKFLOW PREVENTER	H/L103
CA	HUNTER A2C-75D HUNTER ACC2 IRRIGATION CONTROLLER TWO-WIRE, ETHERNET, METAL PEDESTAL	K/L102
WS	HUNTER SOLAR-SYNC WSS-SEN, WIRELESS SOLAR, RAIN FREEZE SENSOR WITH GUTTER MOUNT BRACKET. MOUNT TO ROOF EAVE WITHIN LINE OF SIGHT OF THE IRRIGATION CONTROLLER. PROVIDE SMART CONNECT MODULE AT CONTROLLER.	G/L103
LI	LIGHTNING ARRESTOR LIGHTNING ARRESTOR AND GROUND ROD OR PLATE PER HUNTER SPECIFICATIONS (EVERY 600 FEET) AND AT THE END OF DEAD-END BRANCH LINES	J/L103
FS	HUNTER HFS-200 FLOW SENSOR FOR USE WITH ACC CONTROLLER, 2IN. SCHEDULE 40 SENSOR BODY, 24 VAC, 2 AMP.	I/L102
M	WATER METER 2" 53-10%=47.7 PSI, WATER TEST 5/22/25	SEE CIVIL UTILITY PLANS
	IRRIGATION LATERAL LINE: PVC SCHEDULE 40 SOLVENT WELD, BELL-END, SIZE AS NOTED	C/L103-02
	IRRIGATION MAINLINE: PVC SCHEDULE 40 SOLVENT WELD, BELL-END, SIZE AS NOTED	C/L103-02
	PIPE SLEEVE: PVC SCHEDULE 40 TWICE PIPE SIZE	D/L102
	CONTROL WIRE SLEEVE	E/L102-02
	DRIPLINE MANIFOLD: PVC SCHEDULE 40	B/L103-02
	TWO-WIRE CABLE IN CONDUIT	E/L102-02

\# — VALVE NUMBER
\#" — VALVE SIZE
\# — VALVE FLOW (GPM)

SYMBOL	DESCRIPTION
#	HUNTER ACC2 TWO WIRE STATION DECODERS. DECODER MODULE NUMBER: 1 = 1-STATION ICD DECODER 2 = 2-STATION ICD DECODER 4 = 4-STATION ICD DECODER S = SENSOR DECODER FOR ICD DECODER SYSTEMS
	PROPOSED TREE, SEE PLANTING PLAN ON SHEET L201-02 FOR VARIETY AND SIZE
A	PIPE SHOWN OUTSIDE OF PLANTER FOR CLARITY. INSTALL PIPE WITHIN PLANTER. SEE GENERAL IRRIGATION NOTE #8

NOT TO BE INCLUDED IN CONSTRUCTION DRAWINGS
"FOR REFERENCE ONLY"

SEE SHEET L102 & L103 FOR IRRIGATION NOTES AND DETAILS

Blair, Church & Flynn
CONSULTING ENGINEERS

LICENSED LANDSCAPE ARCHITECT
Signature
7/31/27
Renewal Date
08/29/2025
Date
STATE OF CALIFORNIA


CONSULTANT
Blair, Church & Flynn Consulting Engineers
451 Clovis Avenue, Suite 200
Clovis, California 93612
Tel (559) 326-1400
Fax (559) 326-1500

REF. & REV.

MERCED CITY SCHOOL DISTRICT
26TH STREET MARS/ELO-P FACILITY
2600 K STREET MERCED, CA 95348
IRRIGATION DETAILS

DR. BY: CH
CH. BY: DB
DATE: XX/XX/XX
SCALE AS NOTED

L101



WATER CONSERVATION COMPLIANCE STATEMENT:

I HAVE COMPLIED WITH THE PERFORMANCE COMPLIANCE OPTION CRITERIA OF THE MODEL WATER EFFICIENT LANDSCAPE ORDINANCE (MWELO) AND APPLIED THEM FOR THE EFFICIENT USE OF WATER IN THE LANDSCAPE DESIGN PLAN.

CATO M. HESKETT, RLA 6932


NOT TO BE INCLUDED IN CONSTRUCTION DRAWINGS

"FOR REFERENCE ONLY"

PARKING LOT SHADING (City of Merced)	***QUANTITY PROPOSED (SF)***		
(EXCLUDE COVERED SOLAR/SHADE CANOPY AREAS)			
PARKING LOT STALLS & AISLES	*8,456*		
PARKING LOT LANDSCAPE	*3,633*		
PARKING LOT HARDSCAPE	*2,359*		
TOTAL PARKING AREA	*14,448*		
50% OF TOTAL PARKING AREA REQUIRING SHADE (SF)	*7,224*		
PARKING SPACES	*28*		
TREES REQUIRED (ONE TREE PER SIX PARKING SPACES)	*5*		
TREES PROVIDED	*9*		
OVER (UNDER) TREE REQUIREMENT	*4*		
PROVIDED SHADE TREES (30FT MIN. AT MATURITY)	***PROVIDED SHADE AREA***	***NO. TREES***	
VERY LARGE (40' dia.= 1256 SF)	*0*	*0*	
LARGE (35' dia.= 962 SF)	*8,658*	*9*	
MEDIUM (30' dia.= 707 SF)	*0*	*0*	
TOTALS	*8,658*	*9*	
OVER (UNDER) PARKING LOT SHADE REQUIREMENT			***1,434***

OFFSITE SHADING (City of Merced)	***QUANTITY PROPOSED (SF)***	***PERCENT REQUIRED***	***SHADE AREA REQUIRED (SF)***
LANDSCAPED AREA (EXCLUDING SPECIAL USE & PARKING LANDSCAPE AREAS)	*3,451*	*20*	*690*
UNCOVERED HARDSCAPE AREA (EXCLUDING PARKING HARDSCAPE AREAS)	*3,957*	*20*	*791*
TOTAL SITE SHADE REQUIRED			*1,482*
PROVIDED SHADE TREES	***PROVIDED SHADE AREA***	***NO. TREES***	
VERY LARGE (40' dia.= 1256 SF)	*0*	*0*	
LARGE (35' dia.= 962 SF)	*2,886*	*3*	
MEDIUM (30' dia.= 707 SF)	*0*	*0*	
SMALL (20' dia.= 314 SF)	*0*	*0*	
VERY SMALL (10' dia.= 79 SF)	*316*	*4*	
TOTALS	*3,202*	*7*	
OVER (UNDER) LANDSCAPE & HARDSCAPE SHADE REQUIREMENT			***1,720***

SEE SHEET L201 FOR PLANTING LEGEND, NOTES AND DETAILS



Know what's below. Call before you dig.

Blair, Church & Flynn
CONSULTING ENGINEERS

LICENSED LANDSCAPE ARCHITECT
CATO M. HESKETT No. 6932
Signature 7/31/27 Renewal Date
08/29/2025 Date
STATE OF CALIFORNIA

CONSULTANT
Blair, Church & Flynn Consulting Engineers
451 Clovis Avenue, Suite 200
Clovis, California 93612
Tel (559) 326-1400
Fax (559) 326-1500

REF. & REV.

MERCED CITY SCHOOL DISTRICT

26TH STREET MARS/ELO-P FACILITY
2600 K STREET MERCED, CA 95348
PLANTING PLAN

DR. BY: CH
CH. BY: DB
DATE: XX/XX/XX
SCALE AS NOTED

L200

Drawing: P:\224\224-0395\Site\productiondrawings\Off Site\224395_la01-offsite.dwg: layout1 - BCF.ctb
Plot by: jfelix Feb 05, 2026 - 1:59pm

Loaded Xrefs

ADDENDUM NO. 2

PLANTING NOTES:

1. IMMEDIATELY NOTIFY THE OWNER'S REPRESENTATIVE IF IT IS OBVIOUS THAT OBSTRUCTIONS OR STRUCTURES, IRRIGATION SYSTEM MALFUNCTION, EXISTING TREES OR PLANTS, GRADE DIFFERENCES OR CHANGES IN THE SITE PLAN ARE PRESENT THAT WILL IMPACT THE PLANTING DESIGN. FAILURE TO GIVE SUCH NOTIFICATION SHALL PLACE THE RESPONSIBILITY ON THE CONTRACTOR FOR ANY REVISIONS OR REPLACEMENTS NECESSARY FOR CORRECTION.
2. ANY EXISTING PLANTING SHOWN ON THE PLAN IS FOR REFERENCE ONLY. THE CONTRACTOR SHALL VERIFY THE EXISTING PLANTING AT THE SITE PRIOR TO STARTING WORK. UNLESS NOTED OTHERWISE, THE CONTRACTOR SHALL PROTECT THE EXISTING PLANTING ADJACENT TO THE WORK FROM DAMAGE OR DISTRESS.
3. ALL TREES AND SHRUBS SHALL BE OF CLASS A QUALITY WITHOUT PESTS, DISEASE OR DAMAGE, SHALL BE WELL ESTABLISHED IN THEIR CONTAINERS WITHOUT GIRDLING ROOTS OR EXCESSIVE TOP GROWTH, AND SHALL COMPLY WITH THE REQUIREMENTS OF THE "AMERICAN STANDARDS FOR NURSERY STOCK" (ANSI Z60.1).
4. NOTIFY THE LANDSCAPE ARCHITECT PRIOR TO THE INSTALLATION OF IRRIGATION COMPONENTS AND TREE AND/OR SHRUB PLANTING FOR APPROVAL OF THE PLANT LAYOUT AND PLANT QUALITY. PLANT LOCATIONS SHALL AVOID CONFLICTS WITH EXISTING IMPROVEMENTS, PLANTINGS OR UTILITIES, LIGHT POLES WHILE MEETING THE DESIGN INTENT. DO NOT PLANT TREES WITHIN 15 FEET OF LIGHT POLES UNLESS SPECIFICALLY AUTHORIZED. FAILURE TO OBTAIN SUCH APPROVAL SHALL PLACE THE RESPONSIBILITY ON THE CONTRACTOR FOR ANY RELOCATION OR REPLACEMENT OF IRRIGATION COMPONENTS, PLANTED TREES AND/OR SHRUBS.
5. PLANT QUANTITIES ARE PROVIDED FOR BIDDING CONVENIENCE ONLY. THE CONTRACTOR SHALL PROVIDE SUFFICIENT QUANTITIES OF PLANTS EQUAL TO THE SYMBOL COUNT OR TO FILL THE AREA SHOWN ON THE PLAN AT THE SPECIFIED TRIANGULAR SPACING.
6. WHERE GROUND COVER PLANTS ARE SHOWN AT A SPECIFIED SPACING, THE GROUND COVER PLANTING CONTINUES UNDERNEATH THE TALLER SHRUBS AND TREES AS SHOWN IN THE PLANTING DETAILS. DO NOT PLANT GROUND COVER IN SHRUB OR TREE WATERING BASINS.
7. ALL NEW TREES LOCATED WITHIN 8 FEET OF PAVEMENT OR STRUCTURES SHALL HAVE A ROOT CONTROL BARRIER INSTALLED WHEN PLANTED. UNLESS OTHERWISE SPECIFIED, INSTALL A 12 FOOT LONG X 24 INCH DEEP LINEAR POLYETHYLENE BARRIER VESPRO OR EQUAL AT THE EDGE OF PAVEMENT/STRUCTURE, CENTERED ON THE TREE TRUNK AS SHOWN IN THE PLANTING DETAILS.
8. REMOVE NURSERY STAKES FROM TREES AFTER TREE STAKING OR GUYING AS SHOWN IN THE DETAILS.
9. INSTALL PERFORATED POLYETHYLENE TREE TRUNK PROTECTORS FOR ALL NEW TREES PLANTED IN TURF. UNLESS NOTED OTHERWISE, MAINTAIN A MINIMUM 6 FOOT DIAMETER MULCHED AREA AT THE BASE OF THE TREE INSIDE THE WATERING BASIN.
10. THE CONTRACTOR SHALL PRUNE NEW TREES ONLY WHEN SPECIFICALLY DIRECTED BY THE LANDSCAPE ARCHITECT. TREES HEADED BACK WITHOUT INTACT SCAFFOLDING BRANCH STRUCTURE OR IN ROOT-BOUND CONTAINERS SHALL BE REJECTED.
11. SUBMIT REPRESENTATIVE SOIL SAMPLES OF NATIVE AND PROPOSED IMPORT, IF NEEDED, PLANTING TOPSOIL TO A SOIL LAB FOR HORTICULTURAL ANALYSES AND FERTILITY RECOMMENDATIONS. AMEND SOIL ACCORDING TO THE RECOMMENDATIONS OF THE SOILS REPORT AND LANDSCAPE ARCHITECT'S DIRECTION. SEE THE LANDSCAPE PLANTING SPECIFICATIONS FOR ADDITIONAL INSTRUCTIONS.
12. PROVIDE SANDY LOAM TOPSOIL PER SPECIFICATION IN ALL RAISED PLANTERS AND WHERE IMPORT TOPSOIL IS REQUIRED. NATIVE SITE SOIL MAY BE USED IN RAISED PLANTERS ONLY WHEN THE NATIVE SITE SOIL MEETS THE CRITERIA FOR SANDY LOAM TOPSOIL AS DETERMINED BY A SOIL ANALYSIS.
13. PRIOR TO SOIL CONDITIONING IN NEW PLANTING AREAS, RIP IN TWO DIFFERENT DIRECTIONS WITH TINES AT 12 INCH SPACING, ALL TURFGRASS AREAS TO A 12 INCH DEPTH, AND SHRUB/GROUND COVER AREAS TO A 18 INCH DEPTH. ROUGH GRADE AND TILL THE APPROVED SOIL CONDITIONERS AND FERTILIZERS INTO THE TOP SIX (6) INCHES OF ALL PLANTING AREAS PER THE LANDSCAPE PLANTING SPECIFICATIONS. COMPOST RATE SHALL BE A MINIMUM OF SIX (6) CUBIC YARDS PER 1,000 SQUARE FEET OR AS MODIFIED BY THE LANDSCAPE ARCHITECT BASED ON THE SOUL FERTILITY ANALYSIS.
14. UPON THE COMPLETION OF THE SOIL CONDITIONING, REMOVE ROCKS AND CLODS 1 INCH DIAMETER AND GREATER FROM THE TOP TWO INCHES OF TOPSOIL, AND ALL DEBRIS. FINISH GRADE THE AREA TO +/- 0.04 FOOT TOLERANCE. FINISH GRADE IN MULCHED AREAS SHALL BE STRAIGHT GRADES WITHOUT HUMPS OR DEPRESSIONS AND SHALL BE 2 INCHES BELOW ADJACENT HARDSCAPE, INLETS OR UTILITY BOX COLLARS. RELATIVE DENSITY OF THE TOPSOIL SHALL NOT EXCEED 85% COMPACTION.
15. OBTAIN THE APPROVAL OF THE OWNER'S REPRESENTATIVE TO BEGIN PLANTING OPERATIONS ONCE THE IRRIGATION SYSTEM IS OPERATIONAL AND THE SOIL CONDITIONING AND FINISH GRADING IS COMPLETED.
16. AFTER PLANTING IS COMPLETED AND JUST PRIOR TO MULCH INSTALLATION, APPLY A BROAD SPECTRUM PRE-EMERGENT HERBICIDE TO ALL NON-TURFGRASS PLANTING AREAS PER THE MANUFACTURER'S SPECIFICATIONS.
17. WHERE MULCH IS TO BE INSTALLED IN AN EXISTING PLANTING AREA, BREAKUP/TILL THE EXISTING SOIL TO A MINIMUM 6 INCH DEPTH PER SPECS, AND ADJUST FINISH GRADE ADJACENT TO HARDSCAPE AND DRAINAGE ELEMENTS TO PROVIDE A 2 INCH DEPTH THAT TRANSITIONS TO THE EXISTING GRADE OVER 1 TO 2 FEET.
18. INSTALL A MINIMUM 3 INCH DEPTH OF CHIPPED WALK-ON WOOD MULCH IN ALL PLANTING AREAS AND TREE WATERING BASINS EXCEPT FOR TURFGRASS AREAS, SLOPES 3H:1V OR GREATER, AREAS TO RECEIVE SEED PLANTING, OR AS NOTED ON THE PLAN. AREAS PLANTED WITH FLATS SHALL HAVE A MINIMUM MULCH DEPTH OF 2 INCHES. INSTALL A MINIMUM 3 FOOT RADIUS OF 3 INCH DEEP WOOD MULCH AT THE BASE OF ALL TREES IN NEW TURFGRASS AREAS.
19. ALL EXISTING PLANTS AND/OR TURFGRASS SHOWN TO REMAIN AND DAMAGED OR REMOVED BY CONSTRUCTION OPERATIONS AND/OR UTILITY/IRRIGATION/DRAINAGE LINES SHALL BE REPLACED WITH PLANTS THAT MATCH AS CLOSELY AS POSSIBLE TO THE EXISTING PLANT SPECIES, VARIETY AND SIZE. THE REPLACEMENT TURFGRASS SOD VARIETY SHALL BE THE SAME AS SHOWN IN THE PLANTING LEGEND AS IF FOR NEW WORK, OR SHALL MATCH THE EXISTING TURFGRASS VARIETY WHERE EXISTING. TILL SOIL CONDITIONING MATERIALS INTO THE TOP 6 INCHES OF THE SOIL OVER THE AREA OF REPAIR/REPLACEMENT AS IF FOR NEW WORK. ADJUST FINISH GRADE SO NEW TURFGRASS SOD ABUTS FLUSH TO EXISTING SOD GRADE. THE REPLACEMENT PLANTS AND/OR TURFGRASS SOD SHALL BE MAINTAINED AS PART OF THE ORIGINAL SCOPE OF WORK. THE REPAIR OR REPLACEMENT WORK SHALL BE AT THE CONTRACTOR'S SOLE EXPENSE.
20. CONTRACTOR SHALL MAINTAIN THE NEW PLANTING FOR HEALTHY AND VIGOROUS GROWTH, WHICH INCLUDES BUT IS NOT LIMITED TO WATERING, WEEDING, FERTILIZING, MOWING AND EDGING (AT LEAST ONCE A WEEK), REMOVING TRASH AND DEBRIS, AND OTHER RELATED ACTIVITIES THROUGHOUT THE DURATION OF THE MAINTENANCE PERIOD UNTIL FINAL ACCEPTANCE.



CONTRACTOR SPECIAL PLANTING NOTES:


1. AN ASSESSMENT AND VALUATION OF ONSITE EXISTING TREES SCHEDULED TO REMAIN IN THE AREA OF WORK SHALL BE PERFORMED BY THE CONTRACTOR'S ARBORIST PRIOR TO THE START OF CONSTRUCTION OPERATIONS PER THE 'EXISTING LANDSCAPE PROTECTION' SPECIFICATION.
2. THE CONTRACTOR SHALL RIP, CONDITION AND TILL THE ENTIRE EXTENT OF ALL PLANTING AREAS RECEIVING NEW PLANTS PER THE PLANTING NOTES AND 'LANDSCAPE PLANTING' SPECIFICATIONS.
3. ALL EXISTING MIXED PLANTING AREAS RECEIVING NEW WOOD MULCH SHALL BE MANUALLY TILLED TO A MINIMUM DEPTH OF 4 INCHES, CLODS BROKEN UP TO A MAXIMUM 1 INCH DIAMETER, FINISH GRADED TO 2 INCHES BELOW ADJACENT SURFACES AND UTILITY/IRRIGATION BOXES WITHIN 12 INCHES OF THE HARDSCAPE EDGE, AND A PRE-EMERGENT HERBICIDE APPLIED PRIOR TO WOOD MULCH INSTALLATION. PROTECT EXISTING PLANTING DURING WOOD MULCH PREPARATION AND INSTALLATION.
4. THE ORIGINAL PLANTING OBSERVATION LOG SHALL BE MAINTAINED ON THE AS-BUILT RECORD DRAWING SET.
5. THE AS-BUILT RECORD DRAWING SET AND MAINTENANCE MANUAL SHALL BE SUBMITTED AND ACCEPTED PRIOR TO THE SCHEDULING OF A FINAL ACCEPTANCE REVIEW.

OFFSITE PLANT LEGEND:


TOTAL AREA OF MIXED PLANTING: 3,451 S.F.

SUNSET ZONE: 8

SYMBOL	CODE	BOTANICAL / COMMON NAME	CONT	WATER USE	QTY	DETAIL	REMARKS
SMALL TREES							
	CHI LIN	CHILOPSIS LINEARIS DESERT WILLOW	24"BOX	VL	2	A/L201	DECIDUOUS, STANDARD FORM, FULL SUN MS: 15-30' H X 10-20' W
VERY LARGE TREES							
	QUE LOB	QUERCUS LOBATA VALLEY OAK	24"BOX	L	3	A/L201	DECIDUOUS, STANDARD FORM, FULL SUN, CA NATIVE MS: 60-100' H X 50' W

SYMBOL	CODE	BOTANICAL / COMMON NAME	SIZE	WATER USE	QTY	DETAIL	REMARKS
SHRUBS							
	CEA YAN	CEANOTHUS GRISEUS HORIZONTALIS 'YANKEE POINT' YANKEE POINT CARMEL CREEPER	5 GAL	L	20	B/L201	FULL SUN TO PART SHADE, CA NATIVE MS: 2-3' H X 8-10' W
	CIS PUL	CISTUS X PULVERULENTUS 'SUNSET' SUNSET ROCKROSE	5 GAL	L	28	B/L201	EVERGREEN, FULL SUN TO PARTIAL SHADE MS: 2' H X 6-8' W
	DIA LRV	DIANELLA REVOLUTA 'DR5000' LITTLE REV™ FLAX LILY	5 GAL	L	2	B/L201	EVERGREEN, FULL SUN TO PART SHADE MS: 2-3' H X 2-3' W
	EUR PEC	EURYOPS PECTINATUS GOLDEN SHRUB DAISY	1 GAL	L	2	B/L201	EVERGREEN, FULL SUN MS: 3-6' H X 3-6' W
	LAN XSU	LANTANA X 'SUNBURST' SUNBURST LANTANA	5 GAL	L	1	B/L201	EVERGREEN, FULL SUN MS: 2-3; H X 6-8' W
	LEU COM	LEUCOPHYLLUM FRUTESCENS 'COMPACTA' COMPACT TEXAS SAGE	5 GAL	L	5	B/L201	EVERGREEN, FULL SUN MS: 5' H X 5' W
	RIB SAN	RIBES SANGUINEUM RED FLOWERING CURRANT	5 GAL	L	1	B/L201	DECIDUOUS, PART SHADE TO SHADE, CA NATIVE MS: 6-12' H X 6-12' W
PERENNIALS							
	ACH PAP	ACHILLEA MILLEFOLIUM 'PAPRIKA' PAPRIKA COMMON YARROW	1 GAL	L	57	B/L201	WINTER DORMANT PERENNIAL, SUN TO PART SHADE MS: 1-2' H X 1-2' W
GROUND COVER							
	COT BEA	COTONEASTER DAMMERI `CORAL BEAUTY` CORAL BEAUTY COTONEASTER	1 GAL	L	78	B/L201	EVERGREEN, FULL SUN MS: <1' H X 6' W

SYMBOL	CODE	BOTANICAL / COMMON NAME	CONT	WATER USE	DETAIL	REMARKS
SHRUB AREAS						
	SITETRI	SITE TRIANGLE	N/A		B/L201	40FT FROM PROPERTY LINE TO PROPERTY LINE, DIAGONAL ON THE CORNER
	RB	ROOT BARRIER UB24-2			E/L201	24 INCH DEEP ROOT BARRIER PANELS. INSTALL PER MANUFACTURE'S SPECIFICATIONS.




NOTES:

1. TREE QUALITY SHALL BE IN ACCORDANCE WITH THE GUIDELINE SPECIFICATIONS FOR NURSERY TREE QUALITY, THAT CAN BE FOUND ON http://www.urbantree.org/newspecs.asp.
2. CONDITION OF TREE– TREE SHALL BE FREE OF INJURIY AND DISEASE AND SHALL HAVE NO CIRCULAR, DAMAGED, OR GIRDLING ROOTS.
3. TYPE OF TREE– AS SPECIFIED BY THE PUBLIC WORKS DEPARTMENT.
4. SIZE OF TREE– SHALL BE 15 GALLON, 1–INCH MINIMUM CALIPER, 7–FOOT MINIMUM HEIGHT OR LARGER AND A CANOPY SPREAD OF 2'–3', AS REQUIRED BY DEVELOPMENT APPROVAL.
5. ROOT BARRIERS– NEW SUBDIVISION TREES SHALL HAVE AN APPROVED ROOT BARRIER INSTALLED TO A MINIMUM DEPTH OF 24".

ENGINEERING DEPARTMENT		CITY OF MERCED, CA.
	TREE PLANTING & STAKING	L-1
DRAWN: KGE	APPROVED BY: [signature] DATE 3/17/08	
DATE: 1/02		
REVISED: 3/17/08	CITY ENGINEER	SHEET OF


A / L201 DOUBLE STAKE TREE PLANTING
NOT TO SCALE



LEGEND

1. SHRUB.
2. WOOD MULCH LAYER.
3. 3" HIGH WATERING BASIN.
4. FINISH GRADE.
5. AMENDED BACKFILL. SEE SPECIFICATIONS.
6. FERTILIZER PACKET. SEE SPECIFICATIONS.
7. SITE SOIL.
8. ROOTBALL. SET TOP OF ROOTBALL 1" ABOVE FINISH GRADE.

B / L201 SHRUB PLANTING
NOT TO SCALE




LEGEND:

1. CONTAINER SHRUB OR GROUND COVER IN TRIANGULATED ROWS, SEE SHRUB PLANTING PER DETAIL [X/L201].
2. GROUND COVER FLATS OR LINERS - TRIANGULATED ROWS.
3. SPACE PER PLANT LEGEND. OMIT PLANTS WHERE IN CONFLICT WITH SHRUBS OR TREE WATERING BASINS.
4. SPACING DISTANCE FROM PLANT LEGEND.
5. HARDSCAPE ELEMENT: CURB, WALK, ETC.
6. MULCH PER SPECIFICATIONS.

C / L201 SHRUB AND GROUND COVER SPACING
NOT TO SCALE

NOT TO BE INCLUDED IN CONSTRUCTION DRAWINGS
"FOR REFERENCE ONLY"



D / L201 MULCH DETAIL
NOT TO SCALE

TREE SIZE AND QUALITY STANDARDS									
AMERICAN STANDARDS FOR NURSERY STOCK (ANSI Z60.1) AND GUIDELINE SPECIFICATIONS FOR NURSERY TREE QUALITY (URBAN TREE FOUNDATION SHALL APPLY									
	TYPES 1 & 2 SHADE TREES			TYPE 3 SMALL UPRIGHT TREES **			TYPE 4 SMALL SPREADING TREES ***		
CONTAINER SIZE	MIN. CALIPER	MAX. CALIPER	TYPE 1 MIN./MAX. HEIGHT *	MIN. CALIPER	MAX. CALIPER	MIN./MAX. HEIGHT	MIN. CALIPER	MAX. CALIPER	MIN./MAX. HEIGHT
15 GALLON	0.75	2.0	7-10 FT	0.75	2.0	6-8 FT	0.75	2.0	4-8 FT
24" BOX	1.25	3.0	8-12 FT	1.25	3.0	8-10 FT	1.25	3.0	6-10 FT
36" BOX	1.75	3.5	10-16 FT	1.75	3.5	10-14 FT	1.75	3.5	7-12 FT
42" BOX	2.0	4.0	12-20 FT	2.0	4.0	12-18 FT	2.0	4.0	8-14 FT
48" BOX	2.5	5.0	14-26 FT	2.5	5.0	14-22 FT	2.5	5.0	9-16 FT

* TYPE 2 TREE HEIGHTS SHALL NOT BE LESS THAN TWO-THIRDS THE LISTED HEIGHT RANGE.

** TYPE 3 TREES SHALL HAVE A MINIMUM OF SEVEN BRANCHES.

*** TYPE 4 TREES SHALL HAVE A MINIMUM OF EIGHT BRANCHES.

CALIPER MEASUREMENT FOR CLUMP OR MULTI-STEM TREES IS ONE-HALF THE SUM OF THE THREE LARGEST TRUNK CALIPERS.

CALIPER MEASUREMENT FOR <4" TRUNK IS +6" ABOVE ROOTBALL (NOT INCLUDING ROOTSTOCK). >4" TRUNK IS +12".

TREES SHALL HAVE A CENTRAL LEADER. NEW LEADERS LESS THAN HALF THE DIAMETER OF A HEADED LEADER, BROKEN OR CO-DOMINATE LEADERS ARE NOT ACCEPTABLE.


SCAFFOLD BRANCHES SHALL BE LESS THAN 2/3 THE DIAMETER OF THE TRUNK, WITHOUT INCLUDED BARK AT ATTACHMENT. SCAFFOLD BRANCHES SHALL BE BALANCED, WELL SPACED VERTICALLY, AND WITH A RADIALLY BLANK SECTOR NO GREATER THAN 1/3 OF THE CANOPY CIRCUMFERENCE.

TEMPORARY BRANCHES ON THE LOWER TRUNK SHALL BE LESS THAN 3/8 INCH DIAMETER; AND THE CLEAR TRUNK HEIGHT SHALL BE NO MORE THAN 40% OF THE TOTAL TREE HEIGHT.

THE ROOT COLLAR AND ROOTBALL SHALL BE FREE OF DEFECTS INCLUDING CIRCLING, KINKED AND GIRDLING ROOTS. ROOTS THE EDGE AND BOTTOM OF THE CONTAINER SHALL BE LESS THAN 1/4 INCH DIAMETER, AND UNIFORM THROUGHOUT THE CONTAINER.

TREE CANOPY WIDTH SHALL BE A MINIMUM OF 25% OF THE STANDARD FORM TREE HEIGHT.

DO NOT HEAD BACK OR PRUNE TREES UNLESS APPROVED AND/OR DIRECTED TO BY THE LANDSCAPE ARCHITECT.




LEGEND

1. TREE TRUNK.
2. 12 LF OF 24"-DEEP ROOT CONTROL BARRIER: DEEP ROOT UB24-2 OR EQUIVALENT. CENTER BARRIER ON TRUNK OF TREE. INSTALL PER MANUFACTURER'S SPECIFICATIONS.
3. HARDSCAPE ELEMENT: CURB, SIDEWALK, WALL, ETC.
4. PLANTING AREA.
5. INSTALL ROOT CONTROL BARRIER ON ALL SIDES OF THE PLANTING AREA WHEN SURROUNDED BY HARDSCAPE WITHIN 8' OF THE TREE TRUNK.

E / L201 ROOT CONTROL BARRIER
NOT TO SCALE

Blair, Church & Flynn
CONSULTING ENGINEERS



CONSULTANT	REF. & REV.	MERCED CITY SCHOOL DISTRICT	
Blair, Church & Flynn Consulting Engineers 451 Clovis Avenue, Suite 200 Clovis, California 93612 Tel (559) 326-1400 Fax (559) 326-1500		26TH STREET MARS/ELO-P FACILITY 2600 K STREET MERCED, CA 95348 PLANTING DETAILS	DR. BY: CH CH. BY: DB DATE: XX/XX/XX SCALE AS NOTED L201

Drawing: P:\224\224-0395\Site\productiondrawings\Off Site\224395_ladt01-offsite.dwg; layout1 - BCF.ctb
Plot by: jfelix Feb 05, 2026 - 1:59pm

Loaded Xrefs

ADDENDUM NO. 2

GENERAL TOPOGRAPHIC SURVEY LEGEND:

(NOT ALL SYMBOLS SHOWN APPEAR ON THE PLANS)

Abbreviation	Description
AB	ABUTMENT
AC	ASPHALTIC CONCRETE
ACE	ASPHALTIC CONCRETE EDGE
AD	ASPHALTIC CONCRETE DIKE
AWT	ALL-WEATHER TRACK
BD	BRIDGE DECK
BFC	BOTTOM FACE OF CURB
BGST	STEPS
BGTR	TOP OF ROOF
BGV	BUILDING VENTS
BOD	BOTTOM OF DITCH
BR	BARRICADE
BRK	BRICK
BW	BARRIER WALL
CB	CATCH BASIN
CDA	CONCRETE DRIVE APPROACH
CE	CONCRETE EDGE
CMP	CORRUGATED METAL PIPE
CON	CONCRETE
COTH	COMMUNICATION TRENCH
CR	CROWN OF ROAD
CRQ	QUARTER CROWN
CS	CONCRETE SLAB
CULV	CULVERT
CW	CONCRETE WALL
DD	DOWN DRAIN
DFL	DITCH FLOWLINE
DWY	DRIVEWAY
ECTH	ELECTRICAL TRENCH
EDR	EDGE OF DIRT ROAD
EGR	EDGE OF GRAVEL ROAD
EOD	EDGE OF OILED DIRT
EP	EDGE OF PAVEMENT
ES	EDGE OF SHOULDER
ET	EDGE OF TRAVELED WAY
FF	FINISH FLOOR
FOTH	FIBER OPTIC TRENCH
GB	GRADE BREAK
GFL	GUTTER FLOWLINE
GR	GRATE
GRA	GRAVEL SPOT SHOT
GRAE	EDGE OF GRAVEL
GSTH	GAS TRENCH
HDR	WOOD HEADER
HW	HEAD WALL
KR	K-RAIL
LIP	LIP OF GUTTER
LSDE	DECOMPOSED GRANITE EDGE
LSDG	DECOMPOSED GRANITE
LSGC	GROUND COVER
LSGF	GOLF COURSE FAIRWAY
LSGG	GOLF COURSE GREEN
LSGT	GOLF COURSE TEE
LSSA	SAND
LSSP	SLOPE PROTECTION
LSST	GOLF COURSE SAND TRAP
NPTH	NON-POTABLE TRENCH

Abbreviation	Description
PA	PATIO
PGTH	PROPANE GAS TRENCH
POS	POINT ON SLOPE
RCP	REINFORCED CONCRETE
RIEL	RIPARIAN EDGE OF LAKE
RIEP	RIPARIAN EDGE OF POND
RIES	RIPARIAN EDGE OF STREAM
RIEW	RIPARIAN EDGE OF WETLAND
RIFL	RIPARIAN FLOWLINE
RIMC	RIPARIAN MISC.
RIP	RIP-RAP SLOPE PROTECTION
RK	ROCK
RW	RETAINING WALL
SB	SPEED BUMP
SDCD	STORM DRAIN CROSS DRAIN
SDFL	STORM DRAIN FLOWLINE
SDGR	STORM DRAIN GRATE
SDMG	STORM DRAIN MANHOLE W/ GRATE
SSFL	SEWER FLOWLINE
SDTH	STORM DRAIN TRENCH
SSGT	STORM DRAIN GREASE TRAP
SSST	SEWER TANK (SEPTIC)
SSTH	SEWER TRENCH
SWK	SIDEWALK
SWL	SWALE
T	TURF
TBC	TOP BACK OF CURB
TBW	TOP BACK OF WALK
TF	TOP OF FOOTING
TFC	TOP FACE OF CURB
TFW	TOP FACE OF WALK
TLTH	TELEPHONE TRENCH
TOB	TOP OF BANK
TOE	TOE OF SLOPE
TOP	TOP OF SLOPE
TRDO	TRUNCATED DOMES
TVTH	TV TRENCH
TW	TOP OF WALL
UTH	UNIDENTIFIED TRENCH/SCAR LINE
VGFL	VALLEY GUTTER FLOWLINE
VGR	VALLEY GUTTER
WALBA	BARRIER WALL
WALBW	BLOCK WALL
WALCW	CONCRETE WALL
WALHW	HEAD WALL
WALRW	RETAINING WALL
WALWW	WING WALL
WCR	WHEELCHAIR RAMP
WLPD	WELL PAD
WTTH	WATER TRENCH
WW	WING WALL
(335.21)	EXISTING ELEVATION
AL	ACCENT LIGHT
AV	ALFALFA VALVE
	BACKFLOW ASSEMBLY
	BASKETBALL GOAL
BOV	BLOW-OFF VALVE
	BM=BENCHMARK; OR SBM=SITE BENCHMARK

Symbol	Description
BO	BOLLARD
CO	CLEANOUT
COPB	COMMUNICATION PULLBOX
CVA	COMMUNICATION VAULT
312.55	SURVEY CONTROL MONUMENT
DF	DRINKING FOUNTAIN
DS	DOORSTOP
DW	DRYWELL
EG	ELECTRICAL GROUND
ELC	ELECTRICAL CONDUIT
E	ELECTRICAL METER
EPB	ELECTRICAL PULLBOX
E	ELECTRICAL VAULT LID
ETS	GAS ELECTRONIC TESTING STATION
FDC	FIRE DEPARTMENT CONNECTION
	FIRE HYDRANT
FP	FENCE POST
FLP	FLAG POLE
GAS	GAS LINE; DIAMETER AS SHOWN
GR	GAS REGULATOR
GAV	IRRIGATION GATE VALVE
G	GAS METER
GOP	GOAL POST
GP	GUY POLE
GS	GATE STOP
GSR	GAS RISER
GV	GAS VALVE
GRD	GROUNDING ROD
GUY	GUY WIRE
HB	HOSE BIBB
HR	HANDRAIL
ICB	IRRIGATION CONTROLLER
I	IRRIGATION DISTRICT MANHOLE
IVA	IRRIGATION REMOTE CONTROL VALVE
ISB	IRRIGATION SPLICE BOX
IHB	IN-GROUND HOSE BIBB
IP	IRON PIPE
JP	JOINT UTILITY POLE
LP	LIGHT POLE
MB	MAIL BOX
MH	MANHOLE
MI	MANUAL IRRIGATION VALVE
PB	PULLBOX
PIV	POST INDICATOR VALVE
	UTILITY STUB
	PARKING METER
4"POST	POST; DIAMETER AS SHOWN
PP	POWER POLE
6" PVC	PVC PIPE; DIAMETER AS SHOWN
QC	QUICK COUPLER VALVE
RD	ROOF DRAIN
RDU	ROOF DRAIN UNDERGROUND
RS	ROOF SUPPORT
	STADIUM LIGHT POLE
D	STORM DRAIN MANHOLE
	SIGN
PPB	SIGNAL LIGHT PUSH BUTTON
	STREET LIGHT

Symbol	Description
4" SLE	PIPE SLEEVE; DIAMETER AS SHOWN
	SLOPE
SLPB	STREET LIGHT PULLBOX
4"SLV	PIPE SLEEVE; DIAMETER AS SHOWN
S	SEWER MANHOLE
SP	SERVICE POLE
SPB	SIGNAL PULLBOX
	SPRINKLER
4" SPO	STEEL POST; DIAMETER AS SHOWN
12"SS	SAND SEPARATOR; SIZE AS NOTED
24"STP	STAND PIPE; DIAMETER AS NOTED
12"STUMP	TREE STUMP; DIAMETER AS SHOWN
MW	SURVEY MONUMENT WELL
4"TEL	TELEPHONE; DIAMETER AS SHOWN
T	TELEPHONE MANHOLE
TN	TENNIS NET POLE
TP	TELEPHONE POLE
TPB	TELEPHONE PULLBOX
TVPB	TELEVISION PULLBOX
6	TREE; SPREAD SHOWN GRAPHICALLY AND TRUNK DIAMETER AS SHOWN
	PALM TREE; SPREAD SHOWN GRAPHICALLY
TSB	TELEPHONE SPLICE BOX
	TRAFFIC SIGNAL POLE
TSPB	TRAFFIC SIGNAL PULLBOX
UP	UTILITY POLE
UR	UTILITY RISER
VB	VACUUM BREAKER
VN	VOLLEYBALL NET POST
2"VP	VENT PIPE; DIAMETER AS SHOWN
WELL	WELL
W	WATER METER
WP	WELL PUMP
6"WPO	CIRCULAR WOOD POST; DIAMETER AS SHOWN
4"X4"WPO	SQUARE WOOD POST; SIZE AS SHOWN
4"W	WATER LINE; DIAMETER AS SHOWN
WV	WATER VALVE
	ASPHALT PAVEMENT
	CONCRETE BLOCK WALL
	BUILDING
	CONCRETE
	DETECTABLE WARNINGS
	DG OR GRAVEL
	CHAIN LINK FENCE
	CHAIN LINK ROLL GATE
	EDGE OF ASPHALT PAVEMENT
	WOOD FENCE
	DIRECTION OF FLOW
E	UNDERGROUND ELECTRIC
G 8"	GAS LINE; SIZE AS NOTED
OT	OVERHEAD TELEPHONE
SD 18"	STORM DRAIN LINE; SIZE AS NOTED
S 12"	SEWER LINE; SIZE AS NOTED
T	UNDERGROUND TELEPHONE

Line	Description
W 8"	WATER LINE; SIZE AS NOTED
AG 12"	AGRICULTURAL IRRIGATION LINE; SIZE AS NOTED
A 1"	AIR LINE; SIZE AS NOTED
C	COMMUNICATION LINE
350	MAJOR GRADE CONTOUR LINE
345	MINOR GRADE CONTOUR LINE
CW 2"	CHILLED WATER LINE; SIZE AS NOTED
CWR 2"	CHILLED WATER RETURN LINE; SIZE AS NOTED
CWS 2"	CHILLED WATER SUPPLY LINE; SIZE AS NOTED
	LIMIT OF DIRT
	LIMIT OF TURF
DL 1"	DRAIN LINE; SIZE AS NOTED
EMS	EMERGENCY MANAGEMENT SYSTEM
FA	FIRE ALARM LINE
F 8"	FIRE LINE; SIZE AS NOTED
FO	FIBER OPTIC LINE
	DRAIN TUBE
HW 2"	HOT WATER LINE; SIZE AS NOTED
HWR 2"	HOT WATER RETURN LINE; SIZE AS NOTED
HWS 2"	HOT WATER SUPPLY LINE; SIZE AS NOTED
HYD	HYDRAULIC LINE
ID 18"	IRRIGATION DISTRICT; SIZE AS NOTED
I	IRON FENCE
IRR 3"	IRRIGATION MAIN LINE; SIZE AS NOTED
L 1"	IRRIGATION LATERAL LINE; SIZE AS NOTED
ITS	INTELLIGENT TRAFFIC SYSTEM
JT	JOINTLY TRENCHED UTILITIES
OC	OVERHEAD COMMUNICATIONS LINE
OE	OVERHEAD ELECTRIC LINE
OEC	OVERHEAD ELECTRIC AND COMMUNICATION LINE
OET	OVERHEAD ELECTRIC AND TELEPHONE LINE
OETV	OVERHEAD ELECTRIC AND TELEVISION LINE
OETVT	OVERHEAD ELECTRIC, TELEVISION AND TELEPHONE LINE
OTS	OVERHEAD TRAFFIC SIGNAL LINE
OTV	OVERHEAD TELEVISION LINE
OU	OVERHEAD UTILITY LINE
P 6"	PETROLEUM LINE; SIZE AS NOTED
RWI 3"	RECYCLED WATER IRRIGATION LINE; SIZE AS NOTED
S&SD 8"	SEWER AND STORM DRAIN LINE; SIZE AS NOTED
SFM 6"	SEWER FORCE MAIN; SIZE AS NOTED
ST 2"	STEAM LINE; SIZE AS NOTED
TFO	TRAFFIC FIBER OPTIC LINE
TS	TRAFFIC SIGNAL LINE
TV	TELEVISION LINE
UNK	UNKNOWN UTILITY LINE
X	WIRE FENCE
	PROPERTY LINE
	CITY LIMIT
	EASEMENT 1
	EASEMENT 2
	RIGHT-OF-WAY LINE
	SETBACK LINE

SURVEY NOTES:

1. THIS TOPOGRAPHIC SURVEY LOCATES SPECIFIC PHYSICAL FEATURES OF THE SITE AND THEIR ELEVATION AS DETERMINED NECESSARY BY THE PROJECT ENGINEER. IT IS NOT A COMPLETE TOPOGRAPHIC SURVEY OF THE SITE. THE INFORMATION SHOWN REFLECTS THE DATA OBTAINED BY FIELD SURVEY CONDUCTED ON JANUARY 30, 2025.
2. UTILITY INFORMATION SHOWN HEREON IS BASED ON RECORD INFORMATION SUPPLIED TO THE ENGINEER BY UTILITY COMPANIES, PUBLIC AGENCIES AND THE PROPERTY OWNER, TOGETHER WITH OBSERVATION OF VISIBLE EVIDENCE BY A FIELD SURVEY. THE ENGINEER CAN MAKE NO GUARANTEE AS TO THE ACCURACY OR COMPLETENESS OF THE UNDERGROUND UTILITY FACILITIES SHOWN. PRIOR TO ANY SITE EXCAVATIONS, THE CONTRACTOR SHALL CONTACT THE OWNER AND UNDERGROUND SERVICE ALERT (USA) AND REQUEST THAT THEY IDENTIFY THE LOCATION OF ALL UNDERGROUND UTILITIES AT THE SITE.

SITE BENCHMARK:

CHISELED 'X' ON THE TOP OF THE CONCRETE CURB ON THE WESTERN SIDE OF K STREET, APPROXIMATELY 56'+/- NORTH OF THE INTERSECTION OF K AND 26TH.

ELEV.= 172.94' NAVD88 DATUM

NOT TO BE INCLUDED IN CONSTRUCTION DRAWINGS

"FOR REFERENCE ONLY"

Blair, Church & Flynn
CONSULTING ENGINEERS
451 Clovis Avenue, Suite 200
Clovis, California 93612
Tel (559) 326-1400
Fax (559) 326-1500

Teter, LLP expressly reserves its common law copyright and other property rights in these plans. This document, the ideas and designs incorporated herein, as an instrument of professional service, is not to be used in whole or in part, for any other project without prior written authorization.

MARK	DATE	DESCRIPTION

REGISTERED PROFESSIONAL ENGINEER
PLAN REVIEW ONLY
NOT FOR CONSTRUCTION
CIVIL
STATE OF CALIFORNIA

TETER, INC.
FRESNO HEADQUARTERS
VISALIA I BAKERSFIELD I MODESTO I SAN LUIS OBISPO
ARCHITECTS ENGINEERS CONNECTED
TETER

MARS/ELO-P FACILITY
MCSD-26TH STREET
MERCED CITY SCHOOL DISTRICT
LOCATION, CA


DRAWING TITLE
TOPOGRAPHIC SURVEY LEGEND AND NOTES

PROJECT NO.
24-13084

DRAWING
C100

ADDENDUM NO. 2

P:\224-0395\Site\ProductionDrawings\224395_ts01.dwg



SURVEY NOTES:

1. THIS TOPOGRAPHIC SURVEY LOCATES SPECIFIC PHYSICAL FEATURES OF THE SITE AND THEIR ELEVATION AS DETERMINED NECESSARY BY THE PROJECT ENGINEER. IT IS NOT A COMPLETE TOPOGRAPHIC SURVEY OF THE SITE. THE INFORMATION SHOWN REFLECTS THE DATA OBTAINED BY FIELD SURVEY CONDUCTED ON JANUARY 30, 2025.
2. UTILITY INFORMATION SHOWN HEREON IS BASED ON RECORD INFORMATION SUPPLIED TO THE ENGINEER BY UTILITY COMPANIES, PUBLIC AGENCIES AND THE PROPERTY OWNER, TOGETHER WITH OBSERVATION OF VISIBLE EVIDENCE BY A FIELD SURVEY. THE ENGINEER CAN MAKE NO GUARANTEE AS TO THE ACCURACY OR COMPLETENESS OF THE UNDERGROUND UTILITY FACILITIES SHOWN. PRIOR TO ANY SITE EXCAVATIONS, THE CONTRACTOR SHALL CONTACT THE OWNER AND UNDERGROUND SERVICE ALERT (USA) AND REQUEST THAT THEY IDENTIFY THE LOCATION OF ALL UNDERGROUND UTILITIES AT THE SITE.

SITE BENCHMARK:

CHISELED 'X' ON THE TOP OF THE CONCRETE CURB ON THE WESTERN SIDE OF K STREET, APPROXIMATELY 56'+/- NORTH OF THE INTERSECTION OF K AND 26TH.

ELEV.= 172.94' NAVD88 DATUM

SCALE: 1"=10'

0 5 10 20
SCALE IN FEET

Blair, Church & Flynn
CONSULTING ENGINEERS
451 Clovis Avenue, Suite 200
Clovis, California 93612
Tel (559) 326-1400
Fax (559) 326-1500

Teter, LLP expressly reserves its common law copyright and other property rights in these plans. This document, the ideas and designs incorporated herein, as an instrument of professional service, is not to be used in whole or in part, for any other project without prior written authorization.

MARK	DATE	DESCRIPTION

REGISTERED PROFESSIONAL ... CIVIL ... STATE OF CALIFORNIA
PLAN REVIEW ONLY
NOT FOR CONSTRUCTION

TETER, INC.
FRESNO HEADQUARTERS
VISALIA I BAKERSFIELD I MODESTO I SAN LUIS OBISPO
ARCHITECTS ENGINEERS CONNECTED
TETER

MARS/ELO-P FACILITY
MCSD-26TH STREET
MERCED CITY SCHOOL DISTRICT
LOCATION, CA


DRAWING TITLE
TOPOGRAPHIC SURVEY

PROJECT NO.
24-13084


DRAWING
C101

Drawing: P:\224-0395\Site\ProductionDrawings\224395_ts01.dwg; C101 - ----
Plot by: monaya Feb 11, 2025 - 9:22am

PLOT DATE: 2/11/2025 9:22:08 AM



1 FLOOR PLAN-FIRST LEVEL
1/8" = 1'-0"



2 FLOOR PLAN-SECOND LEVEL
1/8" = 1'-0"

FLOOR PLAN LEGEND

FEC	FIRE EXTINGUISHER CABINET - WITH UL RATED TYPE 2A-10B:C EXTINGUISHER, SEE DETAIL 1/A900-02
AED	AED CABINET WITH PORTABLE AED EQUIPMENT
	WALL - NON-RATED
	WALL - 1 HR RATED FIRE BARRIER
2'-0" EXT. 1'-6" INT. 5'-0" 1'-0" PH 4'-0"	DOOR ACCESSIBLE CLEARANCES SHOWN DASHED PH LABEL INDICATES PANIC HARDWARE REQUIRED
	ACCESSIBLE TURN AROUND (5'-0" DIA.)
48" 30"	30" X 48" ACCESSIBLE CLEAR FLOOR AREA

PLAN NOTES

1. REFER TO ROOM FINISH SCHEDULE FOR FLOOR, WALL AND CEILING FINISHES
2. IN AREAS WITH EXPOSED STRUCTURE CEILINGS, COORDINATE EXACT LOCATION OF MECHANICAL GRILLES, DIFFUSERS, DUCTWORK AND ELECTRICAL FIXTURES WITH EACH RESPECTIVE SUBCONTRACTOR.
3. ALL WALLS EXTEND TO UNDERSIDE OF DECK U.N.O.
4. FLASH DRAINS, CURB, VENTS AND STACKS PER MANUFACTURER'S RECOMMENDATIONS IF DETAIL NOT SHOWN ON PLANS.
5. ALL ROOFING TO BE CLASS A.
6. THE ENTIRE ROOF IS CLEAR OF EQUIPMENT AND PARAPETS. THE ENTIRE ROOF AREA HAS BEEN DESIGNED TO ACCOUNT FOR A SOLAR PV SYSTEM (REFER TO STRUCTURAL BASIC DESIGN LOADS & SPECIAL LOADS). PROVIDE MINIMUM SOLAR ZONE AS SHOWN ON PLAN. PROVIDE 6-FOOT WIDE ACCESS PERIMETER AROUND THE EDGES OF THE ROOF.

KEYNOTE LEGEND

04-01	CMU REFUSE ENCLOSURE, SEE CIVIL DRAWINGS
05-03	PERFORATED METAL CANOPY OVER WINDOW FOR SHADE ONLY, DIMENSIONS PER PLAN, SEE DETAIL 1 AND 2/A804-02
05-07	SOLID LID METAL CANOPY OVER DOOR, DIMENSIONS PER PLAN, SEE DETAILS 3 AND 6/A800-02
05-11	STEEL COLUMN, S.S.D.
05-12	ROOF ACCESS LADDER WITH PLATFORM, SEE A803-02
05-17	ENTRY CANOPY, SEE DETAIL 3/A804-02
07-04	DOWNSPOUT, SEE DETAIL 8/A800-02
10-03	OPERABLE PANEL PARTITION WITH PASS-THRU DOOR, S.S.D. AND SEE DETAIL 7, 8 AND 9/A902-02
12-05	OFOI SYSTEMS FURNITURE
21-02	FIRE SPRINKLER RISER, SEE FIRE PROTECTION DRAWINGS
22-01	HI-LO DRINKING FOUNTAIN WITH BOTTLE FILLER, SEE DETAILS 12/A901-02
22-06	ACCESSIBLE SINK, SEE DETAIL 11/A900-02 AND S.P.D.
26-06	LIGHT FIXTURE, S.E.D.
26-07	ELECTRICAL EQUIPMENT, S.E.D.
26-08	ELECTRICAL FIXTURE, S.E.D.

12/22/2025 1:05:06 AM © YC+D. 2023 - CONFIDENTIAL AND PROPRIETARY INFORMATION THE EXCLUSIVE PROPERTY OF YC+D.

ADDENDUM NO. 2

IDENTIFICATION STAMP
DIV. OF THE STATE ARCHITECT
APP: 02-123377 INC: 02
REVIEWED FOR
SS ☑ FLS ☑ ACS ☑
DATE: 01/08/2026

yc+d ARCHITECTURE
712 BANCROFT ROAD #297
WALNUT CREEK, CA 94598
T: (925) 979-5178
E: HELLO@YCPLUSD.COM

ARCHITECT'S SEAL:

LICENSED ARCHITECT DARA DOURAGHI C-23044 03-31-2027 RENEWAL DATE STATE OF CALIFORNIA

CONSULTANT:

CONSULTANT'S SEAL:

Addenda No. 2 - 2/12/26
For reference only

THIS DRAWING AND THE DESIGNS, ARRANGEMENTS, DEPICTIONS, IDEAS AND OTHER INFORMATION CONTAINED HEREIN CONSTITUTE THE UNPUBLISHED WORK OF YC+D ARCHITECTS AND SHALL REMAIN THE PROPERTY OF YC+D ARCHITECTS IN PERPETUITY. NO PART THEREOF SHALL BE REPRODUCED, COPIED, DISCLOSED, DISTRIBUTED, SOLD, PUBLISHED OR OTHERWISE USED IN ANY WAY WITHOUT THE WRITTEN CONSENT OF YC+D ARCHITECTS. VISUAL CONTACT WITH THE ABOVE DRAWINGS OR ANY PART THEREOF, SHALL CONSTITUTE CONCLUSIVE EVIDENCE OF ACCEPTANCE OF THESE RESTRICTIONS.

PROJECT:
MARS/ELOP FACILITY
MCSD - 26TH ST.
INCREMENT 2

CLIENT:
MERCED CITY SCHOOL DISTRICT


REVISIONS

REV	ISSUE	DATE	TO


PHASE
DSA SUBMITTAL

SHEET TITLE
FLOOR PLANS - MAIN BUILDING


SHEET NUMBER:
A200-02



1 STORAGE BUILDING FLOOR PLAN
1/8" = 1'-0"



2 STORAGE BUILDING RCP
1/8" = 1'-0"



3 STORAGE ROOF PLAN
1/8" = 1'-0"

FLOOR PLAN LEGEND

FEC	FIRE EXTINGUISHER CABINET - WITH UL RATED TYPE 2A-10B:C EXTINGUISHER EXTINGUISHER, SEE DETAIL 2/A900-02
	WALL - NON-RATED
	WALL - 1 HR RATED FIRE BARRIER
2'-0" EXT. 1'-6" INT. 1'-0" PH 5'-0" 4'-0"	DOOR ACCESSIBLE CLEARANCES SHOWN DASHED PH LABEL INDICATES PANIC HARDWARE REQUIRED

PLAN NOTES

1. REFER TO ROOM FINISH SCHEDULE FOR FLOOR, WALL AND CEILING FINISHES
2. IN AREAS WITH EXPOSED STRUCTURE CEILINGS, COORDINATE EXACT LOCATION OF MECHANICAL GRILLES, DIFFUSERS, DUCTWORK AND ELECTRICAL FIXTURES WITH EACH RESPECTIVE SUBCONTRACTOR.
3. ALL WALLS EXTEND TO UNDERSIDE OF DECK U.N.O.
4. FLASH DRAINS, CURB, VENTS AND STACKS PER MANUFACTURER'S RECOMMENDATIONS IF DETAIL NOT SHOWN ON PLANS.
5. ALL ROOFING TO BE CLASS A.
6. THE ENTIRE ROOF IS CLEAR OF EQUIPMENT AND PARAPETS. THE ENTIRE ROOF AREA HAS BEEN DESIGNED TO ACCOUNT FOR A SOLAR PV SYSTEM (REFER TO STRUCTURAL BASIC DESIGN LOADS & SPECIAL LOADS). PROVIDE MINIMUM SOLAR ZONE AS SHOWN ON PLAN. PROVIDE 6-FOOT WIDE ACCESS PERIMETER AROUND THE EDGES OF THE ROOF.

KEYNOTE LEGEND

05-01	STEEL BEAM, S.S.D.
05-13	TIE-ON STANCHION, S.S.D. AND 7/A803-02 FOR FLASHING AROUND PIPE
05-16	STRUCTURAL METAL DECK, S.S.D.
07-01	INSULATED CLASS 'A' STANDING METAL SEAM ROOF PANEL, SEE DETAILS 4,5, AND 7/A800-02
07-02	ROOF GUTTER, SEE DETAIL 7/A800-02
07-03	ROOF FASCIA, SEE DETAIL 5/A800-02
07-04	DOWNSPOUT, SEE DETAIL 8/A800-02
22-04	PLUMBING VENT, S.P.D. AND DETAIL 7/A803-02 FOR FLASHING
23-04	ROOF MOUNTED MECHANICAL UNIT, S.M.D. MOUNTING AND FLASHING, SEE DETAIL 3/A803-02
26-06	LIGHT FIXTURE, S.E.D.
26-07	ELECTRICAL EQUIPMENT, S.E.D.

12/22/2025 1:05:09 AM © YC+D. 2023 - CONFIDENTIAL AND PROPRIETARY INFORMATION THE EXCLUSIVE PROPERTY OF YC+D.

ADDENDUM NO. 2

IDENTIFICATION STAMP
DIV. OF THE STATE ARCHITECT
APP: 02-123377 INC: 02
REVIEWED FOR
SS ☑ FLS ☑ ACS ☑
DATE: 01/08/2026

yc+d ARCHITECTURE
712 BANCROFT ROAD #297
WALNUT CREEK, CA 94598
T: (925) 979-5178
E: HELLO@YCPLUSD.COM

ARCHITECT'S SEAL:

LICENSED ARCHITECT
DARA DOURAGHI
C-23044
03-31-2027
RENEWAL DATE
STATE OF CALIFORNIA

CONSULTANT:

CONSULTANT'S SEAL:

Addenda No. 2 - 2/12/26
For reference only

THIS DRAWING AND THE DESIGNS, ARRANGEMENTS, DEPICTIONS, IDEAS AND OTHER INFORMATION CONTAINED HEREIN CONSTITUTE THE UNPUBLISHED WORK OF YC+D ARCHITECTS AND SHALL REMAIN THE PROPERTY OF YC+D ARCHITECTS IN PERPETUITY. NO PART THEREOF SHALL BE REPRODUCED, COPIED, DISCLOSED, DISTRIBUTED, SOLD, PUBLISHED OR OTHERWISE USED IN ANY WAY WITHOUT THE WRITTEN CONSENT OF YC+D ARCHITECTS. VISUAL CONTACT WITH THE ABOVE DRAWINGS OR ANY PART THEREOF, SHALL CONSTITUTE CONCLUSIVE EVIDENCE OF ACCEPTANCE OF THESE RESTRICTIONS.

PROJECT:
MARS/ELOP FACILITY
MCSD - 26TH ST.
INCREMENT 2

CLIENT:
MERCED CITY SCHOOL DISTRICT

REVISIONS

REV	ISSUE	DATE	TO

PHASE
DSA SUBMITTAL

SHEET TITLE
FLOOR PLAN - STORAGE BUILDING

SHEET NUMBER:
A210-02

Application Status Report

For Merced City School District

Created 02/11/2026 07:48 AM

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
Air Conditioning Solutions, Inc.	Chino Romo	2223 El Sol Avenue, Altadena, CA, 91001	888-685-5660		cromo@acs.us	863580_	C-4 (Boiler, Hot Water Heating and Steam Fitting Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-38 (Refrigeration Contractor), B (General Building Contractor), C-36 (Plumbing Contractor)	APPROVED	11/12/2025	11/12/2026
J J & S ASBESTOS REMOVAL INC dba J J & S ENVIRONMENTAL SERVICES	Mariano Aztiria	925 Poinsettia Ave. Ste. 4, Vista, CA, 92081	760-536-3178	855-827-5421	info@jjandsenviro.com	975044_	C-22 (Asbestos Abatement Contractor), B (General Building Contractor), ASB (Asbestos Certification)	APPROVED	12/09/2025	12/09/2026
Marina Mechanical Services	Jamie Wallace	4763 Bennett Drive, Livermore, CA 94551	510-614-3500	925-294-9238	jwallace@marinam.com	416198_	C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-38 (Refrigeration Contractor), C-2 (Insulation and Acoustical Contractor), C-43 (Sheet Metal Contractor), C-10 (Electrical Contractor), C-4 (Boiler, Hot Water Heating and Steam Fitting Contractor), C-36 (Plumbing Contractor)	APPROVED	07/16/2025	07/16/2026
101 Builders, Inc.	Antoinette Schreder	10435 Monterey Hwy, Gilroy, CA, 95020	530-520-8080		antoinette@101buildersinc.com	1037916	A (General Engineering Contractor), B (General Building Contractor), HAZ (Hazardous Substance Removal Certification)	APPROVED	08/28/2025	08/28/2026
A-C Electric Company	Jackie Blevins	Box 81977	661-410-0000		jackieblevins@a-celectric.com	99849__	C-10 (Electrical Contractor), A (General Engineering Contractor), B (General Building Contractor), C-12 (Earthwork and Paving Contractors), C-61 (Limited Specialty)	APPROVED	09/05/2025	09/05/2026

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
ACCO ENGINEERED SYSTEMS INC dba ACCO ENGINEERED SYSTEMS	Cindi Adler	888 East Walnut Street, Pasadena, CA 91101 / 1133 Aladdin Avenue San Leandro, CA 94577	818-244-6571	000-000-0000	cadler@accoes.com	120696_	A (General Engineering Contractor), B (General Building Contractor), C-4 (Boiler, Hot Water Heating and Steam Fitting Contractor), C-10 (Electrical Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-36 (Plumbing Contractor), C-38 (Refrigeration Contractor), C-16 (Fire Protection Contractor), C-42 (Sanitation System Contractor)	APPROVED	08/29/2025	08/29/2026
ACH Mechanical Contractors, Inc.	Amanda Sanchez	1740 Howard Place, Redlands, CA 92373	909-307-2850	909-307-2853	amandas@achmechanical.com	780560_	C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor)	APPROVED	09/02/2025	09/02/2026
ACS Controls Corporation	Jennifer Smith	4704 Roseville Rd suite 101, North Highlands , CA, 95660	916-640-8800		smithj@acscontrols.com	836670_	C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-10 (Electrical Contractor)	APPROVED	09/05/2025	09/05/2026
ALESSANDRO ELECTRIC INCORPORATED DBA CORE-BUILT CONSTRUCTION	CLINT ALESSANDRO	11335 Sunrise Gold Circle Rancho Cordova, CA 95742	916-283-6966	916-283-6967	estimating@alessandroelectric.com	867775_	C-7 (Low Voltage Systems Contractor), C-10 (Electrical Contractor), B (General Building Contractor)	APPROVED	10/29/2025	10/29/2026
AMG & Associates, Inc.	Albert M. Giacomazzi	26535 Summit Circle, Santa Clarita, CA 91350	661-251-7401	661-251-7405	estimating@amgassociatesinc.com	881824_	B (General Building Contractor), A (General Engineering Contractor), HAZ (Hazardous Substance Removal Certification), ASB (Asbestos Certification)	APPROVED	09/05/2025	09/05/2026
ANV Contractors, Inc	Nicolas Vargas	1230 N. Quinley Ave., Atwater, CA, 95301	209-564-1037		nvargas@anvcontractorsinc.com	831891_	B (General Building Contractor)	APPROVED	05/06/2025	05/06/2026
ARIA ELECTRIC CONSTRUCTION	fariborz yazdi	6128 Palmaya Lane , Orangevale, CA, 95662	916-213-7575		fariborzyazdi@yahoo.com	957360_	B (General Building Contractor), C-10 (Electrical Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-61 (Limited Specialty)	RETURNED		
Adams Commercial Plumbing, LLC	Glen Adams or Rene Garcia	898 Stewart Rd., Yuba City, CA 95991	530-868-4850	530-868-4851	estimating@adamsplumbing.biz	1019969	C-36 (Plumbing Contractor)	APPROVED	11/07/2025	11/07/2026
Adept Electrical Services, Inc	Tami Brinkley	821 Paseo Dr, Hollister, CA, 95023	916-257-6227		tamibrinkley.adeptelect@gmail.com	961816_	C-10 (Electrical Contractor)	REJECTED	08/26/2025	

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
Advanced Alarm & Fire, Inc.	Emma Reyes	8724 Millergrove Dr., Santa Fe Springs, CA, 90670	562-351-3694		emmaq@weprotectall.com	750871_	C-10 (Electrical Contractor)	REJECTED	08/26/2025	
Ag-Con Construction Inc.	Lisa Schultz	580 Harrison Street, San Jose, CA, 95125	408-279-9922	408-279-9933	lisa@ag-con.com	750769_	B (General Building Contractor)	APPROVED	09/05/2025	09/05/2026
Airteks.com, Inc	Jerome Bohland	2432 ARMSTRONG ST, Livermore, CA, 94551	925-292-0148	925-455-7259	bids@airteks.com	930172_	C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor)	REJECTED	08/26/2025	
All American Building Services	ANTHONY INNABI	PO Box 802586, Santa Clarita, CA, 91380	323-422-6013		anthony@allamericanrebuild.com	921499_	A (General Engineering Contractor), B (General Building Contractor), C-10 (Electrical Contractor), C-27 (Landscaping Contractor), C-33 (Painting and Decorating Contractor), C-36 (Plumbing Contractor), HAZ (Hazardous Substance Removal Certification), C-61 (Limited Specialty)	APPROVED	09/24/2025	09/24/2026
American Elite Electric Inc.	Glen Pennycuff	P.O. box 2019, Turlock, CA, 95381	209-479-2750		gp@americanee.com	669819_	C-10 (Electrical Contractor)	APPROVED	03/12/2025	03/12/2026
American Incorporated	Deanna De La Torre	1345 N. American Street, Visalia, CA, 93291	559-651-1776 x1471	559-651-0205	ddelatorre@aminc.com	292529_	A (General Engineering Contractor), B (General Building Contractor), C-4 (Boiler, Hot Water Heating and Steam Fitting Contractor), C-7 (Low Voltage Systems Contractor), C-10 (Electrical Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-36 (Plumbing Contractor), C-38 (Refrigeration Contractor), C-43 (Sheet Metal Contractor), C-61 (Limited Specialty), C-21 (Building Moving/Demolition Contractor)	REJECTED	08/26/2025	

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
American Incorporated	Brooke Faulkner	1345 N. American Street, Visalia, CA, 93291	559-651-1776 x1422	559-651-0205	bids@aminc.com	292529_	A (General Engineering Contractor), B (General Building Contractor), C-4 (Boiler, Hot Water Heating and Steam Fitting Contractor), C-7 (Low Voltage Systems Contractor), C-10 (Electrical Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-21 (Building Moving/Demolition Contractor), C-36 (Plumbing Contractor), C-38 (Refrigeration Contractor), C-43 (Sheet Metal Contractor), C-61 (Limited Specialty)	APPROVED	01/27/2026	01/27/2027
American Paving Co.	Ross Jenkins	525 W. Alluvial Avenue, Fresno, CA, 93711	559-441-1900	559-487-7949	apc-estimating@americanpavingco.com	181430_	A (General Engineering Contractor), B (General Building Contractor), C-8 (Concrete Contractor), C-12 (Earthwork and Paving Contractors), C-31 (Construction Zone Traffic Control Contractor), HAZ (Hazardous Substance Removal Certification)	APPROVED	08/21/2025	08/21/2026
Antonios Economos DBA Economos Painting	Antonios Economos	325 South Sparks St, Burbank, CA, 91506	818-636-5990	818-763-3817	economos50@yahoo.com	388522_	C-33 (Painting and Decorating Contractor)	APPROVED	08/26/2025	08/26/2026
Antonios Economos DBA Economos Painting	Antonios Economos	325 South Sparks St, Burbank, CA, 91506	818-636-5990	818-763-3817	economos50@yahoo.com	388522_	C-33 (Painting and Decorating Contractor)	REJECTED	08/26/2025	
Ardent General, Inc.	James Myers	2960 N. Burl Ave., Fresno, CA, 93727	559-492-3969	559-492-3972	estimating@ardentgeneral.com	968340_	A (General Engineering Contractor), B (General Building Contractor)	APPROVED	11/05/2025	11/05/2026
Arrow Drillers Inc DBA Arrow Construction	Justin Bovolick	1850 Diesel Drive, Sacramento, CA, 95838	916-640-0600	916-640-0700	jbovolick@arrowcon.com	708757_	A (General Engineering Contractor), C-12 (Earthwork and Paving Contractors)	APPROVED	08/29/2025	08/29/2026
Atlas/Pellizzari Electric Inc	Jim Weishaar	450 Howland St, Redwood City, CA, 94063	650-364-1204	650-364-6193	jimw@atlas-pellizzari.com	375862_	C-10 (Electrical Contractor)	APPROVED	02/05/2026	02/05/2027
Audeamus dba Sebastian	Grant Bettega	7600 N. Palm Ave, Fresno, CA, 93711	559-432-5800	559-432-5858	estimating@sebastiancorp.com or contract_admin@sebastiancorp.com	940822_	C-7 (Low Voltage Systems Contractor), C-10 (Electrical Contractor), A (General Engineering Contractor), B (General Building Contractor)	APPROVED	09/18/2025	09/18/2026

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
Avidex Industries LLC	Ron Ponce	20382 Hermana Circle, Lake Forest, CA, 92630	949-428-6333	949-428-6334	biddesk@avidex.com	981651_	C-7 (Low Voltage Systems Contractor), C-10 (Electrical Contractor)	APPROVED	08/28/2025	08/28/2026
Avidex Industries LLC	Ron Ponce	20382 Hermana Circle, Lake Forest, CA, 92630	949-428-6333	949-428-6334	biddesk@avidex.com	981651_	C-7 (Low Voltage Systems Contractor), C-10 (Electrical Contractor)	REJECTED	08/26/2025	
B&H Electric, Inc.	Tim Finch	1122 Black Diamond Way, Lodi, CA, 95240	209-334-6770 x104	209-334-1627	tim@bandhelectric.com	678435_	C-10 (Electrical Contractor)	APPROVED	08/22/2025	08/22/2026
B&M Civil LLC	Patrick Mullen	11330 Sunrise Park Dr., Suite C, Rancho Cordova, CA, 95742	916-638-8626	916-352-6944	Estimating@bm-builders.com ; hvac@bm-builders.com	861848_	A (General Engineering Contractor), B (General Building Contractor), C-8 (Concrete Contractor), C-10 (Electrical Contractor), C-12 (Earthwork and Paving Contractors), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-27 (Landscaping Contractor), C-31 (Construction Zone Traffic Control Contractor), C-53 (Swimming Pool Contractor), C-43 (Sheet Metal Contractor)	APPROVED	11/12/2025	11/12/2026
BDM Inc.	Lyle Bolte	240 North 12th Ave Box 306 Hanford, CA 93230	559-554-5848		admin@bdminc.net	1078193	B (General Building Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor)	APPROVED	03/12/2025	03/12/2026
BESTCO ELECTRIC INC dba BEST ELECTRIC	Shane Sayers	2160 Wardrobe Ave., Merced, CA, 95341	209-723-2061	209-723-9870	shane@bestelectric.us	392737_	C-10 (Electrical Contractor)	APPROVED	08/22/2025	08/22/2026
BMY Construction Group, Inc.	Eric Bower	5485 E. Olive Avenue, Fresno, CA, 93727	559-243-4200	559-222-2380	estimating@bmyinc.com	686178_	A (General Engineering Contractor), B (General Building Contractor), C-8 (Concrete Contractor)	APPROVED	12/29/2025	12/29/2026
BOBO CONSTRUCTION INC	Chris Betzler	9722 Kent Street, Elk Grove, CA, 95624	916-383-7777	916-383-1681	cbobo@boboconstructioninc.com	183537_	A (General Engineering Contractor), B (General Building Contractor), C-8 (Concrete Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-36 (Plumbing Contractor), C-43 (Sheet Metal Contractor), C-61 (Limited Specialty)	APPROVED	02/05/2026	02/05/2027

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
BRET BRIGGS CONSTRUCTION / VALLEYSCAPES.	Bret Briggs	3144 N. G Street, Suite 125 PMB 225, Merced, CA, 95340	209-383-6939 x2	209-383-6935	rachel@bretbriggs.com	821795_	A (General Engineering Contractor), B (General Building Contractor), C-27 (Landscaping Contractor)	APPROVED	07/16/2025	07/16/2026
Barham Inc. dba BZ Construction	Miguel Zamora	2204 Fairview Drive, Ceres, CA, 95307	209-531-1252	209-531-1254	mzamora@bzconst.com	481523_	A (General Engineering Contractor), B (General Building Contractor), C-2 (Insulation and Acoustical Contractor), C-8 (Concrete Contractor), C-12 (Earthwork and Paving Contractors), C-34 (Pipeline Contractor)	APPROVED	11/19/2025	11/19/2026
Barnhart-Benson Builders Inc.	BJ Benson	425 Spruce Avenue, Clovis, CA, 93611	559-432-9070		bj@bbbuildersinc.net	559793_	B (General Building Contractor)	APPROVED	01/02/2026	01/02/2027
Bay Area HVAC inc.	Edgar Andrade	194 Lantz Drive, Morgan Hill, CA, 95037	408-550-5155		bayareahvac5@gmail.com	1021719	C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-61 (Limited Specialty)	APPROVED	09/23/2025	09/23/2026
Bay City Mechanical, Inc.	Crystal Rougeau	870 Harbour Way South Richmond , Ca 94804	510-233-7000	510-669-9856	Crystal@baycitymech.com	645126_	C-4 (Boiler, Hot Water Heating and Steam Fitting Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-36 (Plumbing Contractor), C-43 (Sheet Metal Contractor), B (General Building Contractor)	APPROVED	09/05/2025	09/05/2026
Beals Martin & Associates, Inc.	Dwight Ortmann	2596 Bay Road, Redwood City, CA, 94063	650-566-5884	650-367-7645	Patricia@bealsmartin.com	396189_	A (General Engineering Contractor), B (General Building Contractor)	APPROVED	07/16/2025	07/16/2026
Bernards Bros Inc.	Ali Hansen	555 First Street, San Fernando, CA, 91340	909-559-1891	818-838-7956	ahansen@bernards.com	302007_	A (General Engineering Contractor), B (General Building Contractor)	APPROVED	08/28/2025	08/28/2026
Beta Investments & Contracts Inc.	Haro Bezdikian	1613 East Glenoaks Blvd., Suite A, Glendale, CA, 91206	818-241-6774	818-241-1665	haro@betacontractsinc.com	488644_	B (General Building Contractor), C-10 (Electrical Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-36 (Plumbing Contractor)	APPROVED	09/02/2025	09/02/2026
Better Enterprises, Inc.	Susan Waid	1148 N. Cypress Avenue, Fresno, CA, 93727	559-233-2225	559-233-2850	susan@betterenterprisesinc.com	1012660	B (General Building Contractor), C-33 (Painting and Decorating Contractor), C-8 (Concrete Contractor)	APPROVED	09/05/2025	09/05/2026

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
Bi-JAMAR INC dba Quality Sound	James Bryan	2010 East Fremont Street, Stockton, CA, 95205	209-948-2104	209-948-0965	jbryan@qualitysound.net	496881_	C-7 (Low Voltage Systems Contractor), C-10 (Electrical Contractor)	APPROVED	08/25/2025	08/25/2026
Bockmon & Woody Electric Co., Inc.	Arlene Larsen	1528 El Pinal Drive, Stockton, CA, 95205	209-464-4878	209-464-2615	arlene@bockmonwoody.com	588308_	C-10 (Electrical Contractor), A (General Engineering Contractor)	APPROVED	07/16/2025	07/16/2026
Bockmon & Woody Electric Co., Inc.	Arlene Larsen	1528 El Pinal Drive, Stockton, CA, 95205	209-464-4878	209-464-2615	arlene@bockmonwoody.com	588308_	C-10 (Electrical Contractor)	REJECTED	08/26/2025	
Bowen Engineering and Environmental	Erik Bowen	4664 S. Cedar Ave, Fresno, CA, 93725	559-233-7464	559-233-7468	office@bowendemo.com	816496_	A (General Engineering Contractor), B (General Building Contractor), C-21 (Building Moving/Demolition Contractor), C-22 (Asbestos Abatement Contractor), HAZ (Hazardous Substance Removal Certification), ASB (Asbestos Certification), C-10 (Electrical Contractor), C-39 (Roofing Contractor), C-33 (Painting and Decorating Contractor), C-61 (Limited Specialty)	APPROVED	08/28/2025	08/28/2026
Bowen Engineering and Environmental	Erik Bowen	4664 S. Cedar Ave, Fresno, CA, 93725	559-233-7464	559-233-7468	office@bowendemo.com	816496_	A (General Engineering Contractor), B (General Building Contractor), C-21 (Building Moving/Demolition Contractor), C-22 (Asbestos Abatement Contractor), HAZ (Hazardous Substance Removal Certification), ASB (Asbestos Certification), C-10 (Electrical Contractor), C-39 (Roofing Contractor), C-33 (Painting and Decorating Contractor), C-61 (Limited Specialty)	REJECTED	08/26/2025	
Bradshaw Engineering Corporation	Jeremy Sosh	8645 Argent Street, Suite B, Santee, CA, 92071	619-448-4300		estimator@bradshaweng.com	383330_	C-16 (Fire Protection Contractor), C-34 (Pipeline Contractor)	APPROVED	12/31/2025	12/31/2026
Braun Electric Company Inc.	Brenda Eakin	3000 E Belle Terrace, Bakersfield, CA, 93307	661-241-6306	661-633-1453	bseakin@braunelec.com	602003_	C-10 (Electrical Contractor), B (General Building Contractor)	APPROVED	09/02/2025	09/02/2026

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
Brazos Urethane, Inc.	Craig Opel	28770 Ave. 14 1/2 Madera, CA 93638	559-674-1111	559-674-2222	c.opel@brazosurethane.com	982578_	B (General Building Contractor), C-2 (Insulation and Acoustical Contractor), C-33 (Painting and Decorating Contractor), C-39 (Roofing Contractor), C-43 (Sheet Metal Contractor)	APPROVED	08/26/2025	08/26/2026
Broward Builders Inc	Rosa Trevizo	1200 E Kentucky Ave, Woodland, CA, 95776	530-666-5635	530-666-5723	rosa@browardbuilders.com	602146_	A (General Engineering Contractor), B (General Building Contractor), C-8 (Concrete Contractor), C-9 (Drywall Contractor), ASB (Asbestos Certification)	APPROVED	11/05/2025	11/05/2026
Building Electronic Controls, Inc.	Kimberly Carter-Morey	3937 Alken Street, Suite A, Bakersfield, CA, 93308	661-588-1390	661-588-0116	kmorey@becinc.net	729905_	C-7 (Low Voltage Systems Contractor), C-10 (Electrical Contractor)	APPROVED	09/05/2025	09/05/2026
Built Pacific Inc	Adel Salem	6767 Nancy Ridge Dr. #100, San Diego, CA, 92121	858-546-0053	858-404-0766	adel@builtpacific.com	827275_	A (General Engineering Contractor), B (General Building Contractor)	REJECTED	08/26/2025	
CENCAL Services, InC.	Shannon Burrough	3299 S. CEDAR AVENUE, FRESNO, CA, 93725	559-291-3366	559-291-3369	shannon@cencaldemo.com	976935_	A (General Engineering Contractor), B (General Building Contractor), C-8 (Concrete Contractor), C-21 (Building Moving/Demolition Contractor), C-22 (Asbestos Abatement Contractor), HAZ (Hazardous Substance Removal Certification), ASB (Asbestos Certification)	APPROVED	07/16/2025	07/16/2026
CN O'Neill Electric, Inc.	David O'Neill	901 OXFORD WAY, STOCKTON, CA, 95204	209-941-3949 x101	209-451-2663	doneill@cnoneill.com	1023311	C-10 (Electrical Contractor)	APPROVED	08/28/2025	08/28/2026
CONTI LLC	Shannon Ala	6417 Center Drive, Sterling Heights, MI 48312	586-274-4800	586-274-2268	sala@conticorporation.com	1067502	C-10 (Electrical Contractor), C-7 (Low Voltage Systems Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor)	APPROVED	02/09/2026	02/09/2027
COSCO FIRE PROTECTION INC dba COSCO FIRE PROTECTION	Rick Marlin	4233 W. Sierra Madre, Ste. 108, Fresno, CA, 93722	800-485-3795	559-275-8006	rmarlin@coscofire.com	577621_	C-10 (Electrical Contractor), C-16 (Fire Protection Contractor), B (General Building Contractor)	APPROVED	07/16/2025	07/16/2026
CSI Electrical Contractors Inc.	Lourdes Franco	10623 Fulton Wells Ave, Santa Fe Springs, CA, 90670	562-946-0700 x251	562-946-0701	estimating@csielectric.com	1055811	C-10 (Electrical Contractor), A (General Engineering Contractor), C-7 (Low Voltage Systems Contractor)	REJECTED	08/26/2025	

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
Cal Valley Construction, Inc.	Tony Storelli	5125 N. Gates Avenue, Suite 102, Fresno, CA, 93722	559-274-0300	559-274-0311	estimating@calvalleyconstruction.com	873800_	A (General Engineering Contractor)	APPROVED	09/05/2025	09/05/2026
Caliber Contracting Services, Inc	Christina Watson	5191 E Dakota Ave, Fresno, CA, 93727	559-330-6300	559-233-6300	christina@calibercontracting.net	1049483	A (General Engineering Contractor), B (General Building Contractor), C-2 (Insulation and Acoustical Contractor), C-39 (Roofing Contractor), C-43 (Sheet Metal Contractor), C-33 (Painting and Decorating Contractor)	APPROVED	06/13/2025	06/13/2026
California Waters Development Inc., dba California Waters	Leanne Harvey	23311 E. La Palma Ave, Yorba Linda, CA, 92887	949-528-0900	949-528-0910	leads@californiawaters.com	958960_	A (General Engineering Contractor), C-53 (Swimming Pool Contractor), C-61 (Limited Specialty)	APPROVED	09/24/2025	09/24/2026
Central California Electronics, Inc.	Darla Landseadal	4254 N. Selland Avenue, Suite 101, Fresno, CA, 93722	559-485-1254		darla@centralcalelectronics.com	299868_	C-7 (Low Voltage Systems Contractor), C-10 (Electrical Contractor)	APPROVED	09/02/2025	09/02/2026
Centrica Business Solutions Services, Inc	Jessica Ray	333 S. Anita Drive, Suite 825, Orange, CA, 92868	310-895-7070		jessica.ray@centrica.com	947569_	B (General Building Contractor), C-10 (Electrical Contractor)	APPROVED	11/19/2025	11/19/2026
Champion Industrial Contractors, Inc.	Tanya Cook	1420 Coldwell Ave., Modesto, CA, 95350	209-524-6601	209-524-6931	tcook@championindustrial.com	174777_	B (General Building Contractor), C-2 (Insulation and Acoustical Contractor), C-4 (Boiler, Hot Water Heating and Steam Fitting Contractor), C-10 (Electrical Contractor), C-16 (Fire Protection Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-23 (Ornamental Metal Contractor), C-36 (Plumbing Contractor), C-38 (Refrigeration Contractor), C-42 (Sanitation System Contractor), C-43 (Sheet Metal Contractor), C-51 (Structural Steel Contractor), C-60 (Welding Contractor)	APPROVED	10/06/2025	10/06/2026
Circle City Electric, Inc.	John Johnson	18726 Van Buren Blvd., Riverside, CA 92508	951-789-6872 x102	951-789-0585	john.johnson@circlecityelectric.com	582166_	B (General Building Contractor), C-10 (Electrical Contractor)	APPROVED	09/24/2025	09/24/2026
Clark Roofing Inc.	Debra Mundinger	2076 Acoma Street, Sacramento, CA, 95815	916-929-3311	916-929-3321	debram@clarkroofinginc.com	461137_	C-39 (Roofing Contractor)	APPROVED	12/09/2025	12/09/2026

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
Class Leasing LLC	Tim Nicholas	1651 S Juanita St, San Jacinto, CA, 92543	951-238-7299	951-943-5768	tim@classleasing.net	1001535	B (General Building Contractor)	APPROVED	01/30/2026	01/30/2027
Climatec, LLC	Ray Marquez	2150 S. Towne Centre Pl., Suite 200	949-943-4726	949-474-0956	rmarquez@climatec.com	991066_	B (General Building Contractor), C-10 (Electrical Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-7 (Low Voltage Systems Contractor)	APPROVED	08/21/2025	08/21/2026
Cole Electric LLC	Michael Cole	PO Box 1302, Clovis, CA, 93613	559-294-8303	559-347-9622	mcecski@aol.com	1076170	C-10 (Electrical Contractor)	APPROVED	10/10/2025	10/10/2026
Collins Electrical Company Inc.	Araceli Torres	3412 Metro Drive, Stockton, CA, 95213	209-466-3691	209-466-3146	atorres@collinselectric.com	115427_	A (General Engineering Contractor), B (General Building Contractor), C-10 (Electrical Contractor), C-31 (Construction Zone Traffic Control Contractor)	APPROVED	05/01/2025	05/01/2026
Color New Corp	Louis Loizu	22855 Califa St., Woodland Hills, CA, 91367	818-884-0856		colornewcorp@yahoo.com	1113019	B (General Building Contractor), C-33 (Painting and Decorating Contractor)	APPROVED	09/24/2025	09/24/2026
Comfort Air, Inc. dba Select Building Services	Dustin Saccone	1607 Turnpike Rd, Stockton, CA, 95206	209-466-4601	209-466-2639	agoddard@comfortairinc.com	085895_	C-38 (Refrigeration Contractor), C-36 (Plumbing Contractor), C-4 (Boiler, Hot Water Heating and Steam Fitting Contractor), C-16 (Fire Protection Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-43 (Sheet Metal Contractor), B (General Building Contractor)	APPROVED	10/10/2025	10/10/2026
Commercial Construction Company of Merced, Inc. DBA Commercial Construction Company	William George	1425 Motel Drive, Merced, CA, 95340	209-384-3943	209-384-8002	ccc@cccofmerced.com	443282_	B (General Building Contractor)	APPROVED	08/21/2025	08/21/2026
Commercial Waterproofing Systems, Inc. dba ERC Roofing & Waterproofing	Garrett Clark	1630 Palm Street, Santa Ana, CA, 92701	714-667-6000	714-667-7000	estimating@ercroofing.com	781499_	A (General Engineering Contractor), B (General Building Contractor), C-39 (Roofing Contractor), C-43 (Sheet Metal Contractor)	REJECTED	08/26/2025	
Contra Costa Electric, Inc.	Matt Furrer	4690 E. Carmen Ave., Fresno, CA, 93703	559-252-1114	559-452-1013	mfurrer@emcor.net	139885_	A (General Engineering Contractor), B (General Building Contractor), C-10 (Electrical Contractor)	REJECTED	08/26/2025	

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
Contract Decor Inc.	Penny Warstler	72-184 North Shore Street, Thousand Palms, CA, 92276	760-343-4444 x134	760-343-4441	cdi@contract-decor.com	646748_	C-61 (Limited Specialty)	APPROVED	11/19/2025	11/19/2026
Courtney Inc.	Courtney Inc. Estimating	16781 Millikan Avenue, Irvine, CA, 92606	949-222-2051		joanna@courtneyinc.com	699236_	C-8 (Concrete Contractor), C-33 (Painting and Decorating Contractor), C-39 (Roofing Contractor), C-61 (Limited Specialty), C-43 (Sheet Metal Contractor)	APPROVED	11/21/2025	11/21/2026
Courtney Inc.	Joanna Sung	16781 Millikan Avenue, Irvine, CA, 92606	949-222-2051		joanna@courtneyinc.com	699236_	C-8 (Concrete Contractor), C-33 (Painting and Decorating Contractor), C-39 (Roofing Contractor), C-61 (Limited Specialty)	REJECTED	08/26/2025	
Creative Voice and Data Networks, Inc.	Ted Steffen	PO Box 3377, Merced, CA, 95344	209-723-6047 x102	209-384-9823	ted@creativevdn.com	911067_	C-7 (Low Voltage Systems Contractor)	APPROVED	08/25/2025	08/25/2026
Creekside Commercial Builders Inc.	Holly Kuchenthal	3131 Peacekeeper Way STE 400, McClellan Park, CA, 95952	916-546-1389	916-783-9064	hhockett@creeksideinc.net	925942_	A (General Engineering Contractor), B (General Building Contractor)	APPROVED	01/30/2026	01/30/2027
D & D Painting Co	Dionysios Panagiotopoulos	44 Worrell Road, Antioch, CA, 94509	415-601-6907	925-706-7980	dionysios63@yahoo.com	961228_	C-33 (Painting and Decorating Contractor)	APPROVED	08/28/2025	08/28/2026
D & D Painting Co	Dionysios Panagiotopoulos	44 Worrell Road, Antioch, CA, 94509	415-601-6907	925-706-7980	dionysios63@yahoo.com	961228_	C-33 (Painting and Decorating Contractor)	REJECTED	08/26/2025	
D. A. Bender Mechanical, Inc.	Madison Zenker	10135 Iron Rock Way, Elk Grove, CA, 95624	916-685-8521	916-685-8526	madison@dabendermechanical.com	673938_	C-36 (Plumbing Contractor)	APPROVED	08/28/2025	08/28/2026
DAC SERVICE, INC. DBA FOUR C'S CONSTRUCTION	Linda Chavez	1560 H Street, Fresno, CA, 93721	559-237-3990	559-237-3999	linda@fourcsmetal.com	908294_	C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-39 (Roofing Contractor), C-43 (Sheet Metal Contractor), B (General Building Contractor), C-36 (Plumbing Contractor)	APPROVED	09/05/2025	09/05/2026
DAVID A. BUSH INC dba BUSH CONSTRUCTION	Jasmine Cooper	518 N. Redington St., Hanford, CA 93230, Hanford, CA, 93230	559-584-1575	559-584-1591	jasmine@bushconstruction.net	492686_	A (General Engineering Contractor), B (General Building Contractor), C-8 (Concrete Contractor), C-21 (Building Moving/Demolition Contractor)	APPROVED	09/05/2025	09/05/2026

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
DCL Technology, Inc.	Keven Smith	497 W Bedford Ave. #101, Fresno, CA, 93711	559-269-1772		keven@dcltechnology.com	1022304	C-7 (Low Voltage Systems Contractor), C-10 (Electrical Contractor)	APPROVED	08/26/2025	08/26/2026
DDK Mechanical, Inc	Kenneth Seastrom	5761 Florin-Perkins Rd #9, Sacramento, CA, 95828	916-383-5190	916-383-5191	office3ddk@sbcglobal.net	855723_	B (General Building Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-36 (Plumbing Contractor), C-43 (Sheet Metal Contractor)	APPROVED	09/05/2025	09/05/2026
DK Enterprises Inc. dba King's Roofing	Janell Catalano	PO Box 1542, Patterson, CA, 95363	209-892-3386 x28	209-892-5225	admin@kingsroofing.net	576154_	B (General Building Contractor), C-39 (Roofing Contractor), C-43 (Sheet Metal Contractor)	REJECTED	08/26/2025	
DKM Heating & Air Conditioning	Casey Payne	3163 Rippey Rd, Loomis, CA, 95650	916-652-4478	916-561-0846	Cpayne@dkmhvac.com	548704_	B (General Building Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-43 (Sheet Metal Contractor)	APPROVED	09/05/2025	09/05/2026
Danny Letner Inc. dba Letner Roofing Company	ALBERTO MATA	1490 N. Glassell Street, Orange, CA, 92867	714-633-0030	714-633-0280	amata@letner.com	689961_	B (General Building Contractor), C-39 (Roofing Contractor), C-43 (Sheet Metal Contractor)	APPROVED	09/02/2025	09/02/2026
David M. Bertino Manufacturing, Inc.	Cindy Hutton	P.O. Box 1820, Colton, CA, 92335	909-888-9122	909-381-5577	cindy@davidmbertinomanufacturing.com	520857_	C-6 (Cabinet, Millwork and Finish Carpentry Contractor)	APPROVED	09/12/2025	09/12/2026
Dawson-Mauldin LLC	Tina Coffee	3410 McCall Ave, Selma, CA, 93662	559-896-0098	559-896-1572	bids@dawson-mauldin.com	1042654	A (General Engineering Contractor), C-31 (Construction Zone Traffic Control Contractor)	APPROVED	08/29/2025	08/29/2026
Deep Blue Integration Inc.	Curtis Streeter	3442 Empresa Dr. Suite A, San Luis Obispo, CA, 93420	888-600-0324	805-791-2037	accounting@deepblueintegration.com	943465_	C-10 (Electrical Contractor), C-16 (Fire Protection Contractor)	REJECTED	08/26/2025	
Diede Construction, Inc	Steve Diede	PO Box 1007, Woodbridge, CA, 95258	209-369-8255	209-368-0600	estimating@diedeconstruction.com	632667_	A (General Engineering Contractor), B (General Building Contractor), C-2 (Insulation and Acoustical Contractor), C-8 (Concrete Contractor), C-15 (Flooring and Floor Covering Contractors), C-27 (Landscaping Contractor), C-39 (Roofing Contractor), C-61 (Limited Specialty), HAZ (Hazardous Substance Removal Certification), ASB (Asbestos Certification)	APPROVED	04/04/2025	04/04/2026
DigiTech Integration, Inc.	Colby Semas	104 East Sixth Street, Hanford, CA, 93230	559-582-2300	559-582-2322	csemas@digitechintegrationinc.com	923604_	C-10 (Electrical Contractor)	APPROVED	08/29/2025	08/29/2026

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
Diversified Power Corporation	Scott Berryhill	1285 Stratford Avenue STE G 316, Dixon, CA, 95620	707-678-6328	707-678-8768	scottdpc@sbcglobal.net	766894_	C-10 (Electrical Contractor)	APPROVED	07/16/2025	07/16/2026
Diversified Power Corporation	Scott Berryhill	1285 Stratford Avenue STE G 316, Dixon, CA, 95620	707-678-6328	707-678-8768	scottdpc@sbcglobal.net	766894_	C-10 (Electrical Contractor)	REJECTED	08/26/2025	
Diversified Project Services International, Inc.	Estimating Department	5351 Olive Drive, Suite 100, Bakersfield, CA, 93308	661-371-2800	661-371-2801	bidprojects@dpsiinc.com	973308_	A (General Engineering Contractor), HAZ (Hazardous Substance Removal Certification)	APPROVED	09/24/2025	09/24/2026
Doja, Inc	bassel jaber	5050 mission bvld, ontario, CA, 91762	626-430-8105	909-628-1928	bassel@dojainc.com	597764_	A (General Engineering Contractor), B (General Building Contractor), C-12 (Earthwork and Paving Contractors), C-21 (Building Moving/Demolition Contractor), HAZ (Hazardous Substance Removal Certification)	APPROVED	10/29/2025	10/29/2026
Don H. Mahaffey Drilling Co.	Ashley Mahaffey Tullius	1800 S Alameda Street, Compton, CA, 90221	310-668-2030	310-668-2040	ashley@mahaffeydrilling.com	139513_	A (General Engineering Contractor), HAZ (Hazardous Substance Removal Certification)	REJECTED	08/26/2025	
Doug Ross, Inc. DBA Central Valley Asphalt	Brenda Wolf	23494 Road 196, Lindsay, CA, 93247	559-562-7802	559-562-7902	chelsea@cvavalley.com	777434_	A (General Engineering Contractor)	APPROVED	09/02/2025	09/02/2026
Dowdle & Sons Mechanical, Inc.	Shelley Dowdle	100 Tower Road American Canyon CA 94503, American Canyon, CA, 94503	707-224-6968	707-224-7885	shelley@dowdleandsonsmech.com	542743_	A (General Engineering Contractor), B (General Building Contractor), C-4 (Boiler, Hot Water Heating and Steam Fitting Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-36 (Plumbing Contractor)	APPROVED	09/09/2025	09/09/2026
Duran and Venables, Inc.	Manuela Batkovic	748 South Hillview Drive, Milpitas, CA, 95035	408-934-7300	408-934-7310	ela@dvpave.com	375068_	A (General Engineering Contractor), HAZ (Hazardous Substance Removal Certification)	APPROVED	12/23/2025	12/23/2026
Dutch Contracting, Inc.	Tracey Bussick	6930 26th St. Rio Linda, CA 95673	916-436-5422 x103	916-823-3122	traceyb@dutchcoinc.com	1002925	A (General Engineering Contractor), HAZ (Hazardous Substance Removal Certification)	APPROVED	08/25/2025	08/25/2026
Dynamic Electrical Contracting & Controls, Inc.	Patrick Anderson	2150 Wardrobe Ave, Merced CA 95341	209-257-3267 x1	209-257-3267	patrick@dynamicelectrical.org	925014_	C-10 (Electrical Contractor)	APPROVED	08/28/2025	08/28/2026

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
EIDIM Group Inc. dba EIDIM AV Technology	Aman Jain	1015 S. Placentia Ave. Fullerton, CA 92831	562-777-1009 x104	562-777-9120	estimate@eidim.com	824410_	B (General Building Contractor), C-7 (Low Voltage Systems Contractor), C-10 (Electrical Contractor), C-33 (Painting and Decorating Contractor)	APPROVED	08/26/2025	08/26/2026
EKC Enterprises, Inc.	Greg Alavezos	5153 E Dakota Ave. Fresno, CA 93727	559-438-0330	559-438-0333	greg@ekccorp.com	916095_	C-7 (Low Voltage Systems Contractor), C-10 (Electrical Contractor)	APPROVED	08/29/2025	08/29/2026
ENGINEERED CONTROLS INC dba E C I	RICK MILLARD	1500 TOLLHOUSE RD. SUITE #103, CLOVIS, CA, 93611	559-323-9788	559-323-9762	rick@ecihvac.com	714317_	B (General Building Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-36 (Plumbing Contractor), C-43 (Sheet Metal Contractor), C-61 (Limited Specialty), C-61 (Limited Specialty)	APPROVED	12/30/2025	12/30/2026
Eclipse Pro DBA Resilient Builders	Jamal Khan	9255 Survey Rd unit 8, Elk Grove , CA, 95624	209-406-8353		jamal@resilientbuildersinc.com	1064040	C-5 (Framing and Rough Carpentry Contractor), B (General Building Contractor)	APPROVED	08/21/2025	08/21/2026
Eco Energy Solutions, Inc. dba High Volt Electric	Karo Gyonjyan	4485 Runway St., Simi Valley, CA, 93063	818-993-3732	805-422-8117	karo@highvoltelectric.com	963370_	A (General Engineering Contractor), B (General Building Contractor), C-10 (Electrical Contractor)	APPROVED	08/22/2025	08/22/2026
Edgeworth Integration, LLC	Brandon Haddad	3049 Independence Drive, Ste I. Livermore, CA. 94551	650-787-4984		hpauley@edgeworthsecurity.com	1034768	C-7 (Low Voltage Systems Contractor), C-10 (Electrical Contractor)	APPROVED	02/05/2026	02/05/2027
Elite Earthworks & Engineering	Mark Schwab	19907 Temescal Canyon Road, Corona, CA, 92881	951-496-0305	951-245-2245	Mark.s@elite-earthworks.com	963457_	A (General Engineering Contractor), C-21 (Building Moving/Demolition Contractor)	REJECTED	08/26/2025	
Elite Foodservice Development LLC	Robert Perry	1921 Carnegie Ave. Suite #3C, Santa Ana, CA, 92705	657-210-4512 x101	657-207-5003	rob@elitefsd.com;angie@elitefsd.com;dirk@elitefsd.com	1051412	B (General Building Contractor)	REJECTED	08/26/2025	
Elite Landscape Construction, Inc.	Ariana Jones	2972 Larkin Ave, Clovis, CA, 93612	559-292-2900	559-292-7756	contractadmin@eliteteamoffices.com	967955_	C-27 (Landscaping Contractor)	APPROVED	09/15/2025	09/15/2026
Empyrean Plumbing, Inc.	David Koralewski	3404 Niki Way, Riverside, CA, 92507	951-776-4616	951-346-5675	dave@empyreanplumbing.com	879157_	C-36 (Plumbing Contractor), C-34 (Pipeline Contractor), C-2 (Insulation and Acoustical Contractor), B (General Building Contractor)	APPROVED	11/19/2025	11/19/2026

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
Evergreen Landscape & Sprinklers Inc.	Bryan Maze	1633 Zumwalt Ave., Tulare, CA, 93274	559-685-1579	559-685-0811	evergreenteam@aol.com	348343_	C-27 (Landscaping Contractor), C-61 (Limited Specialty), C-8 (Concrete Contractor)	REJECTED	08/26/2025	
F&H Construction	Taryn Rodriguez	1115 E. Lockeford Street, Lodi, CA 95240	209-931-3738	209-931-4427	trodriguez@f-hconst.com	293306_	A (General Engineering Contractor), B (General Building Contractor)	APPROVED	05/01/2025	05/01/2026
FAMAND INC DBA INDOOR ENVIRONMENTAL SERVICES	Jeanine Eldridge	1604 Airport Blvd, Santa Rosa, CA, 95403	916-803-5178	916-348-3020	jeldridge@ies-hvac.com	0646794	C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-43 (Sheet Metal Contractor), C-4 (Boiler, Hot Water Heating and Steam Fitting Contractor), C-38 (Refrigeration Contractor), C-36 (Plumbing Contractor)	APPROVED	11/19/2025	11/19/2026
GAMA Contracting Services, Inc.	Jose Duenas	1835 Floradale Ave., South El Monte, CA, 91733	626-442-7200	626-442-7204	jduenas@gamacsi.com	780316_	B (General Building Contractor), C-21 (Building Moving/Demolition Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-22 (Asbestos Abatement Contractor), HAZ (Hazardous Substance Removal Certification), ASB (Asbestos Certification), C-39 (Roofing Contractor)	RETURNED		
GB Construction, Inc. dba Golden Bear Construction Co.	KC Kim	18032 Lemon Drive Suite C-344	310-324-3636	310-324-3637	gb@gbci.us	424458_	A (General Engineering Contractor), B (General Building Contractor)	REJECTED	08/26/2025	
GCB1 Inc dba GC Builders	Connie Alvarado	3003 N. Monroe Avenue, Fresno, CA, 93723	559-430-5780		alvarado_connie@comcast.net	933222_	B (General Building Contractor), A (General Engineering Contractor)	APPROVED	11/03/2025	11/03/2026
Garrahan Electric, Inc.	Jeff Garrahan	3338 LuYung Dr, Rancho Cordova, CA, 95742	916-638-3798	916-638-3941	jenelleg@garrahanelectric.net	650844_	C-10 (Electrical Contractor), C-7 (Low Voltage Systems Contractor)	APPROVED	12/09/2025	12/09/2026
Global Modular Inc	Adam DeBard	1120 Commerce Ave, 25, Atwater, CA, 95301	209-676-8029	209-676-8067	adebard@gdvi.net	837357_	B (General Building Contractor)	APPROVED	05/01/2025	05/01/2026
Golden Bay Fence Plus Iron Works, Inc.	Paul Chavez	4104 South B Street, Stockton, CA, 96206	209-944-9754	209-944-5812	sales@goldenbayfence.com	664905_	A (General Engineering Contractor), B (General Building Contractor), C-10 (Electrical Contractor), C-13 (Fencing Contractor), C-23 (Ornamental Metal Contractor)	APPROVED	11/07/2025	11/07/2026

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
Golden Bay Fence Plus Iron works, Inc.	Paul Chavez	4104 South B Street, Stockton, CA, 96206	209-944-9754	209-944-5812	wmoreno@goldenbayfence.com	664905_	A (General Engineering Contractor), B (General Building Contractor), C-10 (Electrical Contractor), C-13 (Fencing Contractor), C-23 (Ornamental Metal Contractor)	REJECTED	08/26/2025	
Graham Prewett, Inc.	Meghan Sanders	2773 N. Business Park Avenue, Suite 102, Fresno, CA, 93727	559-291-3741	559-291-5082	meghan@gpiroofing.com	793065_	A (General Engineering Contractor), B (General Building Contractor), C-33 (Painting and Decorating Contractor), C-39 (Roofing Contractor), C-43 (Sheet Metal Contractor)	APPROVED	09/05/2025	09/05/2026
HCI Systems, Inc.	Jason Beardsley	1219 Elm Street, Ontario CA 91761	909-628-7773	909-628-7774	kmontero@hcisystems.net;Jbeardsley@hcisystems.net	905493_	C-10 (Electrical Contractor), C-7 (Low Voltage Systems Contractor), C-16 (Fire Protection Contractor)	APPROVED	10/22/2025	10/22/2026
HILBERS INC dba BIG S ASPHALT CO	Hannah Taylor	770 N. Walton Ave., Suite 100, Yuba City, CA, 95993	530-673-2947	530-674-4141	htaylor@hilbersinc.com	547970_	A (General Engineering Contractor), B (General Building Contractor)	APPROVED	08/21/2025	08/21/2026
HPS Mechanical, Inc. dba HPS Plumbing Services	Alma Martinez	3100 E. Belle Terrace Bakersifeld, CA 93307	661-397-2121 x8209	661-396-2589	planroom@hpsmechanical.com	793014_	A (General Engineering Contractor), B (General Building Contractor), C-4 (Boiler, Hot Water Heating and Steam Fitting Contractor), C-2 (Insulation and Acoustical Contractor), C-10 (Electrical Contractor), C-16 (Fire Protection Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-34 (Pipeline Contractor), C-36 (Plumbing Contractor), C-42 (Sanitation System Contractor), C-43 (Sheet Metal Contractor), C-46 (Solar Contractor)	APPROVED	12/16/2025	12/16/2026
HS CONSTRUCTION, INC.	Hartinderpreet Sandhu	3226 Portland Ave, Clovis, CA, 93619	559-801-8599		hart@hs-constructioninc.com	1126579	B (General Building Contractor)	APPROVED	12/16/2025	12/16/2026
HVC Plumbing Inc.	Cristela Villalobos	5746 E Shields Ave Ste 103, Fresno, CA, 93727	559-644-5884	559-878-2713	cristela.hvcplumbing@gmail.com	1069779	C-36 (Plumbing Contractor)	APPROVED	10/07/2025	10/07/2026
Harris Builders Inc.	Patti Harris	18736 Bloss Ave, Hilmar, CA, 95324	209-664-9486	209-667-0738	patti@harrisbuildersinc.com	698841_	A (General Engineering Contractor), B (General Building Contractor), C-8 (Concrete Contractor)	APPROVED	07/16/2025	07/16/2026

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
Harris Construction Co., Inc.	Matt Davies	5286 E. Home Ave. Fresno, CA 93727	559-251-0301	559-251-8645	mdavies@harrisconstruction.com	113061_	A (General Engineering Contractor), B (General Building Contractor)	APPROVED	08/21/2025	08/21/2026
Harris Development Corp dba HBC Enterprises	Rob Harris	1840 Shaw Ave, Ste. 105-08, Clovis, CA, 93611	559-575-3000		robathbc@gmail.com	976218_	A (General Engineering Contractor), B (General Building Contractor), C-8 (Concrete Contractor), C-13 (Fencing Contractor), C-29 (Masonry Contractor), C-12 (Earthwork and Paving Contractors), C-61 (Limited Specialty), C-27 (Landscaping Contractor)	APPROVED	09/15/2025	09/15/2026
Haydon Construction, Inc	Nicole Hensley	2019 N. Gateway Blvd. Suite 200 Fresno, CA 93727	559-251-5522	559-251-6933	hr@haydonconst.com	458977_	A (General Engineering Contractor)	APPROVED	08/26/2025	08/26/2026
Hensel Phelps Construction Co.	Aaren Solis	4750 Willow Road, Suite 100, Pleasanton, CA, 94588	925-494-9700	925-251-0199	asolis@henselphelps.com	1020262	A (General Engineering Contractor), B (General Building Contractor)	APPROVED	04/03/2025	04/03/2026
Hensley's Paving & General Engineering, Inc.	Rebecca Hensley	13101 Yosemite Blvd., Waterford, CA, 95386	209-874-9710	209-874-2395	rebecca@hensleyspaving.com	828289_	A (General Engineering Contractor)	APPROVED	04/04/2025	04/04/2026
Holloway Construction, Inc.	Jami Holloway	13101 13th Road West, Hanford, CA, 93230	559-585-0368	559-582-3398	jami@hollowayconstructioninc.net	873511_	A (General Engineering Contractor), B (General Building Contractor), C-9 (Drywall Contractor)	APPROVED	07/16/2025	07/16/2026
Howe Electric Construction, Inc.	Kirstin Howe	4682 E. Olive Avenue, Fresno, CA, 93702	559-255-8992	559-255-9745	kirstin.howe@howe-electric.com	898737_	B (General Building Contractor), C-10 (Electrical Contractor), C-46 (Solar Contractor)	APPROVED	11/19/2025	11/19/2026
INTCHSOLUTIONS CORPORATION dba INTCHSOLUTIONS VOLTAGE SYSTEMS	Brandon Nguyen	4199 Campus Drive Suite 550, Irvine, CA, 92612	562-607-8829		bnguyen@intchsolutions.com	1101216	C-7 (Low Voltage Systems Contractor), C-10 (Electrical Contractor)	APPROVED	09/05/2025	09/05/2026
Industrial Electronic Systems Inc	Lutfi Abed	3250 Monier Circle #F, Rancho Cordova, CA, 95742	916-638-1000	916-638-1105	labed@iesi.net	497350_	C-10 (Electrical Contractor), C-7 (Low Voltage Systems Contractor)	APPROVED	08/26/2025	08/26/2026
Infinity Power Solutions Inc.	Chad Torres	3727 W. Annadale, Fresno, CA, 93706	559-400-8900		chad@infinity-psi.com	1080287	C-10 (Electrical Contractor)	APPROVED	11/03/2025	11/03/2026

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
Intech Mechanical Company LLC	Kaylee Burt	7501 Galilee Road, Roseville, CA, 95678	916-797-4900 x128	916-797-4901	scannon@intech-mech.com	998149_	C-43 (Sheet Metal Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-36 (Plumbing Contractor), C-4 (Boiler, Hot Water Heating and Steam Fitting Contractor), A (General Engineering Contractor), B (General Building Contractor)	REJECTED	08/26/2025	
Ireland Sound Systems Inc.	Christin Gainey	1232 Monte Vista Ave., Suite 7, Upland, CA, 91786	909-294-2802		christin@irelandsoundsystems.com	744332_	C-7 (Low Voltage Systems Contractor), B (General Building Contractor), C-10 (Electrical Contractor)	APPROVED	09/02/2025	09/02/2026
J. Noble Binns Plumbing Co., Inc.	Michelle Heinrichs	3529 Pegasus Drive, Bakersfield, CA, 93308	661-615-6101	661-615-6108	michelle@binnsplumbing.com	481544_	C-36 (Plumbing Contractor), C-4 (Boiler, Hot Water Heating and Steam Fitting Contractor), C-34 (Pipeline Contractor), C-16 (Fire Protection Contractor), C-55 (Water Conditioning Contractor)	APPROVED	08/21/2025	08/21/2026
J.D. Berlgund Group dba Armour Fence	Elise LaMonica	1160 Battery St., Suite 100, San Francisco, CA, 94111	910-778-3254		elise@armourfence.com	1034748	C-13 (Fencing Contractor)	APPROVED	08/21/2025	08/21/2026
J.F. Duncan Industries	Melissa Roller	9301 Stewart And Gray Rd, Downey, CA, 90241	562-862-4269 x129		melissar@durayco.com	598206_	C-43 (Sheet Metal Contractor)	REJECTED	08/26/2025	
JHK CONSTRUCTION, INC	James Kulina or Wendy Barlass	27727 E Tiffani Lane, Escalon, CA, 95320	209-838-2970		jhkcons@velociter.net	764091_	B (General Building Contractor)	APPROVED	11/12/2025	11/12/2026
JOES LANDSCAPING & CONCRETE, INC dba JOE'S LANDSCAPING	JOSE GARCIA	802 INYO AVE, NEWMAN, CA, 95360	209-862-2004	209-862-3331	janet@joeslc.com	853867_	C-8 (Concrete Contractor), C-12 (Earthwork and Paving Contractors), C-13 (Fencing Contractor), B (General Building Contractor), C-61 (Limited Specialty), C-27 (Landscaping Contractor), C-21 (Building Moving/Demolition Contractor)	APPROVED	09/05/2025	09/05/2026
JR Wagner Fire Protection, Inc.	Kristen@jrwagnerfire.com	P.O. Box 5037, Modesto, CA, 95352	888-325-8544	877-232-8944	kristen@jrwagnerfire.com	968003_	C-16 (Fire Protection Contractor)	APPROVED	08/22/2025	08/22/2026

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
JT2, Inc. dba Todd Companies	James Todd	P.O Box 6820 , Visalia , CA, 93290	559-651-5820	559-651-5830	jt2@jt2inc.com	788798_	A (General Engineering Contractor), B (General Building Contractor), C-36 (Plumbing Contractor), C-21 (Building Moving/Demolition Contractor), C-61 (Limited Specialty), C-31 (Construction Zone Traffic Control Contractor)	APPROVED	04/04/2025	04/04/2026
JUAREZ BROTHERS GENERAL ENGINEERING, INC	Daniel Juarez	17244 El Dorado Drive, Madera, CA, 93636	559-367-6909		danielj_22@yahoo.com	956804_	A (General Engineering Contractor)	APPROVED	09/05/2025	09/05/2026
Jergensen Construction Inc	Todd Jergensen	9320 Daisy Rd, Oak hills, CA, 92344	760-947-4545	760-947-4550	tjergensen@msn.com	536592_	A (General Engineering Contractor), B (General Building Contractor), C-8 (Concrete Contractor)	REJECTED	08/26/2025	
Jerico Fire Protection Co., Inc.	GLORIA MAGDALENO	1380 N. Hulbert Avenue, Fresno, CA, 93728	559-255-6446	559-255-0771	gloria@jericofire.com	548570_	C-16 (Fire Protection Contractor)	APPROVED	09/17/2025	09/17/2026
Jerry Thompson & Sons Painting, Inc.	Luke Thompson	3 Simms St, San Rafael, CA, 94901	415-454-1500	415-454-9170	luke@jtspainting.com	684610_	C-33 (Painting and Decorating Contractor)	APPROVED	09/02/2025	09/02/2026
Johnson Controls Fire Protection LP	Jason Abraham	2788 N. Larkin, Fresno , CA, 93727	559-250-7997	559-348-1291	jason.abraham@jci.com	986047_	C-10 (Electrical Contractor), C-16 (Fire Protection Contractor)	REJECTED	08/26/2025	
Johnson Plumbing Industrial Inc	Jenifer Cunningham	65 East 15th Street , Merced, CA, 95340	209-384-1566	209-384-2903	jen@johnsonindustrial.net	526086_	C-36 (Plumbing Contractor)	APPROVED	04/02/2025	04/02/2026
K S Telecom Inc.	Tammy Kirby	PO Box 330, Penryn, CA, 95663	916-652-4735 x230	916-652-4296	acct@kstelecominc.com	790922_	C-7 (Low Voltage Systems Contractor), C-10 (Electrical Contractor)	APPROVED	08/25/2025	08/25/2026
K.E. Rodgers, Inc.	Dawn Peer	530 Texas Street, Redlands, CA 92374	909-735-5038	909-735-5043	dawnpeer@gmail.com	1000195	C-36 (Plumbing Contractor)	APPROVED	08/28/2025	08/28/2026
KBI Painting, Inc	Kylee Brady	Po Box 750397, Petaluma, CA, 94975	707-795-4955		mail@kbipaint.com	944475_	C-33 (Painting and Decorating Contractor)	APPROVED	12/16/2025	12/16/2026
KITCOR CORPORATION	Ruby Soriano	9959 Glenoaks Blvd, Sun Valley, CA, 91352	818-767-4800 x15	818-767-4658	ruby@kitcor.com	244236_	C-43 (Sheet Metal Contractor)	APPROVED	09/24/2025	09/24/2026

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
KYA Services, LLC	Jessica Amaro	1800 E McFadden Ave, Santa Ana, CA, 92705	714-659-6476	714-659-6477	prequal@thekyagroup.com	984827_	B (General Building Contractor), C-15 (Flooring and Floor Covering Contractors), C-61 (Limited Specialty), A (General Engineering Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-10 (Electrical Contractor), C-33 (Painting and Decorating Contractor)	APPROVED	10/02/2025	10/02/2026
KYA Services, LLC	Shane Collins	1800 E McFadden Ave, Santa Ana, CA, 92705	714-659-6476	714-659-6477	Shane.collins@thekyagroup.com	984827_	B (General Building Contractor), C-15 (Flooring and Floor Covering Contractors), C-61 (Limited Specialty), A (General Engineering Contractor)	REJECTED	08/26/2025	
Katch Environmental, Inc DBA Katch General and Katch	Tom Chacon	929 L Street, Fresno, CA, 93721	559-292-6653		tom@katchenvironmental.com; Letisha@katchenvironmental.com	933096_	C-39 (Roofing Contractor), C-21 (Building Moving/Demolition Contractor), A (General Engineering Contractor), B (General Building Contractor), C-22 (Asbestos Abatement Contractor), HAZ (Hazardous Substance Removal Certification), ASB (Asbestos Certification), C-57 (Water Well Drilling Contractor), C-31 (Construction Zone Traffic Control Contractor)	APPROVED	08/21/2025	08/21/2026
Kinetics Mechanical Service Inc	Minh Le	6336 Patterson Pass Rd Suite H, Livermore, CA, 94550	925-245-6200	925-245-6222	mle@kms-inc.com	753650_	C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-36 (Plumbing Contractor), B (General Building Contractor), C-38 (Refrigeration Contractor)	RETURNED		
Kings County Air Conditioning, Inc.	Mark Mathis	14670 Hanford-Armona Road, Hanford, CA, 93230	559-584-4383	559-584-4385	mark@kcairinc.com	828256_	C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-43 (Sheet Metal Contractor), B (General Building Contractor)	APPROVED	12/03/2025	12/03/2026
Klassen Corporation	Katie Angevine	2021 Westwind Drive, Bakersfield, CA, 93301	661-489-4981	661-324-3900	katiea@klassencorp.com	350573_	B (General Building Contractor), C-8 (Concrete Contractor), C-51 (Structural Steel Contractor)	REJECTED	08/26/2025	
Kompan California Inc	Matt Miller	22431 Antonio Parkway, Suite B160-426 Rancho Santa Margarita, CA 92688	800-426-9788	512-788-9285	bids@kompan.com	1072215	A (General Engineering Contractor)	APPROVED	09/12/2025	09/12/2026

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
Kroeker Inc	Evan Aguilar	4627 S Chestnut ave, Fresno, CA, 93725	559-237-3764	559-268-3366	serinaa@kroekerinc.com	621866_	A (General Engineering Contractor), C-12 (Earthwork and Paving Contractors), C-21 (Building Moving/Demolition Contractor), C-57 (Water Well Drilling Contractor), C-10 (Electrical Contractor), C-61 (Limited Specialty), C-49 (Tree and Palm Contractor), HAZ (Hazardous Substance Removal Certification), ASB (Asbestos Certification)	APPROVED	08/25/2025	08/25/2026
LASAR Underground Construction Inc	Lorenzo Ruiz	2929 n burl ave, fresno, CA, 93727	559-824-0656		lorenzor@lasarunderground.com	614677_	A (General Engineering Contractor)	APPROVED	09/05/2025	09/05/2026
LPC Automation Inc.	Joe Calafiore	3140 N. Argyle Ave. Suite 104, Fresno, CA, 93727	888-742-5572	888-742-5572	tescoto@lpcautomation.com	886516_	C-10 (Electrical Contractor)	APPROVED	08/29/2025	08/29/2026
Landmark Modernization Contractors	Ellen Kelton	4312 Anthony Court Suite B, Rocklin, CA 95677	916-663-1953	916-663-1867	ekelton@landmarkconst.net	807981_	A (General Engineering Contractor), B (General Building Contractor)	REJECTED	08/26/2025	
Larger Electric, Inc	Sophia Larger	2011 Second St, Selma, CA, 93662	559-579-6776	559-344-3006	sophia@largerelectric.com	929677_	C-10 (Electrical Contractor)	APPROVED	08/22/2025	08/22/2026
Lawson Mechanical Contractors, LLC	Sarah Pak	6090 S. Watt Ave., Sacramento, CA, 95829	916-381-5000	916-381-5073	prequals@lawsonmechanical.com	1101403	A (General Engineering Contractor), B (General Building Contractor), C-2 (Insulation and Acoustical Contractor), C-4 (Boiler, Hot Water Heating and Steam Fitting Contractor), C-16 (Fire Protection Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-36 (Plumbing Contractor), C-38 (Refrigeration Contractor), C-43 (Sheet Metal Contractor), HAZ (Hazardous Substance Removal Certification), ASB (Asbestos Certification)	APPROVED	08/21/2025	08/21/2026
Lindsay Electric Inc	Steve Lindsay	6321 N Montana, Clovis, CA, 93619	559-281-6308	559-297-7247	steve@lindsay-electric.com	932850_	C-10 (Electrical Contractor)	APPROVED	01/12/2026	01/12/2027
Linoleum Sales Co., Inc. DBA Anderson Commercial Flooring	Chynna Edwards	1000 West Grand Avenue, Oakland, CA, 94607	510-652-1032		chynna.edwards@andersoncf.com	242102_	C-15 (Flooring and Floor Covering Contractors)	APPROVED	12/23/2025	12/23/2026

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
LogicLamp Technologies LLC	Saurabh Awasthi	231 E. Imperial Hwy Suite 104	844-422-2820		cainfo@logiclamp.net	1104860	C-10 (Electrical Contractor)	APPROVED	09/23/2025	09/23/2026
M3 MEP, LLC	Anisa Lopez	5101 Florin Perkins Rd, Sacramento, CA, 95826	916-381-8080	916-386-0363	estimating@mark-three.com	1098716	A (General Engineering Contractor), B (General Building Contractor), C-4 (Boiler, Hot Water Heating and Steam Fitting Contractor), C-10 (Electrical Contractor), C-16 (Fire Protection Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-36 (Plumbing Contractor), C-7 (Low Voltage Systems Contractor)	APPROVED	08/28/2025	08/28/2026
MAGNETAR US INC	Greg Hardin	4319 N Brawley Ave, Fresno, CA, 93722	559-477-4137	559-277-3303	greg.hardin@magnetar.us	904637_	B (General Building Contractor), C-7 (Low Voltage Systems Contractor), C-10 (Electrical Contractor), C-61 (Limited Specialty)	APPROVED	09/05/2025	09/05/2026
MARKO CONSTRUCTION GROUP INC	PAUL GONG	3675 E JENSEN AVE, FRESNO, CA, 93725	559-222-7888	559-222-0888	pkgong@markoconstruction.com	831764_	A (General Engineering Contractor), B (General Building Contractor), C-39 (Roofing Contractor), C-23 (Ornamental Metal Contractor)	APPROVED	12/03/2025	12/03/2026
MARVULLI INC dba MARVULLI	Rocky Hogue	1005 E CHILDS AVE, MERCED, CA, 95341	209-233-9474		rocky@marvulli.com	1004437	B (General Building Contractor)	APPROVED	11/21/2025	11/21/2026
MCGRATH ELECTRIC, INC.	Eric McGrath	2800 INDUSTRIAL, FAIRFIELD, CA, 94533	707-422-4131	707-422-4151	bidding@mcgrathelectricinc.com	853934_	C-10 (Electrical Contractor)	REJECTED	08/26/2025	
MESA ENERGY SYSTEMS INC dba EMCOR SERVICES MESA ENERGY	Rod Galvan	3980 N. Chestnut Diagonal #101, Fresno, CA, 93726	559-277-7900	559-277-4920	rgalvan@emcor.net	611215_	B (General Building Contractor), C-4 (Boiler, Hot Water Heating and Steam Fitting Contractor), C-7 (Low Voltage Systems Contractor), C-10 (Electrical Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-36 (Plumbing Contractor), C-38 (Refrigeration Contractor), C-46 (Solar Contractor)	APPROVED	12/23/2025	12/23/2026
MMJ Construction, Inc.	Judy Bailey-Savage	39100 Air Park drive, Temcula, CA, 92592	951-216-8862	951-457-6484	info@mmjconstruction.com	988999_	B (General Building Contractor), C-10 (Electrical Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-36 (Plumbing Contractor)	REJECTED	08/26/2025	

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
MODESTO INDUSTRIAL ELECTRICAL CO dba INDUSTRIAL ELECTRICAL CO	Michael Crumley	1417 Coldwell Avenue, Modesto, CA, 95350	209-527-2800 x8421	559-292-5939	mcrumley@iecmail.com	135470_	C-10 (Electrical Contractor)	APPROVED	10/02/2025	10/02/2026
MSTALL ELECTRIC INC	MADDIE RINEHART	9701 DINO DRIVE STE 110, ELK GROVE, CA, 95624	209-663-7432		maddie@mstallelectric.com	576070_	C-10 (Electrical Contractor)	APPROVED	08/28/2025	08/28/2026
Mark Wilson Construction Inc.	Dawnette Rivas	5799 E Clinton Ave, Fresno, CA, 93727	559-348-0421	559-348-0471	dawnette@markwilsonconstruction.com	774987_	B (General Building Contractor)	APPROVED	12/30/2025	12/30/2026
Matrix HG, Inc	Ashley Silva	115 Mason Circle, suite B, Concord, CA, 94520	925-459-9200	925-459-9220	projects@matrixhginc.com	812232_	C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-10 (Electrical Contractor), C-36 (Plumbing Contractor), B (General Building Contractor), C-38 (Refrigeration Contractor), C-43 (Sheet Metal Contractor), C-4 (Boiler, Hot Water Heating and Steam Fitting Contractor)	APPROVED	08/29/2025	08/29/2026
McGrath Electric Inc.	Lucas Wulff	2800 Industrial Drive, Fairfield, CA, 94533	707-422-4131		estimatingmei@mcgrathelectricinc.com	853934_	C-10 (Electrical Contractor)	APPROVED	08/28/2025	08/28/2026
Meehleis Modular Buildings, Inc.	Lannete Cunha	1303 E. Lodi Avenue, Lodi, CA, 95240	209-334-4637	209-334-4726	Cadmin@meehleis.com	473488_	B (General Building Contractor)	APPROVED	08/22/2025	08/22/2026
Menghetti Construction, Inc.	Charles Menghetti	PO Box 577516, Modesto, CA, 95357	209-524-2465	209-665-0120	charlie@menghetti.com	697651_	A (General Engineering Contractor), B (General Building Contractor)	APPROVED	03/25/2025	03/25/2026
Michael Venosta Plumbing and Mechanical Inc.	Kelly Venosta	8505 Church Street Unit 13, Gilroy, CA, 95020	408-842-4004	408-842-4005	kelly@michaelvenostaplumbing.com	969247_	C-36 (Plumbing Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-43 (Sheet Metal Contractor)	APPROVED	08/22/2025	08/22/2026
Midstate Construction Corporation	Mickale McChristian	1180 Holm Rd, Petaluma, CA, 94954	707-762-3200	707-762-0700	mickalem@midstateconstruction.com	089455_	B (General Building Contractor)	REJECTED	08/26/2025	

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
Milestone Contractors Inc. dba N.V. Heathorn Co.	Stephanie Pedro	1980 Olivera Rd. Suite C Concord, CA 94520	510-569-9100 x109	510-569-9106	spedro@nvheathorn.com	761659_	C-4 (Boiler, Hot Water Heating and Steam Fitting Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-36 (Plumbing Contractor), C-38 (Refrigeration Contractor), C-43 (Sheet Metal Contractor), B (General Building Contractor), A (General Engineering Contractor), C-2 (Insulation and Acoustical Contractor), C-7 (Low Voltage Systems Contractor), C-10 (Electrical Contractor), C-16 (Fire Protection Contractor), C-21 (Building Moving/Demolition Contractor), C-34 (Pipeline Contractor), C-39 (Roofing Contractor), C-42 (Sanitation System Contractor), C-46 (Solar Contractor)	REJECTED	08/26/2025	
Modern Air Mechanical	Lisa Reyes	2200 Cooper Ave, Merced CA 95348	209-722-1815	209-722-0170	est@modernair.biz	569680_	C-43 (Sheet Metal Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-38 (Refrigeration Contractor)	APPROVED	09/29/2025	09/29/2026
Modesto Executive Electric, Inc.	April Thompson	446 Charity Way, MODESTO, CA, 95356	209-238-9898	209-238-9576	april@modexelec.com	669018_	C-10 (Electrical Contractor)	REJECTED	08/26/2025	
NMI Industrial Holdings, LLC.	Alex Potts	8503 Weyand Ave, Sacramento, CA, 95828	916-635-7030		Invitations@nmiindustrial.com	951227_	A (General Engineering Contractor), C-11 (Elevator Contractor), C-51 (Structural Steel Contractor)	APPROVED	08/28/2025	08/28/2026
NTM Productions	Nathan McGuigan	11369 Avenue 264, Suite B, Visalia, CA 93277	559-550-1500		nathan@ntmproductions.com	1012433	C-7 (Low Voltage Systems Contractor), C-10 (Electrical Contractor)	APPROVED	01/08/2026	01/08/2027
Nations Roof West LLC	Sean Rauch	5463 E. Hedges Ave, Fresno, CA, 93727	559-252-1255	559-252-1256	srauch@nationsroof.com	1012378	B (General Building Contractor), C-39 (Roofing Contractor), C-43 (Sheet Metal Contractor)	APPROVED	09/02/2025	09/02/2026

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
New England Sheet Metal and Mechanical Co.	Joshua Wilkinson	P.O. Box 27409, Fresno, CA, 93729	559-268-7375	559-268-5018	bids@nesm.com	433674_	A (General Engineering Contractor), B (General Building Contractor), C-4 (Boiler, Hot Water Heating and Steam Fitting Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-36 (Plumbing Contractor), C-38 (Refrigeration Contractor), C-43 (Sheet Metal Contractor)	APPROVED	09/23/2025	09/23/2026
NextMod, Inc.	Sean Khan	6361 Box Springs Springs, Riverside, CA, 92507	909-740-3120		sean@nextmodinc.com	992118_	B (General Building Contractor)	APPROVED	08/21/2025	08/21/2026
O.C. Jones & Sons, Inc.	Heidi Faria	1520 Fourth St. Berkeley CA 94710, [Enter City], CA, 00000	510-809-3446	510-526-0990	hfaria@ocjones.com	759729_	A (General Engineering Contractor), HAZ (Hazardous Substance Removal Certification)	APPROVED	08/28/2025	08/28/2026
OPTERRA Energy Services, LLC.	Shon Andrew	500 12th Street, Suite 300, Oakland, CA, 94607	714-686-4440		sandrew@opterraenergy.com	1142716	A (General Engineering Contractor), B (General Building Contractor), C-10 (Electrical Contractor), C-46 (Solar Contractor)	APPROVED	12/30/2025	12/30/2026
Oakview Constructors, Inc.	Tamara Bernardo	PO Box 625/959 Calimesa Boulevard, Calimesa, CA, 92320	909-795-0990	909-795-3150	tammy@oakviewci.com	462847_	B (General Building Contractor), C-8 (Concrete Contractor)	APPROVED	08/29/2025	08/29/2026
Optima Energy Inc.	Young Chang	17306 ROSETON AVE, ARTESIA, CA, 90701	310-320-0611	310-715-8325	intake@opnrg.com	907155_	C-10 (Electrical Contractor)	REJECTED	08/26/2025	
PAC SHIELD Roof Services Inc	Gabriela Lapizco	5151 Pentecost Dr. Ste A-1 , Modesto, CA, 95356	800-689-4716		glapizco@pacshield.com	1031725	C-39 (Roofing Contractor), C-43 (Sheet Metal Contractor), B (General Building Contractor)	APPROVED	08/28/2025	08/28/2026
PAC SHIELD Roof Services Inc	Gabriela Lapizco	5151 Pentecost Dr. Ste A-1 , Modesto, CA, 95356	800-689-4716		glapizco@pacshield.com	1031725	C-39 (Roofing Contractor), C-43 (Sheet Metal Contractor)	REJECTED	08/26/2025	
POWER DESIGN ELECTRIC, INC.	Gabriel Lopez	335 N 5TH AVE, KINGSBURG, CA, 93631	559-897-2599	559-897-0189	glopez@powerdesignelectric.com	851246_	C-10 (Electrical Contractor)	APPROVED	09/05/2025	09/05/2026
Pacific Contractors Group Inc	Setmir Qose	19025 Parthenia St, Unit #122, Northridge, CA 91324	818-993-5899 x0	818-993-5895 x0	pacificcontractorsinc@gmail.com	927973_	B (General Building Contractor), C-33 (Painting and Decorating Contractor), C-35 (Lathing and Plastering Contractor)	APPROVED	09/05/2025	09/05/2026

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
Pacific Power & Systems, Inc.	Abigail Cruz	1590 Solano Way, Suite A	707-437-2300	707-437-2388	abigailc@pacificpowersystem.com	458315_	C-10 (Electrical Contractor)	APPROVED	09/23/2025	09/23/2026
Pacific West Sound Professional Audio & Design, Inc.	Steve Grider	521 E. 21st ST., Bakersfield, CA, 93305	661-395-1448	661-395-3148	steve@pacificwestsound.com	797617_	C-10 (Electrical Contractor)	APPROVED	08/29/2025	08/29/2026
Painting & Decor, Inc.	John Buchner	1210 N Jefferson St, Ste K, Anaheim, CA, 92807	949-888-2565	949-888-2566	bidding@paintinganddecor.com	276640_	B (General Building Contractor), C-33 (Painting and Decorating Contractor)	APPROVED	01/08/2026	01/08/2027
Pathway Communications LTD	Becky Thurmon	12740 Danielson Court, Suite E, Poway, CA, 92064	858-324-1036	858-430-9459	beckyt@pcomus.com	868539_	C-7 (Low Voltage Systems Contractor)	APPROVED	01/27/2026	01/27/2027
Pathway Communications LTD	Becky Thurmon	12740 Danielson Court, Suite E, Poway, CA, 92064	858-324-1036	858-430-9459	beckyt@pcomus.com	868539_	C-7 (Low Voltage Systems Contractor)	REJECTED	08/26/2025	
Perfection Stainless Fabrication, Inc.	Chris Carmignani	901 Sumner Street, Bakersfield, CA, 93305	661-324-5466	661-324-7714	sales@perfectionsf.com	462114_	C-43 (Sheet Metal Contractor), C-61 (Limited Specialty)	APPROVED	09/02/2025	09/02/2026
Piana Construction and Painting Inc	Joseph Papadopoulos	16352 Barneston Street, Granada Hills, CA, 91344	818-488-1740	818-488-1741	pianaconstruction@sbcglobal.net	731555_	C-33 (Painting and Decorating Contractor), B (General Building Contractor)	APPROVED	10/23/2025	10/23/2026
Pisor Fence Division Inc	Jeremiah Alexander	PO Box 7213, Citrus Heights, CA, 95843	916-726-1173	916-726-1198	jalexander@pisorfence.net	316128_	C-13 (Fencing Contractor), C-61 (Limited Specialty), C-23 (Ornamental Metal Contractor), C-51 (Structural Steel Contractor), B (General Building Contractor)	APPROVED	08/25/2025	08/25/2026
Polychrome Construction Inc	Marios Polychronas	8908 Balboa Blvd, Northridge, CA, 91325	818-831-8308	818-775-9944	info@polychromepainting.com	993826_	B (General Building Contractor), C-33 (Painting and Decorating Contractor)	APPROVED	09/24/2025	09/24/2026
Precision West Telecommunications Inc dba Precision West Technologies	Mark Savickas	4231 Pacific Street Ste 3, Rocklin, CA, 95677	916-660-9828	916-660-9830	sales@precision-west.com	594069_	C-7 (Low Voltage Systems Contractor)	APPROVED	01/02/2026	01/02/2027
Premier Culinary Solutions dba Premier Prefabricated Equipment	Scott Roczey	1530 S Lewis, Anaheim, CA, 92805	951-377-3498		info@premierculinarysolutions.com	1057430	C-61 (Limited Specialty)	APPROVED	09/05/2025	09/05/2026

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
Presidential Fire Protection, Inc.	Fabian Robles	4517 Harlin Drive, Sacramento, CA, 95826	916-379-9199	916-379-9099	Fabian@presidentialfireprotection.com	847133_	C-16 (Fire Protection Contractor)	APPROVED	09/02/2025	09/02/2026
Prestige Paving Company, Inc.	Brian Beckner	14656 Industry Circle, La Mirada, CA, 90638	714-888-7555		ar@prestigepavingcompany.com	1110800	A (General Engineering Contractor), C-8 (Concrete Contractor), C-12 (Earthwork and Paving Contractors), C-32 (Parking and Highway Improvement Contractor)	APPROVED	12/09/2025	12/09/2026
Pro Flooring Corporation	Armine Arakelian	2283 WALTONIA DR UNIT 106, MONTROSE, CA, 91020	818-541-0545		amy.profco@gmail.com	1027154	C-15 (Flooring and Floor Covering Contractors)	APPROVED	09/15/2025	09/15/2026
Pro Installations Inc dba ProSpectra Contract Flooring	Steve Landreth	10948 Willow Ct Ste 100 San Diego, CA 92127	858-642-7429	858-642-7691	steve.landreth@spectracf.com	740392_	C-15 (Flooring and Floor Covering Contractors), C-54 (Ceramic and Mosaic Tile Contractor), C-61 (Limited Specialty)	APPROVED	12/23/2025	12/23/2026
Pro-Ex Construction,Inc	Pavel Chernyy	3223 Luyung Dr, Rancho Cordova, CA, 95742	916-970-0097	916-222-1478	bids@proexconstruction.com	959719_	B (General Building Contractor), C-33 (Painting and Decorating Contractor), C-39 (Roofing Contractor)	APPROVED	10/22/2025	10/22/2026
R & D ELECTRIC INC dba R & D ELECTRIC	Nick Vida	5740 Roseville Rd. STE M, Sacramento, CA, 95842	916-550-0075		bids@rdelectric.net	1044712	C-10 (Electrical Contractor), B (General Building Contractor)	APPROVED	08/29/2025	08/29/2026
R & D INTERIORS INC dba BUDGET BLINDS OF CLOVIS	Raymond Deatherage	1065 Holland Ave. , Clovis, CA, 93612	559-360-7000		redray@sbcglobal.net	923499_	C-61 (Limited Specialty)	REJECTED	08/26/2025	
R L H FIRE PROTECTION INC	Eric Fambrough	4300 Stine Rd., Bldg 500, Bakersfield, CA 93313	661-322-9344	661-322-6816	efambrough@rlhfp.com	777717_	C-16 (Fire Protection Contractor), C-10 (Electrical Contractor), A (General Engineering Contractor)	APPROVED	08/25/2025	08/25/2026
R&H Industries dba Best Electric	Samuel Kim	17800 S Main St #407, Gardena, CA, 90248	310-354-9900		info@TheBestElectric.net	771334_	C-10 (Electrical Contractor)	REJECTED	08/26/2025	
R&M Paving Contractors, Inc.	Gabrielle Selway	980 Ames Avenue, Milpitas, CA, 95035	408-946-2974	408-946-8029	gabrielle@randmpaving.com	456578_	A (General Engineering Contractor), B (General Building Contractor)	APPROVED	07/16/2025	07/16/2026

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
R.E. Schultz Construction Inc.	Nicole Roth	1767 N. Batavia St., Orange, CA, 92865	714-649-2627	714-740-5049	nicole@reschultzconstruction.com	1007195	A (General Engineering Contractor), B (General Building Contractor), C-61 (Limited Specialty)	APPROVED	08/22/2025	08/22/2026
RCM Fire Protection LLC	Deborah Stoffel	350 Enterprise Place, Tracy, CA, 95304	209-833-8228	209-833-8221	dstoffel@rcmfire.com	793205_	C-16 (Fire Protection Contractor), C-10 (Electrical Contractor)	APPROVED	08/21/2025	08/21/2026
RED WILLOW LANDSCAPING	Christian Orellana	6119 Merry Lane, Carmichael, CA, 95608	916-661-2393		redwillowlandscaping@gmail.com	1082017	C-27 (Landscaping Contractor)	REJECTED	08/26/2025	
REX MOORE GROUP INC dba REX MOORE	Melissa Bradway	6001 Outfall Cir, Sacrmento, CA, 95661	916-205-7819	916-372-4013	melissa.bradway@rexmoore.com	976827_	B (General Building Contractor), C-10 (Electrical Contractor)	APPROVED	08/26/2025	08/26/2026
RTS Solutionz, Inc. dba Solutionz Low Voltage Systems	Ryan Marrs	16751 Knott Avenue, La Mirada, CA 90638	310-571-1207 x1235	310-943-2388	rmarrs@solutionzinc.com	1126720	C-7 (Low Voltage Systems Contractor)	APPROVED	12/03/2025	12/03/2026
Rakkar Development & Construction	Tajinder Rakkar	2038 N Jensen Ave Suite A, Fresno, CA 93706	559-994-9482		taj@rpccompanies.com	1037594	B (General Building Contractor)	APPROVED	08/28/2025	08/28/2026
Ranch Fence Inc.	Jarrod Twiss	5071 Cole Road, Mariposa, CA, 95338	209-966-5914		estimating@ranchfenceinc.com	912353_	C-13 (Fencing Contractor), B (General Building Contractor), C-61 (Limited Specialty)	APPROVED	01/28/2026	01/28/2027
Rivera Equipment dba Valley Industrial Mechanical	Raymond Rivera	PO Box 3457, Victorville, CA, 92393	760-646-7974		cortney@revim.co	1051483	C-36 (Plumbing Contractor)	APPROVED	10/27/2025	10/27/2026
Robert E. Boyer Construction, Inc. dba Boyer Construction	Robert Boyer	19608 E. Mono Way, Sonora, CA, 95370	209-586-5010	209-586-5099	info@boyerbuild.com	509381_	A (General Engineering Contractor), B (General Building Contractor)	APPROVED	09/05/2025	09/05/2026
Rod-West Floor Covering LLC	Ever Rodriguez	15120 Bonavista Ave Unit 103, Santa Fe Springs, CA, 90670	657-325-4014		ever@rodwestfloor.com	1069444	C-15 (Flooring and Floor Covering Contractors)	APPROVED	08/21/2025	08/21/2026
Roebbelen Contracting, Inc.	Kenneth J. Wenham	1241 Hawks Flight Court, El Dorado Hills, CA, 95762	916-939-4000	916-939-4028	estimating@roebbelen.com	734124_	A (General Engineering Contractor), B (General Building Contractor), C-8 (Concrete Contractor), C-13 (Fencing Contractor)	APPROVED	08/28/2025	08/28/2026

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
Roebbelen Contracting, Inc.	Robert J. Kjome	1241 Hawks Flight Court, El Dorado Hills, CA, 95762	916-939-4000	916-939-4027	estimating@roebbelen.com	734124_	A (General Engineering Contractor), B (General Building Contractor), C-8 (Concrete Contractor), C-13 (Fencing Contractor)	REJECTED	08/26/2025	
Rollin Electric Service Company, Inc. dba Rollin Electric	Rollin Brown	P.O. Box 1053, Loomis, CA, 95650	916-257-0974	916-226-3727	rollinelectric@gmail.com	1019477	B (General Building Contractor), C-10 (Electrical Contractor)	APPROVED	08/21/2025	08/21/2026
Rollin Electric Service Company, Inc. dba Rollin Electric	Rollin Brown	P.O. Box 1053, Loomis, CA, 95650	916-257-0974	916-226-3727	rollinelectric@gmail.com	1019477	B (General Building Contractor), C-10 (Electrical Contractor)	REJECTED	08/26/2025	
Russell Sigler Inc.	Jeffrey Myers	205 South Puente St., Brea, CA, 92821	714-421-2455		jmyers@siglers.com	960159_	C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor)	APPROVED	09/15/2025	09/15/2026
Russell Sigler Inc.	Jeffrey Myers	205 South Puente St., Brea, CA, 92821	714-421-2455		jmyers@siglers.com	960159_	C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor)	REJECTED	08/26/2025	
SAN JOAQUIN FENCE	MICHELLE JENKINS	1933 E. CALIFORNIA AVE, BAKERSFIELD, CA, 93307	661-322-9700	661-322-9600	MICHELLE@SJFENCE.COM	1095547	C-13 (Fencing Contractor)	APPROVED	11/05/2025	11/05/2026
SCC Electric Inc	Charles Slack	1301 Grant Ave, Suite B, Novato, CA, 94945	415-599-6545	415-209-0228	sccelectricinc@gmail.com	1109026	A (General Engineering Contractor), C-10 (Electrical Contractor), C-7 (Low Voltage Systems Contractor), B (General Building Contractor)	APPROVED	01/30/2026	01/30/2027
SJD&B, Inc.	Simon Jeon	20451 Valley Blvd., Walnut, CA, 91789	909-481-0001		info@sjdandb.com	1001950	B (General Building Contractor), A (General Engineering Contractor), C-12 (Earthwork and Paving Contractors)	REJECTED	08/26/2025	
SS+K Construction, Inc	Keykhosrow (Kay) KHADEM	22142 Sabroso, Mission Viejo, CA 92691	818-943-3844		kay@sskconstructioninc.com	1035146	B (General Building Contractor), C-5 (Framing and Rough Carpentry Contractor)	APPROVED	08/26/2025	08/26/2026
SUFFOLK CONSTRUCTION COMPANY INC DBA SUFFOLK-ROEL	Marilu Gonzalez - Yanez	550 South Hope Street, Suite 700, Los Angeles, CA, 90071	213-861-6100	213-861-6100	myanez@suffolk.com	751099_	B (General Building Contractor)	APPROVED	08/29/2025	08/29/2026

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
Saboo Inc.	Toheed Asghar	415 beatrice Court Suite #H, brentwood, CA, 94513	626-260-2849		tasghar@sbcglobal.net	896479_	A (General Engineering Contractor), B (General Building Contractor), C-10 (Electrical Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-17 (Glazing Contractor), C-36 (Plumbing Contractor)	APPROVED	08/26/2025	08/26/2026
Serenity Fire Protection	Robert Black	417 S. Associated Rd., # 215, Brea, CA, 92821	714-914-1463		robert@serenityfireprotection.com	902927_	C-16 (Fire Protection Contractor)	APPROVED	08/28/2025	08/28/2026
Serenity Fire Protection	Robert Black	417 S. Associated Rd., # 215, Brea, CA, 92821	714-914-1463		robert@serenityfireprotection.com	902927_	C-16 (Fire Protection Contractor)	REJECTED	08/26/2025	
Sign Factory, Printing & Office Equipment, Inc. dba Sign Factory	Mario Rodriguez	120 N 4th street, SIGN FACTORY, El Centro, CA, 92243	760-455-7589		mrgerardo@signfactory.org	985388_	C-45 (Electrical Sign Contractor), C-10 (Electrical Contractor), C-61 (Limited Specialty), B (General Building Contractor)	APPROVED	08/21/2025	08/21/2026
Silver Creek Modular LLC.	Mayra Corona	2830 Barrett Ave., Perris, CA, 92571	951-943-5393	951-943-2211	sales@silvercreekmodular.com	1106686	B (General Building Contractor)	APPROVED	08/21/2025	08/21/2026
Simile Construction Service, Inc.	Joe Simile	4725 Enterprise Way, Ste. 1, Modesto, CA, 95356	209-545-6111	209-545-6112	estimating@similebuilt.com	794642_	A (General Engineering Contractor), B (General Building Contractor)	APPROVED	10/06/2025	10/06/2026
Smith Mechanical-Electrical-Plumbing	Koren Cloud	1340 W. Betteravia Road, Santa Maria, CA, 93455	805-621-5000	805-621-5050	kcloud@smithmep.com	420418_	A (General Engineering Contractor), B (General Building Contractor), C-2 (Insulation and Acoustical Contractor), C-4 (Boiler, Hot Water Heating and Steam Fitting Contractor), C-7 (Low Voltage Systems Contractor), C-9 (Drywall Contractor), C-10 (Electrical Contractor), C-16 (Fire Protection Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-36 (Plumbing Contractor), C-38 (Refrigeration Contractor), C-43 (Sheet Metal Contractor)	APPROVED	08/28/2025	08/28/2026

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
Smith Mechanical-Electrical-Plumbing	Koren Cloud	1340 W. Betteravia Road, Santa Maria, CA, 93455	805-621-5000	805-621-5050	kcloud@smithmep.com	420418_	A (General Engineering Contractor), B (General Building Contractor), C-2 (Insulation and Acoustical Contractor), C-4 (Boiler, Hot Water Heating and Steam Fitting Contractor), C-7 (Low Voltage Systems Contractor), C-9 (Drywall Contractor), C-10 (Electrical Contractor), C-16 (Fire Protection Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-36 (Plumbing Contractor), C-43 (Sheet Metal Contractor)	REJECTED	08/26/2025	
So Cal Shaker Plates & Construction Site Services LLC	Maverick Cissell	600 CENTRAL AVE SUITE 105, Lake Elsonire, CA, 92530	951-588-5585		sales@nationalswppp.com	1099259	B (General Building Contractor)	REJECTED	08/26/2025	
Sound Contracting Inc.	Eric Peters	5665 E Westover Ave Suite 104, Fresno, CA, 93727	559-224-2242	559-981-5372	office@soundcontracting.net	595304_	C-7 (Low Voltage Systems Contractor)	APPROVED	09/05/2025	09/05/2026
Southcoast Acoustical Interiors Inc.	Cynthia Ortega	14980 Hilton Dr., Fontana, CA, 92336	909-428-2600	909-428-2602	admin@socoast.us	738787_	C-2 (Insulation and Acoustical Contractor)	APPROVED	09/02/2025	09/02/2026
Sterling Environmental Corporation	Natalie OBrien	10203 E Street, Oakland, CA, 94603	510-638-2800 x201	510-638-2804	nobrien@sterlingenv.com	537909_	A (General Engineering Contractor), C-2 (Insulation and Acoustical Contractor), ASB (Asbestos Certification), C-22 (Asbestos Abatement Contractor)	APPROVED	07/16/2025	07/16/2026
Steven's Electrical Contracting	Steven Harris	17716 road 38, madera, CA, 93636	559-363-9776		stevens3639776@gmail.com	661442_	C-10 (Electrical Contractor)	APPROVED	09/05/2025	09/05/2026

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
Strategic Mechanical Inc	Mariah Oliveira	4661 E Commerce Ave, Fresno, CA, 93725	559-291-1952	559-291-1805	moliveira@strategicmech.com	834679_	B (General Building Contractor), C-2 (Insulation and Acoustical Contractor), C-4 (Boiler, Hot Water Heating and Steam Fitting Contractor), C-10 (Electrical Contractor), C-16 (Fire Protection Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-23 (Ornamental Metal Contractor), C-36 (Plumbing Contractor), C-38 (Refrigeration Contractor), C-42 (Sanitation System Contractor), C-43 (Sheet Metal Contractor), C-51 (Structural Steel Contractor), C-60 (Welding Contractor)	APPROVED	09/05/2025	09/05/2026
Stronger Building Services	Claudia Chavez	580 Harlan St. , San Leandro, CA, 94577	510-487-8363	510-487-8246	strongerbuilding@yahoo.com	955618_	B (General Building Contractor), C-39 (Roofing Contractor)	APPROVED	08/22/2025	08/22/2026
Structure Net Inc	Asef Alizai	2021 Las Positas CT, Suite 135, Livermore, CA, 94551	925-292-9494	925-800-8610	asef@structurenetinc.com	1064400	C-7 (Low Voltage Systems Contractor)	APPROVED	12/16/2025	12/16/2026
Structure Net Inc	Asef Alizai	2021 Las Positas CT, Suite 135, Livermore, CA, 94551	925-292-9494	925-800-8610	asef@structurenetinc.com	1064400	C-7 (Low Voltage Systems Contractor)	REJECTED	08/26/2025	
Summit Plumbing and Mechanical Corporation	Fred Duckart	1120 Doker Drive, Unit #1, Modesto, CA, 95351	209-522-3764	209-522-5087	fred@summitpminc.com	861170_	C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-36 (Plumbing Contractor), C-43 (Sheet Metal Contractor), C-4 (Boiler, Hot Water Heating and Steam Fitting Contractor)	APPROVED	08/21/2025	08/21/2026
Superior Paving Company, Inc. DBA United Paving Co.	Delaney Crump	1880 N Delilah St , Corona, CA, 92879	951-739-9200	951-739-9400	dcrump@united-paving.com	865828_	A (General Engineering Contractor), C-12 (Earthwork and Paving Contractors)	APPROVED	10/07/2025	10/07/2026
Sylvester Roofing Company Incorporated	Brittany Torres or Danna Lozada	306 Suite N, West El Norte Parkway PMB 371, Escondido, CA, 92026	760-743-0048	760-743-4152	office@sylvesterroofing.com	516696_	C-43 (Sheet Metal Contractor), C-39 (Roofing Contractor), ASB (Asbestos Certification)	APPROVED	09/24/2025	09/24/2026
T&S Intermodal Maintenance, Inc. DBA T&S West	Sammy Cox	PO Box 1592, Linden, CA, 95236	209-942-1360	209-942-1368	estimating@tandsinc.us	939001_	A (General Engineering Contractor), B (General Building Contractor)	APPROVED	10/02/2025	10/02/2026

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
T&S Intermodal Maintenance, Inc. DBA T&S West	Sammy Cox	PO Box 1592, Linden, CA, 95236	209-942-1360	209-942-1368	estimating@tandsinc.us	939001_	A (General Engineering Contractor), B (General Building Contractor)	REJECTED	08/26/2025	
TBK Electric, Inc.	Bao Kephart	3960 Lakeview Dr, Lone, CA, 95640	916-627-9857	916-897-6097	sparkybao@gmail.com	896645_	C-10 (Electrical Contractor), C-7 (Low Voltage Systems Contractor)	REJECTED	08/26/2025	
TERRA WEST CONSTRUCTION, INC.	Raegen Foreman	1030 Gettysburg Ave., #107, , Clovis, CA, 93612	559-252-1356	559-390-0483	raegen.foreman@terrawestconstruction.com	924631_	A (General Engineering Contractor), C-12 (Earthwork and Paving Contractors)	APPROVED	08/28/2025	08/28/2026
THP Mechanical LLC	Stacy Therkildsen	1261 Hawks Flight Ct Suite E, Suite E, El Dorado Hills, CA, 95762	833-847-6324		estimating@thpmechanical.com	790840_	B (General Building Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-36 (Plumbing Contractor)	APPROVED	09/05/2025	09/05/2026
TRUELINE CONSTRUCTION & SURFACING INC dba trueline	ED KRUSE	12397 Doherty Street, Riverside, CA 92503	951-817-0777	951-817-0777	trueline40@gmail.com	662625_	A (General Engineering Contractor), C-32 (Parking and Highway Improvement Contractor), ASB (Asbestos Certification)	APPROVED	09/23/2025	09/23/2026
Talkington Inc dba Lancaster Painting	Jennifer Petitt	2750 N. Gratton Rd. , Denair, CA, 95316	209-634-1111	209-634-5482	sales@lancasterpainting.com	868896_	C-33 (Painting and Decorating Contractor)	APPROVED	07/16/2025	07/16/2026
Taylor Backhoe Service Inc. dba TBS Contractors	Krystal Zamora	1605 E. Gerard Avenue, Merced, CA, 95341	209-384-8424	209-384-7629	krystal@taylorbackhoe.com	810520_	A (General Engineering Contractor), B (General Building Contractor), C-21 (Building Moving/Demolition Contractor)	APPROVED	03/31/2025	03/31/2026
The Roofing Friend Inc, dba Western Roofing Systems	Florentino Guerrero Covarrubias	211 Jackson St, Hayward, CA, 94544	510-200-3693		rooffriend@gmail.com	1067709	B (General Building Contractor), C-39 (Roofing Contractor)	APPROVED	07/16/2025	07/16/2026
Thompson Builders Corporation	Jenn O'Toole	5400 Hanna Ranch Road, Novato, CA, 94945	415-456-8972 x4414	415-459-0665	jenno@tbcorp.com	626859_	A (General Engineering Contractor), B (General Building Contractor), C-17 (Glazing Contractor)	APPROVED	08/28/2025	08/28/2026
Tosted Asphalt, Inc	Jose Perez	PO Box 27014, Fresno, CA, 93729	559-441-0137	559-441-0133	shayne@tostedasphalt.com	959499_	A (General Engineering Contractor), C-32 (Parking and Highway Improvement Contractor)	APPROVED	08/29/2025	08/29/2026
Touch Of Green Landscape Inc.	Javier Romo	1865 Herndon Ave, Clovis, CA, 93611	559-242-6352	559-314-6066	neomi@touchofgreenlandscape.us	1065123	C-27 (Landscaping Contractor)	APPROVED	09/05/2025	09/05/2026


Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
Tri-Signal Integration, Inc	Rett Hicks	28110 Avenue Stanford, Unit D, Santa Clarita, CA, 91355	818-581-2715	818-566-8580	Rett@tri-signal.com	758792_	C-10 (Electrical Contractor), C-16 (Fire Protection Contractor)	APPROVED	11/24/2025	11/24/2026
Triad Metal Constructors, LLC	Aaron Kincade	7783 N Ingram Suite 18, Fresno, CA, 93711	559-326-9817		accounting@triadmetalconstructors.com	1116840	C-43 (Sheet Metal Contractor)	APPROVED	10/29/2025	10/29/2026
Tricorp Group, Inc.	Krystall Smith	2540 Warren Drive, Ste. A, Rocklin, CA 95677	916-779-8010	916-779-8011	ksmith@tricorp-group.com	999443_	B (General Building Contractor), C-36 (Plumbing Contractor), C-61 (Limited Specialty)	APPROVED	08/22/2025	08/22/2026
UNLIMITED ENVIRONMENTAL INC	Jill Dupleich	9945 Pioneer Blvd, Santa Fe Springs, CA 90670	562-577-0861	562-912-4415	info@ueiteam.com	668511_	B (General Building Contractor), C-21 (Building Moving/Demolition Contractor), C-22 (Asbestos Abatement Contractor), HAZ (Hazardous Substance Removal Certification), ASB (Asbestos Certification)	APPROVED	08/25/2025	08/25/2026
Universal Coatings, Inc.	Leticia Maggard	5191 E Dakota Ave, Fresno, CA, 93771	559-233-6300	559-233-6200	leticia@universalcoatings.net	717507_	A (General Engineering Contractor), B (General Building Contractor), C-2 (Insulation and Acoustical Contractor), C-33 (Painting and Decorating Contractor), C-39 (Roofing Contractor), C-43 (Sheet Metal Contractor), ASB (Asbestos Certification), C-22 (Asbestos Abatement Contractor)	APPROVED	09/05/2025	09/05/2026
Universal Coatings, Inc.	Leticia Maggard	5191 E Dakota Ave, Fresno, CA, 93771	559-233-6300	559-233-6200	lisa@universalcoatings.net	717507_	A (General Engineering Contractor), B (General Building Contractor), C-2 (Insulation and Acoustical Contractor), C-33 (Painting and Decorating Contractor), C-39 (Roofing Contractor), C-43 (Sheet Metal Contractor), ASB (Asbestos Certification), C-22 (Asbestos Abatement Contractor)	REJECTED	08/26/2025	
Unlimited Telecom Inc	Carlos De Andas	2481 E Orangethorpe Ave. Fullerton CA 92831	714-886-6045		cdeandas@unlimitedtelecom.net	1006851	C-7 (Low Voltage Systems Contractor)	APPROVED	08/29/2025	08/29/2026
Unlimited Telecom Inc	Carlos De Andas	615 S State College Blvd , Fullerton , CA, 92831	714-886-6045		cdeandas@unlimitedtelecom.net	1006851	C-7 (Low Voltage Systems Contractor)	REJECTED	08/26/2025	

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
VLA Construction Inc	Veronique Loizu	22815 Ventura Blvd. #157, Woodland Hills, CA, 91364	818-225-1800	818-225-8112	vlainc@hotmail.com	1040399	B (General Building Contractor), C-33 (Painting and Decorating Contractor)	APPROVED	08/29/2025	08/29/2026
VLA Construction Inc	Veronique Loizu	22815 Ventura Blvd. #157, Woodland Hills, CA, 91364	818-225-1800	818-225-8112	vlainc@hotmail.com	1040399	B (General Building Contractor), C-33 (Painting and Decorating Contractor)	REJECTED	08/26/2025	
VMak Acoustics Inc. dba Cemco Acoustics	Tatyana Makovey	3355 Myrtle Ave #265	916-224-8859		accounting@cemcoacoustics.com	1054206	C-2 (Insulation and Acoustical Contractor)	APPROVED	08/26/2025	08/26/2026
Valley 29 Electric	Juan Flores	1027 Merced ST, newman, CA, 95360	209-756-5452		juan@valley29electric.co	1067696	C-10 (Electrical Contractor)	RETURNED		
Valley Construction Services, Inc.	Wes Eckhart	702 W FREMONT ST, STOCKTON, CA, 95203	209-684-9490		weckhart@vcsi.com	1108389	B (General Building Contractor)	APPROVED	04/02/2025	04/02/2026
Valley Unique Electric, Inc. dba Valley Unique Electric	Mark Worthington	75 Park Creek Dr, Clovis, CA, 93611	559-237-4795	559-237-4799	mark@valleyunique.com	464539_	C-10 (Electrical Contractor)	APPROVED	09/02/2025	09/02/2026
Vanden Bos Electric, Inc.	Patrick Burke	502 Giuseppe Court #5, Roseville, CA 95678	916-773-1500	916-773-1973	Pat@vdbelectric.com	627898_	C-10 (Electrical Contractor), C-7 (Low Voltage Systems Contractor), B (General Building Contractor)	APPROVED	08/26/2025	08/26/2026
Vanden Bos Electric, Inc.	Patrick Burke	502 Giuseppe Court #5, Roseville, CA 95678	916-773-1500	916-773-1973	Pat@vdbelectric.com	627898_	C-10 (Electrical Contractor), C-7 (Low Voltage Systems Contractor), B (General Building Contractor)	REJECTED	08/26/2025	
W. Bradley Electric, LLC	Joe Murphy	90 Hill Road, Novato, CA, 94945	415-898-1400	415-898-5991	vcarroll@wbeinc.com	1114449	C-10 (Electrical Contractor), B (General Building Contractor), A (General Engineering Contractor)	APPROVED	01/08/2026	01/08/2027
W. E. Lyons Construction Co.	Rebecca Boyd	1301 Ygnacio Valley Rd., Walnut Creek, CA, 94598	925-949-4655		rboyd.82@yahoo.com	180607_	A (General Engineering Contractor), B (General Building Contractor)	REJECTED	08/26/2025	

Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
WAGNER MECHANICAL INC	HEATHER STACK	11149 SHELTON ROAD, LINDEN, CA, 95236	209-463-0193	209-463-3460	hs_wagnermech@sbcglobal.net	507799_	C-4 (Boiler, Hot Water Heating and Steam Fitting Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-36 (Plumbing Contractor), C-38 (Refrigeration Contractor)	APPROVED	12/29/2025	12/29/2026
WESTECH SYSTEMS, LLC dba Soltek Solar	Tierra Pang	827 Jefferson Avenue, Clovis, CA, 93612	559-455-1720 x242	559-455-0952	tpang@westechsys.com	1072735	C-10 (Electrical Contractor), C-46 (Solar Contractor)	APPROVED	12/30/2025	12/30/2026
WILD ELECTRIC INCORPORATED	Mario Barragan	4626 E. Olive Avenue, Fresno, CA, 93702	559-251-7770	559-251-2372	estimating@wildelectric.net	500696_	C-10 (Electrical Contractor)	APPROVED	09/05/2025	09/05/2026
Western Allied Mechanical Inc.dba Dynamic Technical Solutions	Charissa Kolar	33210 Central Avenue, Union City, CA, 94506	650-444-8390	650-326-0750	ckolar@westernallied.com	826782_	B (General Building Contractor), C-20 (Warm-Air Heating, Ventilating and Air-Conditioning Contractor), C-36 (Plumbing Contractor)	APPROVED	02/10/2026	02/10/2027
Who Built Creative Builders, Inc. dba Creative Builders	Jana Gebhardt Fenk	P.O. Box 1568, Shafter, CA, 93263	707-763-6210	707-658-2513	jana@whobuilt.biz	808069_	A (General Engineering Contractor)	APPROVED	01/21/2026	01/21/2027
Wilkinson Electric Inc.	Desiree Wilkinson	210 South Sierra Ave. Ste 105. Oakdale, CA 95361	209-678-2161	209-336-5167	wilkinson.electric@yahoo.com	900558_	C-10 (Electrical Contractor)	REJECTED	08/26/2025	
Witbro Inc. DBA Seal Rite Paving and Grading	Brooke Ashjian	4237 W. Swift, Fresno, CA, 93722	559-222-7325	553-325-0760	bids@sealritepaving.com	805585_	A (General Engineering Contractor)	APPROVED	09/05/2025	09/05/2026
World Telecom & Surveillance, Inc.	Todd Westlund	2925 Innsbruck Drive	530-223-9753	530-223-9186	todd@wtands.com	793485_	C-7 (Low Voltage Systems Contractor)	APPROVED	09/05/2025	09/05/2026
World Telecom & Surveillance, Inc.	Todd Westlund	1819 Keystone Court, Redding, CA, 96003	530-223-9753	530-223-9186	todd@wtands.com	793485_	C-7 (Low Voltage Systems Contractor)	REJECTED	08/26/2025	
XIT INC DBA XIT SOLUTIONS	Craig May	1112 20th St, Bakersfield, CA 93301	661-635-0365		cmay@xitsolutions.com	1014012	C-7 (Low Voltage Systems Contractor), C-61 (Limited Specialty)	APPROVED	09/02/2025	09/02/2026
Yosemite Fire & Security	Ryan Hansen	PO Box 1493, North Fork, CA, 93643	559-760-4423		rhansen@yosemitefire.com	1051121	C-10 (Electrical Contractor), C-16 (Fire Protection Contractor)	APPROVED	03/26/2025	03/26/2026
ZAPIEN ELECTRIC, INC.	JOSEPH ZAPIEN	1917 FOUNDRY CT, Suite A, Ceres, CA, 95307	209-538-9050	209-538-9056	zapien@zapienelectric.com	792367_	C-10 (Electrical Contractor), C-38 (Refrigeration Contractor)	APPROVED	08/29/2025	08/29/2026


Company	Name	Address	Phone	Fax	Email	License Number	License Classifications	Status	Status Date	Expires
cws construction group inc	charlie slack	1301 Grant Ave, Suite B, Novato, CA 94945	415-599-6545	415-209-0228	charliejr.cws@gmail.com	811153_	A (General Engineering Contractor), B (General Building Contractor)	APPROVED	08/26/2025	08/26/2026

\\tetr-file1\Users\cesar.silva_TETR\Documents\13084-A-MCSD-260 K ST.IT WAREHOUSE_cesar.sil.rvt



KITCHEN - FLOOR PLAN

1/4" = 1'-0" | 14



KITCHEN - REFLECTED CEILING PLAN

1/4" = 1'-0" | 7

KEYNOTES 00.00

5.41	STAINLESS STEEL SHELF
5.42	STAINLESS STEEL BACKSPLASH
5.43	STAINLESS STEEL CORNER GUARDS
5.44	CUSTOM STAINLESS STEEL COUNTERS
5.45	STAINLESS STEEL HOOD
6.31	STORAGE CABINETS
7.29	OVERHEAD COILING DOOR
8.03	DOOR KICKPLATE
8.16	FOOD GRADE STAINLESS STEEL 6'-0" WIDE ROLL-UP SERVICE DOOR
9.64	FRP AS SCHEDULED, TYP., SEE SHEET A700
10.46	PAPER TOWEL DISPENSER
10.49	SOAP DISPENSER, WALL MOUNTED
11.11	CUSTOM STAINLESS STEEL COUNTERTOP OVER DISHWASHER
11.16	DISHWASHER UNDER COUNTERTOP WITH 208/3 PHASE POWER
23.06	EXHAUST HOOD WITH ANSUL SYSTEM, SEE MECHANICAL
23.07	FLY FAN, SEE MECHANICAL


LEGEND

201A — DOOR REFERENCE
SEE DOOR SCHEDULE ON SHEET A700


F.E. — BRACKET MOUNTED FIRE EXTINGUISHER, SEE 9 / K221-02
FIRE EXTINGUISHER - UL RATED TYPE 2A-K

FLOOR SINK, SEE PLUMBING

FD — FLOOR DRAIN, SEE PLUMBING




1 K200-02 KITCHEN - EAST ELEVATION 1
1/4" = 1'-0"




2 K200-02 KITCHEN - SOUTH ELEVATION
1/4" = 1'-0"

KITCHEN EQUIPMENT SCHEDULE


TAG #	DESCRIPTION	QUANTITY	MANUFACTURER	MODEL	MOUNTING DETAIL
KE-1	WORK TABLE W/ PREP SINK	1	BK RESOURCES	BKS-3-24-14-24T	2/K220-02
KE-2	DISHWASHER	1	HOBART	CUL	8/K220-02
KE-3	MOBILE WORK TABLE	4	CUSTOM	S/S	4/K220-02
KE-4	REFRIGERATORS	1	TRUE, INC.	STG3R-3S	8/K220-02
KE-5	FREZEER	1	TRAULSEN	G30010	8/K220-02
KE-6	36" RESTAURANT RANGE, GAS	1	GARLAND	G36-4G12R	8/K220-02
KE-7	OVEN	2	CRES COR	1000-CH-AL-2DE	8/K220-02
KE-8	HAND SINK W/ SOAP AND TOWEL DISPENSERS	2	IMC TEDDY	ADA-WS-2S	2/K220-02
KE-9	SELF-CONTAINED ICE MACHINE	1	KRATOS	69K-908	8/K220-02
KE-10	AQUA PATROL FILTRATION SYSTEM	1	SCOTSMAN	SSM2-P	2/K221-02




3 K200-02 KITCHEN - WEST ELEVATION 1
1/4" = 1'-0"



4 K200-02 KITCHEN - NORTH ELEVATION
1/4" = 1'-0"



5 K200-02 KITCHEN - WEST ELEVATION
1/4" = 1'-0"



6 K200-02 KITCHEN - EAST ELEVATION 2
1/4" = 1'-0"

GENERAL NOTES

A. FIRE EXTINGUISHER TO BE: CLASS K MIN. PER CFC 906.4, ONE FOR EVERY 3,000 S.F. OR PORTION THEREOF & TRAVEL DISTANCE NOT TO EXCEED 75'-0".

B. ALL DIMENSIONS TO FACE OF STUD, U.N.O. DIMENSIONS WITH "MIN.","CLR.", ARE MEASURED FROM FACE OF WALL FINISH.

C. TYP. INTERIOR WALL FINISH FOR STUD WALLS: 5/8" TYPE 'X' GYP. BD., WATER RESISTANT TYPE IN RESTROOMS WHERE LOCATED WITHIN 2'-0" OF THE FRONT AND/OR SIDES OF PLUMBING FIXT. GYP. BD. APPLICATION SHALL COMPLY w/ CBC SECTION 2508. GYP. BD. SHALL BE FASTENED TO SUPPORTS w/ SCREWS.

D. FOR TYPICAL ACCESSIBLE DOOR MANEUVERING CLEARANCES, SEE DETAIL 8/K221-02

E. FOR ACCESSIBLE SINK KNEE/TOE SPACE, SEE DETAIL 11/A900-02

F. FOR ACCESSIBLE WORK SURFACE KNEE/TOE SPACE, SEE DETAIL 11/A900-02

G. CONTRACTOR SHALL PATCH, REPAIR OR REPLACE ANY ADJACENT WORK (WALL, CEILING, FLOOR SURFACES, ETC.) THAT IS DAMAGED, REMOVED AND/OR DEMOLISHED DURING THE COURSE OF CONSTRUCTION. SEE SPECIFICATION REQUIREMENTS FOR CUTTING & PATCHING.

H. ALL WORK WITHIN OR ON EXISTING WALLS SHALL BE PATCHED TO MATCH THE ADJACENT EXISTING CONDITIONS, INCLUDING BUT NOT LIMITED TO ALL DEMOLITION REQUIRED TO PROPERLY INSTALL PROPOSED IMPROVEMENTS (STRUCTURAL, MECHANICAL, PLUMBING, ELECTRICAL, ETC.).

a. SEE SPECIFICATIONS FOR ADDITIONAL INFORMATION REGARDING CUTTING & PATCHING REQUIREMENTS.

b. COORDINATE WITH RESPECTIVE TRADES FOR THE EXTENT OF DEMOLITION AND PATCHBACK REQUIRED TO PROPERLY INSTALL PROPOSED IMPROVEMENTS.

I. ALL NEW AND EXISTING FLOOR SUBSTRATES ARE TO BE CLEANED, PATCHED, REPAIRED, LEVELED, AND PREPARED AS REQUIRED BY FLOORING FINISH MANUFACTURER RECOMMENDATIONS FOR FLOORING FINISH SYSTEM SCHEDULED.

J. ALL MANUFACTURER REQUIRED AND/OR RECOMMENDED TESTING, CORRECTIVE MEASURES, AND PREPARATIONS WITH REGARD TO THE EXISTING CONCRETE SLAB, INCLUDING PATCHED AREAS, SHALL BE INCLUDED AND PERFORMED.

IDENTIFICATION STAMP
DIV. OF THE STATE ARCHITECT
APP: 02-123377 INC: 02
REVIEWED FOR
SS ☑ FLS ☑ ACS ☑
DATE: 01/08/2026

Teter, Inc., expressly reserves its common law copyright and other property rights in these plans. This document, the ideas and designs incorporated herein, as an instrument of professional service, is not to be used in whole or in part, for any other project without prior written authorization.

MARK	DATE	DESCRIPTION
	12/22/25	INC. 02 DSA SUBMITTAL

LICENSED ARCHITECT CHRISTOPHER NIKKEL C-34253 REGISTERED PROFESSIONAL STATE OF CALIFORNIA

TETER, INC.
ARCHITECTS ENGINEERS CONNECTED
FRESNO HEADQUARTERS
VISALIA | BAKERSFIELD | MODESTO | SAN LUIS OBISPO

TETER

26TH STREET MARS/ELO-P FACILITY
MERCED CITY SCHOOL DISTRICT
2600 K STREET INCREMENT 02
MERCED, CA 95348

DRAWING TITLE
ENLARGED KITCHEN PLAN AND INTERIOR ELEVATIONS

PROJECT NO.
24-13084.00

DRAWING
K200-02

PLOT DATE: 12/19/2025 11:19:52 AM

ADDENDUM NO. 2

BK RESOURCES

5" Riser Tables

16 Ga. Stainless Steel Riser Tables



Use your smart phone to scan the above QR code to visit our website: www.bk-resources.com

Certifications:

NSF

Features:

- Two (2) Sound Deadened 2" Rectangular Steel Tubing to Reinforce and Maintain Level Working Surface
- Legs 1 5/8" Diameter
- 5" Riser
- 84" & 96" Have 6 Legs

Material:

CVTR5 Series: S/S w/ Stainless Steel Legs & Undershelf

- T-304 16 ga. Stainless Steel Top
- Stainless Steel Legs & Adjustable Undershelf
- Adjustable Stainless Steel Feet


Options:


- Single & Double Overshelves
- Drawer Assemblies
- Casters
- Upgraded Bullet Feet
- Extra Shelves
- Adjustable Table Mount Pot Rack

CVTR5 Series


S/S w/ S/S Legs & Undershelf

Length	T-304 S/S 30" Width	Product Weight (lbs)	T-304 S/S 24" Width	Product Weight (lbs)
24"	-	-	CVTR5-2424	-
30"	-	-	CVTR5-3024	-
36"	CVTR5-3630	66.00	CVTR5-3624	-
48"	CVTR5-4830	88.00	CVTR5-4824	-
60"	CVTR5-6030	105.00	CVTR5-6024	-
72"	CVTR5-7230	122.00	CVTR5-7224	-
84"	CVTR5-8430	146.00	CVTR5-8424	132.00
96"	CVTR5-9630	162.00	CVTR5-9624	-





TABLES 7 FT. AND LARGER ARE FURNISHED WITH SIX (6) LEGS



PRODUCT DATA SHEET

BK RESOURCES



4 Shelf Dry Storage Adjustable Stainless Steel Shelving Unit 67"x24"x6'

Item No. VSU6-6724

Dry Storage Shelving Unit • 67"L x 24"W x 72"H • (4) Adjustable Shelves • Galvanized Shelves And Legs • With Adjustable Bullet Feet

› Read full description

☐ Compare product

+ Hover to zoom | Click to enlarge



This website uses cookies to enhance your experience. I AGREE

›Print preview

Attention California Consumers: CA Prop #65 Warning

DESCRIPTION SPECIFICATIONS DOCUMENTS

No.	VSU6-6724
Category	Shelving & Storage
Sub-Category	Dry Storage
Product Width	24"
Product Length	67"
Product Height	72"
Material	Galvanized Steel
Truckline Only	Yes
Warranty Length	1 Year
Gross Weight	121.64

This website uses cookies to enhance your experience.

LAST VIEWED PRODUCTS

View all Clear



12" X 96" Stainless Steel T-304 18 Ga Wall Shelf

Item No. BKWS-1296



36" Wall Cabinet w/ Hinged Doors Lock & Adjustable Shelf

Item No. BKWCH-1536HL



18" X 72" 14 Ga Type 304 Stainl Steel Dish Cabi

Item No. BKDC-

SITEMAP

© Copyright 2025 BK Resources. All rights reserved.

This website uses cookies to enhance your experience.

ADDENDUM NO. 2

Wall Shelves

Stainless Steel Wall Shelves

Use your smart phone to scan the above QR code to visit our website: www.bk-resources.com

Certifications:

NSF



Features:

- Available in Depths of 12" and 16"
- 1 1/2" Backsplash

Material:

BKWS Series: Premium Wall Shelves

- T-304 18 ga. Stainless Steel
- Wall Screws are 1/4"-14 x 2"

BKWSE Series: Economy Wall Shelves

- T-430 18 ga. Stainless Steel
- Wall Screws are 1/4"-14 x 2"

BKWS Series: Premium T-304 Wall Shelves


Length	T-304 S/S 12" Width	Product Weight (lbs)	*Shelf Capacity	T-304 S/S 16" Width	Product Weight (lbs)	*Shelf Capacity
24"	BKWS-1224	9.00	210	BKWS-1624	12.00	255
30/32"	BKWS-1230	10.00	220	BKWS-1630	13.00	220
36"	BKWS-1236	11.50	230	BKWS-1636	15.00	300
48"	BKWS-1248	13.00	255	BKWS-1648	18.00	345
60"	BKWS-1260	17.00	285	BKWS-1660	21.00	395
72"	BKWS-1272	21.00	315	BKWS-1672	27.00	445
84"	BKWS-1284	23.00	340	BKWS-1684	29.00	505
96"	BKWS-1296	26.00	365	BKWS-1696	34.00	550


BKWSE Series: Economy T-403 Wall Shelves

T-430 S/S 12" Width	Product Weight (lbs)	*Shelf Capacity	T-430 S/S 16" Width	Product Weight (lbs)	*Shelf Capacity	# of Support Brackets
BKWSE-1224	8.00	210	BKWSE-1624	11.50	255	2
BKWSE-1232	10.00	220	BKWSE-1632	13.50	225	2
BKWSE-1236	11.00	230	BKWSE-1636	14.50	300	2
BKWSE-1248	13.50	255	BKWSE-1648	26.00	345	2
BKWSE-1260	17.00	285	BKWSE-1660	24.00	395	2
BKWSE-1272	21.00	315	BKWSE-1672	27.00	445	3
BKWSE-1284	23.00	340	BKWSE-1684	30.00	505	3
BKWSE-1296	26.00	365	BKWSE-1696	39.00	550	3


12" Depth Dimensions


** Weight must be evenly distributed*





16" Depth Dimensions





PRODUCT DATA SHEET

BK RESOURCES