

MONTGOMERY COUNTY
PERMIT DEPARTMENT



DEVELOPMENT PERMIT

This notice confirms that the Montgomery County, Texas Permit Department has issued this non-transferable

Onsite Sewage Authorization to Construct Permit

to **EATON, ROBERT** on **02/05/2026**

authorizing **WILLIS INDEPENDENT SCHOOL DISTRICT** to proceed
 with the installation of a **SURFACE APPLICATION** onsite sewage facility at the following described property:

WISD TRANSPORTATION CENTER

17980 TX 75 , WILLIS , Texas 77378

BEING 41.938AC REC IN MCCF #: 2023014449

- ▶ The requirements for the onsite sewage facility are based on the site evaluation performed by **TURNER, HEATH A** on **2025-08-12**.
- ▶ Ground water **Was Not** encountered.

41.938 Acres | 0.041 Application Rate

Water System Type:

MINIMUM REQUIREMENTS

Max GPD 1790 Minimum Discharge Field Area Required **43659 SF** designed by **Turner, Heath**

- ▶ The construction, installation, or substantial modification of a private sewage facility shall be made in accordance with the approved design and requirements of the Permit to Construct. Any changes to specified equipment or GPD WILL REQUIRE OFFICE APPROVAL PRIOR TO INSPECTION. A maintenance agreement is required prior to inspection. Licensed installer or apprentice must be on-site for inspection.
- ▶ This Authorization to Construct expires **02/05/2027** Expired AtCs require re-application. Must pass final inspection to obtain a Notice of Approval.

LeeAnne Kincer *D Reed*

Scott Nichols

ATC By : LeeAnne Kincer OS0036765, Darrell Reed OS0008431

501 North Thompson, Suite 100, Conroe, Texas 77301

936-539-7836 | info.permits@mctx.org

Scott Nichols

Director, Permit Department