

| | |
|---|--|
| Facility or Building Name | Sullivan/Anishinabe Middle School |
| Did the facility test using the MDH testing program (WIIN)? | No |
| Facility Type (School or Child Care) | School |
| School ID Number or Child Care License Number | 0001-03-193 |
| Facility or Building Address | 3100 E 28th St , Minneapolis, MN 55406 |
| Mailing Address | 1225 North 7th Street Minneapolis, |
| Contact Person | Lee Setter |
| Title | Manager, EH&S |
| Phone | 612-668-0308 |
| Email | Lee.Setter@mpls.k12.mn.us |

| SUMMARY | ANSWER |
|---|---------|
| Total number of samples | 50 |
| Total number of fixtures sampled | 50 |
| Total number of results above 5 ppb | 0 |
| Total number of remediation actions | 0 |
| Next Scheduled Sampling Date (Month/Year) | 12/2030 |

| Unique Sample Site Identification | Fixture Type | Location Description | Fixture Status | Sample Collection Type | Laboratory Identification Number | Date/Time Collected | Date/Time Analyzed | Numeric Result | Unit of Measure | Name of Laboratory Used For Analysis | Remediation Action | Other Remediation Please | Was Remediation Successful (ie. Follow-up testing below 5 | Additional Notes or Comments |
|-----------------------------------|-------------------|------------------------|----------------------|------------------------|----------------------------------|---------------------|--------------------|----------------|-----------------|--------------------------------------|--------------------|--------------------------|---|------------------------------|
| 0001-03-193-01 | Bottle Filler | J037-Drinking Fountain | Active - Consumption | Initial - First Draw | 25-15364 | 12/19/2025 4:15 | 16/2026 9:23 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-02 | Drinking Fountain | G7-093 | Active - Consumption | Initial - First Draw | 25-15365 | 12/19/2025 4:15 | 16/2026 9:29 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-03 | Sink | Faculty Room 103 | Active - Consumption | Initial - First Draw | 25-15366 | 12/19/2025 4:17 | 16/2026 9:35 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-04 | Drinking Fountain | 104 | Active - Consumption | Initial - First Draw | 25-15367 | 12/19/2025 4:18 | 16/2026 9:41 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-05 | Drinking Fountain | 106 | Active - Consumption | Initial - First Draw | 25-15368 | 12/19/2025 4:19 | 16/2026 9:48 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-06 | Bottle Filler | 108-DF | Active - Consumption | Initial - First Draw | 25-15369 | 12/19/2025 4:20 | 16/2026 9:54 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-07 | Drinking Fountain | 109 | Active - Consumption | Initial - First Draw | 25-15370 | 12/19/2025 4:22 | 16/2026 10:00 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-08 | Drinking Fountain | 110 | Active - Consumption | Initial - First Draw | 25-15371 | 12/19/2025 4:23 | 16/2026 10:18 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-09 | Drinking Fountain | GT113 | Active - Consumption | Initial - First Draw | 25-15372 | 12/19/2025 4:24 | 16/2026 10:38 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-10 | Drinking Fountain | BT-117 | Active - Consumption | Initial - First Draw | 25-15373 | 12/19/2025 4:24 | 16/2026 10:42 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-11 | Drinking Fountain | 112 | Active - Consumption | Initial - First Draw | 25-15374 | 12/19/2025 4:25 | 16/2026 10:48 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-12 | Drinking Fountain | 118 | Active - Consumption | Initial - First Draw | 25-15375 | 12/19/2025 4:26 | 16/2026 10:54 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-13 | Drinking Fountain | 120 | Active - Consumption | Initial - First Draw | 25-15376 | 12/19/2025 4:27 | 16/2026 11:00 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-14 | Drinking Fountain | 122 | Active - Consumption | Initial - First Draw | 25-15377 | 12/19/2025 4:28 | 16/2026 11:06 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-15 | Drinking Fountain | 124 | Active - Consumption | Initial - First Draw | 25-15378 | 12/19/2025 4:28 | 16/2026 11:12 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-16 | Drinking Fountain | 126 | Active - Consumption | Initial - First Draw | 25-15379 | 12/19/2025 4:29 | 16/2026 11:18 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-17 | Drinking Fountain | 128 | Active - Consumption | Initial - First Draw | 25-15380 | 12/19/2025 4:30 | 16/2026 11:24 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-18 | Drinking Fountain | 130 | Active - Consumption | Initial - First Draw | 25-15381 | 12/19/2025 4:32 | 16/2026 11:45 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-19 | Drinking Fountain | GT-123 | Active - Consumption | Initial - First Draw | 25-15382 | 12/19/2025 4:33 | 16/2026 12:03 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-20 | Bottle Filler | BT-135 | Active - Consumption | Initial - First Draw | 25-15383 | 12/19/2025 4:34 | 16/2026 12:09 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-21 | Sink | Kitchen Dish Wash | Active - Consumption | Initial - First Draw | 25-15384 | 12/19/2025 4:35 | 16/2026 12:15 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-22 | Sink | Kitchen Food Prep | Active - Consumption | Initial - First Draw | 25-15385 | 12/19/2025 4:36 | 16/2026 12:21 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-23 | Drinking Fountain | Gym 406 | Active - Consumption | Initial - First Draw | 25-15386 | 12/19/2025 4:37 | 16/2026 12:27 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-24 | Drinking Fountain | Gym 405 | Active - Consumption | Initial - First Draw | 25-15387 | 12/19/2025 4:39 | 16/2026 12:33 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-25 | Drinking Fountain | Gym 403 | Active - Consumption | Initial - First Draw | 25-15388 | 12/19/2025 4:40 | 16/2026 12:39 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-26 | Drinking Fountain | Gym 402 | Active - Consumption | Initial - First Draw | 25-15389 | 12/19/2025 4:42 | 16/2026 12:45 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-27 | Drinking Fountain | RM085-Nurse Office | Active - Consumption | Initial - First Draw | 25-15390 | 12/19/2025 4:43 | 16/2026 12:51 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-28 | Drinking Fountain | GT201 | Active - Consumption | Initial - First Draw | 25-15391 | 12/19/2025 4:45 | 16/2026 12:53 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-29 | Bottle Filler | BT207 | Active - Consumption | Initial - First Draw | 25-15392 | 12/19/2025 4:47 | 16/2026 12:59 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-30 | Sink | 200E-Lounge | Active - Consumption | Initial - First Draw | 25-15393 | 12/19/2025 4:49 | 16/2026 13:17 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-31 | Drinking Fountain | 208 | Active - Consumption | Initial - First Draw | 25-15394 | 12/19/2025 4:51 | 16/2026 13:35 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-32 | Drinking Fountain | 210 | Active - Consumption | Initial - First Draw | 25-15395 | 12/19/2025 4:54 | 16/2026 13:41 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-33 | Drinking Fountain | 212 | Active - Consumption | Initial - First Draw | 25-15396 | 12/19/2025 4:56 | 16/2026 13:47 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-34 | Bottle Filler | 213-BF | Active - Consumption | Initial - First Draw | 25-15397 | 12/19/2025 4:57 | 16/2026 13:53 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-35 | Drinking Fountain | 214 | Active - Consumption | Initial - First Draw | 25-15398 | 12/19/2025 4:59 | 16/2026 13:59 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-36 | Drinking Fountain | 215 | Active - Consumption | Initial - First Draw | 25-15399 | 12/19/2025 5:03 | 16/2026 14:05 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-37 | Drinking Fountain | 216 | Active - Consumption | Initial - First Draw | 25-15400 | 12/19/2025 5:05 | 16/2026 14:11 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-38 | Drinking Fountain | 217 | Active - Consumption | Initial - First Draw | 25-15401 | 12/19/2025 5:08 | 16/2026 14:17 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-39 | Drinking Fountain | 218 | Active - Consumption | Initial - First Draw | 25-15402 | 12/19/2025 5:08 | 16/2026 14:23 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-40 | Drinking Fountain | 219 | Active - Consumption | Initial - First Draw | 25-15403 | 12/19/2025 5:10 | 16/2026 14:26 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-41 | Drinking Fountain | 220 | Active - Consumption | Initial - First Draw | 25-15404 | 12/19/2025 5:11 | 16/2026 14:32 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-42 | Drinking Fountain | 222 | Active - Consumption | Initial - First Draw | 25-15405 | 12/19/2025 5:13 | 16/2026 14:38 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-43 | Drinking Fountain | GT233 | Active - Consumption | Initial - First Draw | 25-15406 | 12/19/2025 5:14 | 16/2026 14:44 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-44 | Drinking Fountain | GT235 | Active - Consumption | Initial - First Draw | 25-15407 | 12/19/2025 5:16 | 16/2026 14:50 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-45 | Drinking Fountain | GT247 | Active - Consumption | Initial - First Draw | 25-15408 | 12/19/2025 5:18 | 16/2026 14:56 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-46 | Drinking Fountain | BT253 | Active - Consumption | Initial - First Draw | 25-15409 | 12/19/2025 5:20 | 16/2026 15:02 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-47 | Bottle Filler | GT-247 | Active - Consumption | Initial - First Draw | 25-15410 | 12/19/2025 5:22 | 16/2026 15:08 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-48 | Drinking Fountain | GT271 | Active - Consumption | Initial - First Draw | 25-15411 | 12/19/2025 5:28 | 16/2026 15:43 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-49 | Sink | 064-Break Room | Active - Consumption | Initial - First Draw | 25-15412 | 12/19/2025 5:29 | 16/2026 15:49 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |
| 0001-03-193-50 | Drinking Fountain | GT-077/BT-079 | Active - Consumption | Initial - First Draw | 25-15413 | 12/19/2025 5:30 | 16/2026 15:55 | ND | µg/L | Twin City Water Clinic, Inc. | | | | |

Definitions of Reporting Fields

| Field Name | Response Needed or Definition | Where does this information come from? |
|--|--|--|
| Unique Sample Site Identification Number | A unique number or code using numbers and or letters that a facility assigns to each fixture in the building. This prevents confusion about which sample goes with which fixture. | Facility |
| Fixture Type | Describes the type of fixture such as sink, fountain, bottle filler, ice machine, kitchen kettle, coffee machine, etc.. | Facility |
| Location Description | Specific description of the location of the fixture. Ex. Classroom sink in Room 112 or Left drinking fountain in gym | Facility |
| Fixture Status | Describes if the fixture is currently being used and how it is used. Examples are Active-Consumption, Inactive-Consumption, Active-Nonconsumption, Inactive-Nonconsumption | Facility |
| Sample Collection Type | Initial first draw, Initial Flushed, Follow-up First Draw, Follow-up Flushed, Other | Facility |
| Laboratory Identification Number | Number assigned by the laboratory to each sample. It may be helpful for facilities using this spreadsheet to cross reference to their lab results. (Optional) | Lab |
| Date/Time Collected | Date and time the sample was collected Ex. 2/12/2024 7:03 PM or 3/8/24 13:02 | Lab |
| Date/Time Analyzed | Date and time the sample was analyzed Ex. 2/12/2024 7:03 PM or 3/8/24 13:02 | Lab |
| Numeric Result | This is the number representing the result reported by the lab. Ex. 5.12, 7.03, 89.02, for results that are not detected please use ND | Lab |
| Unit of Measure | This is the unit of the result reported by the lab Ex. Parts per billion (ppb), micrograms per liter (ug/L). | Lab |
| Name of Laboratory Used For Analysis | The name of the laboratory used for sample analysis. | Lab |
| Remediation Action | Describes the type of remediation (if needed). Select from drop down menu. You only need to complete if result is 5ppb or more. If the action you took is not listed select OTHER and describe | Facility |
| Other Remediation-Please Describe | Use this field to type in your remediation action if the choice was not listed in the Remediation Action Drop down menu. | Facility |
| Was Remediation Successful (ie. Follow-up) | Select from the drop down. Options are Yes, No, Not Applicable(N/A), and Pending Results | Facility |

| Other Important Terms | Definitions |
|-----------------------|--|
| Consumption | For the purposes of this testing consumption means a fixture where the water is used for drinking water or food/formula preparation. |
| Non-Consumption | A fixture that is not used for drinking water or food preparation such as a laboratory sink or a mop sink in a locked custodial closet. MDH recommends that non-consumption fixtures be labeled as not for drinking if they are not tested. |
| Active | A fixture currently able to be used. |
| Inactive | A fixture that has been taken out of service either temporarily or permanently |
| First Draw | A type of water sample where the water has been stagnant for 8-18 hours before collecting a sample. The most common type of lead sample type. |
| Flushed | A type of water sample where the water has been allowed to run before collecting. Typically collected when investigating to source of lead or evaluating remediation options. |
| Initial | This is typically a first draw sample collected during a round of monitoring. A sample may be an initial-first draw or an initial-flushed |
| Follow-up | This is typically collected if an initial sample collected during a round of sampling is 5ppb or more. Follow-up samples can be repeated first draw samples or flushed samples depending on the type of follow-up activities conducted to reduce lead. |