



Charles County Public Schools
P.O. Box 2770
5980 Radio Station Road
La Plata, MD 20646
Attention:

Tuesday, February 17, 2026
Certificate of Analysis
FINAL

Project Information:

Report for Lab No: 86005.

First Draw samples flushed by Martel on October 15, 2025 sampled by Martel on October 16, 2025.

Project Identification: MD HB 270

School: J.P. Ryon ES

References and Important Notes:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act. Metal analysis performed by Maryland Spectral Services, Inc. for Martel Laboratories JDS, Inc,

* Indicates result(s) greater than 5.5 ug/l - regulatory limit for these samples.

Notices:

Chain of Custody Form(s) are attached and are an integral part of this report.
This report will be retained for at least five years and will be disposed of without notice.
Measurement uncertainty for each listed test is available upon request.
The results presented herein relate only to the samples or items tested.
All samples tested were in acceptable condition, unless otherwise noted.



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
86005	000001	JPRES-1-FC Kitchen - Left Fixture on 3 Comp Sink Sink - Left	10/15/2025 04:10			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
86005	000002	JPRES-2-FC Kitchen - Right Fixture on 3 Comp Sink Sink - Rig	10/15/2025 04:10			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
86005	000003	JPRES-3-IM kitchen Ice Machine	10/15/2025 04:10			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
86005	000004	JPRES-4-FC kitchen sink sink next to ice maker	10/15/2025 04:10			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	1.08	ug/l	EPA 200.8	2	02/03/2026 MSS	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
86005	000005	JPRES-5-FC kitchen 2 comp sink sink	10/15/2025 04:10			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	2.88	ug/l	EPA 200.8	2	02/03/2026 MSS	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
86005	000006	JPRES-6-FC kitchen sink sink	10/15/2025 04:10			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	1.63	ug/l	EPA 200.8	2	02/03/2026 MSS	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
86005	000007	JPRES-7-DC corridor water fountain on left	10/15/2025 04:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS	



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
86005 000008	JPRES-8-DC corridor water fountain on right				10/15/2025 04:19
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
86005 000009	JPRES-13-DC corridor water fountain				10/15/2025 04:20
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
86005 000010	JPRES-26-DC corridor water fountain				10/15/2025 04:22
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
86005 000011	JPRES-31-DC corridor Water Fountain				10/15/2025 04:25
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.15	ug/l	EPA 200.8	2	02/03/2026 MSS

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
86005 000012	JPRES-38-FC Classroom 149 - Pre-K sink - Right				10/15/2025 05:06
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
86005 000013	JPRES-39-DB Classroom 149 - Pre-K bubbler				10/15/2025 05:06
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
86005 000014	JPRES-40-FC Classroom 149 - Pre-K sink - Left				10/15/2025 05:06
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.77	ug/l*	EPA 200.8	2	02/03/2026 MSS



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
86005 000015	JPRES-43-DC corridor water fountain	10/15/2025 04:30			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS
86005 000016	JPRES-46-FC Classroom 148 - Pre-K sink - Left	10/15/2025 05:04			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS
86005 000017	JPRES-47-DB Classroom 148 - Pre-K bubbler	10/15/2025 05:04			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS
86005 000018	JPRES-48-FC Classroom 148 - Pre-K sink - Right	10/15/2025 05:04			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	1.22	ug/l	EPA 200.8	2	02/03/2026 MSS
86005 000019	JPRES-49-FC Classroom 147 - Pre-K sink on left	10/15/2025 05:02			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.01	ug/l	EPA 200.8	2	02/03/2026 MSS
86005 000020	JPRES-50-DB Classroom 147 - Pre-K bubbler on left	10/15/2025 05:02			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS
86005 000021	JPRES-51-FC Classroom 147 - Pre-K sink on right	10/15/2025 05:02			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
86005	000022	JPRES-52-DB Classroom 147 - Pre-K bubbler on right			10/15/2025 05:02
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
86005	000023	JPRES-53-FC Classroom 142 - 1 sink			10/15/2025 04:45
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	1.14	ug/l	EPA 200.8	2	02/03/2026 MSS

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
86005	000024	JPRES-54-DB Classroom 142 - 1 bubbler			10/15/2025 04:45
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
86005	000025	JPRES-55-FC Classroom 141 - 1 sink			10/15/2025 04:44
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	1.91	ug/l	EPA 200.8	2	02/03/2026 MSS

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
86005	000026	JPRES-56-DB Classroom 141 - 1 bubbler			10/15/2025 04:44
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
86005	000027	JPRES-57-FC Classroom 140 - 1 sink			10/15/2025 04:42
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
86005	000028	JPRES-58-DB Classroom 140 - 1 bubbler			10/15/2025 04:42
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS



MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
86005	000029	JPRES-59-FC Classroom 139 - 1 sink				10/15/2025 04:40	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial		
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS		

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
86005	000030	JPRES-60-DB Classroom 139 - 1 bubbler				10/15/2025 04:40	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial		
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS		

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
86005	000031	JPRES-61-FC Classroom 138 - 1 sink				10/15/2025 04:38	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial		
Lead	1.5	ug/l	EPA 200.8	2	02/03/2026 MSS		

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
86005	000032	JPRES-62-DB Classroom 138 - 1 bubbler				10/15/2025 04:38	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial		
Lead	46.9	ug/l*	EPA 200.8	2	02/03/2026 MSS		

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
86005	000033	JPRES-63-DC corridor water fountain on left				10/15/2025 04:36	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial		
Lead	4.48	ug/l	EPA 200.8	2	02/03/2026 MSS		

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
86005	000034	JPRES-64-DC corridor water fountain on right				10/15/2025 04:36	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial		
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS		

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
86005	000035	JPRES-69-FC Classroom 134 - Pre-K sink - Left				10/15/2025 04:33	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial		
Lead	1.59	ug/l	EPA 200.8	2	02/03/2026 MSS		



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
86005	000036	JPRES-72-FC Classroom 130 (Sp-Ed) Life Skills sink				10/15/2025 04:28
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
86005	000037	JPRES-73-DB Classroom 130 (Sp-Ed) Life Skills bubbler				10/15/2025 04:28
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
86005	000038	JPRES-80-DC corridor water fountain on left				10/15/2025 04:25
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
86005	000039	JPRES-81-DC corridor water fountain on right				10/15/2025 04:25
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
86005	000040	JPRES-84-DC corridor water fountain				10/15/2025 04:12
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
86005	000041	JPRES-85-FC staff lounge sink				10/15/2025 04:15
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
86005	000042	JPRES-86-FC nurse office sink				10/15/2025 04:13
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS	



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
86005	000043	JPRES-87-BU Corridor Bottle Filler	10/15/2025 04:12			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
86005	000044	JPRES-88-BU Corridor Bottle Filler	10/15/2025 04:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
86005	000045	JPRES-89-FC Classroom A101 - K sink	10/15/2025 04:52			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	1.22	ug/l	EPA 200.8	2	02/03/2026 MSS	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
86005	000046	JPRES-90-DB Classroom A101 - K bubbler	10/15/2025 04:52			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
86005	000047	JPRES-91-FC Classroom A103 - K sink	10/15/2025 04:59			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
86005	000048	JPRES-92-DB Classroom A103 - K bubbler	10/15/2025 04:59			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
86005	000049	JPRES-93-FC Classroom A105 - K sink	10/15/2025 04:58			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS	



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
86005	000050	JPRES-94-DB Classroom A105 - K bubbler	10/15/2025 04:58			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
86005	000051	JPRES-95-FC Classroom A104 - K sink	10/15/2025 04:56			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
86005	000052	JPRES-96-DB Classroom A104 - K bubbler	10/15/2025 04:56			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
86005	000053	JPRES-97-FC Classroom A102 - K sink	10/15/2025 04:54			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	1.89	ug/l	EPA 200.8	2	02/03/2026 MSS	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
86005	000054	JPRES-98-DB Classroom A102 - K bubbler	10/15/2025 04:54			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
86005	000055	JPRES-99-FC Classroom A104 - Activity sink	10/15/2025 04:50			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
86005	000056	JPRES-100-D Classroom A104 - Activity bubbler	10/15/2025 04:50			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	1.06	ug/l	EPA 200.8	2	02/03/2026 MSS	



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
86005 000057	JPRES-101-D corridor water fountain on left	10/15/2025 04:49			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
86005 000058	JPRES-102-D corridor water fountain on right	10/15/2025 04:49			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
86005 000059	JPRES-103-B Corridor Bottle Filler	10/15/2025 04:49			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
86005 000060	JPRES-1F-FC Kitchen - Left Fixture on 3 Comp Sink Sink - Lef	10/15/2025 04:15			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
86005 000061	JPRES-2F-FC Kitchen - Right Fixture on 3 Comp Sink Sink - Ri	10/15/2025 04:15			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
86005 000062	JPRES-4F-FC kitchen sink sink next to ice maker	10/15/2025 04:15			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
86005 000063	JPRES-5F-FC kitchen 2 comp sink sink	10/15/2025 04:15			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	1.57	ug/l	EPA 200.8	2	02/03/2026 MSS

MARTEL NO. 86005	000064	CLIENT SAMPLE IDENTIFICATION JPRES-6F-FC kitchen sink sink				Sample Date/Time 10/15/2025 04:15
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS

MARTEL NO. 86005	000065	CLIENT SAMPLE IDENTIFICATION JPRES-86F-F nurse office sink				Sample Date/Time 10/15/2025 04:10
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<1.00	ug/l	EPA 200.8	2	02/03/2026 MSS

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Charles County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Sample Start Date/Time: 10/16/25 4:10am End Date/Time: 10/16/25 5:14am

Sampler/Relinquished By: Nellie Smith Received at Martel by: [Signature] Date/Time: 10/17/25

First Draw
14 J.P. Ryon Elementary School

12140 Vivian Adams Drive Waldorf, MD 20601

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 10 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

86005

Martel #	Sample #	Location ID #	Fixture Type (Sink, bubbler, Water Fountain, Geosneck, Ice Machine, Hose Bibb)	Outlet Key Codes	Room/Location	Consumption C or NC?	Flush	Sample Time
							Flush Date	
1	1	JPRES-1-FC	Sink - Left fixture	FC	Kitchen - Left fixture on 3 Comp Sink	C	10/15	4:10
2	2	JPRES-2-FC	Sink - Right fixture	FC	Kitchen - Right fixture on 3 Comp Sink	C	↓	
3	3	JPRES-3-IM	Ice Machine	IM	kitchen	C		
4	4	JPRES-4-FC	sink next to ice maker	FC	kitchen sink	C		
5	5	JPRES-5-FC	sink	FC	kitchen 2 comp sink	C		
6	6	JPRES-6-FC	sink	FC	kitchen sink	C		
7	7	JPRES-7-DC	water fountain on left	DC	corridor	C		4:19
8	8	JPRES-8-DC	water fountain on right	DC	corridor	C		4:19
9	13	JPRES-13-DC	water fountain	DC	corridor	C		4:20
10	26	JPRES-26-DC	water fountain	DC	corridor	C		4:22
11	31	JPRES-31-DC	Water Fountain	DC	corridor	C		4:25
12	38	JPRES-38-FC	sink - Right	FC	Classroom 149 - Pre-K	C		5:06
13	39	JPRES-39-DB	bubbler	DB	Classroom 149 - Pre-K	C		↓
14	40	JPRES-40-FC	sink - Left	FC	Classroom 149 - Pre-K	C		
15	43	JPRES-43-DC	water fountain	DC	corridor	C		4:30
16	46	JPRES-46-FC	sink - Left	FC	Classroom 148 - Pre-K	C		5:04
17	47	JPRES-47-DB	bubbler	DB	Classroom 148 - Pre-K	C		↓
18	48	JPRES-48-FC	sink - Right	FC	Classroom 148 - Pre-K	C		
19	49	JPRES-49-FC	sink on left	FC	Classroom 147 - Pre-K	C		5:02
20	50	JPRES-50-DB	bubbler on left	DB	Classroom 147 - Pre-K	C		↓
21	51	JPRES-51-FC	sink on right	FC	Classroom 147 - Pre-K	C		
22	52	JPRES-52-DB	bubbler on right	DB	Classroom 147 - Pre-K	C		↓
23	53	JPRES-53-FC	sink	FC	Classroom 142 - 1	C		
24	54	JPRES-54-DB	bubbler	DB	Classroom 142 - 1	C		4:45

First Draw

14 J.P. Ryon Elementary School

12140 Vivian Adams Drive Waldorf, MD 20601

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 10 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

86005

							Flush	Martel NO:
								86005
25	55	JPRES-55-FC	sink	FC	Classroom 141 - 1	C	10/15	4:44
26	56	JPRES-56-DB	bubbler	DB	Classroom 141 - 1	C		4:44
27	57	JPRES-57-FC	sink	FC	Classroom 140 - 1	C		4:42
28	58	JPRES-58-DB	bubbler	DB	Classroom 140 - 1	C		4:42
29	59	JPRES-59-FC	sink	FC	Classroom 139 - 1	C		4:40
30	60	JPRES-60-DB	bubbler	DB	Classroom 139 - 1	C		4:40
31	61	JPRES-61-FC	sink	FC	Classroom 138 - 1	C		4:38
32	62	JPRES-62-DB	bubbler	DB	Classroom 138 - 1	C		4:38
33	63	JPRES-63-DC	water fountain on left	DC	corridor	C		4:36
34	64	JPRES-64-DC	water fountain on right	DC	corridor	C		4:36
35	69	JPRES-69-FC	sink - Left	FC	Classroom 134 - Pre-K	C		4:33
36	72	JPRES-72-FC	sink	FC	Classroom 130 (Sp-Ed) Life Skills	C		4:28
37	73	JPRES-73-DB	bubbler	DB	Classroom 130 (Sp-Ed) Life Skills	C		4:28
38	80	JPRES-80-DC	water fountain on left	DC	corridor	C		4:25
39	81	JPRES-81-DC	water fountain on right	DC	corridor	C		4:25
40	84	JPRES-84-DC	water fountain	DC	corridor	C		4:12
41	85	JPRES-85-FC	sink	FC	staff lounge	C		4:15
42	86	JPRES-86-FC	sink	FC	nurse office	C		4:13
43	87	JPRES-87-BU	Bottle Filler	BU	Corridor	C		4:12
44	88	JPRES-88-BU	Bottle Filler	BU	Corridor	C		4:19
45	89	JPRES-89-FC	sink	FC	Classroom A101 - K	C		4:52
46	90	JPRES-90-DB	bubbler	DB	Classroom A101 - K	C		4:52
47	91	JPRES-91-FC	sink	FC	Classroom A103 - K	C		4:59
48	92	JPRES-92-DB	bubbler	DB	Classroom A103 - K	C		4:59
49	93	JPRES-93-FC	sink	FC	Classroom A105 - K	C		4:58
50	94	JPRES-94-DB	bubbler	DB	Classroom A105 - K	C		4:58
51	95	JPRES-95-FC	sink	FC	Classroom A104 - K	C		4:56
52	96	JPRES-96-DB	bubbler	DB	Classroom A104 - K	C		4:56
53	97	JPRES-97-FC	sink	FC	Classroom A102 - K	C		4:54
54	98	JPRES-98-DB	bubbler	DB	Classroom A102 - K	C		4:54
55	99	JPRES-99-FC	sink	FC	Classroom A104 - Activity	C		4:50
56	100	JPRES-100-DB	bubbler	DB	Classroom A104 - Activity	C		4:50

First Draw
14 J.P. Ryon Elementary School

12140 Vivian Adams Drive Waldorf, MD 20601

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 10 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

							Flush	Martel NO: 86005
57	101	JPRES-101-DC	water fountain on left	DC	corridor	C	10/15	4:49
58	102	JPRES-102-DC	water fountain on right	DC	corridor	C	↓	
59	103	JPRES-103-BU	Bottle Filler	BU	Corridor	C		
60	1F	JPRES-1F-FC	Sink - Left fixture	FC	Kitchen - Left Fixture on 3 Comp Sink	C		FLUSH 5:14
61	2F	JPRES-2F-FC	Sink - Right fixture	FC	Kitchen - Right Fixture on 3 Comp Sink	C	FLUSH	↓
62	4F	JPRES-4F-FC	sink next to ice maker	FC	kitchen sink	C	FLUSH	
63	5F	JPRES-5F-FC	sink	FC	kitchen 2 comp sink	C	FLUSH	↓
64	6F	JPRES-6F-FC	sink	FC	kitchen sink	C	FLUSH	
65	86F	JPRES-86F-FC	sink	FC	nurse office	C	FLUSH 5:10	