

Iroquois CSD - Intermediate School																	Date Last Updated:	2/24/2026
Lead in School Drinking Water Remedial Action Plan																		
School Outlet ID (Should match Sampling Plan)	Laboratory Sample ID	Outlet Location	Outlet Description	Was the outlet deemed 'Applicable' or 'Not Applicable'? *if not applicable place criteria in Notes/Comments	Sample Results (ppb or mcg/L) *if not applicable mark "N/A"		Remedial Actions (Please mark "x" for all that apply)										Date(s) Remedial Action Taken	Notes/Comments
					Initial	Post Remediation	Date Taken out of Service	Date Returned to Service	Outlet / Plumbing Replacement	Permanent Removal	Filter Installed and Maintained	Signage	Supervision	Continuing Education	Systematic Flushing	Engineering Controls		
IS-001	N/A	BR-I	BOILER ROOM EYE WASH	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-002	N/A	BR-I	BOILER ROOM HOSE SPICKET	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-003	N/A	99	CLASSROOM - LEFT SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-004	N/A	99	CLASSROOM - RIGHT SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-005	N/A	98	CLASSROOM SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-006	N/A	14	CLASSROOM SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-007	N/A	13	CLASSROOM SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-008	N/A	15	CLASSROOM SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-009	N/A	12	CLASSROOM SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-010	N/A	16	CLASSROOM SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-011	N/A	11	CLASSROOM SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-012	N/A	17	CLASSROOM SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-013	N/A	10	CLASSROOM SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-014	N/A	59	GIRLS RESTROOM LEFT SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-015	N/A	59	GIRLS RESTROOM MIDDLE SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-016	N/A	59	GIRLS RESTROOM RIGHT SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-017	N/A	CUST-56	MOP SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-018	N/A	57	BOYS RESTROOM LEFT SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-019	N/A	57	BOYS RESTROOM MIDDLE SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-021	N/A	57	BOYS RESTROOM RIGHT SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-022	N/A	9	CLASSROOM SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-023	N/A	18	CLASSROOM SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-024	N/A	8A	MEDIA ROOM OFFICE SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-025	N/A	19	CLASSROOM SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-026	N/A	51	OFFICE RESTROOM SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-027	N/A	51	OFFICE SHOWER	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-028	N/A	52	BOYS LOCKER ROOM SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.

IS-029	N/A	52	BOYS LOCKER ROOM SHOWER 1	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-030	N/A	52	BOYS LOCKER ROOM SHOWER 2	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-031	N/A	52	BOYS LOCKER ROOM SHOWER 3	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-032	N/A	52	BOYS LOCKER ROOM SHOWER 4	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-033	N/A	52	BOYS LOCKER ROOM SHOWER 5	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-034	N/A	52	BOYS LOCKER ROOM SHOWER 6	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-035	N/A	20	CLASSROOM SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-036	N/A	22	CLASSROOM SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-038	N/A	54	BOYS RESTROOM LEFT SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-039	N/A	54	BOYS RESTROOM MIDDLE SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-040	N/A	54	BOYS RESTROOM RIGHT SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-041	N/A	CUST	MOP SINK BETWEEN B/G RESTROOMS	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-042	N/A	53	GIRLS RESTROOM LEFT SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-043	N/A	53	GIRLS RESTROOM MIDDLE SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-044	N/A	53	GIRLS RESTROOM RIGHT SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-045	N/A	23	CLASSROOM SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-046	N/A	30	CLASSROOM SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-047	N/A	24	CLASSROOM SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-048	N/A	29	CLASSROOM SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-049	N/A	25	CLASSROOM SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-050	N/A	28	CLASSROOM SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-051	N/A	26	CLASSROOM SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-052	N/A	27	CLASSROOM SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-053	N/A	7A	SINGLE RESTROOM ADULT SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-054	N/A	7B	SINGLE RESTROOM ADULT SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-055	N/A	48 (42 DOOR)	GIRLS LOCKER ROOM SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-056	N/A	49	OFFICE RESTROOM SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-057	N/A	49	OFFICE SHOWER	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-058	N/A	OSOR5	CUSTODIAN BUCKET FILL STATION	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-059	N/A	5	STAFF LOUNGE SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-060A	N/A	5A	HANDICAP RESTROOM SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-060B	N/A	4R	HEALTH OFFICE RESTROOM SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-062	N/A	3	PRINCIPAL OFFICE RESTROOM SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-064	N/A	45A	MOP SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-065	N/A	41M	MENS RESTROOM SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-066	N/A	42W	WOMENS RESTROOM SINK	NOT APPLICABLE	N/A	N/A						X	X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.

IS-067	N/A	45	KITCHEN CENTER WALL NORTH SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-069	R2516778-009	151	KITCHEN WEST WALL RIGHT SINK	APPLICABLE	6.9	N/A	1/28/2026					X		X			1/28/2026	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-070	N/A	45	KITCHEN DISHWASHER NORTH WALL	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-071	N/A	45	KITCHEN DISHWASHER SINK NORTH WALL	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-072	N/A	44	WOMENS RESTROOM SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-073	N/A	BASEMENT	CUSTODIAN OFFICE SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-074	N/A	39	MUSIC ROOM SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-075	N/A	38A	OFFICE SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-076	N/A	31A	OFFICE SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-077	N/A	32	CLASSROOM SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-078	N/A	33	OFFICE SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-079	N/A	34RR	OFFICE SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-082	N/A	36RR	OFFICE SINK	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-083	N/A	OSOR31	OUTDOOR WATER SPICKET	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-084	N/A	OSOR29	OUTDOOR WATER SPICKET	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-085	N/A	OSOR24	OUTDOOR WATER SPICKET	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-086	N/A	OSOR57	OUTDOOR WATER SPICKET	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-087	N/A	OSOR4C	OUTDOOR WATER SPICKET	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
IS-088	N/A	OSOR14	OUTDOOR WATER SPICKET	NOT APPLICABLE	N/A	N/A						X		X			10/29/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.