



7469 Whitepine Rd  
North Chesterfield, VA 23237  
Telephone: 800.347.4010

## Lead in Drinking Water Analysis Report

**Client:** Stohl Environmental  
3860 California Road  
Orchard Park, NY 14127

**Report Number:** 26-02-00304

**Received Date:** 02/02/2026

**Reported Date:** 02/04/2026

**Sampled By:** Client

**Tech Certification #:**

**Project/Test Address:** 2023L.213.2; Iroquois Middle School; 2111 Girdle Rd; Elma, NY

**Client Number:**

33-5980

**Fax Number:**

716-312-8092

# Laboratory Results

| Lab Sample Number | Client Sample ID | Collection Date | Collection Location          | Concentration ug/L (ppb) | Analysis Date | Narrative ID |
|-------------------|------------------|-----------------|------------------------------|--------------------------|---------------|--------------|
| 26-02-00304-001   | MS-118           | 01/30/2026      | 404 SOUTH WALL SINK<br>RIGHT | <1.00                    | 02/04/2026    |              |

**Method:** EPA 200.8

**Analyst:** Nicole Holloway

**Accreditation #:** NY 11714

Reviewed By Authorized Signatory:

*Melissa Kanode*

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND      ug/L= micrograms per liter      ppb = parts per billion

