



7469 Whitepine Rd
North Chesterfield, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 26-02-00306

Received Date: 02/02/2026

Reported Date: 02/04/2026

Sampled By: Client

Tech Certification #:

Project/Test Address: 2023L.213.1; Iroquois High School; 2111 Girdle Rd; Elma, NY

Client Number:

33-5980

Fax Number:

716-312-8092

Laboratory Results

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
26-02-00306-001	HS-052	01/30/2026	146D TRAINERS WATER JUG SPICKET	<1.00	02/04/2026	
26-02-00306-002	HS-100	01/30/2026	151 COFFEE MAKER	<1.00	02/04/2026	

Method: EPA 200.8

Analyst: Nicole Holloway

Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Melissa Kanode

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



STOHL Job # 2023L-213.1

Location: 2111 Girdle Rd, Elma, NY

X

48 Hours

Page 1 of 1