

Iroquois CSD - Athletic Building																Date Last Updated:	2/24/2026	
Lead in School Drinking Water Remedial Action Plan																		
School Outlet ID (Should match Sampling Plan)	Laboratory Sample ID	Outlet Location	Outlet Description	Was the outlet deemed 'Applicable' or 'Not Applicable' for sampling? *if not applicable place criteria in Notes/Comments	Sample Results (ppb or mcg/L) *if not applicable mark "N/A"		Remedial Actions (Please mark "x" for all that apply)										Date(s) Remedial Action Taken	Notes/Comments
							Actions Requiring Maintenance Schedule [Link to Maintenance Schedule Here] [Link to Maintenance Documentation Here]											
					Initial	Post Remediation	Date Taken out of Service	Date Returned to Service	Outlet / Plumbing Replacement	Permanent Removal	Filter Installed and Maintained	Signage	Supervision	Continuing Education	Systematic Flushing	Engineering Controls		
AB-001	N/A	STORAGE	STORAGE AREA HOT WATER HOSE SPICKET	NOT APPLICABLE	N/A	N/A						X		X			10/22/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
AB-002	25-11-04452-002	STORAGE	STORAGE AREA COLD WATER HOSE SPICKET	NOT APPLICABLE	15.3	N/A	1/28/2026	1/29/2026				X		X			1/28/2026	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
AB-006	N/A	MENS	RESTROOM SINK LEFT	NOT APPLICABLE	N/A	N/A						X		X			10/22/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
AB-007	N/A	MENS	RESTROOM SINK RIGHT	NOT APPLICABLE	N/A	N/A						X		X			10/22/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
AB-008	N/A	WOMENS	RESTROOM SINK LEFT	NOT APPLICABLE	N/A	N/A						X		X			10/22/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.
AB-009	N/A	WOMENS	RESTROOM SINK RIGHT	NOT APPLICABLE	N/A	N/A						X		X			10/22/2025	Clear "Do Not Drink" signage. Staff and students educated to not use for consumption.