



**Business Services
Contracts Office**

5735 47th Avenue • Sacramento, CA 95824
(916) 643-2464

*Lisa Grant-Dawson, Interim Chief Business Officer
Robert Aldama, Purchasing Manager II*

ADDENDUM NO. 1

Date: February 25, 2026

Issued by: Sacramento City Unified School District

**Project: Project #: 26-043026
Recoating Gym and Dance Flooring**

This addenda shall supersede the original Information, attachments, and specifications regarding Project No. 26-043026 where it adds to, deletes from, clarifies or otherwise modifies them. All other conditions and any previous addenda shall remain unchanged.

Part A – Bidding and Contract Requirements

AD1.01 QUESTIONS

The scope of work indicates one coat of finish.

However, in the manufacturer's specifications for the application, there is one coat of sealer then one coat of finish. Do we follow the specification, which is that two coats (seal and finish) Or only one coat of finish?

AD1.01 ANSWER

One (1) coat to seal and one (1) coat to finish is accurate.

AD1.02 QUESTION

According to the bid documents, the approved finish for recoating throughout the project is AquaChoice Sport B Green, a water-based finish approved by the MFMA.

We contacted the manufacturer, and they referred us to their supplier in CA, Boberg Hardwood Floors. They refuse to sell this product directly to us and there is no other supplier for this product in CA.

Please note that Boberg Hardwood Floors attended the mandatory job walk and will bid on this project.

This is a conflict of interest, since one of the bidders is the direct supplier of the specified finish.

Project No: 26-043026
Recoating Gym and Dance Flooring at Multiple Sites
ADDENDUM NO. 1

To be able to bid this project on equal terms, we propose adding an MFMA approved water-based finish from Basic Coatings to the project specifications.

Please find attached information for the Gym Shoe finish from Basic Coatings for your review and approval.

AD1.02 ANSWER

The District will accept the substituted Gym Shoe Finish from Basic Coatings.

Part B – Scope of Work

- 1. Scope of Work with revised square footages**

END OF ADDENDUM NO. 1

Acknowledgement of this Addendum will be required at time of bid: