

Lead in School Drinking Water Report

Sumner Middle School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2026-01-09

Date(s) analyzed: 2026-01-14, 2026-01-21

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	411364	Main Building	Pot Filler	Kitchen	3 of 3	Sprayer	center	43
2	411360	Main Building	Sink - Multi-compartment	Kitchen	1 of 3	Tap	center	12
3	411376	Portable 707	Sink	Portable 707	1 of 1	Tap	center	11
4	411382	Main Building	Sink - Multi-compartment	Room 501	2 of 7. Orange kitchen	Tap	center	7
5	411380	Main Building	Sink - Multi-compartment	Room 501	1 of 7. Blue kitchen	Tap	center	6
6	411383	Main Building	Sink - Multi-compartment	Room 501	3 of 7. Purple kitchen	Tap	center	6
7	411385	Main Building	Sink - Multi-compartment	Room 501	5 of 7. Green kitchen	Tap	center	6
8	411392	Main Building	Sink	Nurses Office	1 of 1	Tap	center	6
9	411393	Main Building	Sink - Multi-compartment	Staff Lounge	1 of 1	Tap	center	6
10	411398	Main Building	Sink	Room 311	1 of 2	Tap	center	6

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	411361	Main Building	Sink - Multi-compartment	Kitchen	1 of 3	Sprayer	center	5
12	411366	Main Building	Sink - Multi-compartment	Room 410	1 of 1	Tap	center	5
13	411368	Main Building	Fountain Tap Combo	Room 409	1 of 1	Water Fountain	right	5
14	411375	Portable 706	Sink	Portable 706	1 of 1	Tap	center	5
15	411387	Main Building	Sink - Multi-compartment	Room 501	7 of 7. Yellow kitchen	Tap	center	5
16	411390	Main Building	Fountain Tap Combo	Room 506	1 of 1	Water Fountain	right	5
17	411369	Main Building	Fountain Tap Combo	Room 403	1 of 1	Water Fountain	right	4
18	411370	Main Building	Fountain Tap Combo	Room 404	1 of 1	Water Fountain	right	4
19	411386	Main Building	Sink - Multi-compartment	Room 501	6 of 7. Red kitchen	Tap	center	4
20	411391	Main Building	Fountain Tap Combo	Room 504	1 of 1	Water Fountain	right	4
21	411396	Main Building	Fountain Tap Combo	Room 201	1 of 1	Water Fountain	right	4

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
22	411371	Main Building	Fountain Tap Combo	Room 407	1 of 1	Water Fountain	right	3
23	411372	Main Building	Fountain Tap Combo	Room 406	1 of 1	Water Fountain	right	3
24	411384	Main Building	Sink - Multi-compartment	Room 501	4 of 7 demonstration sink	Tap	center	3
25	411397	Main Building	Fountain Tap Combo	Room 301	1 of 1	Water Fountain	right	3
26	411441	Main Building	Fountain Tap Combo	Room 309	1 of 1	Water Fountain	right	3
27	411363	Main Building	Pot Filler	Kitchen	3 of 3	Tap	center	2
28	411440	Main Building	Fountain Tap Combo	Room 305	1 of 1	Water Fountain	right	2
29	411373	Portable 701	Sink	Portable 701	1 of 1	Tap	center	1
30	411388	Main Building	Fountain - Multi-level	Gym Hall	1 of 1	Water Fountain	left	1
31	411389	Main Building	Fountain - Multi-level	Gym Hall	1 of 1	Water Fountain	right	1
32	411362	Main Building	Ice Machine	Kitchen	2 of 3	Ice Machine	center	<1

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
33	411374	Portable 703	Sink - Multi-compartment	Portable 703	1 of 1	Tap	center	<1
34	411377	Portable 705	Sink	Portable 705	1 of 1	Tap	center	<1
35	411378	Main Building	Fountain With Bottle Filler	Cafeteria	1 of 1	Water Bottle Filler	center	<1
36	411379	Main Building	Fountain With Bottle Filler	Cafeteria	1 of 1	Water Fountain	right	<1
37	411394	Main Building	Fountain With Bottle Filler	2nd Floor Outside Of Offices	1 of 1	Water Bottle Filler	center	<1
38	411395	Main Building	Fountain With Bottle Filler	2nd Floor Outside Of Offices	1 of 1	Water Fountain	right	<1
39	411399	Main Building	Ice Machine	Room 311	2 of 2	Ice Machine	center	<1