

Facility or Building Name	Whittier Elementary School
Did the facility test using the MDH testing program (WIIN)? (Yes or No)	No
Facility Type (School or Child Care)	School
School ID Number or Child Care License Number	0001-03-289
Facility or Building Address	315 West 26th St, Minneapolis, MN 55404
Mailing Address	1225 North 7th Street Minneapolis, MN 55411
Contact Person	Lee Setter
Title	Manager, EH&S
Phone	612-668-0308
Email	Lee.Setter@mpls.k12.mn.us

SUMMARY	ANSWER
Total number of samples	52
Total number of fixtures sampled	52
Total number of results above 5 ppb	0
Total number of remediation actions	0
Next Scheduled Sampling Date (Month/Year)	02/2031

Unique Sample Site	Fixture Type	Location Description	Fixture Status	Sample Collection	Laboratory	Date/Time	Date/Time	Numeric Result	Unit of	Name of Laboratory Used	Remediation Action	Other	Was Remediation Successful	Additional Notes or Comments
0001-03-289-01	Sink	Justodian break room/restroom	Active - Consumption	Initial - First Draw	26-01498	2/13/2026 4:15	2/17/2026 10:27	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-02	Drinking Fountain	Room 006-Hallway	Active - Consumption	Initial - First Draw	26-01499	2/13/2026 4:17	2/17/2026 10:33	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-03	Drinking Fountain	RM-116-Right	Active - Consumption	Initial - First Draw	26-01500	2/13/2026 4:18	2/17/2026 10:39	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-04	Drinking Fountain	RM-116-Left	Active - Consumption	Initial - First Draw	26-01501	2/13/2026 4:19	2/17/2026 10:45	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-05	Drinking Fountain	107-Lunch room-Right	Active - Consumption	Initial - First Draw	26-01502	2/13/2026 4:20	2/17/2026 10:51	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-06	Drinking Fountain	107-Lunch room-Left	Active - Consumption	Initial - First Draw	26-01503	2/13/2026 4:22	2/17/2026 10:57	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-07	Sink	108-Kitchen wash	Active - Consumption	Initial - First Draw	26-01504	2/13/2026 4:23	2/17/2026 11:04	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-08	Drinking Fountain	176	Active - Consumption	Initial - First Draw	26-01505	2/13/2026 4:24	2/17/2026 11:22	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-09	Drinking Fountain	175	Active - Consumption	Initial - First Draw	26-01506	2/13/2026 4:24	2/17/2026 11:40	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-10	Drinking Fountain	174	Active - Consumption	Initial - First Draw	26-01507	2/13/2026 4:25	2/17/2026 11:46	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-11	Drinking Fountain	172	Active - Consumption	Initial - First Draw	26-01508	2/13/2026 4:26	2/17/2026 11:52	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-12	Drinking Fountain	170	Active - Consumption	Initial - First Draw	26-01509	2/13/2026 4:27	2/17/2026 11:58	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-13	Sink	165	Active - Consumption	Initial - First Draw	26-01510	2/13/2026 4:28	2/17/2026 12:04	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-14	Drinking Fountain	163-Hallway	Active - Consumption	Initial - First Draw	26-01511	2/13/2026 4:28	2/17/2026 12:10	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-15	Drinking Fountain	163-Hallway	Active - Consumption	Initial - First Draw	26-01512	2/13/2026 4:29	2/17/2026 12:16	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-16	Drinking Fountain	162	Active - Consumption	Initial - First Draw	26-01513	2/13/2026 4:30	2/17/2026 12:22	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-17	Sink	146-Health Office	Active - Consumption	Initial - First Draw	26-01514	2/13/2026 4:32	2/17/2026 12:28	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-18	Sink	145-Work RM	Active - Consumption	Initial - First Draw	26-01515	2/13/2026 4:33	2/19/2026 12:48	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-19	Sink	138	Active - Consumption	Initial - First Draw	26-01516	2/13/2026 4:34	2/19/2026 12:54	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-20	Drinking Fountain	138	Active - Consumption	Initial - First Draw	26-01517	2/13/2026 4:35	2/19/2026 13:00	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-21	Drinking Fountain	124	Active - Consumption	Initial - First Draw	26-01518	2/13/2026 4:36	2/19/2026 13:07	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-22	Drinking Fountain	125-Hallway-Right	Active - Consumption	Initial - First Draw	26-01519	2/13/2026 4:37	2/19/2026 13:13	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-23	Drinking Fountain	125-Hallway-Left	Active - Consumption	Initial - First Draw	26-01520	2/13/2026 4:39	2/19/2026 13:19	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-24	Drinking Fountain	131	Active - Consumption	Initial - First Draw	26-01521	2/13/2026 4:40	2/19/2026 13:25	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-25	Drinking Fountain	132	Active - Consumption	Initial - First Draw	26-01522	2/13/2026 4:42	2/19/2026 13:43	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-26	Drinking Fountain	133	Active - Consumption	Initial - First Draw	26-01523	2/13/2026 4:43	2/19/2026 14:01	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-27	Drinking Fountain	206	Active - Consumption	Initial - First Draw	26-01524	2/13/2026 4:45	2/19/2026 14:07	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-28	Drinking Fountain	207	Active - Consumption	Initial - First Draw	26-01525	2/13/2026 4:47	2/19/2026 14:13	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-29	Drinking Fountain	210	Active - Consumption	Initial - First Draw	26-01526	2/13/2026 4:49	2/19/2026 14:19	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-30	Drinking Fountain	213	Active - Consumption	Initial - First Draw	26-01527	2/13/2026 4:51	2/19/2026 14:25	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-31	Drinking Fountain	214	Active - Consumption	Initial - First Draw	26-01528	2/13/2026 4:54	2/19/2026 14:31	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-32	Drinking Fountain	217	Active - Consumption	Initial - First Draw	26-01529	2/13/2026 4:56	2/19/2026 14:37	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-33	Drinking Fountain	218-Hallway-Right	Active - Consumption	Initial - First Draw	26-01530	2/13/2026 4:57	2/19/2026 14:43	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-34	Bottle Filler	218-Hallway-Left	Active - Consumption	Initial - First Draw	26-01531	2/13/2026 4:59	2/19/2026 14:49	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-35	Sink	261	Active - Consumption	Initial - First Draw	26-01532	2/13/2026 5:03	2/24/2026 11:43	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-36	Drinking Fountain	258	Active - Consumption	Initial - First Draw	26-01533	2/13/2026 5:05	2/24/2026 11:49	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-37	Drinking Fountain	257	Active - Consumption	Initial - First Draw	26-01534	2/13/2026 5:06	2/24/2026 11:55	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-38	Drinking Fountain	250	Active - Consumption	Initial - First Draw	26-01535	2/13/2026 5:08	2/24/2026 12:01	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-39	Drinking Fountain	249	Active - Consumption	Initial - First Draw	26-01536	2/13/2026 5:11	2/24/2026 12:07	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-40	Drinking Fountain	259-Hallway	Active - Consumption	Initial - First Draw	26-01537	2/13/2026 5:13	2/24/2026 12:13	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-41	Drinking Fountain	248	Active - Consumption	Initial - First Draw	26-01538	2/13/2026 5:15	2/24/2026 12:20	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-42	Drinking Fountain	237	Active - Consumption	Initial - First Draw	26-01539	2/13/2026 5:17	2/24/2026 12:38	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-43	Drinking Fountain	235	Active - Consumption	Initial - First Draw	26-01540	2/13/2026 5:19	2/24/2026 12:56	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-44	Drinking Fountain	230	Active - Consumption	Initial - First Draw	26-01541	2/13/2026 5:21	2/24/2026 13:02	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-45	Drinking Fountain	289	Active - Consumption	Initial - First Draw	26-01542	2/13/2026 5:23	2/24/2026 13:08	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-46	Drinking Fountain	227	Active - Consumption	Initial - First Draw	26-01543	2/13/2026 5:24	2/24/2026 13:14	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-47	Drinking Fountain	226	Active - Consumption	Initial - First Draw	26-01544	2/13/2026 5:25	2/24/2026 13:20	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-48	Drinking Fountain	225-Hallway-Right	Active - Consumption	Initial - First Draw	26-01545	2/13/2026 5:27	2/24/2026 13:26	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-49	Drinking Fountain	225-Hallway-Right	Active - Consumption	Initial - First Draw	26-01546	2/13/2026 5:28	2/24/2026 13:32	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-50	Drinking Fountain	222	Active - Consumption	Initial - First Draw	26-01547	2/13/2026 5:29	2/24/2026 13:38	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-51	Drinking Fountain	221	Active - Consumption	Initial - First Draw	26-01548	2/13/2026 5:31	2/24/2026 13:44	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-289-52	Drinking Fountain	220	Active - Consumption	Initial - First Draw	26-01549	2/13/2026 5:33	2/26/2026 10:31	ND	µg/L	Twin City Water Clinic, Inc				

Definitions of Reporting Fields

Field Name	Response Needed or Definition	Where does this information come from?
Unique Sample Site Identification Number	A unique number or code using numbers and or letters that a facility assigns to each fixture in the building. This prevents confusion about which sample goes with which fixture.	Facility
Fixture Type	Describes the type of fixture such as sink, fountain, bottle filler, ice machine, kitchen kettle, coffee machine, etc..	Facility
Location Description	Specific description of the location of the fixture. Ex. Classroom sink in Room 112 or Left drinking fountain in gym	Facility
Fixture Status	Describes if the fixture is currently being used and how it is used. Examples are Active-Consumption, Inactive-Consumption, Active-Nonconsumption, Inactive-Nonconsumption	Facility
Sample Collection Type	Initial first draw, Initial Flushed, Follow-up First Draw, Follow-up Flushed, Other	Facility
Laboratory Identification Number	Number assigned by the laboratory to each sample. It may be helpful for facilities using this spreadsheet to cross reference to their lab results. (Optional)	Lab
Date/Time Collected	Date and time the sample was collected Ex. 2/12/2024 7:03 PM or 3/8/24 13:02	Lab
Date/Time Analyzed	Date and time the sample was analyzed Ex. 2/12/2024 7:03 PM or 3/8/24 13:02	Lab
Numeric Result	This is the number representing the result reported by the lab. Ex. 5.12, 7.03, 89.02, for results that are not detected please use ND	Lab
Unit of Measure	This is the unit of the result reported by the lab Ex. Parts per billion (ppb), micrograms per liter (ug/L).	Lab
Name of Laboratory Used For Analysis	The name of the laboratory used for sample analysis.	Lab
Remediation Action	Describes the type of remediation (if needed). Select from drop down menu. You only need to complete if result is 5ppb or more. If the action you took is not listed select OTHER and describe	Facility
Other Remediation-Please Describe	Use this field to type in your remediation action if the choice was not listed in the Remediation Action Drop down menu.	Facility
Was Remediation Successful (ie. Follow-up)	Select from the drop down. Options are Yes, No, Not Applicable(N/A), and Pending Results	Facility

Other Important Terms	Definitions
Consumption	For the purposes of this testing consumption means a fixture where the water is used for drinking water or food/formula preparation.
Non-Consumption	A fixture that is not used for drinking water or food preparation such as a laboratory sink or a mop sink in a locked custodial closet. MDH recommends that non-consumption fixtures be labeled as not for drinking if they are not tested.
Active	A fixture currently able to be used.
Inactive	A fixture that has been taken out of service either temporarily or permanently
First Draw	A type of water sample where the water has been stagnant for 8-18 hours before collecting a sample. The most common type of lead sample type.
Flushed	A type of water sample where the water has been allowed to run before collecting. Typically collected when investigating to source of lead or evaluating remediation options.
Initial	This is typically a first draw sample collected during a round of monitoring. A sample may be an initial-first draw or an initial-flushed
Follow-up	This is typically collected if an initial sample collected during a round of sampling is 5ppb or more. Follow-up samples can be repeated first draw samples or flushed samples depending on the type of follow-up activities conducted to reduce lead.