

Sprinkler and Related Equipment Frequency Inspection and Testing

Item	Frequency
Alarm Valves	
Exterior	Quarterly
Interior	5 Years
Strainers, filters, orifices	5 Years
Backflow Prevention Assemblies	
Reduced pressure	Weekly
Reduced-pressure detectors	Weekly
Interior	5 years
Check Valves	
Interior	5 Years
Control Valves	
All valves except locked or supervised	Weekly
Locked or supervised	Monthly
Electronically supervised	Quarterly
Dry pipe valves/quick-opening devices	
Enclosure (during cold weather)	-
Exterior	Monthly
Interior	Annually
Strainers, filters, orifices	5 Years
Deluge Valves	
Enclosure (during cold weather)	Daily/weekly
Exterior	Monthly

Sprinkler and Related Equipment Frequency Inspection and Testing

Interior	Annually/ 5 years
Strainers, filters, orifices	5 Years
Fire Department connections	Quarterly
Gauges	Quarterly
Hose valves	Quarterly
Pre-action valves	
Enclosure (during cold weather)	-
Exterior	Monthly
Interior	Annually/ 5 years
Strainers, filters, orifices	5 Years
Pressure-regulating and relief valves	
Master pressure regulating	Weekly
Sprinkler system pressure reducing	Quarterly
Hose connection pressure regulating	Annually
Fire pump circulation relief	With no flow test
Fire pump main pressure-relief	With fire pump test
Valve supervisory signal initiating device	Quarterly
Supervisory signal devices (except valve supervisory switches)	Quarterly
Air compressors and nitrogen generators	Monthly
Waterflow Alarms	Quarterly