TOWN OF SUFFIELD

83 Mountain Rd, Suffield, CT 06078
www.suffieldct.gov

MOBILE FOOD VEHICLE INSPECTION CHECKLIST

Permit No.: _____

Date: _____ Time of Inspection: _____

Location of Inspection: _____ Vehicle Representative: _____

Contact Number: _____ Email: _____

License Plate No.: _____

FIRE EXTINGUISHERS:

☐ 2A10BC ☐ 3A40BC ☐ Inspected per NFPA 10 ☐ Mounted ☐ Accessible

☐ Class K Extinguisher ☐ Inspected per NFPA 10 ☐ Mounted ☐ Accessible

LPG (Propane):

☐ L.P. Gas containers shall be located and secured on the exterior of vehicle.

Not to be located on roof, inside passenger compartment, or extend further then the rear bumper and shall be protected from vehicle collision.

☐ "NO SMOKING" sign posted with a minimum of 4-inch lettering above propane bottle.

☐ Hose used to pipe L.P. Gas must be Underwriter Laboratories (UL) or FM listed (marked 350 psi working pressure)

☐ Couplings, fittings, and other deices meet UL or FM requirements.

☐ LPG tanks are to be located outside the vehicle with a minimum 5 feet from primary means of egress.

TYPE I / II HOOD / FIRE SUPPRESSION SYSTEM:

☐ Type I / II Hood cleaned with record of cleaning verified.

☐ Fire Suppression System serviced with record of service verified.

GENERATOR:

☐ Refueling of generators to be performed in an approved location not less than 20 feet from vehicle.

☐ Fuel to be stored away from vehicle, no less than 20 feet, or in approved flammable liquid safety container.

☐ Storage is in an approved location (secured from movement).

☐ Generators shall be grounded in an approved method.

☐ Generators shall not be refueled in areas occupied by the public.

☐ Generators shall be caged or fenced off to prevent public access in approved manner.

☐ A minimum 2A10BC extinguisher shall be located a minimum of 20 feet from generator while refueling.

☐ Generators shall be 12 feet away from mobile food truck or any other mobile food trucks.

GENERAL FIRE SAFETY:

☐ Carbon Monoxide detector installed where LP Gas or Natural gas or open flames are used.

☐ Aisle-way on interior of vehicle kept clear of storage and combustible materials.

☐ Exit door latch mechanism(s) shall be operable by hand.

☐ Mobile food trucks shall be 10 feet away from structures and other mobile food trucks.

☐ Approved ☐ Disapproved If Approved Permit Sticker Number: _____

Inspected by: _____ Date: _____

Re-Inspection Re-Scheduled for Date: _____