



**USING DESIGN TO ELEVATE
ENVIRONMENTS AND EXPERIENCES**

Architecture • Interior Design • Landscape Architecture | www.KBA-Architects.com

**A D D E N D U M N O . 2
H V A C - P U L A S K I**

**HVAC IMPROVEMENT
PULASKI & SLADE MIDDLE SCHOOLS**
New Britain, CT
KBA #25014.00 KBA #25014.00 | SPN#089-173 HVAC-
PULASKI - SPN#089-174-SLADE

Date: March 13, 2026
Page: 1 of 1

The following changes to the Project Manual shall become a part of the Drawings, Specifications, Bidding Requirements and Contract Documents; superseding previously issued Drawings, Specifications, Bidding Requirements, Contract Documents and Addenda, to the extent modified by this Addendum.

CLARIFICATIONS

See Response to Dyna Inc. RFI #001 attached at the end of this Addendum.

ATTACHMENTS

Bid Questions and Responses:
RFI#001 – Dyna Inc.

**PULASKI MIDDLE SCHOOL
NEW BRITAIN, CT**

**HVAC IMPROVEMENT
STATE PROJECT #089-0173 HVAC – PULASKI
KBA #25014.00**

From: Rob Uccello <rob@dynainc.com>
Sent: Wednesday, March 11, 2026 10:50 AM
To: Nelson Bastos <nbastos@kba-architects.com>
Subject: Pulaski/Slade School HVAC renovation

RFI #001

Good morning, Nelson,

I would like to inquire about the “Main Switchboard” in the basement and “Panel DPM” located in the Mechanical Penthouse. Unfortunately, I was only able to attend the tail ending of the walk through and consequently was unable to identify what brand /manufacturer produced them. I would need to match the breakers that are to be added to these panels so I hope you would be able to answer that for me. Also, I’m curious to know the Fire Alarm monitoring company on the change we would need to contact them.

I look forward to your response.

Thank you,

Robert Uccello

540 North Main Street A1
Manchester, CT 06042
Office: (860) 643-1331
Cell: (860) 810-7409
Web: <https://dynainc.com/>
Bridging the gap between technology and craftsmanship
Sent from [Mail](#) for Windows 10

KBA/RZ DESIGN RESPONSE:

The Main Switchboard is a Siemens ITE switchboard.

I’m afraid I don’t have the manufacturer information for Panel DPM. You would have to do a field visit to verify that.

The monitoring company is Altone Clear.

DAVID S. LUCHINI, P.E.

Electrical Engineer
P 860.436.4336 x117
rzdesignassociates.com
www.gm2inc.com



Disclaimer

The information contained in this communication from the sender is confidential. It is intended solely for use by the recipient and others authorized to receive it. If you are not the recipient, you are hereby notified that any disclosure, copying, distribution or taking action in relation of the contents of this information is strictly prohibited and may be unlawful