



**USING DESIGN TO ELEVATE
ENVIRONMENTS AND EXPERIENCES**

Architecture • Interior Design • Landscape Architecture | www.KBA-Architects.com

A D D E N D U M N O . 2

**ROOF REPLACEMENT
PULASKI MIDDLE SCHOOL**
New Britain, CT
KBA #25015.00 | SPN#089-175RR

Date: March 13, 2026
Page: 1 of 1

The following changes to the Project Manual shall become a part of the Drawings, Specifications, Bidding Requirements and Contract Documents; superseding previously issued Drawings, Specifications, Bidding Requirements, Contract Documents and Addenda, to the extent modified by this Addendum.

CLARIFICATIONS

See Response to Gold Seal Roofing RFI #002 attached at the end of this Addendum.

ATTACHMENTS

Bid Questions and Responses:
RFI#002 – Gold Seal Roofing

**PULASKI MIDDLE SCHOOL
NEW BRITAIN, CT**

**ROOF REPLACEMENT
STATE PROJECT #089-175RR
KBA #25015.00**

From: Steve Osnato <sosnato@gsroofs.com>
Sent: Wednesday, March 11, 2026 11:55 AM
To: Matthew Kozikowski <mkozikowski@kba-architects.com>
Subject: Pulaski Middle School RFI

RFI #002

Matt,

Can you please confirm that roof sections A/F/G/H do not have sloped metal decks and are 1/4" tapered. The reason we ask is because at the end of the construction type key it states "to be fastened on ETR low slope deck". We typically see this statement as on a flat metal deck, when the deck is flat.

Regards,

Steve Osnato
Estimator
Gold Seal Roofing LLC.
95 Bysiewicz Drive
Middletown, CT 06457
(860)484-8430 ext. 202
[AA/EOE](#)

KBA Response:

Roof types A/F/G/H/ do not have sloped decks.
Type "C" does have sloped deck.