



Purchasing Department  
900 Kenyon Street, Medford OR 97501  
Pam.Thoren@medford.k12.or.us  
(541) 842-1118

## **ADDENDUM 1**

Project: Fire Alarm Testing & Inspections 2-year Contract

Date: March 16, 2026

Invitation for Bid No.: 26-00-22

Owner: Medford School District 549C

---

### Instructions to Prospective Bidders:

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents and/or prior Addenda as noted below. All conditions, requirements, materials and workmanship are to be as described in the Contract Documents unless specifically stated otherwise. This Addendum consists of one page.

---

### General Notes:

- None

### Questions and Answers:

Q1: Regarding Innovation Academy High School – The Ansul Hood System is the kitchen hood, correct?

A1: Yes

Q2: Can you clarify what an FASP is for fire panel inspections?

A2: It is a NAC power supply, usually with four outputs.

Q3: Would MSD be open to having the testing done during normal business hours during the summer, spring and winter breaks?

A3: Yes, you can perform testing during breaks and holidays. The testing of notification devices must be done during those times or must be done after school is dismissed.