

January 27, 2026

Mr. Chris Graham  
Genesee Valley Central School  
1 Jaguar Drive  
Belmont, New York 14813

**Re: Lead Testing in School Drinking Water**

Dear Mr. Graham:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for Genesee Valley Central School, including:

- **Genesee Valley Central School – 1 Jaguar Drive, Belmont, NY**

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: *Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Sampling was performed on December 11, 2025. As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 7 sources of potable water at the Genesee Valley Central School have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion. To comply with NYS regulations, response actions by the district are required. Response actions are outlined in Section 1.3 (*Response Actions Required Under NYS Regulations*).

Thank you for the opportunity to be of service to Genesee Valley Central School.

Sincerely,  
Stohl Environmental, LLC.



Michael Scinta  
EPA Lead Risk Assessor

**Lead Testing in School Drinking Water**

**Prepared for:**

**Genesee Valley Central School**

**Prepared by:**



**3860 California Road  
Orchard Park, New York 14127**

**Conditions as of December 11, 2025**

## Summary Tabulation

### Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports and Chain of Custody Documents
- 1.5. Laboratory Certifications

## 1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Genesee Valley Central School to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building:

- **Genesee Valley Central School – 1 Jaguar Drive, Belmont, NY**

### Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within the Genesee Valley Central School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

### Sampling Protocol:

In accordance with NYS regulations, **Subpart 67-4: Lead Testing in School Drinking Water**, and the EPA guidance document, **3Ts for Reducing Lead in Drinking Water in Schools**, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

## 1.2 Executive Summary of Sampling and Analysis:

### Summary of Samples Collected at Genesee Valley Central School:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Genesee Valley Central School	12/11/2025	128	121	7

\*NYS Action Level is 5 parts per billion

### Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet type	Laboratory Analysis (in ppb)
220.1-24	1262 Drinking Fountain	Drinking Fountain	65.4
220.1-40B	Right Bottle Fill Next to 1201	Bottle Fill	16.7
220.1-41	Left Drinking Fountain Next to 1201	Drinking Fountain	63.2
220.1-63	2259 Drinking Fountain	Drinking Fountain	12.0
220.1-65	2261 Drinking Fountain	Drinking Fountain	12.8
220.1-66	2261 Sink	Sink	5.6
220.1-69	2258 Drinking Fountain	Drinking Fountain	69.6

220.1-24 - Drinking Fountain Bubbler was replaced with NEW

220.1-40B/220.1-41 - Drinking Fountain and Bottle Fill was replaced with NEW

220.1-63 - Drinking Fountain Bubbler was replaced with NEW

220.1-65 - Drinking Fountain Bubbler was replaced with NEW

220.1-66 - NEW faucet was installed

220.1-69 - NEW Drinking Fountain Bubbler was installed

**1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:**

For outlets analyzed with a lead concentration more than the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
  - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
  - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

#### 1.4 Laboratory Analytical Reports and Chain of Custody Documents



January 08, 2026

Service Request No:R2516862

Michael Scinta  
Stohl Environmental  
3860 California Road  
Orchard Park, NY 14219

**Laboratory Results for: Genesee Valley CSD - Central School**

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory December 15, 2025  
For your reference, these analyses have been assigned our service request number **R2516862**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at [Meghan.Pedro@alsglobal.com](mailto:Meghan.Pedro@alsglobal.com).

Respectfully submitted,

**ALS Group USA, Corp. dba ALS Environmental**

Meghan Pedro  
Project Manager

CC: Rebecca  
Franjoine

**ADDRESS** 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
**PHONE** +1 585 288 5380 | **FAX** +1 585 288 8475  
ALS Group USA, Corp.  
dba ALS Environmental



# Narrative Documents

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School  
**Sample Matrix:** Drinking Water

**Service Request:** R2516862  
**Date Received:** 12/15/2025

**CASE NARRATIVE**

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

**Sample Receipt:**

Thirty six drinking water samples were received for analysis at ALS Environmental on 12/15/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

**Metals:**

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by \_\_\_\_\_

Date 01/08/2026



### SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

<b>CLIENT ID: 220.1-4A</b>	<b>Lab ID: R2516862-004</b>
----------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.0			1.0	ug/L	200.8

<b>CLIENT ID: 220.1-4B</b>	<b>Lab ID: R2516862-005</b>
----------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.0			1.0	ug/L	200.8

<b>CLIENT ID: 220.1-7</b>	<b>Lab ID: R2516862-009</b>
---------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.2			1.0	ug/L	200.8

<b>CLIENT ID: 220.1-12</b>	<b>Lab ID: R2516862-015</b>
----------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.0			1.0	ug/L	200.8

<b>CLIENT ID: 220.1-16</b>	<b>Lab ID: R2516862-019</b>
----------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.3			1.0	ug/L	200.8

<b>CLIENT ID: 220.1-24</b>	<b>Lab ID: R2516862-028</b>
----------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	65.4			0.50	ug/L	200.8

<b>CLIENT ID: 220.1-27</b>	<b>Lab ID: R2516862-031</b>
----------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8

<b>CLIENT ID: 220.1-29</b>	<b>Lab ID: R2516862-033</b>
----------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.2			1.0	ug/L	200.8

<b>CLIENT ID: 220.1-32</b>	<b>Lab ID: R2516862-036</b>
----------------------------	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.3			1.0	ug/L	200.8



## Sample Receipt Information

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:**R2516862

**SAMPLE CROSS-REFERENCE**

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2516862-001	220.1-1	12/11/2025	
R2516862-002	220.1-2	12/11/2025	
R2516862-003	220.1-3	12/11/2025	
R2516862-004	220.1-4A	12/11/2025	
R2516862-005	220.1-4B	12/11/2025	
R2516862-006	220.1-5	12/11/2025	
R2516862-007	220.1-6A	12/11/2025	
R2516862-008	220.1-6B	12/11/2025	
R2516862-009	220.1-7	12/11/2025	
R2516862-010	220.1-8	12/11/2025	
R2516862-011	220.1-9A	12/11/2025	
R2516862-012	220.1-9B	12/11/2025	
R2516862-013	220.1-10	12/11/2025	
R2516862-014	220.1-11	12/11/2025	
R2516862-015	220.1-12	12/11/2025	
R2516862-016	220.1-13	12/11/2025	
R2516862-017	220.1-14	12/11/2025	
R2516862-018	220.1-15	12/11/2025	
R2516862-019	220.1-16	12/11/2025	
R2516862-020	220.1-17	12/11/2025	
R2516862-021	220.1-18	12/11/2025	
R2516862-022	220.1-19	12/11/2025	
R2516862-023	220.1-20	12/11/2025	
R2516862-024	220.1-21	12/11/2025	
R2516862-025	220.1-22	12/11/2025	
R2516862-026	220.1-23A	12/11/2025	
R2516862-027	220.1-23B	12/11/2025	
R2516862-028	220.1-24	12/11/2025	
R2516862-029	220.1-25	12/11/2025	
R2516862-030	220.1-26	12/11/2025	
R2516862-031	220.1-27	12/11/2025	
R2516862-032	220.1-28	12/11/2025	
R2516862-033	220.1-29	12/11/2025	
R2516862-034	220.1-30	12/11/2025	
R2516862-035	220.1-31	12/11/2025	
R2516862-036	220.1-32	12/11/2025	



# Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-220.1

Client: Genesee Valley CSD

Contact: Chris Graham

Building: Genesee Valley Central School

Location: 1 Jaguar Drive, Belmont NY

### LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
220.1-1	Kitchen 2 Bay	Sink	5:11
220.1-2	Kitchen Pot Filler	Pot Filler	5:12
220.1-3	Kitchen 3 Bay R	Sink	5:13
220.1-4A	Cafeteria DF	DF	5:14
220.1-4B	Cafeteria DFB	DFB	5:15
220.1-5	Cafeteria L DF	DF	5:16
220.1-6A	Cafeteria R DF	DF	5:17
220.1-6B	Cafeteria R DFB	DFB	5:18
220.1-7	1287 Sink	Sink	5:20
220.1-8	R DF Next to 1252	DF	5:21
220.1-9A	L DF Next to 1252	DF	5:22
220.1-9B	L DFB Next to 1252	DFB	5:23
220.1-10	1257 DF	DF	5:24
220.1-11	1257 Sink	Sink	5:25
220.1-12	1259 DF	DF	5:26
220.1-13	1259 Sink	Sink	5:28
220.1-14	1261 DF	DF	5:29
220.1-15	1261 Sink	Sink	5:30

### Notes:

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)  If checked, also e-mail results to: [Mscinta@stohlenvironmental.com](mailto:Mscinta@stohlenvironmental.com)

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 12/11/2025

Relinquished By: [Signature] Print Name Connor Crilly Stohl Env: Connor Crilly Date: 12/15/2025

Received (Name / Lab): [Signature] Date: 12/15/25 Time: 17:00

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_





# Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
 PHONE (716) 312-0070 FAX (716) 312-8092  
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-220.1

Client: Genesee Valley CSD

Contact: Chris Graham

Building: Genesee Valley Central School


Location: 1 Jaguar Drive, Belmont NY


<b>LEAD</b>		<i>Turnaround</i>
Water by 200.8	<u>X</u>	<u>10 Days</u>

Sample #	Location	Outlet Type	Time
220.1-16	1260 DF	DF	5:31
220.1-17	1260 Sink Next to DF	Sink	5:32
220.1-18	1260 Island Sink	Sink	5:33
220.1-19	1258 DF	DF	5:34
220.1-20	1258 Sink Next to DF	Sink	5:35
220.1-21	1258 Island Sink	Sink	5:37
220.1-22	L DF Next to 1262	DF	5:38
220.1-23A	R DF Next to 1262	DF	5:39
220.1-23B	R DFB Next to 1262	DFB	5:40
220.1-24	1262 DF	DF	5:41
220.1-25	1262 Sink	Sink	5:42
220.1-26	1263 DF	DF	5:43
220.1-27	1263 Sink	Sink	5:45
220.1-28	1265 DF	DF	5:46
220.1-29	1265 Sink	Sink	5:47
220.1-30	1267 DF	DF	5:48
220.1-31	1267 Sink	Sink	5:49
220.1-32	1269 DF	DF	5:50

Notes:  
 Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com) [Mscinta@stohlenvironmental.com](mailto:Mscinta@stohlenvironmental.com)

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 12/11/2025

Relinquished By:  Print Name Connor Crilly Stohl Env: Connor Crilly Date: 12/15/2025

Received (Name / Lab):  Date: 12/25/25 Time: 17:00

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



R2516862

5

Stohl Environmental  
Genesee Valley CSD - Central School



### Cooler Receipt and Preservation Check Form

Project/Client Stohl Folder Number \_\_\_\_\_

Cooler received on 12/15/25 by: MM

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>N</u>
2	Custody papers properly completed (ink, signed)?	Y <u>N</u>
3	Did all bottles arrive in good condition (unbroken)?	Y <u>N</u>
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>N</u>

5a	Did VOA vials have sig* bubbles?	Y N <u>NA</u>
5b	Sig* bubbles: Alk? Y N <u>NA</u> Sulfide? Y N <u>NA</u>	
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035set	<u>NA</u>

8. Temperature Readings Date: 12/15/25 Time: 17:17 ID: R#11 IR#12 IR#13 From: Temp Blank Sample Bottle

Temp (°C)	<u>11.6</u>						
Within 0-6°C?	Y <u>N</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: \_\_\_\_\_ Ice melted Poorly Packed (described below) Same Day Rule  
& Client Approval to Run Samples: \_\_\_\_\_ Standing Approval Client aware at drop-off Client notified by: \_\_\_\_\_

All samples held in storage location: SMO by MM on 12/15/25 at 17:19  
5035 samples placed in storage location: \_\_\_\_\_ by \_\_\_\_\_ on \_\_\_\_\_ at \_\_\_\_\_ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check\*\*: Date: 12/16/25 Time: 14:08 by: IT

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
- 13. Were dissolved metals filtered in the field? YES NO N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
<u>≤2</u>	<u>202325</u>	HNO <sub>3</sub>		✓			<u>20-1-1-20-132</u>	<u>4ml</u>	<u>275078</u>	<u>5.2</u>
≤2		H <sub>2</sub> SO <sub>4</sub>								
<4		NaHSO <sub>4</sub>								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> (625, 608, CN), ascorbic (phenol).					
		Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>								
		ZnAcetate	-	-						
		HCl	**	**						

\*\*VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 092925-2ER6

Explain all Discrepancies/ Other Comments: \_\_\_\_\_

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: IT \*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



## Miscellaneous Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



## REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- \* Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ( $\geq 100\%$  Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)  
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

### Rochester Lab ID # for State Accreditations<sup>1</sup>



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

<sup>1</sup> Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

# ALS Laboratory Group

---

## Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516862

**Sample Name:** 220.1-1  
**Lab Code:** R2516862-001  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-2  
**Lab Code:** R2516862-002  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-3  
**Lab Code:** R2516862-003  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-4A  
**Lab Code:** R2516862-004  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-4B  
**Lab Code:** R2516862-005  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516862

**Sample Name:** 220.1-5  
**Lab Code:** R2516862-006  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-6A  
**Lab Code:** R2516862-007  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-6B  
**Lab Code:** R2516862-008  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-7  
**Lab Code:** R2516862-009  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-8  
**Lab Code:** R2516862-010  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516862

**Sample Name:** 220.1-9A  
**Lab Code:** R2516862-011  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-9B  
**Lab Code:** R2516862-012  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-10  
**Lab Code:** R2516862-013  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-11  
**Lab Code:** R2516862-014  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-12  
**Lab Code:** R2516862-015  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516862

**Sample Name:** 220.1-13  
**Lab Code:** R2516862-016  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-14  
**Lab Code:** R2516862-017  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-15  
**Lab Code:** R2516862-018  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-16  
**Lab Code:** R2516862-019  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-17  
**Lab Code:** R2516862-020  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516862

**Sample Name:** 220.1-18  
**Lab Code:** R2516862-021  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-19  
**Lab Code:** R2516862-022  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-20  
**Lab Code:** R2516862-023  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-21  
**Lab Code:** R2516862-024  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-22  
**Lab Code:** R2516862-025  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516862

**Sample Name:** 220.1-23A  
**Lab Code:** R2516862-026  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-23B  
**Lab Code:** R2516862-027  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-24  
**Lab Code:** R2516862-028  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**  
GCONSTANTINO

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-25  
**Lab Code:** R2516862-029  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-26  
**Lab Code:** R2516862-030  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516862

**Sample Name:** 220.1-27  
**Lab Code:** R2516862-031  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-28  
**Lab Code:** R2516862-032  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-29  
**Lab Code:** R2516862-033  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-30  
**Lab Code:** R2516862-034  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-31  
**Lab Code:** R2516862-035  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**ALS Group USA, Corp.**

**dba ALS Environmental**

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516862

**Sample Name:** 220.1-32  
**Lab Code:** R2516862-036  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER



## PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

### INORGANIC

#### Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

#### Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

### ORGANIC

**Preparation Methods for Organic methods are listed in the header of the Results pages.**

#### Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



# Sample Results

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-1  
**Lab Code:** R2516862-001

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 16:11	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-2  
**Lab Code:** R2516862-002

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 16:13	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-3  
**Lab Code:** R2516862-003

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 16:14	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-4A  
**Lab Code:** R2516862-004

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0	ug/L	1.0	1	01/07/26 16:15	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-4B  
**Lab Code:** R2516862-005

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0	ug/L	1.0	1	01/07/26 16:17	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-5  
**Lab Code:** R2516862-006

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 16:18	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-6A  
**Lab Code:** R2516862-007

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 16:20	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-6B  
**Lab Code:** R2516862-008

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 16:21	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-7  
**Lab Code:** R2516862-009

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	01/07/26 16:22	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-8  
**Lab Code:** R2516862-010

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 16:27	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-9A  
**Lab Code:** R2516862-011

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 16:28	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-9B  
**Lab Code:** R2516862-012

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 16:29	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-10  
**Lab Code:** R2516862-013

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 16:31	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-11  
**Lab Code:** R2516862-014

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 16:38	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-12  
**Lab Code:** R2516862-015

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.0	ug/L	1.0	1	01/07/26 16:45	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-13  
**Lab Code:** R2516862-016

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 16:46	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-14  
**Lab Code:** R2516862-017

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 16:47	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-15  
**Lab Code:** R2516862-018

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 16:49	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-16  
**Lab Code:** R2516862-019

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	01/07/26 16:50	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-17  
**Lab Code:** R2516862-020

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 16:52	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-18  
**Lab Code:** R2516862-021

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 16:53	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-19  
**Lab Code:** R2516862-022

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 16:54	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-20  
**Lab Code:** R2516862-023

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 16:56	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-21  
**Lab Code:** R2516862-024

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 17:00	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-22  
**Lab Code:** R2516862-025

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 17:01	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-23A  
**Lab Code:** R2516862-026

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 17:03	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-23B  
**Lab Code:** R2516862-027

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 17:04	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-24  
**Lab Code:** R2516862-028

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	65.4	ug/L	0.50	1	01/07/26 15:05	01/06/26	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-25  
**Lab Code:** R2516862-029

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 17:06	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-26  
**Lab Code:** R2516862-030

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 17:07	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-27  
**Lab Code:** R2516862-031

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	01/07/26 17:08	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-28  
**Lab Code:** R2516862-032

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 17:10	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-29  
**Lab Code:** R2516862-033

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	01/07/26 17:11	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-30  
**Lab Code:** R2516862-034

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 17:12	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-31  
**Lab Code:** R2516862-035

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 17:25	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-32  
**Lab Code:** R2516862-036

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.3	ug/L	1.0	1	01/07/26 17:29	



## QC Summary Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2516862-MB1

**Service Request:** R2516862  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	ND U	ug/L	0.50	1	01/07/26 14:44	01/06/26	
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 17:22	NA	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2516862-MB2

**Service Request:** R2516862  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 16:35	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2516862-MB3

**Service Request:** R2516862  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 15:53	

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25  
**Date Analyzed:** 01/7/26

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 220.1-10  
**Lab Code:** R2516862-013  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2516862-013MS		Result	Duplicate Matrix Spike R2516862-013DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	20.3	20.0	102	21.9	20.0	110	70-130	8	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25  
**Date Analyzed:** 01/7/26

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 220.1-11  
**Lab Code:** R2516862-014  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2516862-014MS		Duplicate Matrix Spike R2516862-014DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	20.6	20.0	103	20.6	20.0	103	70-130	<1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25  
**Date Analyzed:** 01/7/26

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 220.1-30  
**Lab Code:** R2516862-034  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2516862-034MS		Result	Duplicate Matrix Spike R2516862-034DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	21.2	20.0	106	21.3	20.0	106	70-130	<1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water

**Service Request:** R2516862  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25  
**Date Analyzed:** 01/7/26

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 220.1-31  
**Lab Code:** R2516862-035  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2516862-035MS		Result	Duplicate Matrix Spike R2516862-035DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	20.8	20.0	104	21.1	20.0	106	70-130	2	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water

**Service Request:** R2516862

**Date Analyzed:** 01/07/26

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L

**Basis:**NA

**Lab Control Sample**  
R2516862-LCS1

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	21.4	20.0	107	85-115
Lead, Total	200.8	20.5	20.0	103	85-115

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water

**Service Request:** R2516862

**Date Analyzed:** 01/07/26

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L

**Basis:**NA

**Lab Control Sample**  
R2516862-LCS2

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	20.8	20.0	104	85-115

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water

**Service Request:** R2516862

**Date Analyzed:** 01/07/26

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L

**Basis:**NA

**Lab Control Sample**  
R2516862-LCS3

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	20.8	20.0	104	85-115



January 08, 2026

Service Request No:R2516865

Michael Scinta  
Stohl Environmental  
3860 California Road  
Orchard Park, NY 14219

**Laboratory Results for: Genesee Valley CSD - Central School**

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory December 15, 2025  
For your reference, these analyses have been assigned our service request number **R2516865**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at [Meghan.Pedro@alsglobal.com](mailto:Meghan.Pedro@alsglobal.com).

Respectfully submitted,

**ALS Group USA, Corp. dba ALS Environmental**

Meghan Pedro  
Project Manager

CC: Rebecca  
Franjoine

**ADDRESS** 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
**PHONE** +1 585 288 5380 | **FAX** +1 585 288 8475  
ALS Group USA, Corp.  
dba ALS Environmental



# Narrative Documents

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School  
**Sample Matrix:** Drinking Water

**Service Request:** R2516865  
**Date Received:** 12/15/2025

**CASE NARRATIVE**

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

**Sample Receipt:**

Thirty six drinking water samples were received for analysis at ALS Environmental on 12/15/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

**Metals:**

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by \_\_\_\_\_

Date 01/08/2026



### SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

<b>CLIENT ID: 220.1-34</b>	<b>Lab ID: R2516865-002</b>					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8

<b>CLIENT ID: 220.1-40B</b>	<b>Lab ID: R2516865-010</b>					
-----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	16.7			1.0	ug/L	200.8

<b>CLIENT ID: 220.1-41</b>	<b>Lab ID: R2516865-011</b>					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	63.2			1.0	ug/L	200.8

<b>CLIENT ID: 220.1-42</b>	<b>Lab ID: R2516865-012</b>					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.2			1.0	ug/L	200.8

<b>CLIENT ID: 220.1-53</b>	<b>Lab ID: R2516865-025</b>					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.0			1.0	ug/L	200.8

<b>CLIENT ID: 220.1-62</b>	<b>Lab ID: R2516865-034</b>					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.4			1.0	ug/L	200.8

<b>CLIENT ID: 220.1-63</b>	<b>Lab ID: R2516865-035</b>					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	12.0			1.0	ug/L	200.8



## Sample Receipt Information

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:**R2516865

**SAMPLE CROSS-REFERENCE**

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2516865-001	220.1-33	12/11/2025	
R2516865-002	220.1-34	12/11/2025	
R2516865-003	220.1-35	12/11/2025	
R2516865-004	220.1-36	12/11/2025	
R2516865-005	220.1-37	12/11/2025	
R2516865-006	220.1-38	12/11/2025	
R2516865-007	220.1-39A	12/11/2025	
R2516865-008	220.1-39B	12/11/2025	
R2516865-009	220.1-40A	12/11/2025	
R2516865-010	220.1-40B	12/11/2025	
R2516865-011	220.1-41	12/11/2025	
R2516865-012	220.1-42	12/11/2025	
R2516865-013	220.1-43	12/11/2025	
R2516865-014	220.1-44	12/11/2025	
R2516865-015	220.1-45A	12/11/2025	
R2516865-016	220.1-45B	12/11/2025	
R2516865-017	220.1-46	12/11/2025	
R2516865-018	220.1-47	12/11/2025	
R2516865-019	220.1-48	12/11/2025	
R2516865-020	220.1-49	12/11/2025	
R2516865-021	220.1-50A	12/11/2025	
R2516865-022	220.1-50B	12/11/2025	
R2516865-023	220.1-51	12/11/2025	
R2516865-024	220.1-52	12/11/2025	
R2516865-025	220.1-53	12/11/2025	
R2516865-026	220.1-54	12/11/2025	
R2516865-027	220.1-55	12/11/2025	
R2516865-028	220.1-56	12/11/2025	
R2516865-029	220.1-57	12/11/2025	
R2516865-030	220.1-58	12/11/2025	
R2516865-031	220.1-59	12/11/2025	
R2516865-032	220.1-60	12/11/2025	
R2516865-033	220.1-61	12/11/2025	
R2516865-034	220.1-62	12/11/2025	
R2516865-035	220.1-63	12/11/2025	
R2516865-036	220.1-64	12/11/2025	



# Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
 PHONE (716) 312-0070 FAX (716) 312-8092  
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-220.1

Client: Genesee Valley CSD

Contact: Chris Graham

Building: Genesee Valley Central School

Location: 1 Jaguar Drive, Belmont NY

**LEAD**

Water by 200.8 X

*Turnaround*

10 Days

Sample #	Location	Outlet Type	Time
220.1-33	1269 Sink	Sink	5:51
220.1-34	1266 DF	DF	5:52
220.1-35	1266 Sink	Sink	5:54
220.1-36	Main Office Sink	Sink	5:55
220.1-37	Guidance Sink	Sink	5:56
220.1-38	Guidance L DF	DF	5:57
220.1-39A	Guidance R DF	DF	5:58
220.1-39B	Guidance R DFB	DFB	5:59
220.1-40A	R DF Next to 1201	DF	6:00
220.1-40B	R DFB Next to 1201	DFB	6:02
220.1-41	L DF Next to 1201	DF	6:03
220.1-42	CSE Bathroom Sink	Sink	6:04
220.1-43	1121 Sink	Sink	6:05
220.1-44	1109 Sink	Sink	6:06
220.1-45A	L DF Near 1107	DF	6:07
220.1-45B	L DFB Near 1107	DFB	6:08
220.1-46	R DF Near 1107	DF	6:09
220.1-47	1102 L Sink	Sink	6:11

Notes:

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

[Mscinta@stohlenvironmental.com](mailto:Mscinta@stohlenvironmental.com)

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 12/11/2025

Relinquished By: [Signature] Print Name Connor Crilly Stohl Env: Connor Crilly Date: 12/15/2025

Received (Name / Lab): [Signature] Date: 12/15/25 Time: 17:00

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

**R2516865** **5**  
 Stohl Environmental  
 Genesee Valley CSD - Central School



# Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
 PHONE (716) 312-0070 FAX (716) 312-8092  
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-220.1

Client: Genesee Valley CSD

Contact: Chris Graham

Building: Genesee Valley Central School

Location: 1 Jaguar Drive, Belmont NY

**LEAD**

Water by 200.8 X


*Turnaround*

10 Days

Sample #	Location	Outlet Type	Time
220.1-48	1102 R Sink	Sink	6:12
220.1-49	1137 L DF	DF	6:13
220.1-50A	1137 R DF	DF	6:14
220.1-50B	1137 R DFB	DFB	6:15
2201.-51	2263 DF	DF	6:16
2201.-52	2263 Sink	Sink	6:17
2201.-53	2265 DF	DF	6:19
2201.-54	2265 Sink	Sink	6:20
2201.-55	2267 DF	DF	6:21
2201.-56	2267 Sink	Sink	6:22
2201.-57	2268 DF	DF	6:23
2201.-58	2268 Sink	Sink	6:24
2201.-59	2266 DF	DF	6:25
2201.-60	2266 Sink	Sink	6:26
2201.-61	2262 DF	DF	6:28
2201.-62	2262 Sink	Sink	6:29
220.1-63	2259 DF	DF	6:30
220.1-64	2259 Sink	Sink	6:31

Notes: Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com) [Mscinta@stohlenvironmental.com](mailto:Mscinta@stohlenvironmental.com)

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 12/11/2025

Relinquished By:  Print Name Connor Crilly Stohl Env: Connor Crilly Date: 12/15/2025

Received (Name / Lab): Matthew Long Date: 12/15/25 Time: 17:00

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



R2516865

5

Stohl Environmental  
Genesee Valley CSD - Central School



### Cooler Receipt and Preservation Check Form

Project/Client Stohl Folder Number \_\_\_\_\_

Cooler received on 12/15/25 by: MM

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="checkbox"/> N <input checked="" type="checkbox"/>	5a	Did VOA vials have sig* bubbles?	Y N <input checked="" type="checkbox"/> NA <input checked="" type="checkbox"/>
2	Custody papers properly completed (ink, signed)?	Y <input checked="" type="checkbox"/> N <input checked="" type="checkbox"/>	5b	Sig* bubbles: Alk? Y N <input checked="" type="checkbox"/> Sulfide? Y N <input checked="" type="checkbox"/> NA <input checked="" type="checkbox"/>	
3	Did all bottles arrive in good condition (unbroken)?	Y <input checked="" type="checkbox"/> N <input checked="" type="checkbox"/>	6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <input checked="" type="checkbox"/> N <input checked="" type="checkbox"/>	7	Soil VOA received as: Bulk Encore 5035set	<input checked="" type="checkbox"/> NA <input checked="" type="checkbox"/>

8. Temperature Readings Date: 12/15/25 Time: 17:17 ID: R#11 IR#12 IR#13 From: Temp Blank Sample Bottle

Temp (°C)	<u>11.6</u>						
Within 0-6°C?	Y <input checked="" type="checkbox"/> N <input checked="" type="checkbox"/>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: \_\_\_\_\_ Ice melted Poorly Packed (described below) Same Day Rule

& Client Approval to Run Samples: \_\_\_\_\_ Standing Approval Client aware at drop-off Client notified by: \_\_\_\_\_

All samples held in storage location: SMO by MM on 12/15/25 at 17:19  
 5035 samples placed in storage location: \_\_\_\_\_ by \_\_\_\_\_ on \_\_\_\_\_ at \_\_\_\_\_ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check\*\*: Date: 12/16/25 Time: 14:30 by: ET

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES  NO
- 10. Did all bottle labels and tags agree with custody papers? YES  NO
- 11. Were correct containers used for the tests indicated? YES  NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES  NO
- 13. Were dissolved metals filtered in the field? YES  NO

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
2	<u>202325</u>	HNO <sub>3</sub>	<input checked="" type="checkbox"/>		<u>24017806</u>	<u>1/27</u>	<u>33-60</u>	<u>4ml</u>	<u>245078</u>	<u>2</u>
2		H <sub>2</sub> SO <sub>4</sub>								
<4		NaHSO <sub>4</sub>								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> (625, 608, CN), ascorbic (phenol).					
		Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>								
		ZnAcetate	-	-						
		HCl	**	**						

\*\*VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 092925-2ERG, 072125-2E1J

Explain all Discrepancies/ Other Comments: \_\_\_\_\_

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: ET

\*significant air bubbles: VOA > 5-6 mm; WC > 1 in. diameter



## Miscellaneous Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



## REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- \* Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ( $\geq 100\%$  Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)  
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

### Rochester Lab ID # for State Accreditations<sup>1</sup>



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

<sup>1</sup> Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

# ALS Laboratory Group

---

## Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516865

**Sample Name:** 220.1-33  
**Lab Code:** R2516865-001  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-34  
**Lab Code:** R2516865-002  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-35  
**Lab Code:** R2516865-003  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-36  
**Lab Code:** R2516865-004  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-37  
**Lab Code:** R2516865-005  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516865

**Sample Name:** 220.1-38  
**Lab Code:** R2516865-006  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-39A  
**Lab Code:** R2516865-007  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-39B  
**Lab Code:** R2516865-008  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-40A  
**Lab Code:** R2516865-009  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-40B  
**Lab Code:** R2516865-010  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516865

**Sample Name:** 220.1-41  
**Lab Code:** R2516865-011  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-42  
**Lab Code:** R2516865-012  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-43  
**Lab Code:** R2516865-013  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-44  
**Lab Code:** R2516865-014  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-45A  
**Lab Code:** R2516865-015  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516865

**Sample Name:** 220.1-45B  
**Lab Code:** R2516865-016  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-46  
**Lab Code:** R2516865-017  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-47  
**Lab Code:** R2516865-018  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-48  
**Lab Code:** R2516865-019  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-49  
**Lab Code:** R2516865-020  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516865

**Sample Name:** 220.1-50A  
**Lab Code:** R2516865-021  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-50B  
**Lab Code:** R2516865-022  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-51  
**Lab Code:** R2516865-023  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-52  
**Lab Code:** R2516865-024  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-53  
**Lab Code:** R2516865-025  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516865

**Sample Name:** 220.1-54  
**Lab Code:** R2516865-026  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-55  
**Lab Code:** R2516865-027  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-56  
**Lab Code:** R2516865-028  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-57  
**Lab Code:** R2516865-029  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-58  
**Lab Code:** R2516865-030  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516865

**Sample Name:** 220.1-59  
**Lab Code:** R2516865-031  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-60  
**Lab Code:** R2516865-032  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-61  
**Lab Code:** R2516865-033  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-62  
**Lab Code:** R2516865-034  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-63  
**Lab Code:** R2516865-035  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**ALS Group USA, Corp.**

**dba ALS Environmental**

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516865

**Sample Name:** 220.1-64  
**Lab Code:** R2516865-036  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER



## PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

### INORGANIC

#### Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

#### Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

### ORGANIC

**Preparation Methods for Organic methods are listed in the header of the Results pages.**

#### Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



# Sample Results

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-33  
**Lab Code:** R2516865-001

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 17:31	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-34  
**Lab Code:** R2516865-002

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	01/07/26 17:32	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-35  
**Lab Code:** R2516865-003

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 17:33	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-36  
**Lab Code:** R2516865-004

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 17:35	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-37  
**Lab Code:** R2516865-005

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 17:39	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-38  
**Lab Code:** R2516865-006

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 17:40	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-39A  
**Lab Code:** R2516865-007

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 17:42	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-39B  
**Lab Code:** R2516865-008

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 17:43	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-40A  
**Lab Code:** R2516865-009

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 17:45	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-40B  
**Lab Code:** R2516865-010

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	16.7	ug/L	1.0	1	01/07/26 17:46	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-41  
**Lab Code:** R2516865-011

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	63.2	ug/L	1.0	1	01/07/26 17:47	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-42  
**Lab Code:** R2516865-012

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.2	ug/L	1.0	1	01/07/26 17:49	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-43  
**Lab Code:** R2516865-013

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 17:50	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-44  
**Lab Code:** R2516865-014

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 17:51	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-45A  
**Lab Code:** R2516865-015

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 17:56	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-45B  
**Lab Code:** R2516865-016

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 17:57	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-46  
**Lab Code:** R2516865-017

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 17:58	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-47  
**Lab Code:** R2516865-018

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 18:00	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-48  
**Lab Code:** R2516865-019

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 18:07	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-49  
**Lab Code:** R2516865-020

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 18:14	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-50A  
**Lab Code:** R2516865-021

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 18:15	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-50B  
**Lab Code:** R2516865-022

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 18:17	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-51  
**Lab Code:** R2516865-023

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 18:18	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-52  
**Lab Code:** R2516865-024

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 18:19	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-53  
**Lab Code:** R2516865-025

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.0	ug/L	1.0	1	01/07/26 18:21	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-54  
**Lab Code:** R2516865-026

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 18:22	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-55  
**Lab Code:** R2516865-027

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 18:24	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-56  
**Lab Code:** R2516865-028

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 18:25	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-57  
**Lab Code:** R2516865-029

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 18:29	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-58  
**Lab Code:** R2516865-030

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 18:31	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-59  
**Lab Code:** R2516865-031

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 18:32	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-60  
**Lab Code:** R2516865-032

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 18:33	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-61  
**Lab Code:** R2516865-033

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 18:35	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-62  
**Lab Code:** R2516865-034

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.4	ug/L	1.0	1	01/07/26 18:36	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-63  
**Lab Code:** R2516865-035

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	12.0	ug/L	1.0	1	01/07/26 18:37	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-64  
**Lab Code:** R2516865-036

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 18:39	



## QC Summary Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2516865-MB1

**Service Request:** R2516865  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 18:04	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2516865-MB2

**Service Request:** R2516865  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/07/26 17:22	

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25  
**Date Analyzed:** 01/7/26

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 220.1-47  
**Lab Code:** R2516865-018  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2516865-018MS		Duplicate Matrix Spike R2516865-018DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	20.2	20.0	101	20.0	20.0	100	70-130	1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water

**Service Request:** R2516865  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25  
**Date Analyzed:** 01/7/26

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 220.1-48  
**Lab Code:** R2516865-019  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2516865-019MS		Result	Duplicate Matrix Spike R2516865-019DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	20.7	20.0	104	19.9	20.0	100	70-130	4	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water

**Service Request:** R2516865  
**Date Analyzed:** 01/07/26

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L  
**Basis:**NA

**Lab Control Sample**  
R2516865-LCS1

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	20.8	20.0	104	85-115

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water

**Service Request:** R2516865  
**Date Analyzed:** 01/07/26

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L  
**Basis:**NA

**Lab Control Sample**  
R2516865-LCS2

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	20.5	20.0	103	85-115



January 15, 2026

Service Request No:R2516886

Michael Scinta  
Stohl Environmental  
3860 California Road  
Orchard Park, NY 14219

**Laboratory Results for: Genesee Valley CSD - Central School**

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory December 15, 2025  
For your reference, these analyses have been assigned our service request number **R2516886**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at [Meghan.Pedro@alsglobal.com](mailto:Meghan.Pedro@alsglobal.com).

Respectfully submitted,

**ALS Group USA, Corp. dba ALS Environmental**

Meghan Pedro  
Project Manager

CC: Rebecca  
Franjoine

**ADDRESS** 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
**PHONE** +1 585 288 5380 | **FAX** +1 585 288 8475  
ALS Group USA, Corp.  
dba ALS Environmental



# Narrative Documents

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School  
**Sample Matrix:** Drinking Water

**Service Request:** R2516886  
**Date Received:** 12/15/2025

**CASE NARRATIVE**

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

**Sample Receipt:**

Thirty six drinking water samples were received for analysis at ALS Environmental on 12/15/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

**Metals:**

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by \_\_\_\_\_

Date 01/15/2026



### SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 220.1-65		Lab ID: R2516886-001					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	12.8			0.50	ug/L	200.8	
CLIENT ID: 220.1-66		Lab ID: R2516886-002					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	5.6			1.0	ug/L	200.8	
CLIENT ID: 220.1-67		Lab ID: R2516886-003					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.8			1.0	ug/L	200.8	
CLIENT ID: 220.1-69		Lab ID: R2516886-005					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	69.6			0.50	ug/L	200.8	
CLIENT ID: 220.1-73		Lab ID: R2516886-010					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.6			1.0	ug/L	200.8	
CLIENT ID: 220.1-75		Lab ID: R2516886-012					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.65			0.50	ug/L	200.8	
CLIENT ID: 220.1-76		Lab ID: R2516886-013					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.9			1.0	ug/L	200.8	
CLIENT ID: 220.1-79		Lab ID: R2516886-016					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.3			1.0	ug/L	200.8	
CLIENT ID: 220.1-80		Lab ID: R2516886-017					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.6			1.0	ug/L	200.8	
CLIENT ID: 220.1-82		Lab ID: R2516886-019					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.0			1.0	ug/L	200.8	
CLIENT ID: 220.1-83		Lab ID: R2516886-020					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.4			1.0	ug/L	200.8	
CLIENT ID: 220.1-85		Lab ID: R2516886-022					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.3			1.0	ug/L	200.8	



### SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 220.1-91		Lab ID: R2516886-029				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.2			1.0	ug/L	200.8



## Sample Receipt Information

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:**R2516886

**SAMPLE CROSS-REFERENCE**

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2516886-001	220.1-65	12/11/2025	
R2516886-002	220.1-66	12/11/2025	
R2516886-003	220.1-67	12/11/2025	
R2516886-004	220.1-68	12/11/2025	
R2516886-005	220.1-69	12/11/2025	
R2516886-006	220.1-70	12/11/2025	
R2516886-007	220.1-71	12/11/2025	
R2516886-008	220.1-72A	12/11/2025	
R2516886-009	220.1-72B	12/11/2025	
R2516886-010	220.1-73	12/11/2025	
R2516886-011	220.1-74	12/11/2025	
R2516886-012	220.1-75	12/11/2025	
R2516886-013	220.1-76	12/11/2025	
R2516886-014	220.1-77	12/11/2025	
R2516886-015	220.1-78	12/11/2025	
R2516886-016	220.1-79	12/11/2025	
R2516886-017	220.1-80	12/11/2025	
R2516886-018	220.1-81	12/11/2025	
R2516886-019	220.1-82	12/11/2025	
R2516886-020	220.1-83	12/11/2025	
R2516886-021	220.1-84	12/11/2025	
R2516886-022	220.1-85	12/11/2025	
R2516886-023	220.1-86	12/11/2025	
R2516886-024	220.1-87	12/11/2025	
R2516886-025	220.1-88	12/11/2025	
R2516886-026	220.1-89A	12/11/2025	
R2516886-027	220.1-89B	12/11/2025	
R2516886-028	220.1-90	12/11/2025	
R2516886-029	220.1-91	12/11/2025	
R2516886-030	220.1-92	12/11/2025	
R2516886-031	220.1-93A	12/11/2025	
R2516886-032	220.1-93B	12/11/2025	
R2516886-033	220.1-94	12/11/2025	
R2516886-034	220.1-95A	12/11/2025	
R2516886-035	220.1-95B	12/11/2025	
R2516886-036	220.1-96	12/11/2025	



# Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
 PHONE (716) 312-0070 FAX (716) 312-8092  
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-220.1

Client: Genesee Valley CSD

Contact: Chris Graham

Building: Genesee Valley Central School

Location: 1 Jaguar Drive, Belmont NY

**LEAD**

Water by 200.8

X

Turnaround

10 Days

R2516886

Stohl Environmental  
Genesee Valley CSD - Central School



Sample #	Location	Outlet Type	Time
220.1-65	2261 DF	DF	6:32
220.1-66	2261 Sink	Sink	6:33
220.1-67	2260 DF	DF	6:34
220.1-68	2260 Sink	Sink	6:36
220.1-69	2258 DF	DF	6:37
220.1-70	2258 Sink	Sink	6:38
220.1-71	L DF Near 2259	DF	6:39
220.1-72A	R DF Near 2259	DF	6:40
220.1-72B	R DFB Near 2259	DFB	6:41
220.1-73	2240 DF	DF	6:42
220.1-74	2240 Sink	Sink	6:43
220.1-75	2239 DF	DF	6:45
220.1-76	2239 Sink	Sink	6:46
220.1-77	2234 DF	DF	6:47
220.1-78	2234 Sink	Sink	6:48
220.1-79	2232 DF	DF	6:49
220.1-80	2232 Sink	Sink	6:50
220.1-81	2230 DF	DF	6:51

**Notes:**

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

[Mscinta@stohlenvironmental.com](mailto:Mscinta@stohlenvironmental.com)

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 12/11/2025

Relinquished By: [Signature] Print Name Connor Crilly Stohl Env: Connor Crilly Date: 12/15/2025

Received (Name / Lab): [Signature] Date: 12/15/25 Time: 17:00

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



# Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
 PHONE (716) 312-0070 FAX (716) 312-8092  
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-220.1

Client: Genesee Valley CSD

Contact: Chris Graham

Building: Genesee Valley Central School

Location: 1 Jaguar Drive, Belmont NY

**LEAD**  
 Water by 200.8 X

*Turnaround*  
10 Days

Sample #	Location	Outlet Type	Time
220.1-82	2230 Sink	Sink	6:53
220.1-83	2220 DF	DF	6:54
220.1-84	2220 Sink	Sink	6:55
220.1-85	2218 DF	DF	6:56
220.1-86	2218 Sink	Sink	6:57
220.1-87	2216 DF	DF	6:58
220.1-88	2216 Sink	Sink	6:59
220.1-89A	L DF Near 2201	DF	7:00
220.1-89B	L DFB Near 2201	DFB	7:02
220.1-90	R DF Near 2201	DF	7:03
220.1-91	District Office Sink	Sink	7:04
220.1-92	L DF Near 2137	DF	7:05
220.1-93A	R DF Near 2137	DF	7:06
220.1-93B	R DFB Near 2137	DFB	7:07
220.1-94	2120 Sink	Sink	7:08
220.1-95A	DF Near 2106	DF	7:10
220.1-95B	DFB Near 2106	DFB	7:11
220.1-96	2101 #1 Sink	Sink	7:12

Notes: Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com) [Mscinta@stohlenvironmental.com](mailto:Mscinta@stohlenvironmental.com)

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 12/11/2025

Relinquished By: [Signature] Print Name Connor Crilly Stohl Env: Connor Crilly Date: 12/15/2025

Received (Name / Lab): [Signature] Date: 12/15/25 Time: 17:00

Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_




# Cooler Receipt and Preservation Check Form

R2516886

5

Stohl Environmental  
Genesee Valley CSD - Central School



Project/Client Stohl Folder Number \_\_\_\_\_

Cooler received on 12/15/25 by: MM

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>N</u>
2	Custody papers properly completed (ink, signed)?	Y <u>N</u>
3	Did all bottles arrive in good condition (unbroken)?	Y <u>N</u>
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>N</u>

5a	Did VOA vials have sig* bubbles?	Y N <u>NA</u>
5b	Sig* bubbles: Alk? Y N <u>NA</u> Sulfide? Y N <u>NA</u>	
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035set	<u>NA</u>

8. Temperature Readings Date: 12/15/25 Time: 17:17 ID: R#11 IR#12 IR#13 From: Temp Blank Sample Bottle

Temp (°C)	<u>11.6</u>						
Within 0-6°C?	Y <u>N</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: \_\_\_\_\_ Ice melted Poorly Packed (described below) Same Day Rule  
& Client Approval to Run Samples: \_\_\_\_\_ Standing Approval Client aware at drop-off Client notified by: \_\_\_\_\_

All samples held in storage location: SMD by MM on 12/15/25 at 17:19  
5035 samples placed in storage location: \_\_\_\_\_ by \_\_\_\_\_ on \_\_\_\_\_ at \_\_\_\_\_ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check\*\*: Date: 12/16/25 Time: 16:06 by: MM

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
- 13. Were dissolved metals filtered in the field? YES NO N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
>12		NaOH								
<u>2</u>	<u>202325</u>	HNO <sub>3</sub>	<u>Y</u>		<u>24017806</u>	<u>1/27</u>				
<u>2</u>		H <sub>2</sub> SO <sub>4</sub>								
<4		NaHSO <sub>4</sub>								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> (625, 608, CN), ascorbic (phenol).					
		Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>								
		ZnAcetate	-	-						
		HCl	**	**						

\*\*VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 072125-2EKJ  
Explain all Discrepancies/ Other Comments: \_\_\_\_\_

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: MM \*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



## Miscellaneous Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



## REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- \* Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ( $\geq 100\%$  Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)  
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

### Rochester Lab ID # for State Accreditations<sup>1</sup>



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

<sup>1</sup> Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

# ALS Laboratory Group

---

## Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516886

**Sample Name:** 220.1-65  
**Lab Code:** R2516886-001  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**  
MKASTAN

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-66  
**Lab Code:** R2516886-002  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 220.1-67  
**Lab Code:** R2516886-003  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 220.1-68  
**Lab Code:** R2516886-004  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 220.1-69  
**Lab Code:** R2516886-005  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**  
MKASTAN

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516886

**Sample Name:** 220.1-70  
**Lab Code:** R2516886-006  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 220.1-71  
**Lab Code:** R2516886-007  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 220.1-72A  
**Lab Code:** R2516886-008  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 220.1-72B  
**Lab Code:** R2516886-009  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 220.1-73  
**Lab Code:** R2516886-010  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516886

**Sample Name:** 220.1-74  
**Lab Code:** R2516886-011  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 220.1-75  
**Lab Code:** R2516886-012  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**  
MKASTAN

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-76  
**Lab Code:** R2516886-013  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** 220.1-77  
**Lab Code:** R2516886-014  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-78  
**Lab Code:** R2516886-015  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516886

**Sample Name:** 220.1-79  
**Lab Code:** R2516886-016  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-80  
**Lab Code:** R2516886-017  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-81  
**Lab Code:** R2516886-018  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-82  
**Lab Code:** R2516886-019  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-83  
**Lab Code:** R2516886-020  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516886

**Sample Name:** 220.1-84  
**Lab Code:** R2516886-021  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-85  
**Lab Code:** R2516886-022  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-86  
**Lab Code:** R2516886-023  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-87  
**Lab Code:** R2516886-024  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-88  
**Lab Code:** R2516886-025  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516886

**Sample Name:** 220.1-89A  
**Lab Code:** R2516886-026  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-89B  
**Lab Code:** R2516886-027  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-90  
**Lab Code:** R2516886-028  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-91  
**Lab Code:** R2516886-029  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-92  
**Lab Code:** R2516886-030  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516886

**Sample Name:** 220.1-93A  
**Lab Code:** R2516886-031  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-93B  
**Lab Code:** R2516886-032  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-94  
**Lab Code:** R2516886-033  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-95A  
**Lab Code:** R2516886-034  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-95B  
**Lab Code:** R2516886-035  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**ALS Group USA, Corp.**

dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516886

**Sample Name:** 220.1-96  
**Lab Code:** R2516886-036  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25

**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER



## PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

### INORGANIC

#### Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

#### Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

### ORGANIC

**Preparation Methods for Organic methods are listed in the header of the Results pages.**

#### Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



# Sample Results

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-65  
**Lab Code:** R2516886-001

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Date Extracted</b>	<b>Q</b>
Lead, Total	200.8	12.8	ug/L	0.50	1	01/12/26 13:15	01/09/26	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-66  
**Lab Code:** R2516886-002

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.6	ug/L	1.0	1	01/12/26 17:25	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-67  
**Lab Code:** R2516886-003

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.8	ug/L	1.0	1	01/12/26 17:27	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-68  
**Lab Code:** R2516886-004

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/12/26 17:28	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-69  
**Lab Code:** R2516886-005

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	69.6	ug/L	0.50	1	01/12/26 13:17	01/09/26	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-70  
**Lab Code:** R2516886-006

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/12/26 17:30	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-71  
**Lab Code:** R2516886-007

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/12/26 17:31	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-72A  
**Lab Code:** R2516886-008

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/12/26 17:33	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-72B  
**Lab Code:** R2516886-009

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/12/26 17:38	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-73  
**Lab Code:** R2516886-010

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.6	ug/L	1.0	1	01/12/26 17:39	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-74  
**Lab Code:** R2516886-011

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/12/26 17:41	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-75  
**Lab Code:** R2516886-012

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Date Extracted</b>	<b>Q</b>
Lead, Total	200.8	4.65	ug/L	0.50	1	01/12/26 13:18	01/09/26	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-76  
**Lab Code:** R2516886-013

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.9	ug/L	1.0	1	01/12/26 17:42	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-77  
**Lab Code:** R2516886-014

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 16:06	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-78  
**Lab Code:** R2516886-015

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 16:08	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-79  
**Lab Code:** R2516886-016

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	01/09/26 16:09	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-80  
**Lab Code:** R2516886-017

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.6	ug/L	1.0	1	01/09/26 16:11	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-81  
**Lab Code:** R2516886-018

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 16:12	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-82  
**Lab Code:** R2516886-019

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0	ug/L	1.0	1	01/09/26 16:13	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-83  
**Lab Code:** R2516886-020

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	1.4	ug/L	1.0	1	01/09/26 16:18	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-84  
**Lab Code:** R2516886-021

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 16:19	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-85  
**Lab Code:** R2516886-022

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	01/09/26 16:20	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-86  
**Lab Code:** R2516886-023

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 16:22	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-87  
**Lab Code:** R2516886-024

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:01	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-88  
**Lab Code:** R2516886-025

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:05	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-89A  
**Lab Code:** R2516886-026

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:06	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-89B  
**Lab Code:** R2516886-027

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:08	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-90  
**Lab Code:** R2516886-028

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:09	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-91  
**Lab Code:** R2516886-029

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.2	ug/L	1.0	1	01/09/26 17:10	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-92  
**Lab Code:** R2516886-030

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:15	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-93A  
**Lab Code:** R2516886-031

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:16	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-93B  
**Lab Code:** R2516886-032

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:17	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-94  
**Lab Code:** R2516886-033

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:19	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-95A  
**Lab Code:** R2516886-034

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:20	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-95B  
**Lab Code:** R2516886-035

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:22	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-96  
**Lab Code:** R2516886-036

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:23	



# QC Summary Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2516886-MB1

**Service Request:** R2516886  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	ND U	ug/L	0.50	1	01/12/26 12:39	01/09/26	
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 15:44	NA	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2516886-MB2

**Service Request:** R2516886  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 16:58	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2516886-MB3

**Service Request:** R2516886  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/12/26 17:01	

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25  
**Date Analyzed:** 01/12/26

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 220.1-76  
**Lab Code:** R2516886-013  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2516886-013MS		Result	Duplicate Matrix Spike R2516886-013DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	2.9	26.5	20.0	118	26.0	20.0	115	70-130	2	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25  
**Date Analyzed:** 01/9/26

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 220.1-86  
**Lab Code:** R2516886-023  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2516886-023MS		Result	Duplicate Matrix Spike R2516886-023DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	21.2	20.0	106	21.5	20.0	108	70-130	2	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water

**Service Request:** R2516886  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25  
**Date Analyzed:** 01/9/26

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 220.1-87  
**Lab Code:** R2516886-024  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2516886-024MS		Result	Duplicate Matrix Spike R2516886-024DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	20.2	20.0	101	20.9	20.0	104	70-130	3	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water

**Service Request:** R2516886  
**Date Analyzed:** 01/09/26 - 01/12/26

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L  
**Basis:**NA

**Lab Control Sample**  
R2516886-LCS1

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	21.2	20.0	106	85-115
Lead, Total	200.8	21.9	20.0	109	85-115

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water

**Service Request:** R2516886  
**Date Analyzed:** 01/09/26

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L  
**Basis:**NA

**Lab Control Sample**  
R2516886-LCS2

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	19.4	20.0	97	85-115

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water

**Service Request:** R2516886  
**Date Analyzed:** 01/12/26

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L  
**Basis:**NA

**Lab Control Sample**  
R2516886-LCS3

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	22.4	20.0	112	85-115



January 13, 2026

Service Request No:R2516888

Michael Scinta  
Stohl Environmental  
3860 California Road  
Orchard Park, NY 14219

**Laboratory Results for: Genesee Valley CSD - Central School**

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory December 15, 2025  
For your reference, these analyses have been assigned our service request number **R2516888**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at [Meghan.Pedro@alsglobal.com](mailto:Meghan.Pedro@alsglobal.com).

Respectfully submitted,

**ALS Group USA, Corp. dba ALS Environmental**

Meghan Pedro  
Project Manager

CC: Rebecca  
Franjoine

**ADDRESS** 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
**PHONE** +1 585 288 5380 | **FAX** +1 585 288 8475  
ALS Group USA, Corp.  
dba ALS Environmental



# Narrative Documents

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School  
**Sample Matrix:** Drinking Water

**Service Request:** R2516888  
**Date Received:** 12/15/2025

**CASE NARRATIVE**

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

**Sample Receipt:**

Twenty drinking water samples were received for analysis at ALS Environmental on 12/15/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

**Metals:**

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by \_\_\_\_\_

Date 01/13/2026



### SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

<b>CLIENT ID: 220.1-97</b>	<b>Lab ID: R2516888-001</b>					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.7			1.0	ug/L	200.8

<b>CLIENT ID: 220.1-99</b>	<b>Lab ID: R2516888-003</b>					
----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.1			1.0	ug/L	200.8

<b>CLIENT ID: 220.1-103</b>	<b>Lab ID: R2516888-008</b>					
-----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.2			1.0	ug/L	200.8

<b>CLIENT ID: 220.1-110</b>	<b>Lab ID: R2516888-018</b>					
-----------------------------	-----------------------------	--	--	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	0.62			0.50	ug/L	200.8



## Sample Receipt Information

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:**R2516888

**SAMPLE CROSS-REFERENCE**

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2516888-001	220.1-97	12/11/2025	
R2516888-002	220.1-98	12/11/2025	
R2516888-003	220.1-99	12/11/2025	
R2516888-004	220.1-100	12/11/2025	
R2516888-005	220.1-101A	12/11/2025	
R2516888-006	220.1-101B	12/11/2025	
R2516888-007	220.1-102	12/11/2025	
R2516888-008	220.1-103	12/11/2025	
R2516888-009	220.1-104	12/11/2025	
R2516888-010	220.1-105A	12/11/2025	
R2516888-011	220.1-105B	12/11/2025	
R2516888-012	220.1-106A	12/11/2025	
R2516888-013	220.1-106B	12/11/2025	
R2516888-014	220.1-107	12/11/2025	
R2516888-015	220.1-108A	12/11/2025	
R2516888-016	220.1-108B	12/11/2025	
R2516888-017	220.1-109	12/11/2025	
R2516888-018	220.1-110	12/11/2025	
R2516888-019	220.1-111	12/11/2025	
R2516888-020	220.1-112	12/11/2025	



# Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
 PHONE (716) 312-0070 FAX (716) 312-8092  
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-220.1

Client: Genesee Valley CSD

Contact: Chris Graham

Building: Genesee Valley Central School

Location: 1 Jaguar Drive, Belmont NY

**LEAD**

Water by 200.8

X

Turnaround

10 Days

**R2516888**  
 Stohl Environmental  
 Genesee Valley CSD - Central School



Sample #	Location	Outlet Type	Time
220.1-97	2101 #2 Sink	Sink	7:13
220.1-98	2101 #3 Sink	Sink	7:14
220.1-99	2101 #4 Sink	Sink	7:15
220.1-100	L DF Near 1155	DF	7:16
220.1-101A	R DF Near 1155	DF	7:17
220.1-101B	R DFB Near 1155	DFB	7:19
220.1-102	1159 Sink	Sink	7:20
220.1-103	1161 Sink	Sink	7:21
220.1-104	Fitness Center L DF	DF	7:22
220.1-105A	Fitness Center R DF	DF	7:23
220.1-105B	Fitness Center R DFB	DFB	7:24
220.1-106A	1170 L DF	DF	7:25
220.1-106B	1170 L DFB	DFB	7:27
220.1-107	1170 R DF	DF	7:28
220.1-108A	L DF Near 1294	DF	7:29
220.1-108B	L DFB Near 1294	DFB	7:30
220.1-109	R DF Near 1294	DF	7:31
220.1-110	1414 Hose	Hose	7:32

**Notes:**

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

[Mscinta@stohlenvironmental.com](mailto:Mscinta@stohlenvironmental.com)

Sampled By: Jared Rider Print Name Jared Rider Stohl Env: Jared Rider Date: 12/11/2025  
 Relinquished By: [Signature] Print Name Connor Crilly Stohl Env: Connor Crilly Date: 12/15/2025  
 Received (Name / Lab): [Signature] Date: 12/15/25 Time: 17:00  
 Sample Login (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Analysis (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 QA/QC Review (Name / Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_





# Cooler Receipt and Preservation Check Form

R2516888

5

Stahl Environmental  
Genesee Valley CSD - Central School



Project/Client Stahl Folder Number \_\_\_\_\_

Cooler received on 12/15/25 by: MM

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>N</u>	5a	Did VOA vials have sig* bubbles?	Y N <u>NA</u>
2	Custody papers properly completed (ink, signed)?	<u>Y</u> N	5b	Sig* bubbles: Alk? Y N <u>NA</u> Sulfide? Y N <u>NA</u>	
3	Did all bottles arrive in good condition (unbroken)?	<u>Y</u> N	6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>N</u>	7	Soil VOA received as: Bulk Encore 5035set	<u>NA</u>

8. Temperature Readings Date: 12/15/25 Time: 17:17 ID: IR#1 IR#2 IR#13 From: Temp Blank Sample Bottle

Temp (°C)	<u>11.6</u>						
Within 0-6°C?	Y <u>N</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: \_\_\_\_\_ Ice melted Poorly Packed (described below) Same Day Rule

& Client Approval to Run Samples: \_\_\_\_\_ Standing Approval Client aware at drop-off Client notified by: \_\_\_\_\_

All samples held in storage location: SMO by MM on 12/15/25 at 17:19  
5035 samples placed in storage location: \_\_\_\_\_ by \_\_\_\_\_ on \_\_\_\_\_ at \_\_\_\_\_ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check\*\*: Date: 12/16/25 Time: 16:25 by: MM

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
- 13. Were dissolved metals filtered in the field? YES NO N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
>12		NaOH								
<u>&lt;2</u>	<u>202325</u>	HNO <sub>3</sub>	<u>X</u>		<u>24017806</u>	<u>1/27</u>				
<2		H <sub>2</sub> SO <sub>4</sub>								
<4		NaHSO <sub>4</sub>								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> (625, 608, CN), ascorbic (phenol).					
		Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>								
		ZnAcetate	-	-						
		HCl	**	**						

\*\*VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 072125-2EKJ

Explain all Discrepancies/ Other Comments: \_\_\_\_\_

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: MM \*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



## Miscellaneous Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



## REPORT QUALIFIERS AND DEFINITIONS

- |   |  |
|---|--|
| <p><b>U</b> Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.</p> <p><b>J</b> Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration &gt;40% difference between two GC columns (pesticides/Aroclors).</p> <p><b>B</b> Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.</p> <p><b>E</b> Inorganics- Concentration is estimated due to the serial dilution was outside control limits.</p> <p><b>E</b> Organics- Concentration has exceeded the calibration range for that specific analysis.</p> <p><b>D</b> Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.</p> <p><b>*</b> Indicates that a quality control parameter has exceeded laboratory limits. Under the “Notes” column of the Form I, this qualifier denotes analysis was performed out of Holding Time.</p> <p><b>H</b> Analysis was performed out of hold time for tests that have an “immediate” hold time criteria.</p> <p><b>#</b> Spike was diluted out.</p> | <p><b>+</b> Correlation coefficient for MSA is &lt;0.995.</p> <p><b>N</b> Inorganics- Matrix spike recovery was outside laboratory limits.</p> <p><b>N</b> Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.</p> <p><b>S</b> Concentration has been determined using Method of Standard Additions (MSA).</p> <p><b>W</b> Post-Digestion Spike recovery is outside control limits and the sample absorbance is &lt;50% of the spike absorbance.</p> <p><b>P</b> Concentration &gt;40% difference between the two GC columns.</p> <p><b>C</b> Confirmed by GC/MS</p> <p><b>Q</b> DoD reports: indicates a pesticide/Aroclor is not confirmed (<math>\geq 100\%</math> Difference between two GC columns).</p> <p><b>X</b> See Case Narrative for discussion.</p> <p><b>MRL</b> Method Reporting Limit. Also known as:</p> <p><b>LOQ</b> Limit of Quantitation (LOQ)<br/>The lowest concentration at which the method analyte may be reliably quantified under the method conditions.</p> <p><b>MDL</b> Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).</p> <p><b>LOD</b> Limit of Detection. A value at or above the MDL which has been verified to be detectable.</p> <p><b>ND</b> Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.</p> |
|---|--|

### Rochester Lab ID # for State Accreditations<sup>1</sup>



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

<sup>1</sup> Analyses were performed according to our laboratory’s NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

# ALS Laboratory Group

---

## Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516888

**Sample Name:** 220.1-97  
**Lab Code:** R2516888-001  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-98  
**Lab Code:** R2516888-002  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-99  
**Lab Code:** R2516888-003  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-100  
**Lab Code:** R2516888-004  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-101A  
**Lab Code:** R2516888-005  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516888

**Sample Name:** 220.1-101B  
**Lab Code:** R2516888-006  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-102  
**Lab Code:** R2516888-007  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-103  
**Lab Code:** R2516888-008  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-104  
**Lab Code:** R2516888-009  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-105A  
**Lab Code:** R2516888-010  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516888

**Sample Name:** 220.1-105B  
**Lab Code:** R2516888-011  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-106A  
**Lab Code:** R2516888-012  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-106B  
**Lab Code:** R2516888-013  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-107  
**Lab Code:** R2516888-014  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-108A  
**Lab Code:** R2516888-015  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1

**Service Request:** R2516888

**Sample Name:** 220.1-108B  
**Lab Code:** R2516888-016  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-109  
**Lab Code:** R2516888-017  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-110  
**Lab Code:** R2516888-018  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**  
MKASTAN

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-111  
**Lab Code:** R2516888-019  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER

**Sample Name:** 220.1-112  
**Lab Code:** R2516888-020  
**Sample Matrix:** Drinking Water

**Date Collected:** 12/11/25  
**Date Received:** 12/15/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
DWINTER



## PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

### INORGANIC

#### Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

#### Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

### ORGANIC

**Preparation Methods for Organic methods are listed in the header of the Results pages.**

#### Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



# Sample Results

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-97  
**Lab Code:** R2516888-001

**Service Request:** R2516888  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.7	ug/L	1.0	1	01/09/26 17:24	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-98  
**Lab Code:** R2516888-002

**Service Request:** R2516888  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:26	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-99  
**Lab Code:** R2516888-003

**Service Request:** R2516888  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.1	ug/L	1.0	1	01/09/26 17:27	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-100  
**Lab Code:** R2516888-004

**Service Request:** R2516888  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:31	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-101A  
**Lab Code:** R2516888-005

**Service Request:** R2516888  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:33	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-101B  
**Lab Code:** R2516888-006

**Service Request:** R2516888  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:34	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-102  
**Lab Code:** R2516888-007

**Service Request:** R2516888  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:35	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-103  
**Lab Code:** R2516888-008

**Service Request:** R2516888  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	01/09/26 17:42	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-104  
**Lab Code:** R2516888-009

**Service Request:** R2516888  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:49	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-105A  
**Lab Code:** R2516888-010

**Service Request:** R2516888  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:51	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-105B  
**Lab Code:** R2516888-011

**Service Request:** R2516888  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:52	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-106A  
**Lab Code:** R2516888-012

**Service Request:** R2516888  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:54	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-106B  
**Lab Code:** R2516888-013

**Service Request:** R2516888  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:55	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-107  
**Lab Code:** R2516888-014

**Service Request:** R2516888  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:56	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-108A  
**Lab Code:** R2516888-015

**Service Request:** R2516888  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:58	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-108B  
**Lab Code:** R2516888-016

**Service Request:** R2516888  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:59	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-109  
**Lab Code:** R2516888-017

**Service Request:** R2516888  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 18:01	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-110  
**Lab Code:** R2516888-018

**Service Request:** R2516888  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	0.62	ug/L	0.50	1	01/12/26 13:19	01/09/26	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-111  
**Lab Code:** R2516888-019

**Service Request:** R2516888  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 18:06	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** 220.1-112  
**Lab Code:** R2516888-020

**Service Request:** R2516888  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25 17:00  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 18:08	



## QC Summary Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2516888-MB1

**Service Request:** R2516888  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	ND U	ug/L	0.50	1	01/12/26 12:39	01/09/26	
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 16:58	NA	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2516888-MB2

**Service Request:** R2516888  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/09/26 17:40	

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water

**Service Request:** R2516888  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25  
**Date Analyzed:** 01/9/26

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 220.1-102  
**Lab Code:** R2516888-007  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2516888-007MS		Duplicate Matrix Spike R2516888-007DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	21.6	20.0	108	21.6	20.0	108	70-130	<1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water

**Service Request:** R2516888  
**Date Collected:** 12/11/25  
**Date Received:** 12/15/25  
**Date Analyzed:** 01/9/26

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** 220.1-103  
**Lab Code:** R2516888-008  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2516888-008MS		Result	Duplicate Matrix Spike R2516888-008DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.2	21.9	20.0	104	21.1	20.0	100	70-130	4	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water

**Service Request:** R2516888  
**Date Analyzed:** 01/09/26 - 01/12/26

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L  
**Basis:**NA

**Lab Control Sample**  
R2516888-LCS1

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	21.2	20.0	106	85-115
Lead, Total	200.8	19.4	20.0	97	85-115

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Stohl Environmental  
**Project:** Genesee Valley CSD - Central School/2023L-220.1  
**Sample Matrix:** Drinking Water

**Service Request:** R2516888

**Date Analyzed:** 01/09/26

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L


**Basis:**NA

**Lab Control Sample**  
R2516888-LCS2

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	20.1	20.0	100	85-115

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2026  
Issued April 01, 2025

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**  
*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

**MS. CHRISTINE KUTZER**  
ALS ENVIRONMENTAL - ROCHESTER  
1565 JEFFERSON ROAD BUILDING 300, SUITE 360  
ROCHESTER, NY 14623


NY Lab Id No: 10145

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
National Environmental Laboratory Accreditation Conference Standards (2016) for the category  
ENVIRONMENTAL ANALYSES POTABLE WATER  
All approved analytes are listed below:*

<b>Bacteriology</b>	
Coliform, Total / E. coli (Qualitative)	SM 20, 21-23 9223B (-04) (Colliert)
<b>Dissolved Gases</b>	
Acetylene	RSK-175
Ethane	RSK-175
Ethene (Ethylene)	RSK-175
Methane	RSK-175
Propane	RSK-175
<b>Fuel Additives</b>	
Methyl tert-butyl ether	EPA 524.2
Naphthalene	EPA 524.2
<b>Metals I</b>	
Arsenic, Total	EPA 200.8 Rev. 5.4
Barium, Total	EPA 200.8 Rev. 5.4
Cadmium, Total	EPA 200.8 Rev. 5.4
Chromium, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Iron, Total	EPA 200.7 Rev. 4.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Mercury, Total	EPA 245.1 Rev. 3.0
Selenium, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Zinc, Total	EPA 200.7 Rev. 4.4

Serial No.: 70111

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-6570 or by email to [elap@health.ny.gov](mailto:elap@health.ny.gov).



Page 1 of 5