Belfast Central School

Lead in School Drinking Water Remedial Action Plan

Date Last Updated: 2/3/2026

School Outlet ID (Should match Sampling Plan)	Laboratory Sample ID	Outlet Location	Outlet Description	Was the outlet deemed 'Applicable' or 'Not Applicable' for sampling? *if not applicable place criteria in Notes/Comments	Sample Results (ppb or mcg/L) *if not applicable mark "N/A"		Remedial Actions (Please mark "x" for all that apply)													
												Actions Requiring Maintenance Schedule								
					Initial	Post Remediation	Date Taken out of Service	Date Retested	Date Returned to Service	Outlet / Plumbing Replacement	Permanent Removal	Filter Installed and Maintained	Signage	Supervision	Continuing Education	Systematic Flushing	Engineering Controls	Date(s) Remedial Action Taken	Notes/Comments
BCS Main Building	218.1-1	Kitchen Back Corner Handwash	Sink	Not Applicable	12.1		12/2/25					1/5/26	12/2/25			X			Hand Washing Station labeled with clear 'Do not Drink' signage.
BCS Main Building	218.1-2	Kitchen Center 2 Bay	Kitchen Sink	Applicable	7.2	**3.06**	12/2/25	1/23/26	1/30/2026			1/5/26	12/2/25			X			water filtration system with lead removal installed
BCS Main Building	218.1-4	Kitchen 3 Bay Left	Kitchen Sink	Applicable	5.5	**<1.00**	12/2/25	1/23/26	1/30/2026			1/5/26	12/2/25			X			water filtration system with lead removal installed
BCS Main Building	218.1-6	Kitchen 3 Bay Right	Kitchen Sink	Applicable	12.4	**2.99**	12/2/25	1/23/26	1/30/2026			1/5/26	12/2/25			X			water filtration system with lead removal installed
BCS Main Building	218.1-7	Kitchen Hand Wash by Cafe Entrance	Sink	Not Applicable	6.9	**<1.00**	12/2/25	1/23/26	1/30/2026				12/2/25			X			Hand Washing Station labeled with clear 'Do not Drink' signage.
BCS Main Building	218.1-8	Kitchen Lav	Restroom Sink	Not Applicable	5.3	**1.67**	12/2/25	1/23/26	1/30/2026				12/2/25			X			Tempered bathroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption
BCS Main Building	218.1-11	150 Kitchenette Sink	Sink	Applicable	9.6		12/2/25					1/5/26	12/2/25	X	X	X			
BCS Main Building	218.1-12	150 Left Lav	Restroom Sink	Not Applicable	14.7		12/2/25						12/2/25	X	X	X			Tempered bathroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption
BCS Main Building	218.1-13	150 Left Low Sink	Classroom Sink	Not Applicable	5.7		12/2/25						12/2/25	X	X	X			Classroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption
BCS Main Building	218.1-14	150 Right Low Sink	Classroom Sink	Not Applicable	7.5		12/2/25						12/2/25	X	X	X			Classroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption
BCS Main Building	218.1-15	150 Right Lav	Restroom Sink	Not Applicable	9.9		12/2/25						12/2/25	X	X	X			Tempered bathroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption
BCS Main Building	218.1-20	106D Faculty Room	Sink	Applicable	7	**1.2**	12/2/25	1/23/26	1/30/2026			1/5/26	12/2/25			X			
BCS Main Building	218.1-21	100 Main	Classroom Sink	Not Applicable	5.4		12/2/25						12/2/25	X	X	X			Classroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption
BCS Main Building	218.1-22	100 DF	Drinking Fountain	Applicable	5.4		12/2/25						12/2/25			X			
BCS Main Building	218.1-23	100 Lav	Restroom Sink	Not Applicable	6.4		12/2/25						12/2/25	X	X	X			Tempered bathroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption
BCS Main Building	218.1-25	101 DF	Drinking Fountain	Applicable	11.2		12/2/25						12/2/25			X			
BCS Main Building	218.1-26	101 Lav	Restroom Sink	Not Applicable	5.7		12/2/25						12/2/25	X	X	X			Tempered bathroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption
BCS Main Building	218.1-27	102 Main	Classroom Sink	Not Applicable	6.9		12/2/25						12/2/25	X	X	X			Classroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption
BCS Main Building	218.1-29	103 Main	Classroom Sink	Not Applicable	8.1		12/2/25						12/2/25	X	X	X			Classroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption
BCS Main Building	218.1-30	103 Lav	Restroom Sink	Not Applicable	5.2		12/2/25						12/2/25	X	X	X			Tempered bathroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption
BCS Main Building	218.1-31	104 Main	Classroom Sink	Not Applicable	8.8		12/2/25						12/2/25	X	X	X			Classroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption
BCS Main Building	218.1-32	104 DF	Drinking Fountain	Applicable	5.2		12/2/25						12/2/25			X			
BCS Main Building	218.1-33	104 Lav	Restroom Sink	Not Applicable	14.7		12/2/25						12/2/25	X	X	X			Tempered bathroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption
BCS Main Building	218.1-34	105 Main	Classroom Sink	Not Applicable	8		12/2/25						12/2/25	X	X	X			Classroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption
BCS Main Building	218.1-35	105 Lav	Restroom Sink	Not Applicable	7.1		12/2/25						12/2/25	X	X	X			Tempered bathroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption
BCS Main Building	218.1-37	Janitor Utility Sink Near 104	Janitor Sink	Not Applicable	15.1		12/2/25						12/2/25	X	X	X			Janitor closet: outlet marked do not drink; closet door closed and locked for limited access to prevent water from being used for cooking or drinking
BCS Main Building	218.1-43	Room 109	Janitor Sink	Not Applicable	58.7		12/2/25						12/2/25	X	X	X			Boiler Room: outlet marked do not drink; closet door closed and locked for limited access to prevent water from being used for cooking or drinking
BCS Main Building	218.1-48	Room 203	Classroom Sink	Not Applicable	5.5		12/2/25						12/2/25	X	X	X			Classroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption
BCS Main Building	218.1-63	Girls Locker Room L	Restroom Sink	Not Applicable	12.9		12/2/25						12/2/25	X	X	X			Tempered bathroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption
BCS Main Building	218.1-64	Girls Locker room R	Restroom Sink	Not Applicable	9.7		12/2/25						12/2/25	X	X	X			Tempered bathroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption
BCS Main Building	218.1-65	Girls Phys Ed Office	Restroom Sink	Not Applicable	8.8		12/2/25						12/2/25	X	X	X			Tempered bathroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption
BCS Main Building	218.1-66	Boys Phys Ed Office	Restroom Sink	Not Applicable	8.3		12/2/25						12/2/25	X	X	X			Tempered bathroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption
BCS Main Building	218.1-67	Boys Locker Room L	Restroom Sink	Not Applicable	13.9		12/2/25						12/2/25	X	X	X			Tempered bathroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption

BCS Main Building	218.1-68	Boys Locker Room R	Restroom Sink	Not Applicable	38.9		12/2/25						12/2/25	X	X	X			Tempered bathroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption
BCS Main Building	218.1-81	HS Art Room 142 Right	Classroom Sink	Not Applicable	36.4		12/2/25						12/2/25	X	X	X			Classroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption
Concessions/Athletic Field	218.3-7	Back L Bathroom	Restroom Sink	Not Applicable	9.4		12/2/25						12/2/25	X	X	X			Tempered bathroom sink with clear "Do Not Drink" signage. Staff and students educated to not use for consumption
Bus Garage	218.2-1	Bus Garage Locker Room	Sink	Not Applicable	6		12/2/25						12/2/25			X			Bus Garage does not house students.
Bus Garage	218.2-2	Bus Garage Men's Lav	Restroom Sink	Not Applicable	6.9		12/2/25						12/2/25			X			Bus Garage does not house students.