Sherman Central School

127 Park Street • P.O. Box 950 • Sherman, NY 14781-0950
phone (716) 761-6121 • fax (716) 761-6119
www.shermancsd.org



March 19, 2026

Dear School Community/Staff/Students:

It is a priority of every school district to maintain a safe and healthy learning environment for its students, and clean water is no exception. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead and restricted the lead content of faucets, pipes, and other plumbing materials. Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers, and lakes. New laws that went into effect in 2014 reduced the amount of lead that plumbing fixtures can contain from 8% to 1%. Brass faucets, fittings and valves – including those advertised as "lead free" – may still contribute lead to drinking water.

The Sherman Central School District is in compliance with New York State Public Health Laws requiring all schools and Boards of Cooperative Educational Services (BOCES) to test potable water outlets for lead contamination, to remediate contamination where found, and to notify parents of children and the public of test results. Levels of lead at any water outlet above 5 parts per billion (ppb) require action to remediate this issue.

As required, the Sherman Central School District tested all applicable water sources in every building for lead on March 4, 2026. As provided to us under specific protocols, first draw water samples were taken after letting the water remain unmoving in the pipes over a period of 8 to 18 hours. The results of this testing were received on March 17, 2026 and of the 71 water samples tested, only 14 showed lead levels above the 5 ppb mark.

Listed below are the areas that exceeded the threshold of 5 ppb:

- K-3, Dishwasher Room Hand Wash Sink, 36.9 ppb
- K-10, Kitchen Dishwashing Sink, 8.50 ppb
- 3-18, Rm 172 Sink, 5.57 ppb
- 5-16, Rm 265 Sink, 7.51 ppb
- 5-17, Rm 263 Sink, 17.8 ppb
- B-5, Bus Garage, 10.8 ppb

While we will be taking measures to resolve these sources, we are pleased to report that student drinking fountains and areas where water is used in food preparation are all at acceptable levels. The Sherman Central District is taking a number of steps to correct the problem. We have shut off the water supply to those fixtures used for drinking or cooking. Any water sources used for other purposes such as handwashing and general cleaning have been clearly labeled with warning signs not to be used for drinking or cooking. The next step is to develop a remediation plan that will be approved and guided by the experts in the field of water remediation.

The timetable for remediation of each of the identified sources will depend on the availability of parts, installation, and the process for retesting. It is important to note that none of the sources will be put back into service and

Mrs. Carrie Yohe • Superintendent
Mrs. Leslie Melquist • PreK-12 Principal
Mrs. Kati Carcaterro • Director of Pupil Services

Board of Education
Mrs. Teresa Guzman • President
Mrs. Brooke Long • Vice President
Mrs. Emily Reynolds
Mr. Joe DeLellis
Mrs. Kathy Sweatman

Mrs. Kimberly Oehlbeck • School Business Administrator
Ms. Kristin Irwin • District Clerk

Sherman Central School

127 Park Street • P.O. Box 950 • Sherman, NY 14781-0950
phone (716) 761-6121 • fax (716) 761-6119
www.shermancsd.org



available for drinking or cooking until the sources are fully mitigated and meet New York State Department of Health Standards.

A copy of our water testing results are available at the Director of Facilities office, which is open Monday through Friday from 8:00 am to 4:00 pm. Results are also posted on the District website at www.shermancsd.org.

For more information about water quality and sampling for lead contact the Erie County Department of Health at 961-6800 or the Chautauqua County Department of Health and Human Services at 753-4000.

Sincerely,

Mrs. Carrie Yohe
Superintendent

Mrs. Carrie Yohe • Superintendent
Mrs. Leslie Melquist • PreK-12 Principal
Mrs. Kati Carcaterro • Director of Pupil Services

Board of Education
Mrs. Teresa Gurman • President
Mrs. Brooke Long • Vice President
Mrs. Emily Reynolds
Mr. Joe DeLellis
Mrs. Kathy Sweatman

Mrs. Kimberly Oehlbeck • School Business Administrator
Ms. Kristin Irwin • District Clerk

CERTIFICATE OF ANALYSIS

F6C0399

Analytical Testing Parameters

Client Sample ID: Gr-3A
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-01
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:13

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.0000612	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1457	03/11/26 1541	DLO

Client Sample ID: Gr-3B
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-02
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:14

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.0000612	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1457	03/11/26 1547	DLO

Client Sample ID: Gr-11A
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-03
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:23

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.0000612	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1457	03/11/26 1549	DLO

Client Sample ID: Gr-11B
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-04
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:23

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.0000612	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1457	03/11/26 1551	DLO

Client Sample ID: Gr-13
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-05
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:25

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
d	<0.0000612	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1457	03/11/26 1552	DLO

CERTIFICATE OF ANALYSIS

F6C0399

Client Sample ID:	Gr-14		
Sample Matrix:	Drinking Water	**Collected By:**	Jared Oehlbeck
Lab Sample ID:	F6C0399-06	**Collection Date:**	03/04/2026 5:25

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	<0.0000612	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1457	03/11/26 1554	DLO

Client Sample ID:	K-1		
Sample Matrix:	Drinking Water	**Collected By:**	Jared Oehlbeck
Lab Sample ID:	F6C0399-07	**Collection Date:**	03/04/2026 5:17

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00403	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1457	03/11/26 1600	DLO

Client Sample ID:	K-2		
Sample Matrix:	Drinking Water	**Collected By:**	Jared Oehlbeck
ab Sample ID:	F6C0399-08	**Collection Date:**	03/04/2026 5:18

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00274	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1457	03/11/26 1602	DLO

Client Sample ID:	K-3		
Sample Matrix:	Drinking Water	**Collected By:**	Jared Oehlbeck
Lab Sample ID:	F6C0399-09	**Collection Date:**	03/04/2026 5:18

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	**0.0369**	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1457	03/11/26 1603	DLO

Client Sample ID:	K-4		
Sample Matrix:	Drinking Water	**Collected By:**	Jared Oehlbeck
Lab Sample ID:	F6C0399-10	**Collection Date:**	03/04/2026 5:18

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00266	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1457	03/11/26 1605	DLO

CERTIFICATE OF ANALYSIS

F6C0399

Client Sample ID: K-5
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-11
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:19

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00185	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1457	03/11/26 1607	DLO

Client Sample ID: K-6
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-12
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:19

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00160	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1457	03/11/26 1611	DLO

Client Sample ID: K-7
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-13
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:19

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00265	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1457	03/11/26 1613	DLO

Client Sample ID: K-8
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-14
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:20

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00224	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1457	03/11/26 1614	DLO

Client Sample ID: K-9
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-15
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:20

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	**0.0373**	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1457	03/11/26 1616	DLO

CERTIFICATE OF ANALYSIS

F6C0399

Client Sample ID:	K-10		
Sample Matrix:	Drinking Water	**Collected By:**	Jared Oehlbeck
Lab Sample ID:	F6C0399-16	**Collection Date:**	03/04/2026 5:20

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	**0.00850**	0.00500 AL	0.000122	0.00100	mg/L		03/11/26 1457	03/12/26 1452	DLO

Client Sample ID:	K-11		
Sample Matrix:	Drinking Water	**Collected By:**	Jared Oehlbeck
Lab Sample ID:	F6C0399-17	**Collection Date:**	03/04/2026 5:21

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00272	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1457	03/11/26 1624	DLO

Client Sample ID:	3-1		
Sample Matrix:	Drinking Water	**Collected By:**	Jared Oehlbeck
Lab Sample ID:	F6C0399-18	**Collection Date:**	03/04/2026 5:35

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.000471	0.00500 AL	0.0000612	0.00100	mg/L	J	03/11/26 1457	03/11/26 1626	DLO

Client Sample ID:	3-2		
Sample Matrix:	Drinking Water	**Collected By:**	Jared Oehlbeck
Lab Sample ID:	F6C0399-19	**Collection Date:**	03/04/2026 5:35

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.000298	0.00500 AL	0.0000612	0.00100	mg/L	J	03/11/26 1457	03/11/26 1627	DLO

Client Sample ID:	3-3		
Sample Matrix:	Drinking Water	**Collected By:**	Jared Oehlbeck
Lab Sample ID:	F6C0399-20	**Collection Date:**	03/04/2026 5:35

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.000188	0.00500 AL	0.0000612	0.00100	mg/L	J	03/11/26 1457	03/11/26 1629	DLO

CERTIFICATE OF ANALYSIS

F6C0399

Client Sample ID: 3-6
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-21
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:38

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.000652	0.00500 AL	0.0000612	0.00100	mg/L	J	03/11/26 1458	03/11/26 1638	DLO

Client Sample ID: 3-7
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-22
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:38

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.000360	0.00500 AL	0.0000612	0.00100	mg/L	J	03/11/26 1458	03/11/26 1644	DLO

Client Sample ID: 3-8
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-23
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:38

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.000346	0.00500 AL	0.0000612	0.00100	mg/L	J	03/11/26 1458	03/11/26 1646	DLO

Client Sample ID: 3-10
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-24
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:39

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.000891	0.00500 AL	0.0000612	0.00100	mg/L	J	03/11/26 1458	03/11/26 1648	DLO

Client Sample ID: 3-12
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-25
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:41

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00176	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1458	03/11/26 1650	DLO

CERTIFICATE OF ANALYSIS

F6C0399

Client Sample ID: 3-13
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-26
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:42

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00134	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1458	03/11/26 1651	DLO

Client Sample ID: 3-14
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-27
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:42

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.000886	0.00500 AL	0.0000612	0.00100	mg/L	J	03/11/26 1458	03/11/26 1657	DLO

Client Sample ID: 3-15
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-28
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:42

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00105	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1458	03/11/26 1659	DLO

Client Sample ID: 3-33
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-29
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:48

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00187	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1458	03/11/26 1701	DLO

Client Sample ID: 3-34
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-30
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:48

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.000509	0.00500 AL	0.0000612	0.00100	mg/L	J	03/11/26 1458	03/11/26 1702	DLO

CERTIFICATE OF ANALYSIS

F6C0399

Client Sample ID: 3-35
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-31
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:49

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.000773	0.00500 AL	0.0000612	0.00100	mg/L	J	03/11/26 1458	03/11/26 1704	DLO

Client Sample ID: 3-36
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-32
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:49

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.00236	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1458	03/11/26 1708	DLO

Client Sample ID: 3-37
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-33
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:50

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.00112	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1458	03/11/26 1710	DLO

Client Sample ID: 3-38
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-34
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:50

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.00123	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1458	03/11/26 1712	DLO

Client Sample ID: 3-39
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-35
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:50

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.00198	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1458	03/11/26 1713	DLO

CERTIFICATE OF ANALYSIS

F6C0399

Client Sample ID:	3-45		
Sample Matrix:	Drinking Water	**Collected By:**	Jared Oehlbeck
Lab Sample ID:	F6C0399-36	**Collection Date:**	03/04/2026 5:37

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	<0.0000612	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1458	03/11/26 1719	DLO

Client Sample ID:	5-1		
Sample Matrix:	Drinking Water	**Collected By:**	Jared Oehlbeck
Lab Sample ID:	F6C0399-38	**Collection Date:**	03/04/2026 5:57

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	<0.0000612	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1458	03/11/26 1721	DLO

Client Sample ID:	5-2		
Sample Matrix:	Drinking Water	**Collected By:**	Jared Oehlbeck
Lab Sample ID:	F6C0399-39	**Collection Date:**	03/04/2026 6:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	<0.0000612	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1458	03/11/26 1723	DLO

Client Sample ID:	5-10		
Sample Matrix:	Drinking Water	**Collected By:**	Jared Oehlbeck
Lab Sample ID:	F6C0399-40	**Collection Date:**	03/04/2026 6:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00178	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1458	03/11/26 1725	DLO

Client Sample ID:	5-11		
Sample Matrix:	Drinking Water	**Collected By:**	Jared Oehlbeck
Lab Sample ID:	F6C0399-41	**Collection Date:**	03/04/2026 6:01

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00137	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1500	03/11/26 1833	DLO

CERTIFICATE OF ANALYSIS

F6C0399

Client Sample ID: 5-12
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-42
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 6:01

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.000896	0.00500 AL	0.0000612	0.00100	mg/L	J	03/11/26 1500	03/11/26 1838	DLO

Client Sample ID: 5-13
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-43
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 6:01

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00228	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1500	03/11/26 1840	DLO

Client Sample ID: 5-14
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-44
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 6:01

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	<0.0000612	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1500	03/11/26 1842	DLO

Client Sample ID: 5-15
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-45
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 6:01

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	<0.0000612	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1500	03/11/26 1844	DLO

Client Sample ID: 5-16
Sample Matrix: Drinking Water
Lab Sample ID: F6C0399-46
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 6:03

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	**0.00751**	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1500	03/11/26 1846	DLO

MICROBAC®

Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

F6C0399

Client Sample ID:	5-17		
Sample Matrix:	Drinking Water	**Collected By:**	Jared Oehlbeck
Lab Sample ID:	F6C0399-47	**Collection Date:**	03/04/2026 6:03

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	**0.0178**	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1500	03/11/26 1851	DLO

*Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.*

CERTIFICATE OF ANALYSIS

F6C0397

Analytical Testing Parameters

Client Sample ID: Gr-2
Sample Matrix: Drinking Water
Lab Sample ID: F6C0397-01
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:15

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.000560	0.00500 AL	0.0000612	0.00100	mg/L	J	03/11/26 1459	03/11/26 1736	DLO

Client Sample ID: Gr-4
Sample Matrix: Drinking Water
Lab Sample ID: F6C0397-02
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:16

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.000923	0.00500 AL	0.0000612	0.00100	mg/L	J	03/11/26 1459	03/11/26 1741	DLO

Client Sample ID: Gr-8
Sample Matrix: Drinking Water
Lab Sample ID: F6C0397-03
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 7:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	<0.0000612	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1459	03/11/26 1743	DLO

Client Sample ID: Gr-9
Sample Matrix: Drinking Water
Lab Sample ID: F6C0397-04
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:26

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00236	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1459	03/11/26 1745	DLO

Client Sample ID: Gr-10
Sample Matrix: Drinking Water
Lab Sample ID: F6C0397-05
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:26

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00343	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1459	03/11/26 1747	DLO

CERTIFICATE OF ANALYSIS

F6C0397

Client Sample ID: 2-1
Sample Matrix: Drinking Water
Lab Sample ID: F6C0397-06
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:29

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	<0.0000612	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1459	03/11/26 1748	DLO

Client Sample ID: 2-2
Sample Matrix: Drinking Water
Lab Sample ID: F6C0397-07
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:29

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	<0.0000612	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1459	03/11/26 1754	DLO

Client Sample ID: 2-3
Sample Matrix: Drinking Water
Lab Sample ID: F6C0397-08
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:32

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.000965	0.00500 AL	0.0000612	0.00100	mg/L	J	03/11/26 1459	03/11/26 1756	DLO

Client Sample ID: 2-4
Sample Matrix: Drinking Water
Lab Sample ID: F6C0397-09
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:32

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.000760	0.00500 AL	0.0000612	0.00100	mg/L	J	03/11/26 1459	03/11/26 1758	DLO

Client Sample ID: 2-5
Sample Matrix: Drinking Water
Lab Sample ID: F6C0397-10
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:32

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00109	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1459	03/11/26 1759	DLO

CERTIFICATE OF ANALYSIS

F6C0397

Client Sample ID: 2-6
Sample Matrix: Drinking Water
Lab Sample ID: F6C0397-11
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:32

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.0000918	0.00500 AL	0.0000612	0.00100	mg/L	J	03/11/26 1459	03/11/26 1801	DLO

Client Sample ID: 3-16
Sample Matrix: Drinking Water
Lab Sample ID: F6C0397-12
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:44

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00141	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1459	03/11/26 1805	DLO

Client Sample ID: 3-17
Sample Matrix: Drinking Water
Lab Sample ID: F6C0397-13
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:44

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00178	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1459	03/11/26 1807	DLO

Client Sample ID: 3-18
Sample Matrix: Drinking Water
Lab Sample ID: F6C0397-14
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:44

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	**0.00557**	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1459	03/11/26 1809	DLO

Client Sample ID: 3-22
Sample Matrix: Drinking Water
Lab Sample ID: F6C0397-15
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:46

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00453	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1459	03/11/26 1810	DLO

CERTIFICATE OF ANALYSIS

F6C0397

Client Sample ID:	3-23		
Sample Matrix:	Drinking Water	**Collected By:**	Jared Oehlbeck
Lab Sample ID:	F6C0397-16	**Collection Date:**	03/04/2026 5:46

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00169	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1459	03/11/26 1816	DLO

Client Sample ID:	3-24		
Sample Matrix:	Drinking Water	**Collected By:**	Jared Oehlbeck
Lab Sample ID:	F6C0397-17	**Collection Date:**	03/04/2026 5:46

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00199	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1459	03/11/26 1818	DLO

Client Sample ID:	4-5		
Sample Matrix:	Drinking Water	**Collected By:**	Jared Oehlbeck
Lab Sample ID:	F6C0397-18	**Collection Date:**	03/04/2026 5:54

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00371	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1459	03/11/26 1820	DLO

Client Sample ID:	4-6		
Sample Matrix:	Drinking Water	**Collected By:**	Jared Oehlbeck
Lab Sample ID:	F6C0397-19	**Collection Date:**	03/04/2026 5:54

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	0.00179	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1459	03/11/26 1822	DLO

Client Sample ID:	4-7		
Sample Matrix:	Drinking Water	**Collected By:**	Jared Oehlbeck
Lab Sample ID:	F6C0397-20	**Collection Date:**	03/04/2026 5:54

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)									
Lead	<0.0000612	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1459	03/11/26 1823	DLO

CERTIFICATE OF ANALYSIS

F6C0397

Client Sample ID: 4-8
Sample Matrix: Drinking Water
Lab Sample ID: F6C0397-21
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 5:54

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.0000612	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1500	03/11/26 1858	DLO

Client Sample ID: 6-4
Sample Matrix: Drinking Water
Lab Sample ID: F6C0397-22
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 6:07

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.0000612	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1500	03/11/26 1853	DLO

Client Sample ID: 6-5
Sample Matrix: Drinking Water
Lab Sample ID: F6C0397-23
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 6:07

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.0000653	0.00500 AL	0.0000612	0.00100	mg/L	J	03/11/26 1500	03/11/26 1855	DLO

Client Sample ID: B-1
Sample Matrix: Drinking Water
Lab Sample ID: F6C0397-24
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 6:18

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.000703	0.00500 AL	0.0000612	0.00100	mg/L	J	03/11/26 1500	03/11/26 1857	DLO

Client Sample ID: B-5
Sample Matrix: Drinking Water
Lab Sample ID: F6C0397-25
Collected By: Jared Oehlbeck
Collection Date: 03/04/2026 6:18

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	MDL	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	**0.0108**	0.00500 AL	0.0000612	0.00100	mg/L		03/11/26 1500	03/11/26 1902	DLO

*Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.*