

CUPERTINO UNION SCHOOL DISTRICT

10301 Vista Drive

Cupertino, CA 95014

ADDENDUM NO. 03

26-IB03-35

District Plumbing Parts

DATE: March 24, 2026

Notice is hereby given that the following revisions, additions and/or deletions are made a part of and incorporated into the IFB #26-IB03-35 dated 3/24/2026. This addendum is issued to provide for modifications and clarifications to the IFB documents. Bidder shall ascertain prior to submitting their proposal that they have received all addenda issued.

In the event of a conflict between the terms and provisions of this addendum and the terms and provisions of the RFQ documents, the terms and provisions of this addendum shall control. In all other respects, the RFQ documents shall remain unchanged and in full force and effect.

DESCRIPTION: This addendum is issued to answer questions submitted by prospective bidders, to clarify aspects of the IFB and to supply requested supplemental information.

Question: The vendor informed me that the 950 backflow is available only up to two inches.

Answer: Additional part information

Original Part

909 Watts

6" Wilkins 950

Updated part information

4" Wilkins 375ASTR w/spool

6" Wilkins 350ASTR w/OSY 62" flange to flange

END OF ADDENDUM NO. 03