

Water Quality Action Plan

March 2026



								Post-Remediation				Second Post-Remediation			
School	Room Type	Fixture Type	Location	Communication to site	DOH Initial Sampling Dates	DOH test results (PPB)	Actions	Sampling dates	Results (PPB)	Communication to site	Actions	Sampling dates	Results (PPB)	Communication to site	Actions
Edgerton	Classroom	Fountain	22-01-123	Shut down as soon as practicable. Posted signage temporarily shut down	2024	80	The signage was removed. Permanent fountain removal								
Edgerton	Classroom Kitchen	Sink	22-01-113A	Shut down as soon as practicable. Posted signage temporarily shut down	2024	19	Fixture replacement	2024	2	Yes	The The signage was removed. Turned on .				
Edgerton	Classroom	Sink	22-01-123	Posted signage hand wash only	2024	11	Fixture replacement	2024	6	Yes	Signage remains posted. No further action required				
Edgerton	Kitchen	Food Prep Sink #3 of 3	22-01-135	Posted signage prewash/dish rinse station only	2024	10	Fixture replacement	2024	6	Yes	Signage remains posted. Filter installed	2025	1	Yes	The signage was removed. No further action required
Edgerton	Classroom	Sink	22-01-119	Posted signage hand wash only	2024	9	Signage remains posted. No further action required								
Edgerton	Classroom	Sink	22-01-107	Posted signage hand wash only	2024	8	Signage remains posted. No further action needed								
Edgerton	Classroom	Fountain	22-01-115	Shut down as soon as practicable. Posted signage temporarily shut down	2024	8	The signage was removed. Permanent fountain removal								
Edgerton	Hallway	Fountain/ Right	22-01-H02	Shut down as soon as practicable. Posted signage temporarily shut down	2024	8	Fixture replacement	2024	17	Yes	Signage remains posted. Water filling station installed	2025	<1	Yes	The The signage was removed. Turned on
Edgerton	Classroom	Sink	22-01-109	Posted signage hand wash only	2024	7	Signage remains posted. No further action required								
Edgerton	Classroom	Sink	22-01-113	Posted signage hand wash only	2024	7	Signage remains posted. No further action required								
Edgerton	Classroom	Sink	22-01-203	Posted signage hand wash only	2024	6	Signage remains posted. No further action required								
Edgerton	Classroom	Sink	22-01-209	Posted signage hand wash only	2024	6	Signage remains posted. No further action required								
Edgerton	Kitchen	Sink - multicompart ment #1 of 3 right	22-01-135	Posted signage prewash dish rinse station only	2024	6	Fixture replacement	2024	2	Yes	The signage was removed. No further action is required.				

Water Quality Action Plan

March 2026



Kalles	Culinary Classroom	Sink #6 of 9	34-01-138	Posted signage hand wash only	2024	6	Fixture replacement	2024	4	Yes	The signage was removed. Turned on				
Kalles	Culinary Classroom	Sink # 8 of 9	34-01-138	Posted signage hand wash only	2024	6	Fixture replacement	2024	6	Yes	Signage remains posted. Filter installed	2025	<1	Yes	The signage was removed. Turned on
Ferrucci	Orchestra Room	Sink	30-01-110	Note: Follow up testing from 2016 sample results. Shut down as soon as practicable. Posted signage temporarily shut down	2023	36	Fixture replacement	2024	68	Yes	Signage remains posted. Filter installed	2025	12	Yes	Temporarily shut down until school testing is completed
Ferrucci	Workroom	Sink	30-01-119E	Note: Follow up testing from 2016 sample results. Shut down as soon as practicable. Posted signage temporarily shut down	2023	16	Fixture replacement	2024	22	Yes	Signage remains posted. Filter installed	2025	5	Yes	Posted hand wash only signage. Turned on. No further action required
Brouillet	Nurses Office	Sink	18-01-101H	Note: Follow up testing from 2016 sample results. Posted signage hand wash only	2023	14	Fixture replacement	2024	19	Yes	Shut down as soon as practicable. Posted signage temporarily shut down. Filter installed	2025	1	Yes	The The signage was removed. Turned on
Spinning	Classroom	Sink	10-01-130	Note: Follow up testing from 2016 sample results. Shut down as soon as practicable. Posted signage temporarily shut down	2023	54	Fixture replacement	2024	15	Yes	Posted hand wash only signage. Turned on. No further action is required.				
ERHS	Kitchen	Multi compartment Sink #2 of 4	52-01-113	Shut down as practicable. Posted signage temporarily shut down	2024	27	Fixture replacement	2025	2	Yes	The signage was removed. Turned on				
ERHS	Kitchen	Sink #3 of 4	52-01-113	Shut down as soon as practicable. Posted signage temporarily shut down	2024	14	Fixture replacement	2025	10	Yes	Signage remains posted. Filter installed.	2025	1	Yes	The signage was removed. Turned on.
ERHS	Kitchen	Sink #4 of 4	52-01-113	Shut down as soon as practicable. Posted signage temporarily shut down	2024	8	Fixture replacement	2025	2	Yes	The signage was removed. Turned on				
ERHS	Classroom Kitchen	Fountain	52-01-106	Shut down as soon as practicable. Posted signage temporarily shut down	2024	7	The signage was removed. Permanent fountain removal								
MPLWD	Back stage Kitchen	Sink multi compartment	05-01-127	Shut down as soon as practicable. Posted signage temporarily shut down	2025	20	Fixture replacement	2025	5	Yes	The signage was removed. Turned on				

Water Quality Action Plan

March 2026



MPLWD	Classroom Kitchen	Sink multi compartment	05-01-111A	Shut down as soon as practicable. Posted signage temporarily shut down	2025	12	Fixture replacement	2025	3	Yes	The signage was removed. Turned on				
Waller Road	Nurses' office	Sink	13-01-101E	Posted signage hand wash only	2025	13	Fixture replacement	2025	2	Yes	The signage was removed. Turned on				
Spinning	Nurses' office	Sink	10-01-102E	Shut down as soon as practicable. Posted signage temporarily shut down	2025	16	Fixture replacement	2025	2	Yes	The signage was removed. Turned on				
Spinning	Staff Lounge	Sink	10-01-106	posted signage hand wash only	2025	9	Fixture replacement	2025	7	Yes	The signage remains posted. Filter install				
Spinning	Classroom Kitchen	Sink	10-01-124C	Posted signage hand wash only	2025	8	Fixture replacement	2025	1	Yes	The signage was removed. Turned on				
Brouillet	Classroom Kitchen	Sink	18-01-138	Posted signage hand wash only	2025	12	Fixture replacement	2025	<1	Yes	The signage was removed. Turned on				
Mt. View	Nurses' office	Sink	07-01-101D	Posted signage hand wash only	2025	7	Fixture replacement	2025	4	Yes	The signage was removed. Turned on				
Shaw Road	Classroom Kitchen	Sink	20-01-138	Posted signage hand wash only	2025		Fixture replacement	2205	1	Yes	The signage was removed. Turned on				
Fruitland	Nurses' office	Sink	02-01-101G	Posted signage hand wash only	2025	12	Fixture replacement	2025	3	Yes	The signage was removed. Turned on				
Edgemont	Training Room	Fountain	33--01-B03	Posted signage temporarily shut down	2025	117	The signage was removed. Permanent fountain removal								
Edgemont	Kitchen	Sink #3 of 4	33-01-002	Posted signage temporarily shut down	2025	55	Fixture replacement	2025	30	Yes	The signage remains posted. Filter install				
Edgemont	Kitchen	Sink #1 of 4	33-01-002	Signage temporarily shut down	2025	30	Fixture replacement								
Edgemont	Culinary Classroom	Sink #7 of 8	33-01-119	Posted signage temporarily shut down	2025	29	Fixture replacement	2025	8	Yes	The signage remains posted. Filter install				
Edgemont	Culinary Classroom	Sink #8 of 8	33-01-119	Posted signage temporarily shut down	2025	15	Fixture replacement	2025	5	Yes	The signage was removed. Turned on				
Edgemont	Culinary Classroom	Sink # 6 of 8	33-01-119	Posted signage temporarily shut down	2025	12	Fixture replacement	2025	2	Yes	The signage was removed. Turned on.				
Edgemont	Kitchen	Sink #4 of 4 sprayer	33-01-002	Posted signage temporarily shut down	2025	11	Fixture replacement	2025	26	Yes	The signage was removed. Turned on.				

Water Quality Action Plan

March 2026



Edgemont	Kitchen	Sink #2 of 4	33-01-002	Posted signage temporarily shut down	2025	10	Fixture replacement	2025	5	Yes	The signage was removed. Turned on.				
Edgemont	Culinary Classroom	Sink #5 of 8	33-01-119	Posted signage temporarily shut down	2025	9	Fixture replacement	2025	2	Yes	The signage was removed. Turned on.				
Edgemont	Kitchen	Sink #4 of 4	33-01-002	Posted signage temporarily shut down	2025	9	Fixture replacement	2025	3	Yes	The signage was removed. Turned on.				
Edgemont	Nurses' office	Fountain	33-01-102	Posted signage temporarily shut down	2025	8	The signage was removed. Permanent fountain removal								
Edgemont	Kitchen	Sink #3 of 4 sprayer	33-01-002	Postage signage temporarily shut down	2025	6	Fixture replacement	2025	26	Yes	The signage remains posted. Filter install				
PHS	Career/Tech Ed Bldg Culinary arts	Pot Filler #7 of 8	50-04-161	Shut down as soon as practicable. Posted signage temporarily shut down	2025	376	Fixture capped due to not being used. Testing required before future use.								
PHS	Career/Tech Ed Bldg Culinary arts	Pot Filler #8 of 8	50-04-161	Shut down as soon as practicable. Posted signage temporarily shut down	2025	305	Fixture capped due to not being used. Testing required before future use.								
PHS	Main Building Kitchen	Pot Filler #3 of 5	50-01-106	Shut down as soon as practicable. Posted signage temporarily shut down	2025	153	Fixture replacement and filter install								
PHS	Main Building Kitchen	Sink #1 of 5	50-01-106	Shut down as soon as practicable. Posted signage temporarily shut down	2025	44	Fixture replacement and filter install								
PHS	Career/Tech Ed Bldg Culinary arts	Pot Filler #5 of 8	50-04-161	Shut down as soon as practicable. Posted signage temporarily shut down	2025	40	Filter Install								
PHS	Main Building Kitchen	Multi compartment sink sprayer #2 of 5	50-01-106	Shut down as soon as practicable. Posted signage temporarily shut down	2025	37	Fixture replacement and filter install								
PHS	Main Building Kitchen	Multicompart ment sink #2 of 5	50-01-106	Shut down as soon as practicable. Posted signage temporarily shut down	2025	29	Fixture replacement and filter install								
PHS	Main Building Classroom	Sink #2 of 4	50-01-116	Shut down as soon as practicable. Posted signage temporarily shut down	2025	22	Fixture replacement and filter install								

Water Quality Action Plan

March 2026



Stewart	Kitchen	Sink #1 of 1	11-01-121	Posted signage hand wash only	2025	7	Fixture replacement and filter install								
Woodland	Nurses' office	Sink	15-01-101G	Posted signage hand wash only	2025	7	Fixture replacement and filter install								
RHS	Main Building Kitchen	Multicompart ment sink sprayer #1 of 3	51-01-123	Shut down as soon as practicable. Posted signage temporarily shut down	2025/2026	13	Fixture replacement and filter install								