



PROPOSED 1.0 MG  
ATKINSON TANK  
BASE=396'  
HGL=437'

PROPOSED METER  
& PUMPING STATION

PROPOSED 12" MAIN  
IN ATKINSON 1,200 LF

PROPOSED 12" MAIN  
IN PLAISTOW 3,100 LF

PROPOSED EXTENSION  
SIZE TBD  
~600 LF

PROPOSED  
8" MAIN  
2,300 LF

PROPOSED  
12" MAIN  
5,400 LF

PROPOSED 0.4 M.G.  
SWEET HILL TANK  
BASE=266', HGL=286'

EXISTING  
HAWC PRV STATION  
UPGRADE/ADJUST  
HGL=

PROPOSED  
8" MAIN  
1,250 LF

**LEGEND:**

- EXISTING**
- 3" WATERMAIN
  - 4" WATERMAIN
  - 6" WATERMAIN
  - 8" WATERMAIN
  - 10" WATERMAIN
  - 12" WATERMAIN
  - 16" WATERMAIN
  - 20" WATERMAIN
  - PENNICHUCK WATER WORKS (PWW) SYSTEMS
  - WATER SYSTEM FACILITIES
  - WATER STORAGE TANKS
  - WATER BOOSTER PUMPING STATION
  - PRESSURE REDUCING VALVE STATION
  - MTBE LISTED SITE
  - REFERENCE LANDMARK
  - HYDRAULIC MODEL CALIBRATION POINT

- PROPOSED**
- NEW WATER MAIN - PHASE 1
  - MINOR WATER MAIN SERVICE EXTENSIONS
  - ALTERNATE/FUTURE WATER MAIN
  - PROPOSED WATER SYSTEM FACILITIES
  - PROPOSED WATER STORAGE TANKS
  - PROPOSED WATER BOOSTER PUMPING STATION
  - PROPOSED PRESSURE REDUCING VALVE STATION
  - APPROX. (MIN. 35PSI) PRESSURE LIMITS OF PROPOSED SYSTEM



DATE  
09/19  
PROJECT  
2384



25 Vaughan Mall, Portsmouth, N.H. 03801  
Tel. 603-436-6192 Fax. 603-431-4733

SOUTHERN NEW HAMPSHIRE  
REGIONAL WATER IMPROVEMENTS  
TOWN OF PLAISTOW  
PLAISTOW, NEW HAMPSHIRE

Presented at work session TRSB 12/5/2019