



ADDENDUM NO. 04
Washington Elementary School Modernization
Project #0938-8238-360-34
4/22/2025

RESPONSE TO CONTRACTOR QUESTIONS

12. Addendum #2 (Drg A2.01) calls for abating and application of new finishes to RM 115 (auditorium). Please provide details of the existing flooring in the auditorium and the other items that require abatement.

A: Existing Vinyl Floor Tile only to be removed. Epoxy floor finish to be applied. Refer to Sheet A9.00 for detail

13. Addendum #2 (Drg A2.01) calls for application of new finishes to RM 11 (auditorium). Please provide a finishes schedule for the auditorium. None was provided on Drg A9.00.

A: Epoxy floor finish to be applied at RM 115.

14. Provide size of window above transom to be removed and fixing details of new window.

A. Transom 4'-1"H x 3'- 4 7/8"W

* * * END OF ADDENDUM * * *