Alexandria City (T.C. Williams) High School Copper and Lead Drinking Water Results Table		
Sample Number	**Copper Result (mg/L)**	**Lead Result (mg/L)**
102821ACHS-25-A317-BM-RS-6	0.137	N/A
102821ACHS-13-C210-L-LS	N/A	0.002
102821ACHS-09-B218-L-R4	0.985	N/A
102821ACHS-08-B218-L-R3	1.180	N/A
The EPA's Lead and Copper Rule set an action level of 0.015 mg/L for lead and an action level of 1.3 mg/L for copper. Note these levels are related to public water systems (PWSs). The Code of Virginia requires school boards notify parents if testing results exceed 0.01 mg/L of Lead (Pb).		

Table Notes:
Red = Above the Action Level
Orange = Above 0.010 mg/L and below 0.015 mg/L
N/A = Not Applicable