

ADDENDUM #2

FROM : ARCHITECTNICA
555 W. BENJAMIN HOLT DRIVE
SUITE 423
STOCKTON, CA 95207
(209) 952-5850 FAX (209) 952-2442

PROJECT: Bridge Classroom Portable at Erma B. Reese ES
Lodi Unified School District

LOCATION : Erma B. Reese ES, 1800 W. Elm Street, Lodi, CA 95242

REF. # : District Project No. # 2600-4402-942-26
DSA FILE # 39-50
Erma B. Reese ES
Arch Project No. 2023-05
DSA App. No. 02-123433
DSA PTN: 68585-281

OPSC NO. : n/a

OWNER : Lodi Unified School District
1305 East Vine Street
Lodi, CA 95240

DATE : April 8, 2026

NOTICE TO ALL BIDDERS

IT IS THE PURPOSE AND INTENT OF THIS ADDENDUM TO MODIFY AND/OR CLARIFY THE DRAWINGS AND SPECIFICATIONS FOR THIS PROJECT AND THIS ADDENDUM SHALL BECOME A PART OF THE CONTRACT DOCUMENTS. THESE CHANGES AND/OR INTERPRETATIONS SHALL BE INCORPORATED INTO YOUR BID.

REFER TO PROJECT PLANS AND SPECIFICATIONS PREPARED BY ARCHITECTNICA, DSA APPROVED January 20, 2026.

ITEM 1 RFI #1

Q: "Are we to provide the following for the portable building as shown on AA2.2"

- Integrated walk off mat at door
- Interior and exterior lighting
- Wall mounted electric heat pump
- Downspout
- Exterior finishes #1-6
- Interior finishes #1-4

A: All mentioned items shown on sheet AA2.2 as it relates to the classroom portable are to be furnished and installed by the building manufacturer, Class Leasing.

ADDENDUM #2

ITEM 2 Intrusion Alarm

The contractor is to provide pathways / wiring for Intrusion Alarm systems, including 6"x6"x4" Nema 3R J-boxes above T-bar ceiling at portable buildings with 1" conduit pathway between new and existing portable as described on revised sheet 1-ES1.1. The District is to supply and install the intrusion alarm devices.

END OF ADDENDUM #2
ARCHITECTURAL
By

Timothy Dearborn, AIA
Architect

Attachments: 1-ES1.1



