



Inlet from parking lot

Pond skimmer/ Overflow to public system





**Final catch basin
before pond – CB #5**



**Inlets from other
parts of parking lot to
CB #5**



**Vegetation in
summer**



Pond in mid-summer



Dredging in 2015

BMP ID 6388		Wet Pond		
Inspection Date / / 20		Inspector:		
Inspection Activity	Observations Measurements	Maintenance	Maint. Required	Actions Required/Date Completed/Responsible Foreman
General: Visual inspection of sumps, inlets, and pond margins for trash and debris, 3 x/year, at least once after a 1" rain event		Metro Blooms clean out trash and debris from all structures on each visit, and will advise MPS staff when a professional maintenance service is needed.	Yes No	/ / 20 Responsible Party:
Erosion: Visual inspection for erosion around inlet and outlet structures Inspect side slopes and embankments 3 x/year, at least once after a 1" rain event		Metro Blooms can address some maintenance objectives at catch basin inlets, outlets, and overflow structures. Otherwise a professional contractor will be arranged.	Yes No	/ / 20 Responsible Party:
Sedimentation: Once yearly measurement of sediment level in pond basin, performed in winter when ice has formed. Should be measured in a longitudinal line between inlet at outlet		Metro Blooms will advise MPS staff when a professional maintenance is required; pond basin elevation was designed at 835' and normal HWL is 839'; pond is due for dredging when it becomes more than 50% full (bottom elev. = 827' or greater)	Yes No	/ / 20 Responsible Party:
Vegetation: Inspect pond edges and shallows for dead or diseased plants, weeds and bare spots. 3 x/year, at least once after a 1" rain event		Metro Blooms will remove dead or diseased plants and weeds by pulling from the roots. Do not use herbicide. Re-plant any bare or denuded areas.	Yes No	/ / 20 Responsible Party:
Inlets/Outlets: Inspect all inlets (including catch basins), outlets, aprons, culverts and any conveyance pipes in the system, 3 x/year, at least once after a 1" rain event		Metro Blooms will advise MPS staff when a professional maintenance is required	Yes No	/ / 20 Responsible Party: