

April 10, 2026

Mr. Paul Feathers
Lewiston- Porter CSD
4061 Creek Road
Youngstown, New York 14174

Re: Lead Testing in School Drinking Water – Resampling

Dear Mr. Feathers:

Stohl Environmental was retained by Lewiston - Porter CSD to perform sampling and analysis of potable water for lead concentrations. Sampling was performed on March 24, 2026 in client directed locations.

- **Lewiston-Porter HS/MS/Intermediate/Primary School – 4061 Creek Road, Youngstown, NY**

Based upon the sampling and analysis performed, 8 sources of potable water at Lewiston-Porter CSD have been identified as having lead concentrations in water below the NYS Action Level of 5 parts per billion. A summary of the results is as follows:

Initial Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/ Outlet type	Laboratory Analysis (in ppb) – Initial Testing	Laboratory Analysis (in ppb) – 3/24/26
151.1-3	Kitchen Right Pot Fill	Sink	16.2	<1.00- Cleared
151.1-4	Kitchen Left Pot Fill	Sink	7.4	1.90- Cleared
151.2-2	Kitchen Double Sink Far	Sink	5.1	3.51- Cleared
151.2-7	Home Ec Clockwise of Last Sample 402	Sink	8.6	1.54- Cleared
151.2-8	Home Ec Clockwise of Last Sample 402	Sink	13.3	1.16- Cleared
151.3-1	Kitchen 2 Bay by Entrance	Sink	5.1	4.44- Cleared
151.4-2	Kitchen Handwash	Sink	13.8	N/A
151.4-19	Green Wing G11	Sink	8.0	<1.00- Cleared
151.4-32	Red Wing R9	Sink	68.0	4.14 - Cleared

If after reviewing this letter you have any questions, or if we can be of assistance in any other way, please do not hesitate to call. Thank you for the opportunity to be of service to Lewiston-Porter CSD.

Sincerely,
Stohl Environmental, LLC.



Michael Scinta
EPA Lead Risk Assessor

Enc.



7469 Whitepine Rd
North Chesterfield, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 26-03-05722

Received Date: 03/27/2026
Reported Date: 04/03/2026
Sampled By: Jared Rider
Tech Certification #:

Project/Test Address: 2023L-151; Lew-Port CSD; 4061 Creek Rd; Youngstown, NY

Client Number:
33-5980

Laboratory Results

Fax Number:
716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
26-03-05722-001	151.1-3		KITCHEN RIGHT POT FILL	<1.00	04/01/2026	
26-03-05722-002	151.1-4		KITCHEN LEFT POT FILL	1.90	04/01/2026	
26-03-05722-003	151.2-2		KITCHEN DOUBLE SINK FAR	3.51	04/01/2026	
26-03-05722-004	151.2-7		HOME EC CLOCKWISE OF LAST SAMPLE 402	1.54	04/01/2026	
26-03-05722-005	151.2-8		HOME EC CLOCKWISE OF LAST SAMPLE 402	1.16	04/01/2026	
26-03-05722-006	151.3-1		KITCHEN 2 BAY BY ENTRANCE	4.44	04/01/2026	
26-03-05722-007	151.4-19		GREEN WING G11	<1.00	04/01/2026	
26-03-05722-008	151.1-32		RIDE WING R9	4.14	04/01/2026	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 26-03-05722

Project/Test Address: 2023L-151; Lew-Port CSD; 4061 Creek Rd;
Youngstown, NY

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
----------------------	---------------------	--------------------	---------------------	-----------------------------	------------------	-----------------

Method: EPA 200.8

Analyst: Nicole Holloway

Accreditation #: NY 11714

Reviewed By Authorized Signatory:



Tasha Eaddy

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2026
Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. JULIE DICKERSON
ENVIRONMENTAL HAZARDS SERVICES, LLC
7469 WHITEPINE ROAD
N. CHESTERFIELD, VA 23237

NY Lab Id No: 11714

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Metals I

Arsenic, Total	EPA200.8 Rev. 5.4
Copper, Total	EPA200.8 Rev. 5.4
Lead, Total	EPA200.8 Rev. 5.4
Manganese, Total	EPA200.8 Rev. 5.4



Serial No.: 70597

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wad/elappubliweb/>, by phone (518) 485-5570 or by email to elap@health.ny.gov.

