Stohl ENVIRONMENTAL BUFFALO ROCHESTER

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

January 27, 2026

Keith E. Langlotz
Director of Facilities
Williamsville Central Schools
480 Lawrence Bell Dr.
Williamsville, NY 14221

Re: Lead Testing in School Drinking Water

Dear Mr. Langlotz:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for Williamsville Central School District, including:

- **Heim Middle School – 175 Heim Road, Williamsville, NY**

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: *Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

The collection of water samples was performed by Williamsville CSD on December 6, 2025, following the requirements of 10 NYCRR Subpart 67-4: *Lead Testing in School Drinking Water* as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools". Water samples were delivered by School District staff to Stohl Environmental and then transferred by Stohl Environmental to an independent laboratory approved by the NYS Department of Health's Environmental Laboratory Approval Program (ELAP) following strict chain-of-custody protocols.

As detailed below, based upon the analysis performed, 1 source of potable water in Heim Middle School has been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion. To comply with NYS regulations, response actions by the district are required. Response actions are outlined below *(Response Actions Required Under NYS Regulations)*.

Laboratory reports and Chain of Custody forms are included as attachments to this letter.

Thank you for the opportunity to be of service to Williamsville Central School District.

Sincerely,
Stohl Environmental, LLC.

M. Scinta

Michael Scinta
EPA Lead Risk Assessor

Stohl BUFFALO ROCHESTER ENVIRONMENTAL

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

Executive Summary of Sampling and Analysis:

Summary of Samples Collected at Heim Middle School:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Heim Middle School	12/6/2025	20	19	1

**NYS Action Level is 5 parts per billion*

Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet type	Laboratory Analysis (in ppb)
HM-120	Outlet by Steamer in Kitchen	Sink	14.9

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration more than the NYS Action Level, regulations require:

(a) Prohibit use of the outlet until:

(1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and

(2) test results indicate that the lead levels are at or below the action level;

(b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;

(c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and

(d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

Stohl BUFFALO ROCHESTER ENVIRONMENTAL

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

Laboratory Analytical Reports and Chain of Custody Documents

January 08, 2026 Service Request No:R2516830

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Williamsville CSD Heim Middle School

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory December 12, 2025
For your reference, these analyses have been assigned our service request number **R2516830.**

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental



Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | FAX +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental

Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: Williamsville CSD Heim Middle School
Sample Matrix: Drinking Water

Service Request: R2516830
Date Received: 12/12/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Twenty drinking water samples were received for analysis at ALS Environmental on 12/12/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

Method 200.8, 01/06/2026: The upper control criterion was exceeded for Lead in the Laboratory Control Sample (LCS). There were no detections of the analyte above the MRL in the associated field samples. The error associated with elevated recovery equates to a high bias. The sample data is not significantly affected. No further corrective action was appropriate.

Approved by _____ Date 01/08/2026

SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: HM-105			Lab ID: R2516830-006			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	1.7			1.0	ug/L	200.8

CLIENT ID: HM-108			Lab ID: R2516830-009			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	1.2			1.0	ug/L	200.8

CLIENT ID: HM-115			Lab ID: R2516830-015			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	1.2			1.0	ug/L	200.8

CLIENT ID: HM-118			Lab ID: R2516830-018			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	2.4			1.0	ug/L	200.8

CLIENT ID: HM-119			Lab ID: R2516830-019			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	1.5			1.0	ug/L	200.8

CLIENT ID: HM-120			Lab ID: R2516830-020			
Analyte	**Results**	**Flag**	**MDL**	**MRL**	**Units**	**Method**
Lead, Total	14.9			1.0	ug/L	200.8

Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental **Service Request:**R2516830

Project: Williamsville CSD Heim Middle School/2023L-139.1

SAMPLE CROSS-REFERENCE

SAMPLE #	CLIENT SAMPLE ID	DATE	TIME
R2516830-001	HM-100	12/6/2025	
R2516830-002	HM-101	12/6/2025	
R2516830-003	HM-102	12/6/2025	
R2516830-004	HM-103	12/6/2025	
R2516830-005	HM-104	12/6/2025	
R2516830-006	HM-105	12/6/2025	
R2516830-007	HM-106	12/6/2025	
R2516830-008	HM-107	12/6/2025	
R2516830-009	HM-108	12/6/2025	
R2516830-010	HM-110	12/6/2025	
R2516830-011	HM-111	12/6/2025	
R2516830-012	HM-112	12/6/2025	
R2516830-013	HM-113	12/6/2025	
R2516830-014	HM-114	12/6/2025	
R2516830-015	HM-115	12/6/2025	
R2516830-016	HM-116	12/6/2025	
R2516830-017	HM-117	12/6/2025	
R2516830-018	HM-118	12/6/2025	
R2516830-019	HM-119	12/6/2025	
R2516830-020	HM-120	12/6/2025	

Stohl ENVIRONMENTAL
3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-139.1

Client: Williamsville CSD Contact: Keith Langlotz

Building: Heim Middle School Location: 175 Heim Rd. Williasmville, NY 14221

LEAD		Turnaround
Water by 200.8	X	10 Days

Sample #	Location	Outlet Type	Time
HM-100	Room D7 Classroom Sink # 1	Sink	6:09
HM-101	Room D7 Classroom Sink # 2	Sink	6:10
HM-102	Room D7 Classroom Sink # 3	Sink	6:11
HM-103	Room D7 Classroom Sink # 4	Sink	6:12
HM-104	Hallway Fountain By D6	Fountain	6:14
HM-105	Room D-7 Sink # 5	Fountain	6:16
HM-106	Fountain Boys Lockeroom	Fountain	6:21
HM-107	Water Fountain Hall By Gym/Café	Fountain	6:23
HM-108	Fountain in Girls Locker Room	Fountain	6:24
HM-110	Hallway Founrtain by C-13	Fountain	6:47
HM-111	Hallway Fountain by C-14	Fountain	6:50
HM-112	Hallway Fountain by A-13	Fountain	6:42
HM-113	Hallway Fountain by Aud	Fountain	6:53
HM-114	Faculty Dining Sink	Sink	6:30
HM-115	Kitchen Sink # 1	Sink	6:32
HM-116	Kitchen Sink # 2	Sink	6:32
HM-117	Kitchen Sink # 3	Sink	6:34
HM-118	Kitchen Sink # 4	Sink	6:35

Notes:
Please e-mail lab results to labs@stohlenv.com ☑ If checked, also e-mail results to: Kelangl@williasmvillek12.org

Sampled By: Keith Langlotz Print Name [signature] Date: 12/6/2025

Relinquished By: Keith Langlotz Print Name [signature] Date: 12/8/2025

Received (Name / Lab): [signature] Date: 12/12/25 Time: 17:20

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

R2516830 5
Stohl Environmental
Williamsville CSD Heim Middle School

[redacted]

Stohl ENVIRONMENTAL

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-139.1

Client: Williamsville CSD Contact: Keith Langlotz

Building: Heim Middle School Location: 175 Heim Rd. Williasmville, NY 14221

LEAD		Turnaround
Water by 200.8	X	10 Days

Sample #	Location	Outlet Type	Time
HM-119	Kitchen Sink # 5	Sink	6:36
HM-120	Outlet by Steamer in Kitchen	Sink	6:37

Notes:
Please e-mail lab results to labs@stohlenv.com Kelangl@williamsvillek12.org

Sampled By: Keith Langlotz Print Name [redacted] Date: 12/6/2025

Relinquished By: Keith Langlotz Print Name [redacted] Date: 12/8/2025

Received (Name / Lab): [redacted] Date: 12/12/25 Time: 17:20

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

Cooler Receipt and Preservation Check Form

R2516830 5
Stohl Environmental
Williamsville CSD Helm Middle School

Project/Client Stohl Folder Number

Cooler received on 12/12/25 by: MM

COURIER: ALS UPS FEDEX VELOCITY (CLIENT)

1	Were **Custody seals** on outside of cooler?	Y (N)	5a	Did **VOA** vials have sig* **bubbles**?	Y N (NA)
2	**Custody papers** properly completed (ink, signed)?	Y (N)	5b	Sig* bubbles: **Alk?** Y N (NA) **Sulfide?**	Y N (NA)
3	Did all bottles arrive in good **condition** (unbroken)?	(Y) N	6	Where did the bottles originate?	(ALS/ROC) CLIENT
4	Circle: **Wet Ice Dry Ice Gel packs** present?	Y (N)	7	Soil VOA received as: Bulk Encore 5035set (NA)	

8. Temperature Readings Date: 12/13/25 Time: 11:36 ID: IR#11 (IR#12) IR#13 From: Temp Blank (Sample Bottle)

Temp (°C)	16.8						
Within 0-6°C?	Y (N)	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: No ICE Ice melted Poorly Packed (described below) Same Day Rule

&Client Approval to Run Samples: Standing Approval Client aware at drop-off Client notified by:

All samples held in storage location: SMO by MM on 12/13/25 at 11:37
5035 samples placed in storage location: by on at within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 12/16/25 Time: 0955 by: CE

9. Were all bottle labels complete (*i.e.* analysis, preservation, etc.)? YES (NO)
10. Did all bottle labels and tags agree with custody papers? YES (NO)
11. Were correct containers used for the tests indicated? (YES) NO
12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO (N/A)
13. Were dissolved metals filtered in the field? YES NO (N/A)

pH	Lot of test paper	Reagent	Preserved? Yes	Preserved? No	Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
≥12		NaOH								
≤2	202325	HNO_3		✓			All	4ml	245078	<2.0
≤2		H_2SO_4								
<4		$NaHSO_4$								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add $Na_2S_2O_3$ (625, 608, CN), ascorbic (phenol).					
		$Na_2S_2O_3$								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 08125-ZADD
Explain all Discrepancies/ Other Comments:

9/10) No bottle Labels

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: CE *significant air bubbles: VOA > 5-6 mm : WC >1 in. diameter

Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

REPORT QUALIFIERS AND DEFINITIONS

U	Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
J	Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Arclors).
B	Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
E	Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
E	Organics- Concentration has exceeded the calibration range for that specific analysis.
D	Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
*	Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
H	Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
#	Spike was diluted out.
+	Correlation coefficient for MSA is <0.995.
N	Inorganics- Matrix spike recovery was outside laboratory limits.
N	Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
S	Concentration has been determined using Method of Standard Additions (MSA).
W	Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
P	Concentration >40% difference between the two GC columns.
C	Confirmed by GC/MS
Q	DoD reports: indicates a pesticide/Aroclor is not confirmed (≥100% Difference between two GC columns).
X	See Case Narrative for discussion.
MRL LOQ	Method Reporting Limit. Also known as: Limit of Quantitation (LOQ) The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
MDL	Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
LOD	Limit of Detection. A value at or above the MDL which has been verified to be detectable.
ND	Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations[1]

NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

[1] Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

Client: Stohl Environmental **Service Request:** R2516830
Project: Williamsville CSD Heim Middle School/2023L-139.1

Sample Name: HM-100 **Date Collected:** 12/6/25
Lab Code: R2516830-001 **Date Received:** 12/12/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		DWINTER

Sample Name: HM-101 **Date Collected:** 12/6/25
Lab Code: R2516830-002 **Date Received:** 12/12/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		DWINTER

Sample Name: HM-102 **Date Collected:** 12/6/25
Lab Code: R2516830-003 **Date Received:** 12/12/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		DWINTER

Sample Name: HM-103 **Date Collected:** 12/6/25
Lab Code: R2516830-004 **Date Received:** 12/12/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		DWINTER

Sample Name: HM-104 **Date Collected:** 12/6/25
Lab Code: R2516830-005 **Date Received:** 12/12/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		DWINTER

Client: Stohl Environmental **Service Request:** R2516830
Project: Williamsville CSD Heim Middle School/2023L-139.1

Sample Name: HM-105 **Date Collected:** 12/6/25
Lab Code: R2516830-006 **Date Received:** 12/12/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		DWINTER

Sample Name: HM-106 **Date Collected:** 12/6/25
Lab Code: R2516830-007 **Date Received:** 12/12/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		DWINTER

Sample Name: HM-107 **Date Collected:** 12/6/25
Lab Code: R2516830-008 **Date Received:** 12/12/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		DWINTER

Sample Name: HM-108 **Date Collected:** 12/6/25
Lab Code: R2516830-009 **Date Received:** 12/12/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		DWINTER

Sample Name: HM-110 **Date Collected:** 12/6/25
Lab Code: R2516830-010 **Date Received:** 12/12/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		DWINTER

Client: Stohl Environmental **Service Request:** R2516830
Project: Williamsville CSD Heim Middle School/2023L-139.1

Sample Name: HM-111 **Date Collected:** 12/6/25
Lab Code: R2516830-011 **Date Received:** 12/12/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		DWINTER

Sample Name: HM-112 **Date Collected:** 12/6/25
Lab Code: R2516830-012 **Date Received:** 12/12/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		DWINTER

Sample Name: HM-113 **Date Collected:** 12/6/25
Lab Code: R2516830-013 **Date Received:** 12/12/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		DWINTER

Sample Name: HM-114 **Date Collected:** 12/6/25
Lab Code: R2516830-014 **Date Received:** 12/12/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		DWINTER

Sample Name: HM-115 **Date Collected:** 12/6/25
Lab Code: R2516830-015 **Date Received:** 12/12/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		DWINTER

Client: Stohl Environmental **Service Request:** R2516830
Project: Williamsville CSD Heim Middle School/2023L-139.1

Sample Name: HM-116 **Date Collected:** 12/6/25
Lab Code: R2516830-016 **Date Received:** 12/12/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		DWINTER

Sample Name: HM-117 **Date Collected:** 12/6/25
Lab Code: R2516830-017 **Date Received:** 12/12/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		DWINTER

Sample Name: HM-118 **Date Collected:** 12/6/25
Lab Code: R2516830-018 **Date Received:** 12/12/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		DWINTER

Sample Name: HM-119 **Date Collected:** 12/6/25
Lab Code: R2516830-019 **Date Received:** 12/12/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		DWINTER

Sample Name: HM-120 **Date Collected:** 12/6/25
Lab Code: R2516830-020 **Date Received:** 12/12/25
Sample Matrix: Drinking Water

Analysis Method	Extracted/Digested By	Analyzed By
200.8		DWINTER

PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":
For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.

Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2516830
Project:	Williamsville CSD Heim Middle School/2023L-139.1	**Date Collected:**	12/06/25
Sample Matrix:	Drinking Water	**Date Received:**	12/12/25 17:20
Sample Name:	HM-100	**Basis:**	NA
Lab Code:	R2516830-001		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/06/26 19:15	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2516830
Project:	Williamsville CSD Heim Middle School/2023L-139.1	**Date Collected:**	12/06/25
Sample Matrix:	Drinking Water	**Date Received:**	12/12/25 17:20
Sample Name:	HM-101	**Basis:**	NA
Lab Code:	R2516830-002		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/06/26 19:17	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2516830
Project:	Williamsville CSD Heim Middle School/2023L-139.1	**Date Collected:**	12/06/25
Sample Matrix:	Drinking Water	**Date Received:**	12/12/25 17:20
Sample Name:	HM-102	**Basis:**	NA
Lab Code:	R2516830-003		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/06/26 19:29	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2516830
Project:	Williamsville CSD Heim Middle School/2023L-139.1	**Date Collected:**	12/06/25
Sample Matrix:	Drinking Water	**Date Received:**	12/12/25 17:20
Sample Name:	HM-103	**Basis:**	NA
Lab Code:	R2516830-004		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/06/26 19:33	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2516830
Project:	Williamsville CSD Heim Middle School/2023L-139.1	**Date Collected:**	12/06/25
Sample Matrix:	Drinking Water	**Date Received:**	12/12/25 17:20
Sample Name:	HM-104	**Basis:**	NA
Lab Code:	R2516830-005		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/06/26 19:35	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2516830
Project:	Williamsville CSD Heim Middle School/2023L-139.1	**Date Collected:**	12/06/25
Sample Matrix:	Drinking Water	**Date Received:**	12/12/25 17:20
Sample Name:	HM-105	**Basis:**	NA
Lab Code:	R2516830-006		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.7**	ug/L	1.0	1	01/06/26 19:36	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2516830
Project:	Williamsville CSD Heim Middle School/2023L-139.1	**Date Collected:**	12/06/25
Sample Matrix:	Drinking Water	**Date Received:**	12/12/25 17:20
Sample Name:	HM-106	**Basis:**	NA
Lab Code:	R2516830-007		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/06/26 19:38	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2516830
Project:	Williamsville CSD Heim Middle School/2023L-139.1	**Date Collected:**	12/06/25
Sample Matrix:	Drinking Water	**Date Received:**	12/12/25 17:20
Sample Name:	HM-107	**Basis:**	NA
Lab Code:	R2516830-008		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/06/26 19:39	

Client:	Stohl Environmental	**Service Request:**	R2516830
Project:	Williamsville CSD Heim Middle School/2023L-139.1	**Date Collected:**	12/06/25
Sample Matrix:	Drinking Water	**Date Received:**	12/12/25 17:20
Sample Name:	HM-108	**Basis:**	NA
Lab Code:	R2516830-009		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.2**	ug/L	1.0	1	01/06/26 19:43	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2516830
Project:	Williamsville CSD Heim Middle School/2023L-139.1	**Date Collected:**	12/06/25
Sample Matrix:	Drinking Water	**Date Received:**	12/12/25 17:20
Sample Name:	HM-110	**Basis:**	NA
Lab Code:	R2516830-010		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/06/26 19:44	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2516830
Project:	Williamsville CSD Heim Middle School/2023L-139.1	**Date Collected:**	12/06/25
Sample Matrix:	Drinking Water	**Date Received:**	12/12/25 17:20
Sample Name:	HM-111	**Basis:**	NA
Lab Code:	R2516830-011		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/06/26 19:46	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2516830
Project:	Williamsville CSD Heim Middle School/2023L-139.1	**Date Collected:**	12/06/25
Sample Matrix:	Drinking Water	**Date Received:**	12/12/25 17:20
Sample Name:	HM-112	**Basis:**	NA
Lab Code:	R2516830-012		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/06/26 19:47	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2516830
Project:	Williamsville CSD Heim Middle School/2023L-139.1	**Date Collected:**	12/06/25
Sample Matrix:	Drinking Water	**Date Received:**	12/12/25 17:20
Sample Name:	HM-113	**Basis:**	NA
Lab Code:	R2516830-013		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/06/26 19:49	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2516830
Project:	Williamsville CSD Heim Middle School/2023L-139.1	**Date Collected:**	12/06/25
Sample Matrix:	Drinking Water	**Date Received:**	12/12/25 17:20
Sample Name:	HM-114	**Basis:**	NA
Lab Code:	R2516830-014		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/06/26 19:50	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2516830
Project:	Williamsville CSD Heim Middle School/2023L-139.1	**Date Collected:**	12/06/25
Sample Matrix:	Drinking Water	**Date Received:**	12/12/25 17:20
Sample Name:	HM-115	**Basis:**	NA
Lab Code:	R2516830-015		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.2**	ug/L	1.0	1	01/06/26 19:51	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2516830
Project:	Williamsville CSD Heim Middle School/2023L-139.1	**Date Collected:**	12/06/25
Sample Matrix:	Drinking Water	**Date Received:**	12/12/25 17:20
Sample Name:	HM-116	**Basis:**	NA
Lab Code:	R2516830-016		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/06/26 19:53	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2516830
Project:	Williamsville CSD Heim Middle School/2023L-139.1	**Date Collected:**	12/06/25
Sample Matrix:	Drinking Water	**Date Received:**	12/12/25 17:20
Sample Name:	HM-117	**Basis:**	NA
Lab Code:	R2516830-017		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/06/26 19:54	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2516830
Project:	Williamsville CSD Heim Middle School/2023L-139.1	**Date Collected:**	12/06/25
Sample Matrix:	Drinking Water	**Date Received:**	12/12/25 17:20
Sample Name:	HM-118	**Basis:**	NA
Lab Code:	R2516830-018		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**2.4**	ug/L	1.0	1	01/06/26 19:56	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2516830
Project:	Williamsville CSD Heim Middle School/2023L-139.1	**Date Collected:**	12/06/25
Sample Matrix:	Drinking Water	**Date Received:**	12/12/25 17:20
Sample Name:	HM-119	**Basis:**	NA
Lab Code:	R2516830-019		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**1.5**	ug/L	1.0	1	01/06/26 20:00	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2516830
Project:	Williamsville CSD Heim Middle School/2023L-139.1	**Date Collected:**	12/06/25
Sample Matrix:	Drinking Water	**Date Received:**	12/12/25 17:20
Sample Name:	HM-120	**Basis:**	NA
Lab Code:	R2516830-020		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	**14.9**	ug/L	1.0	1	01/06/26 20:01	

QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2516830
Project:	Williamsville CSD Heim Middle School/2023L-139.1	**Date Collected:**	NA
Sample Matrix:	Drinking Water	**Date Received:**	NA
Sample Name:	Method Blank	**Basis:**	NA
Lab Code:	R2516830-MB1		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/06/26 19:27	

Analytical Report

Client:	Stohl Environmental	**Service Request:**	R2516830
Project:	Williamsville CSD Heim Middle School/2023L-139.1	**Date Collected:**	NA
Sample Matrix:	Drinking Water	**Date Received:**	NA
Sample Name:	Method Blank	**Basis:**	NA
Lab Code:	R2516830-MB2		

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/06/26 18:39	

Client:	Stohl Environmental	**Service Request:**	R2516830
Project:	Williamsville CSD Heim Middle School/2023L-139.1	**Date Collected:**	12/06/25
Sample Matrix:	Drinking Water	**Date Received:**	12/12/25
		Date Analyzed:	01/6/26

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name:	HM-101	**Units:**	ug/L
Lab Code:	R2516830-002	**Basis:**	NA
Analysis Method:	200.8		

		Matrix Spike			Duplicate Matrix Spike					
		R2516830-002MS			R2516830-002DMS					
Analyte Name	**Sample Result**	**Result**	**Spike Amount**	**% Rec**	**Result**	**Spike Amount**	**% Rec**	**% Rec Limits**	**RPD**	**RPD Limit**
Lead, Total	ND U	19.8	20.0	99	19.4	20.0	97	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client:	Stohl Environmental	**Service Request:**	R2516830
Project:	Williamsville CSD Heim Middle School/2023L-139.1	**Date Collected:**	12/06/25
Sample Matrix:	Drinking Water	**Date Received:**	12/12/25
		Date Analyzed:	01/6/26

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name:	HM-102	**Units:**	ug/L
Lab Code:	R2516830-003	**Basis:**	NA
Analysis Method:	200.8		

		Matrix Spike			Duplicate Matrix Spike					
		R2516830-003MS			R2516830-003DMS					
Analyte Name	**Sample Result**	**Result**	**Spike Amount**	**% Rec**	**Result**	**Spike Amount**	**% Rec**	**% Rec Limits**	**RPD**	**RPD Limit**
Lead, Total	ND U	19.5	20.0	97	19.5	20.0	98	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client: Stohl Environmental
Project: Williamsville CSD Heim Middle School/2023L-139.1
Sample Matrix: Drinking Water

Service Request: R2516830
Date Analyzed: 01/06/26

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516830-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.4	20.0	102	85-115

Client: Stohl Environmental
Project: Williamsville CSD Heim Middle School/2023L-139.1
Sample Matrix: Drinking Water

Service Request: R2516830
Date Analyzed: 01/06/26

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2516830-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	29.5	20.0	148 *	85-115

3860 California Road
Orchard Park, New York 14127
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER

Expires 12:01 AM April 01, 2026
Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE
Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. CHRISTINE KUTZER
ALS ENVIRONMENTAL - ROCHESTER
1565 JEFFERSON ROAD BUILDING 300, SUITE 360
ROCHESTER, NY 14623

NY Lab Id No: 10145

is hereby APPROVED as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference Standards (2016) for the category ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:

Bacteriology	
Coliform, Total / E. coli (Qualitative)	SM 20, 21-23 9223B (-04) (Colilert)
Dissolved Gases	
Acetylene	RSK-175
Ethane	RSK-175
Ethene (Ethylene)	RSK-175
Methane	RSK-175
Propane	RSK-175
Fuel Additives	
Methyl tert-butyl ether	EPA 524.2
Naphthalene	EPA 524.2
Metals I	
Arsenic, Total	EPA 200.8 Rev. 5.4
Barium, Total	EPA 200.8 Rev. 5.4
Cadmium, Total	EPA 200.8 Rev. 5.4
Chromium, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Iron, Total	EPA 200.7 Rev. 4.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Mercury, Total	EPA 245.1 Rev. 3.0
Selenium, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Zinc, Total	EPA 200.7 Rev. 4.4

Serial No.: 70111

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/, by phone (518) 485-5570 or by email to elap@health.ny.gov.

Page 1 of 5