

## **NON-VIABLE MOLD SAMPLING**

Prepared for:

### **LINCOLNSHIRE-PRAIRIEVIEW SCHOOL DISTRICT #103**

111 Barclay Blvd.  
Lincolnshire, IL 60069

Project Location:



### **DANIEL WRIGHT JUNIOR HIGH SCHOOL ROOMS 112,117, 124, 203, 215, & CORRIDOR**

*1370 Riverwoods Road  
Lincolnshire, IL 60069*

Date: March 27, 2026

MEC Project #: 26-03-0255-IH

**Corporate  
Headquarters**  
2551 N. Bridge Street  
Yorkville, Illinois 60560  
P: 630-553-3989

**Chicago Office**  
954 W. Washington Blvd.  
Suite 425  
Chicago, Illinois 60607  
P: 312-535-3228

**Peoria Office**  
3100 N. Knoxville Ave.  
Suite 204  
Peoria, Illinois 61603  
P: 309-621-4680



**LINCOLNSHIRE-PRAIRIEVIEW  
SCHOOL DISTRICT #103  
DANIEL WRIGHT JUNIOR HIGH SCHOOL  
ROOMS 112,117, 124, 203, 215, & CORRIDOR  
1370 Riverwoods Road  
Lincolnshire, IL 60069**

Table of Contents  
MEC Project #: 26-03-0255-I.H.

|   |                  |
|---|------------------|
| <i>Sampling Report</i>                      | <i>Section 1</i> |
| <i>Mold Air Sample Location Photographs</i> | <i>Section 2</i> |
| <i>Laboratory Analytical Report</i>         | <i>Section 3</i> |



April 3, 2026

Lincoln-Prairieview School District.#103  
111 Barclay Blvd. Suite 100  
Lincolnshire, IL 60069

Attention: Eric Jonasson, Director of Facilities

Subject: **Non-Viable Mold Air Sampling**  
**Daniel Wright Junior High School**  
**1370 Riverwoods Road, Lincolnshire, IL 60069**  
**MEC Project #: 26-03-0255-IH**

Dear Mr. Jonasson:

On March 27, 2026, Mr. Stuart Bruce from Midwest Environmental Consulting Services, Inc. (MEC), collected a total of seven (7) non-viable mold air samples from select areas within Daniel Wright located at 1370 Riverwoods Rd., Lincolnshire, Illinois, 60069. Air-O-Cell Spore Trap cassettes were utilized for the sample collection.

Mold air samples were collected from the following areas:

|                 |                 |                    |
|-----------------|-----------------|--------------------|
| • Classroom 112 | • Classroom 117 | • Classroom 124    |
| • Classroom 203 | • Classroom 215 | • Central Corridor |
| • Outdoors      |                 |                    |

An independent laboratory, Eurofins Built Environment Testing Central, LLC, Illinois accredited by the American Industrial Hygiene Association (AIHA) was used for all microscopic identification.

There are many variables to consider when interpreting indoor airborne mold concentrations, including:

- The indoor concentrations of *Aspergillus/Penicillium*, *Chaetomium*, and/or *Fusarium*, should be less than their respective outdoor concentrations.
- *Stachybotrys/Memnoniella* should be absent from indoor environments.
- Ideally, the amount of total molds found indoors should be 1,000 Count/m<sup>3</sup> or less.

In relation to the outdoor air sample, *Aspergillus/Penicillium* were not present in any of the indoor or the outdoor sample

**Corporate Headquarters**  
2551 N. Bridge Street  
Yorkville, Illinois 60560  
P: 630-553-3989

**Chicago Office**  
954 W. Washington Blvd.  
Suite 425  
Chicago, Illinois 60607  
P: 312-535-3228


**Peoria Office**  
3100 N. Knoxville Ave.  
Suite 204  
Peoria, Illinois 61603  
P: 309-621-4680




There were no indoor locations with total airborne mold concentrations over 1,000 Count/m<sup>3</sup>.

If you have any questions or concerns, please feel free to contact MEC at (630) 553-3989. Thank you for providing us with an opportunity to service your environmental needs.

Respectfully submitted,  
Midwest Environmental Consulting Services, Inc.

  
Stuart J. Bruce  
Industrial Hygienist


**Mold Air Sample Location Photographs**  
**Lincolnshire-Prairieview School District 103**  
**Daniel Wright Jr. High School**  
**1370 Riverwoods Rd, Lincolnshire, IL 60069**  
**March 27, 2026**



*View Sample Location Classroom 112.  
Location of Mold Air Sample 41611159*



*View of Sample Location in Classroom 117  
Location of Mold Air Sample 41611148*



*View Sample Location Classroom 124.  
Location of Mold Air Sample 41611135*



*View Sample Location Classroom 203.  
Location of Mold Air Sample 41611145*

**Mold Air Sample Location Photographs**  
**Lincolnshire-Prairieview School District 103**  
**Daniel Wright Jr. High School**  
**1370 Riverwoods Rd, Lincolnshire, IL 60069**  
**March 27, 2026**



*View Sample Location Classroom 215.  
Location of Mold Air Sample 41611146*



*View of Sample Location in Corridor  
Location of Mold Air Sample 41611134*



*View Sample Location Outdoors  
Location of Mold Air Sample 41611137*


Report for:

**Stuart Bruce**  
**Midwest Environmental Consulting Services**  
2551 N. Bridge Street  
Yorkville, IL 60560

---

Regarding: Eurofins Built Environment Testing Central, LLC  
Project: 26-03-0255-IH; Daniel Wright Mold Sample  
EML ID: 4470987

Approved by:



Business Unit Manager  
Itzel Cuellar

Dates of Analysis:

Spore trap analysis: 03-31-2026

Service SOPs: Spore trap analysis (EBET-DE-SOP89537(formerly EB-MY-S-1038))  
AIHA LAP, LLC accredited service, Lab ID #176641

---

All samples were received in acceptable condition unless noted in the Report Comments portion in the body of the report. Due to the nature of the analyses performed, field blank correction of results is not applied. The results relate only to the samples as received and tested. Information supplied by the client which can affect the validity of results: sample air volume.

Eurofins Built Environment Testing Central, LLC ("the Company"), a member of the Eurofins Built Environment Testing group of companies, shall have no liability to the client or the client's customer with respect to decisions or recommendations made, actions taken or courses of conduct implemented by either the client or the client's customer as a result of or based upon the Test Results. In no event shall the Company be liable to the client with respect to the Test Results except for the Company's own willful misconduct or gross negligence nor shall the Company be liable for incidental or consequential damages or lost profits or revenues to the fullest extent such liability may be disclaimed by law, even if the Company has been advised of the possibility of such damages, lost profits or lost revenues. In no event shall the Company's liability with respect to the Test Results exceed the amount paid to the Company by the client therefor.

Eurofins Built Environment Testing Central, LLC's LabServe® reporting system includes automated fail-safes to ensure that all AIHA LAP, LLC quality requirements are met and notifications are added to reports when any quality steps remain pending.

Client: Midwest Environmental Consulting Services    Date of Sampling: 03-27-2026  
 C/O: Stuart Bruce    Date of Receipt: 03-27-2026  
 Re: 26-03-0255-IH; Daniel Wright Mold Sample    Date of Report: 03-31-2026

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

| Location:                      | 4161 1159:<br>In Room 112 |        |           | 4161 1148:<br>In Room 117 |        |           |
|--------------------------------|---------------------------|--------|-----------|---------------------------|--------|-----------|
| Comments (see below)           | None                      |        |           | None                      |        |           |
| Lab ID-Version‡:               | 22467541-1                |        |           | 22467542-1                |        |           |
| Analysis Date:                 | 03/31/2026                |        |           | 03/31/2026                |        |           |
|                                | raw ct.                   | % read | spores/m3 | raw ct.                   | % read | spores/m3 |
| Ascospores                     |                           |        |           |                           |        |           |
| Basidiospores                  |                           |        |           |                           |        |           |
| Bipolaris/Drechslera group     |                           |        |           |                           |        |           |
| Botrytis                       |                           |        |           |                           |        |           |
| Chaetomium                     |                           |        |           |                           |        |           |
| Cladosporium                   |                           |        |           |                           |        |           |
| Curvularia                     |                           |        |           |                           |        |           |
| Epicoccum                      |                           |        |           |                           |        |           |
| Fusarium                       |                           |        |           |                           |        |           |
| Myrothecium                    |                           |        |           |                           |        |           |
| Nigrospora                     |                           |        |           |                           |        |           |
| Other colorless                |                           |        |           |                           |        |           |
| Penicillium/Aspergillus types† |                           |        |           |                           |        |           |
| Pithomyces                     |                           |        |           |                           |        |           |
| Rusts                          |                           |        |           |                           |        |           |
| Smuts, Periconia, Myxomycetes  |                           |        |           |                           |        |           |
| Stachybotrys                   |                           |        |           |                           |        |           |
| Stemphylium                    |                           |        |           |                           |        |           |
| Torula                         |                           |        |           |                           |        |           |
| Ulocladium                     |                           |        |           |                           |        |           |
| Zygomycetes                    |                           |        |           |                           |        |           |
| Background debris (1-4+)       | 2+                        |        |           | 2+                        |        |           |
| Hyphal fragments/m3            | < 13                      |        |           | < 13                      |        |           |
| Pollen/m3                      | < 13                      |        |           | < 13                      |        |           |
| Skin cells (1-4+)              | 1+                        |        |           | 1+                        |        |           |
| Sample volume (liters)         | 75                        |        |           | 75                        |        |           |
| <b>§ TOTAL SPORES/m3</b>       |                           |        | < 13      |                           |        | < 13      |

**Comments:**

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

† The spores of *Aspergillus* and *Penicillium* (and others such as *Acremonium*, *Paecilomyces*) are small and round with very few distinguishing characteristics. They cannot be differentiated by non-viable sampling methods. Also, some species with very small spores are easily missed, and may be undercounted.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

The analytical sensitivity is the spores/m<sup>3</sup> divided by the raw count, expressed in spores/m<sup>3</sup>, per spore and per sample.

For more information regarding analytical sensitivity, please contact QA by calling the laboratory.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Spores/m<sup>3</sup> has been rounded to two significant figures to reflect analytical precision.

Client: Midwest Environmental Consulting Services Date of Sampling: 03-27-2026  
 C/O: Stuart Bruce Date of Receipt: 03-27-2026  
 Re: 26-03-0255-IH; Daniel Wright Mold Sample Date of Report: 03-31-2026

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

| Location:                      | 4161 1135:<br>In Room 124 |        |           | 4161 1145:<br>In Room 203 |        |                |
|--------------------------------|---------------------------|--------|-----------|---------------------------|--------|----------------|
| Comments (see below)           | None                      |        |           | None                      |        |                |
| Lab ID-Version‡:               | 22467543-1                |        |           | 22467544-1                |        |                |
| Analysis Date:                 | 03/31/2026                |        |           | 03/31/2026                |        |                |
|                                | raw ct.                   | % read | spores/m3 | raw ct.                   | % read | spores/m3      |
| Ascospores                     |                           |        |           |                           |        |                |
| Basidiospores                  | 1                         | 25     | 53        |                           |        |                |
| Bipolaris/Drechslera group     |                           |        |           |                           |        |                |
| Botrytis                       |                           |        |           |                           |        |                |
| Chaetomium                     |                           |        |           |                           |        |                |
| Cladosporium                   |                           |        |           |                           |        |                |
| Curvularia                     |                           |        |           |                           |        |                |
| Epicoccum                      |                           |        |           |                           |        |                |
| Fusarium                       |                           |        |           |                           |        |                |
| Myrothecium                    |                           |        |           |                           |        |                |
| Nigrospora                     |                           |        |           |                           |        |                |
| Other colorless                |                           |        |           |                           |        |                |
| Penicillium/Aspergillus types† |                           |        |           |                           |        |                |
| Pithomyces                     |                           |        |           |                           |        |                |
| Rusts                          |                           |        |           |                           |        |                |
| Smuts, Periconia, Myxomycetes  |                           |        |           |                           |        |                |
| Stachybotrys                   |                           |        |           |                           |        |                |
| Stemphylium                    |                           |        |           |                           |        |                |
| Torula                         |                           |        |           |                           |        |                |
| Ulocladium                     |                           |        |           |                           |        |                |
| Zygomycetes                    |                           |        |           |                           |        |                |
| Background debris (1-4+)       | 2+                        |        |           | 1+                        |        |                |
| Hyphal fragments/m3            | < 13                      |        |           | < 13                      |        |                |
| Pollen/m3                      | < 13                      |        |           | < 13                      |        |                |
| Skin cells (1-4+)              | 1+                        |        |           | < 1+                      |        |                |
| Sample volume (liters)         | 75                        |        |           | 75                        |        |                |
| <b>§ TOTAL SPORES/m3</b>       |                           |        | <b>53</b> |                           |        | <b>&lt; 13</b> |

**Comments:**

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

† The spores of *Aspergillus* and *Penicillium* (and others such as *Acremonium*, *Paecilomyces*) are small and round with very few distinguishing characteristics. They cannot be differentiated by non-viable sampling methods. Also, some species with very small spores are easily missed, and may be undercounted.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

The analytical sensitivity is the spores/m<sup>3</sup> divided by the raw count, expressed in spores/m<sup>3</sup>, per spore and per sample.

For more information regarding analytical sensitivity, please contact QA by calling the laboratory.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Spores/m<sup>3</sup> has been rounded to two significant figures to reflect analytical precision.

Client: Midwest Environmental Consulting Services Date of Sampling: 03-27-2026  
 C/O: Stuart Bruce Date of Receipt: 03-27-2026  
 Re: 26-03-0255-IH; Daniel Wright Mold Sample Date of Report: 03-31-2026

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

| Location:                      | 4161 1146:<br>In Room 215 |        |           | 4161 1134:<br>Indoor Corridor |        |           |
|--------------------------------|---------------------------|--------|-----------|-------------------------------|--------|-----------|
| Comments (see below)           | None                      |        |           | None                          |        |           |
| Lab ID-Version‡:               | 22467545-1                |        |           | 22467546-1                    |        |           |
| Analysis Date:                 | 03/31/2026                |        |           | 03/31/2026                    |        |           |
|                                | raw ct.                   | % read | spores/m3 | raw ct.                       | % read | spores/m3 |
| Ascospores                     |                           |        |           |                               |        |           |
| Basidiospores                  |                           |        |           |                               |        |           |
| Bipolaris/Drechslera group     |                           |        |           |                               |        |           |
| Botrytis                       |                           |        |           |                               |        |           |
| Chaetomium                     |                           |        |           |                               |        |           |
| Cladosporium                   |                           |        |           |                               |        |           |
| Curvularia                     |                           |        |           |                               |        |           |
| Epicoccum                      |                           |        |           |                               |        |           |
| Fusarium                       |                           |        |           |                               |        |           |
| Myrothecium                    |                           |        |           |                               |        |           |
| Nigrospora                     |                           |        |           |                               |        |           |
| Other colorless                |                           |        |           |                               |        |           |
| Penicillium/Aspergillus types† |                           |        |           |                               |        |           |
| Pithomyces                     |                           |        |           |                               |        |           |
| Rusts                          |                           |        |           |                               |        |           |
| Smuts, Periconia, Myxomycetes  |                           |        |           |                               |        |           |
| Stachybotrys                   |                           |        |           |                               |        |           |
| Stemphylium                    |                           |        |           |                               |        |           |
| Torula                         |                           |        |           |                               |        |           |
| Ulocladium                     |                           |        |           |                               |        |           |
| Zygomycetes                    |                           |        |           |                               |        |           |
| Background debris (1-4+)       | < 1+                      |        |           | < 1+                          |        |           |
| Hyphal fragments/m3            | < 13                      |        |           | < 13                          |        |           |
| Pollen/m3                      | < 13                      |        |           | < 13                          |        |           |
| Skin cells (1-4+)              | < 1+                      |        |           | < 1+                          |        |           |
| Sample volume (liters)         | 75                        |        |           | 75                            |        |           |
| <b>§ TOTAL SPORES/m3</b>       |                           |        | < 13      |                               |        | < 13      |

**Comments:**

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

† The spores of *Aspergillus* and *Penicillium* (and others such as *Acremonium*, *Paecilomyces*) are small and round with very few distinguishing characteristics. They cannot be differentiated by non-viable sampling methods. Also, some species with very small spores are easily missed, and may be undercounted.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

The analytical sensitivity is the spores/m<sup>3</sup> divided by the raw count, expressed in spores/m<sup>3</sup>, per spore and per sample.

For more information regarding analytical sensitivity, please contact QA by calling the laboratory.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Spores/m<sup>3</sup> has been rounded to two significant figures to reflect analytical precision.

Client: Midwest Environmental Consulting Services Date of Sampling: 03-27-2026  
 C/O: Stuart Bruce Date of Receipt: 03-27-2026  
 Re: 26-03-0255-IH; Daniel Wright Mold Sample Date of Report: 03-31-2026

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

|                                |                        |        |                |
|--------------------------------|------------------------|--------|----------------|
| Location:                      | 4161 1137:<br>Outdoors |        |                |
| Comments (see below)           | None                   |        |                |
| Lab ID-Version‡:               | 22467547-1             |        |                |
| Analysis Date:                 | 03/31/2026             |        |                |
|                                | raw ct.                | % read | spores/m3      |
| Ascospores                     |                        |        |                |
| Basidiospores                  |                        |        |                |
| Bipolaris/Drechslera group     |                        |        |                |
| Botrytis                       |                        |        |                |
| Chaetomium                     |                        |        |                |
| Cladosporium                   |                        |        |                |
| Curvularia                     |                        |        |                |
| Epicoccum                      |                        |        |                |
| Fusarium                       |                        |        |                |
| Myrothecium                    |                        |        |                |
| Nigrospora                     |                        |        |                |
| Other colorless                |                        |        |                |
| Penicillium/Aspergillus types† |                        |        |                |
| Pithomyces                     |                        |        |                |
| Rusts                          |                        |        |                |
| Smuts, Periconia, Myxomycetes  |                        |        |                |
| Stachybotrys                   |                        |        |                |
| Stemphylium                    |                        |        |                |
| Torula                         |                        |        |                |
| Ulocladium                     |                        |        |                |
| Zygomycetes                    |                        |        |                |
| Background debris (1-4+)       | 2+                     |        |                |
| Hyphal fragments/m3            | 13                     |        |                |
| Pollen/m3                      | < 13                   |        |                |
| Skin cells (1-4+)              | < 1+                   |        |                |
| Sample volume (liters)         | 75                     |        |                |
| <b>§ TOTAL SPORES/m3</b>       |                        |        | <b>&lt; 13</b> |

**Comments:**

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

† The spores of *Aspergillus* and *Penicillium* (and others such as *Acremonium*, *Paecilomyces*) are small and round with very few distinguishing characteristics. They cannot be differentiated by non-viable sampling methods. Also, some species with very small spores are easily missed, and may be undercounted.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

The analytical sensitivity is the spores/m<sup>3</sup> divided by the raw count, expressed in spores/m<sup>3</sup>, per spore and per sample.

For more information regarding analytical sensitivity, please contact QA by calling the laboratory.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Spores/m<sup>3</sup> has been rounded to two significant figures to reflect analytical precision.

**Eurofins Built Environment Testing Central, LLC**  
1815 West Diehl Road, Suite 800, Naperville, IL 60563  
(866) 871-1984 www.eurofinsus.com/Built

Client: Midwest Environmental Consulting Services Date of Sampling: 03-27-2026  
C/O: Stuart Bruce Date of Receipt: 03-27-2026  
Re: 26-03-0255-IH; Daniel Wright Mold Sample Date of Report: 03-31-2026

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

---

**PROJECT ANALYST AND SIGNATORY REPORT**

---

**Project Analyst**



---

**Analyst:** Jonathan Anthony

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by AIHA LAP, LLC, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".


Report for:

**Stuart Bruce**  
**Midwest Environmental Consulting Services**  
2551 N. Bridge Street  
Yorkville, IL 60560

---

Regarding: Eurofins Built Environment Testing Central, LLC  
Project: 26-03-0255-IH; Daniel Wright Mold Sample  
EML ID: 4470987

Approved by:



Business Unit Manager  
Itzel Cuellar

Dates of Analysis:

Spore trap analysis: 03-31-2026

Service SOPs: Spore trap analysis (EBET-DE-SOP89537(formerly EB-MY-S-1038))  
AIHA LAP, LLC accredited service, Lab ID #176641

---

All samples were received in acceptable condition unless noted in the Report Comments portion in the body of the report. Due to the nature of the analyses performed, field blank correction of results is not applied. The results relate only to the samples as received and tested. Information supplied by the client which can affect the validity of results: sample air volume.

Eurofins Built Environment Testing Central, LLC ("the Company"), a member of the Eurofins Built Environment Testing group of companies, shall have no liability to the client or the client's customer with respect to decisions or recommendations made, actions taken or courses of conduct implemented by either the client or the client's customer as a result of or based upon the Test Results. In no event shall the Company be liable to the client with respect to the Test Results except for the Company's own willful misconduct or gross negligence nor shall the Company be liable for incidental or consequential damages or lost profits or revenues to the fullest extent such liability may be disclaimed by law, even if the Company has been advised of the possibility of such damages, lost profits or lost revenues. In no event shall the Company's liability with respect to the Test Results exceed the amount paid to the Company by the client therefor.

Eurofins Built Environment Testing Central, LLC's LabServe® reporting system includes automated fail-safes to ensure that all AIHA LAP, LLC quality requirements are met and notifications are added to reports when any quality steps remain pending.

Client: Midwest Environmental Consulting Services    Date of Sampling: 03-27-2026  
 C/O: Stuart Bruce    Date of Receipt: 03-27-2026  
 Re: 26-03-0255-IH; Daniel Wright Mold Sample    Date of Report: 03-31-2026

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

| Location:                      | 4161 1159:<br>In Room 112 |        |           | 4161 1148:<br>In Room 117 |        |           |
|--------------------------------|---------------------------|--------|-----------|---------------------------|--------|-----------|
| Comments (see below)           | None                      |        |           | None                      |        |           |
| Lab ID-Version‡:               | 22467541-1                |        |           | 22467542-1                |        |           |
| Analysis Date:                 | 03/31/2026                |        |           | 03/31/2026                |        |           |
|                                | raw ct.                   | % read | spores/m3 | raw ct.                   | % read | spores/m3 |
| Ascospores                     |                           |        |           |                           |        |           |
| Basidiospores                  |                           |        |           |                           |        |           |
| Bipolaris/Drechslera group     |                           |        |           |                           |        |           |
| Botrytis                       |                           |        |           |                           |        |           |
| Chaetomium                     |                           |        |           |                           |        |           |
| Cladosporium                   |                           |        |           |                           |        |           |
| Curvularia                     |                           |        |           |                           |        |           |
| Epicoccum                      |                           |        |           |                           |        |           |
| Fusarium                       |                           |        |           |                           |        |           |
| Myrothecium                    |                           |        |           |                           |        |           |
| Nigrospora                     |                           |        |           |                           |        |           |
| Other colorless                |                           |        |           |                           |        |           |
| Penicillium/Aspergillus types† |                           |        |           |                           |        |           |
| Pithomyces                     |                           |        |           |                           |        |           |
| Rusts                          |                           |        |           |                           |        |           |
| Smuts, Periconia, Myxomycetes  |                           |        |           |                           |        |           |
| Stachybotrys                   |                           |        |           |                           |        |           |
| Stemphylium                    |                           |        |           |                           |        |           |
| Torula                         |                           |        |           |                           |        |           |
| Ulocladium                     |                           |        |           |                           |        |           |
| Zygomycetes                    |                           |        |           |                           |        |           |
| Background debris (1-4+)       | 2+                        |        |           | 2+                        |        |           |
| Hyphal fragments/m3            | < 13                      |        |           | < 13                      |        |           |
| Pollen/m3                      | < 13                      |        |           | < 13                      |        |           |
| Skin cells (1-4+)              | 1+                        |        |           | 1+                        |        |           |
| Sample volume (liters)         | 75                        |        |           | 75                        |        |           |
| <b>§ TOTAL SPORES/m3</b>       |                           |        | < 13      |                           |        | < 13      |

**Comments:**

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

† The spores of *Aspergillus* and *Penicillium* (and others such as *Acremonium*, *Paecilomyces*) are small and round with very few distinguishing characteristics. They cannot be differentiated by non-viable sampling methods. Also, some species with very small spores are easily missed, and may be undercounted.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

The analytical sensitivity is the spores/m<sup>3</sup> divided by the raw count, expressed in spores/m<sup>3</sup>, per spore and per sample.

For more information regarding analytical sensitivity, please contact QA by calling the laboratory.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Spores/m<sup>3</sup> has been rounded to two significant figures to reflect analytical precision.

Client: Midwest Environmental Consulting Services Date of Sampling: 03-27-2026  
 C/O: Stuart Bruce Date of Receipt: 03-27-2026  
 Re: 26-03-0255-IH; Daniel Wright Mold Sample Date of Report: 03-31-2026

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

| Location:                      | 4161 1135:<br>In Room 124 |        |           | 4161 1145:<br>In Room 203 |        |                |
|--------------------------------|---------------------------|--------|-----------|---------------------------|--------|----------------|
| Comments (see below)           | None                      |        |           | None                      |        |                |
| Lab ID-Version‡:               | 22467543-1                |        |           | 22467544-1                |        |                |
| Analysis Date:                 | 03/31/2026                |        |           | 03/31/2026                |        |                |
|                                | raw ct.                   | % read | spores/m3 | raw ct.                   | % read | spores/m3      |
| Ascospores                     |                           |        |           |                           |        |                |
| Basidiospores                  | 1                         | 25     | 53        |                           |        |                |
| Bipolaris/Drechslera group     |                           |        |           |                           |        |                |
| Botrytis                       |                           |        |           |                           |        |                |
| Chaetomium                     |                           |        |           |                           |        |                |
| Cladosporium                   |                           |        |           |                           |        |                |
| Curvularia                     |                           |        |           |                           |        |                |
| Epicoccum                      |                           |        |           |                           |        |                |
| Fusarium                       |                           |        |           |                           |        |                |
| Myrothecium                    |                           |        |           |                           |        |                |
| Nigrospora                     |                           |        |           |                           |        |                |
| Other colorless                |                           |        |           |                           |        |                |
| Penicillium/Aspergillus types† |                           |        |           |                           |        |                |
| Pithomyces                     |                           |        |           |                           |        |                |
| Rusts                          |                           |        |           |                           |        |                |
| Smuts, Periconia, Myxomycetes  |                           |        |           |                           |        |                |
| Stachybotrys                   |                           |        |           |                           |        |                |
| Stemphylium                    |                           |        |           |                           |        |                |
| Torula                         |                           |        |           |                           |        |                |
| Ulocladium                     |                           |        |           |                           |        |                |
| Zygomycetes                    |                           |        |           |                           |        |                |
| Background debris (1-4+)       | 2+                        |        |           | 1+                        |        |                |
| Hyphal fragments/m3            | < 13                      |        |           | < 13                      |        |                |
| Pollen/m3                      | < 13                      |        |           | < 13                      |        |                |
| Skin cells (1-4+)              | 1+                        |        |           | < 1+                      |        |                |
| Sample volume (liters)         | 75                        |        |           | 75                        |        |                |
| <b>§ TOTAL SPORES/m3</b>       |                           |        | <b>53</b> |                           |        | <b>&lt; 13</b> |

**Comments:**

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

† The spores of *Aspergillus* and *Penicillium* (and others such as *Acremonium*, *Paecilomyces*) are small and round with very few distinguishing characteristics. They cannot be differentiated by non-viable sampling methods. Also, some species with very small spores are easily missed, and may be undercounted.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

The analytical sensitivity is the spores/m<sup>3</sup> divided by the raw count, expressed in spores/m<sup>3</sup>, per spore and per sample.

For more information regarding analytical sensitivity, please contact QA by calling the laboratory.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Spores/m<sup>3</sup> has been rounded to two significant figures to reflect analytical precision.

Client: Midwest Environmental Consulting Services    Date of Sampling: 03-27-2026  
 C/O: Stuart Bruce    Date of Receipt: 03-27-2026  
 Re: 26-03-0255-IH; Daniel Wright Mold Sample    Date of Report: 03-31-2026

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

| Location:                      | 4161 1146:<br>In Room 215 |        |           | 4161 1134:<br>Indoor Corridor |        |           |
|--------------------------------|---------------------------|--------|-----------|-------------------------------|--------|-----------|
| Comments (see below)           | None                      |        |           | None                          |        |           |
| Lab ID-Version‡:               | 22467545-1                |        |           | 22467546-1                    |        |           |
| Analysis Date:                 | 03/31/2026                |        |           | 03/31/2026                    |        |           |
|                                | raw ct.                   | % read | spores/m3 | raw ct.                       | % read | spores/m3 |
| Ascospores                     |                           |        |           |                               |        |           |
| Basidiospores                  |                           |        |           |                               |        |           |
| Bipolaris/Drechslera group     |                           |        |           |                               |        |           |
| Botrytis                       |                           |        |           |                               |        |           |
| Chaetomium                     |                           |        |           |                               |        |           |
| Cladosporium                   |                           |        |           |                               |        |           |
| Curvularia                     |                           |        |           |                               |        |           |
| Epicoccum                      |                           |        |           |                               |        |           |
| Fusarium                       |                           |        |           |                               |        |           |
| Myrothecium                    |                           |        |           |                               |        |           |
| Nigrospora                     |                           |        |           |                               |        |           |
| Other colorless                |                           |        |           |                               |        |           |
| Penicillium/Aspergillus types† |                           |        |           |                               |        |           |
| Pithomyces                     |                           |        |           |                               |        |           |
| Rusts                          |                           |        |           |                               |        |           |
| Smuts, Periconia, Myxomycetes  |                           |        |           |                               |        |           |
| Stachybotrys                   |                           |        |           |                               |        |           |
| Stemphylium                    |                           |        |           |                               |        |           |
| Torula                         |                           |        |           |                               |        |           |
| Ulocladium                     |                           |        |           |                               |        |           |
| Zygomycetes                    |                           |        |           |                               |        |           |
| Background debris (1-4+)       | < 1+                      |        |           | < 1+                          |        |           |
| Hyphal fragments/m3            | < 13                      |        |           | < 13                          |        |           |
| Pollen/m3                      | < 13                      |        |           | < 13                          |        |           |
| Skin cells (1-4+)              | < 1+                      |        |           | < 1+                          |        |           |
| Sample volume (liters)         | 75                        |        |           | 75                            |        |           |
| <b>§ TOTAL SPORES/m3</b>       |                           |        | < 13      |                               |        | < 13      |

**Comments:**

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

† The spores of *Aspergillus* and *Penicillium* (and others such as *Acremonium*, *Paecilomyces*) are small and round with very few distinguishing characteristics. They cannot be differentiated by non-viable sampling methods. Also, some species with very small spores are easily missed, and may be undercounted.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

The analytical sensitivity is the spores/m<sup>3</sup> divided by the raw count, expressed in spores/m<sup>3</sup>, per spore and per sample.

For more information regarding analytical sensitivity, please contact QA by calling the laboratory.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Spores/m<sup>3</sup> has been rounded to two significant figures to reflect analytical precision.

Client: Midwest Environmental Consulting Services    Date of Sampling: 03-27-2026  
 C/O: Stuart Bruce    Date of Receipt: 03-27-2026  
 Re: 26-03-0255-IH; Daniel Wright Mold Sample    Date of Report: 03-31-2026

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

|                                |                        |        |                |
|--------------------------------|------------------------|--------|----------------|
| Location:                      | 4161 1137:<br>Outdoors |        |                |
| Comments (see below)           | None                   |        |                |
| Lab ID-Version‡:               | 22467547-1             |        |                |
| Analysis Date:                 | 03/31/2026             |        |                |
|                                | raw ct.                | % read | spores/m3      |
| Ascospores                     |                        |        |                |
| Basidiospores                  |                        |        |                |
| Bipolaris/Drechslera group     |                        |        |                |
| Botrytis                       |                        |        |                |
| Chaetomium                     |                        |        |                |
| Cladosporium                   |                        |        |                |
| Curvularia                     |                        |        |                |
| Epicoccum                      |                        |        |                |
| Fusarium                       |                        |        |                |
| Myrothecium                    |                        |        |                |
| Nigrospora                     |                        |        |                |
| Other colorless                |                        |        |                |
| Penicillium/Aspergillus types† |                        |        |                |
| Pithomyces                     |                        |        |                |
| Rusts                          |                        |        |                |
| Smuts, Periconia, Myxomycetes  |                        |        |                |
| Stachybotrys                   |                        |        |                |
| Stemphylium                    |                        |        |                |
| Torula                         |                        |        |                |
| Ulocladium                     |                        |        |                |
| Zygomycetes                    |                        |        |                |
| Background debris (1-4+)       | 2+                     |        |                |
| Hyphal fragments/m3            | 13                     |        |                |
| Pollen/m3                      | < 13                   |        |                |
| Skin cells (1-4+)              | < 1+                   |        |                |
| Sample volume (liters)         | 75                     |        |                |
| <b>§ TOTAL SPORES/m3</b>       |                        |        | <b>&lt; 13</b> |

**Comments:**

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

† The spores of *Aspergillus* and *Penicillium* (and others such as *Acremonium*, *Paecilomyces*) are small and round with very few distinguishing characteristics. They cannot be differentiated by non-viable sampling methods. Also, some species with very small spores are easily missed, and may be undercounted.

††Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

The analytical sensitivity is the spores/m<sup>3</sup> divided by the raw count, expressed in spores/m<sup>3</sup>, per spore and per sample.

For more information regarding analytical sensitivity, please contact QA by calling the laboratory.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Spores/m<sup>3</sup> has been rounded to two significant figures to reflect analytical precision.

**Eurofins Built Environment Testing Central, LLC**  
1815 West Diehl Road, Suite 800, Naperville, IL 60563  
(866) 871-1984 www.eurofinsus.com/Built

Client: Midwest Environmental Consulting Services Date of Sampling: 03-27-2026  
C/O: Stuart Bruce Date of Receipt: 03-27-2026  
Re: 26-03-0255-IH; Daniel Wright Mold Sample Date of Report: 03-31-2026

**SPORE TRAP REPORT: NON-VIABLE METHODOLOGY**

---

**PROJECT ANALYST AND SIGNATORY REPORT**

---

**Project Analyst**



---

**Analyst:** Jonathan Anthony

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by AIHA LAP, LLC, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

# CHAIN OF CUSTODY



www.eurofinsus.com/Built  
1815 W. Diehl Road, #800  
Naperville, IL 60563

| WEATHER  | Fog | Rain | Snow | Wind | Clear |
|----------|-----|------|------|------|-------|
| None     |     |      |      |      |       |
| Light    |     |      |      |      |       |
| Moderate |     |      |      |      |       |
| Heavy    |     |      |      |      |       |

| REQUESTED      |  |
|----------------|--|
| Non-Culturable |  |
| Spore Trap     |  |
| Tape Swab      |  |
| Bulk           |  |
| BioCassette    |  |
| Water, Bulk,   |  |



### CONTACT INFORMATION

Company: **Midwest Environmental Consulting Services**  
 Address: 2551 N. Bridge Street, Yorkville, IL 60560  
 Contact: **STUART BRUCE**  
 Phone/Email: 630.608.8957/sbruce@mec-us.com  
 Special Instructions: Send Results to: results@mec-us.com  
 Send Invoice to: invoice@mec-us.com

### PROJECT INFORMATION

Project ID: **26 03-0255-114**  
 Project Desc.: **Daniel Wright Mold Sample**  
 Project: **60069**  
 Zip Code: **60069**  
 PO Number: Same as Project ID

### TURN AROUND TIME CODES - (TAT)

STD - Standard (DEFAULT)  
 ND - Next Business Day  
 SD - Same Business Day Rush  
 WH - Weekend/Holiday  
 Rushes received after 2pm or on weekends, will be considered received the next business day. Please alert us in advance of weekend analysis needs.

| Sample ID | Description          | Sample Type (Below) | TAT (Above) | Total Volume/Area (as applicable) | NOTES (Time of day, Temp, RH, etc.) |
|-----------|----------------------|---------------------|-------------|-----------------------------------|-------------------------------------|
| 4161159   | IN Room 112          | ST                  | STD         | 75L                               | A.M.                                |
| 1144      | IN Room 117          | ↑                   | ↑           | ↑                                 | ↑                                   |
| 1135      | IN Room 124          | ↑                   | ↑           | ↑                                 | ↑                                   |
| 1145      | IN Room 203          | ↑                   | ↑           | ↑                                 | ↑                                   |
| 1146      | IN Room 215          | ↑                   | ↑           | ↑                                 | ↑                                   |
| 1134      | INDOORS - COOPERATOR | ↑                   | ↑           | ↑                                 | ↑                                   |
| 1137      | OUTDOORS             | ↑                   | ↑           | ↑                                 | ↑                                   |

### SAMPLE TYPE CODES

|                    |  |           |            |
|--------------------|--|-----------|------------|
| BC - BioCassette™  | ST - Spore Trap; Zefon, Allergenco, Burkard, ... | T - Tape  | D - Dust   |
| A1S - Andersen     | SAS - Surface Air Sampler                        | SW - Swab | SO - Soil  |
| CP - Contact Plate | NP - Non-Potable Water                           | B - Bulk  | O - Other: |

### RELINQUISHED BY

*Stuart Bruce*

### DATE & TIME

3/27/26 4:30

### RECEIVED BY

*[Signature]*  
 REC'D  
 MAY 27 2026

### DATE & TIME

4:37pm

|   |  |
|---|--|
| Fungi - Spore Trap Analysis                             |  |
| Spore Trap Analysis - Other particles                   |  |
| Direct Microscopic Exam (Qualitative)                   |  |
| Quantitative Spore Count Direct Exam                    |  |
| 1-Media Surface Fungi (Genus ID + Asp. spp.)            |  |
| 2-Media Surface Fungi (Genus ID + Asp. spp.)            |  |
| 3-Media Surface Fungi (Genus ID + Asp. spp.)            |  |
| Culturable Air Fungi (Genus ID + Asp. spp.)             |  |
| Gram Stain and Counts (Culturable Air and Surface Back) |  |
| Legionella culture                                      |  |
| Total Coliform, E. coli (Presence/Absence)              |  |
| Membrane Filtration (Please specify organism)           |  |
| MPN Bacteria (Please specify organism)                  |  |
| Quant Tray - Sewage Screen                              |  |
| Asbestos Analysis - PCM Airborne Fiber Count (NIOSH 7)  |  |
| Asbestos Analysis - PLM (EPA method 600/R-93-116)       |  |
| PCR (please specify test)                               |  |

By submitting this Chain of Custody, you agree to be bound by the terms and conditions set forth at [www.emlabpk.com/terms.html](http://www.emlabpk.com/terms.html)  
 Copyright © 2002-2009 EMLab P&K



**AIHA Laboratory Accreditation Programs, LLC**  
*acknowledges that*  
**Eurofins Built Environment Testing Central- Chicago, IL.**  
**Eurofins Built Environment Testing Central, LLC.**  
**1815 West Diehl Rd, Suite 800, Naperville, IL 60563-6421**  
**Laboratory ID: LAP-176641**

along with all premises from which key activities are performed, as listed above, has fulfilled the requirements of the AIHA Laboratory Accreditation Programs, LLC (AIHA LAP) accreditation to the ISO/IEC 17025:2017 international standard, General Requirements for the Competence of Testing and Calibration Laboratories in the following:

**LABORATORY ACCREDITATION PROGRAMS**

- |                                     |                            |   |
|-------------------------------------|----------------------------|---|
| <input type="checkbox"/>            | INDUSTRIAL HYGIENE         | Accreditation Expires:                    |
| <input type="checkbox"/>            | ENVIRONMENTAL LEAD         | Accreditation Expires:                    |
| <input checked="" type="checkbox"/> | ENVIRONMENTAL MICROBIOLOGY | Accreditation Expires: September 01, 2027 |
| <input type="checkbox"/>            | FOOD                       | Accreditation Expires:                    |
| <input type="checkbox"/>            | UNIQUE SCOPES              | Accreditation Expires:                    |
| <input type="checkbox"/>            | BE FIELD/MOBILE            | Accreditation Expires:                    |

Specific Field(s) of Testing/Method(s) within each Accreditation Program for which the above named laboratory maintains accreditation is outlined on the attached Scope of Accreditation. Continued accreditation is contingent upon successful on-going compliance with ISO/IEC 17025:2017 and AIHA LAP requirements. This certificate is not valid without the attached Scope of Accreditation. Please review the AIHA LAP website ([www.aihaaccreditedlabs.org](http://www.aihaaccreditedlabs.org)) for the most current Scope.

A handwritten signature in cursive script that reads 'Cheryl O. Morton'.

Cheryl O Morton  
Managing Director, AIHA Laboratory Accreditation Programs, LLC



# AIHA Laboratory Accreditation Programs, LLC

## SCOPE OF ACCREDITATION

**Eurofins Built Environment Testing  
Central- Chicago, IL.**  
Eurofins Built Environment Testing  
Central, LLC.  
1815 West Diehl Rd, Suite 800, Naperville, IL  
60563-6421

Laboratory ID: LAP-176641

Issue Date: 07/01/2025

Expire Date: 09/01/2027

The laboratory is approved for those specific field(s) of testing/methods listed in the table below. Clients are urged to verify the laboratory's current accreditation status for the particular field(s) of testing/Methods, since these can change due to proficiency status, suspension and/or withdrawal of accreditation.

### Environmental Microbiology Laboratory Accreditation Program (EMLAP)

**Initial Accreditation Date: 09/01/2005**

| EMLAP Scope Category | Field of Testing (FOT)       | Component, parameter, characteristic, material, or product tested | Method  | Method Description<br><i>(for internal methods only)</i>   |
|----------------------|------------------------------|---|---|--|
| Bacterial            | Legionella                   | Water, Swabs  | EB-BT-S-1045<br>(ISO 11731:2017)  | Detection and Enumeration of Legionella (based on ISO 11731:2017 Method)   |
| Bacterial            | Legionella                   | Water, Swabs, Wipes, Bulk, Air                                    | EB-BT-1045 (Procedures for the Recovery of Legionella from the Environment, US DHHS, CDC, 2005) | Detection and Enumeration of Legionella bacteria (based on CDC method)   |
| Fungal               | Air - Direct Examination     | Spore Trap Air Samples  | EM-MY-S-1038  | Preparation and Analysis of Spore Trap (Air) Samples for Fungal Spores, Other Biological and Non-Biological Particles      |
| Fungal               | Bulk - Direct Examination    | Tape, Swab, Wipe, Bulk, Dust, Soil                                | EM-MY-S-1039  | Preparation and Analysis of Tape, Swab, Wipe, Bulk and Dust - Soil Samples for Qualitative Direct Microscopic Examination  |
| Fungal               | Bulk - Direct Examination    | Tape, Swab, Wipe, Bulk, Dust, Soil                                | EM-MY-S-1041  | Preparation and Analysis of Tape, Swab, Wipe, Bulk and Dust - Soil Samples for Quantitative Direct Microscopic Examination |
| Fungal               | Surface - Direct Examination | Tape, Swab, Wipe, Bulk, Dust, Soil                                | EM-MY-S-1039  | Preparation and Analysis of Tape, Swab, Wipe, Bulk and Dust - Soil Samples   |



| EMLAP Scope Category | Field of Testing (FOT)       | Component, parameter, characteristic, material, or product tested | Method       | Method Description<br><i>(for internal methods only)</i>   |
|----------------------|------------------------------|---|--------------|--|
|                      |                              |   |              | for Qualitative Direct Microscopic Examination   |
| Fungal               | Surface - Direct Examination | Tape, Swab, Wipe, Bulk, Dust, Soil                                | EM-MY-S-1041 | Preparation and Analysis of Tape, Swab, Wipe, Bulk and Dust - Soil Samples for Quantitative Direct Microscopic Examination |

A complete listing of currently accredited EMLAP laboratories is available on the AIHA LAP, LLC website at: <http://www.aihaaccreditedlabs.org>