

## Greenway

Fixture Number	Sample Number	Building	Location / Room No.	Fixture Type	Results (ppb)
001	22431157-001KF21A	Main	Kitchen	Kitchen Prep Sink	1.06
002	22431157-002KF21A	Main	Kitchen	Kitchen Kettle <i>(out of service)</i>	33.6
002 - Follow Up	22431157-002KF21B	Main	Kitchen	Kitchen Kettle - Follow Up <i>(removed from service)</i>	17.7
003	22431157-003SF21A	Main	Staff Break Room	Staff Sink	0.551
004	22431157-004DW21A	Main	Main Hall	Drinking Fountain	ND
005	22431157-005DW21A	Main	Gym	Drinking Fountain	2.99
006	22431157-006SF21A	Main	Health Room	Staff Sink	3.21
007	22431157-007CF21A	Main	A102	Classroom Faucet	4.82
008	22431157-008DW21A	Main	A102	Drinking Fountain	2.13
009	22431157-009CF21A	Main	A104	Classroom Faucet	5.39
010	22431157-010DW21A	Main	A104	Drinking Fountain	3.38
011	22431157-011CF21A	Main	A106	Classroom Faucet	6.79
012	22431157-012DW21A	Main	A106	Drinking Fountain	2.42
013	22431157-013CF21A	Main	A108	Classroom Faucet	3.9
014	22431157-014DW21A	Main	A108	Drinking Fountain	0.362
015	22431157-015CF21A	Main	A110	Classroom Faucet	7.5
016	22431157-016DW21A	Main	A110	Drinking Fountain	3.48
017	22431157-017CF21A	Main	A112	Classroom Faucet	9.61
018	22431157-018CF21A	Main	A114	Classroom Faucet	10.1
019	22431157-019DW21A	Main	A114	Drinking Fountain	3.36
020	22431157-020CF21A	Main	A116	Classroom Faucet	11.4
021	22431157-021DW21A	Main	A116	Drinking Fountain	3.8
022	22431157-022CF21A	Main	A118	Classroom Faucet	9.77
023	22431157-023DW21A	Main	A118	Drinking Fountain	2.48
024	22431157-024CF21A	Main	A120	Classroom Faucet	2.78
025	22431157-025DW21A	Main	A120	Drinking Fountain	2.44
026	22431157-026CF21A	Main	A122	Classroom Faucet	7.37
027	22431157-027DW21A	Main	A122	Drinking Fountain	32.2
027 - Follow Up	22431157-027DW21B	Main	A122	Drinking Fountain <i>(post-mitigation)</i>	1.08
028	22431157-028CF21A	Main	A124	Classroom Faucet	13.9
029	22431157-029DW21A	Main	A124	Drinking Fountain	2.65
030	22431157-030CF21A	Main	A100	Classroom Faucet	6.6
031	22431157-031DW21A	Main	A100	Drinking Fountain	0.625
032	22431157-032CF21A	Main	A126	Classroom Faucet	1.74
033	22431157-033CF21A	Main	M100	Classroom Faucet	16.6
033	22431157-033CF21B	Main	M100	Classroom Faucet <i>(post-mitigation)</i>	12.1
034	22431157-034DW21A	Main	M100	Drinking Fountain	2.9
035	22431157-035CF21A	Main	M102	Classroom Faucet	0.299
036	22431157-036DW21A	Main	M102	Drinking Fountain	1.96
037	22431157-037CF21A	Main	M104	Classroom Faucet	0.278
038	22431157-038DW21A	Main	M104	Drinking Fountain	8.4
039	22431157-039CF21A	Main	M106	Classroom Faucet	8.21
040	22431157-040DW21A	Main	M106	Drinking Fountain	1.05
041	22431157-041CF21A	Main	M108	Classroom Faucet	13.5
042	22431157-042DW21A	Main	M108	Drinking Fountain	2.9
043	22431157-043DW21A	Main	M Commons	Drinking Fountain	0.87
044	22431157-044SF21A	Main	Stockroom 8	Staff Room Sink	21.3
044 - Follow Up	22431157-044SF21B	Main	Stockroom 8	Staff Room Sink - Follow Up	23.6
	22430500- 001SF23A	Main	Stockroom 8	Staff Room Sink <i>(restricted use/handwashing only)</i>	31.4
	22430500- 001SF23B	Main	Stockroom 8	Staff Room Sink <i>(flush sample)</i>	1.64
045	22431157-045DW21A	Main	Stockroom 8	Drinking Fountain <i>(permanently removed from service)</i>	17.2
045 - Follow Up	22431157-045DW21B	Main	Stockroom 8	Drinking Fountain <i>(permanently removed from service)</i>	27
046	22431157-046CF21A	Main	B112	Classroom Faucet	4.31
047	22431157-047DW21A	Main	B112	Drinking Fountain	2.07
048	22431157-048CF21A	Main	B116	Classroom Faucet	6.09
049	22431157-049DW21A	Main	B116	Drinking Fountain	5.99
050	22431157-050CF21A	Main	B114	Classroom Faucet	34.5
050 - Follow Up	22431157-050CF21B	Main	B114	Classroom Faucet <i>(post-mitigation)</i>	3.8
051	22431157-051DW21A	Main	B114	Drinking Fountain	1.11

052	22431157-052CF21A	Main	B104	Classroom Faucet	9.55
053	22431157-053DW21A	Main	B104	Drinking Fountain	2.08
054	22431157-054CF21A	Main	B102	Classroom Faucet	1.61
055	22431157-055DW21A	Main	B102	Drinking Fountain	2.41
056	22431157-056CF21A	Main	B100	Classroom Faucet	8.06
057	22431157-057DW21A	Main	B100	Drinking Fountain	0.799
	22430500-002OT24A	Main	Kitchen	Kitchen (faucet) <i>(after remodel)</i>	1.34
	22430500-003KS24A	Main	Kitchen	Kitchen (kettle) <i>(after remodel)</i>	1.59
	22430500-004OT24A	Main	Kitchen	Kitchen (sprayer) <i>(after remodel)</i>	0.0455