

# Lead in School Drinking Water Report

## Mountain View Middle School



### EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: [leadfreekids@doh.wa.gov](mailto:leadfreekids@doh.wa.gov).

## DEFINITIONS

Fixture Housing  
Location

Room/space where  
fixture is located  
(i.e. room number,  
gym, playground)

Fixture Housing Type

Structure that contains  
the individual fixtures  
where water samples  
were collected from.  
Fixture housing may  
contain one or more  
individual fixture for  
sampling.

Fixture Location  
Details

Location within a  
room or space where  
fixture housing is  
located, starting to the  
left of the entrance and  
rotating clockwise, of  
the total number of  
fixture housings in a  
room or space  
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water  
Fountain, Water Bottle  
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2026-01-31

Date(s) analyzed: 2026-02-11, 2026-02-18

|   | Sample ID | Sample Collected Date | Building Name | Fixture Housing Type     | Fixture Location | Fixture Location Details          | Fixture Type   | Fixture Position | Lead Test Result (ppb) |
|---|-----------|-----------------------|---------------|--------------------------|------------------|-----------------------------------|----------------|------------------|------------------------|
| 1 | 414954    | 2026-01-31            | Main Building | Pot Filler               | Kitchen          | 2 of 4. Closest to walk in fridge | Sprayer        | left             | 3451                   |
| 2 | 414955    | 2026-01-31            | Main Building | Pot Filler               | Kitchen          | 2 of 4. Closest to walk in fridge | Tap            | right            | 366                    |
| 3 | 414957    | 2026-01-31            | Main Building | Pot Filler               | Kitchen          | 4 of 4. Next to room 438          | Sprayer        | left             | 15                     |
| 4 | 414947    | 2026-01-31            | Main Building | Fountain Tap Combo       | Nurses Office    | 1 of 1                            | Tap            | center           | 13                     |
| 5 | 414952    | 2026-01-31            | Main Building | Sink - Multi-compartment | Kitchen          | 1 of 4                            | Tap            | center           | 10                     |
| 6 | 414956    | 2026-01-31            | Main Building | Sink - Multi-compartment | Kitchen          | 3 of 4                            | Tap            | center           | 8                      |
| 7 | 414937    | 2026-01-31            | Main Building | Fountain Tap Combo       | Room 419         | 1 of 1                            | Water Fountain | right            | 4                      |
| 8 | 414945    | 2026-01-31            | Main Building | Fountain Tap Combo       | Room 109         | 1 of 1                            | Water Fountain | left             | 4                      |

| .  | Sample ID | Sample Collected Date | Building Name | Fixture Housing Type     | Fixture Location | Fixture Location Details | Fixture Type   | Fixture Position | Lead Test Result (ppb) |
|----|-----------|-----------------------|---------------|--------------------------|------------------|--------------------------|----------------|------------------|------------------------|
| 9  | 414958    | 2026-01-31            | Main Building | Pot Filler               | Kitchen          | 4 of 4. Next to room 438 | Tap            | right            | 4                      |
| 10 | 414920    | 2026-01-31            | Main Building | Fountain Tap Combo       | Room 405         | 1 of 1                   | Water Fountain | left             | 3                      |
| 11 | 414921    | 2026-01-31            | Main Building | Fountain Tap Combo       | Room 407         | 1 of 1                   | Water Fountain | left             | 3                      |
| 12 | 414925    | 2026-01-31            | Main Building | Fountain Tap Combo       | Room 206         | 1 of 1                   | Water Fountain | right            | 3                      |
| 13 | 414928    | 2026-01-31            | Main Building | Fountain Tap Combo       | Room 304         | 1 of 1                   | Water Fountain | right            | 3                      |
| 14 | 414953    | 2026-01-31            | Main Building | Sink - Multi-compartment | Kitchen          | 1 of 4                   | Sprayer        | center           | 3                      |
| 15 | 414922    | 2026-01-31            | Main Building | Fountain Tap Combo       | Office 201       | 1 of 1                   | Water Fountain | right            | 2                      |
| 16 | 414923    | 2026-01-31            | Main Building | Fountain Tap Combo       | Room 208         | 1 of 1                   | Water Fountain | right            | 2                      |
| 17 | 414927    | 2026-01-31            | Main Building | Fountain Tap Combo       | Room 204         | 1 of 1                   | Water Fountain | right            | 2                      |
| 18 | 414929    | 2026-01-31            | Main Building | Fountain Tap Combo       | Room 305         | 1 of 1                   | Water Fountain | left             | 2                      |

|    | Sample ID | Sample Collected Date | Building Name | Fixture Housing Type   | Fixture Location         | Fixture Location Details | Fixture Type   | Fixture Position | Lead Test Result (ppb) |
|----|-----------|-----------------------|---------------|------------------------|--------------------------|--------------------------|----------------|------------------|------------------------|
| 19 | 414935    | 2026-01-31            | Main Building | Fountain - Multi-level | Hallway Next To Room 419 | 1 of 1                   | Water Fountain | right            | 2                      |
| 20 | 414936    | 2026-01-31            | Main Building | Fountain - Multi-level | Hallway Next To Room 419 | 1 of 1                   | Water Fountain | left             | 2                      |
| 21 | 414938    | 2026-01-31            | Main Building | Fountain Tap Combo     | Room 110                 | 1 of 2. East wall        | Water Fountain | left             | 2                      |
| 22 | 414941    | 2026-01-31            | Main Building | Fountain Tap Combo     | Room 105                 | 1 of 1                   | Water Fountain | right            | 2                      |
| 23 | 414943    | 2026-01-31            | Main Building | Fountain Tap Combo     | Room 107                 | 1 of 1                   | Water Fountain | left             | 2                      |
| 24 | 414944    | 2026-01-31            | Main Building | Fountain Tap Combo     | Room 108                 | 1 of 1                   | Water Fountain | right            | 2                      |
| 25 | 414946    | 2026-01-31            | Main Building | Fountain Tap Combo     | Outside Of Office 508    | 1 of 1                   | Water Fountain | right            | 2                      |
| 26 | 414948    | 2026-01-31            | Main Building | Fountain Tap Combo     | Nurses Office            | 1 of 1                   | Water Fountain | right            | 2                      |
| 27 | 414924    | 2026-01-31            | Main Building | Fountain Tap Combo     | Room 207                 | 1 of 1                   | Water Fountain | right            | 1                      |
| 28 | 414931    | 2026-01-31            | Main Building | Fountain Tap Combo     | Room 307                 | 1 of 1                   | Water Fountain | right            | 1                      |
| 29 | 414942    | 2026-01-31            | Main Building | Fountain Tap Combo     | Room 106                 | 1 of 1                   | Water Fountain | right            | 1                      |

|    | Sample ID | Sample Collected Date | Building Name | Fixture Housing Type        | Fixture Location | Fixture Location Details | Fixture Type        | Fixture Position | Lead Test Result (ppb) |
|----|-----------|-----------------------|---------------|-----------------------------|------------------|--------------------------|---------------------|------------------|------------------------|
| 30 | 414926    | 2026-01-31            | Main Building | Fountain Tap Combo          | Room 205         | 1 of 1                   | Water Fountain      | right            | <1                     |
| 31 | 414930    | 2026-01-31            | Main Building | Fountain Tap Combo          | Room 306         | 1 of 1                   | Water Fountain      | right            | <1                     |
| 32 | 414932    | 2026-01-31            | Main Building | Fountain Tap Combo          | Room 308         | 1 of 1                   | Water Fountain      | right            | <1                     |
| 33 | 414933    | 2026-01-31            | Main Building | Fountain Tap Combo          | Room 309         | 1 of 1                   | Water Fountain      | right            | <1                     |
| 34 | 414934    | 2026-01-31            | Main Building | Fountain Tap Combo          | Room 310         | 1 of 1                   | Water Fountain      | right            | <1                     |
| 35 | 414939    | 2026-01-31            | Main Building | Fountain Tap Combo          | Room 110         | 2 of 2. South wall       | Water Fountain      | right            | <1                     |
| 36 | 414940    | 2026-01-31            | Main Building | Fountain Tap Combo          | Room 104         | 1 of 1                   | Water Fountain      | right            | <1                     |
| 37 | 414949    | 2026-01-31            | Main Building | Sink                        | Staff Lounge     | 1 of 1                   | Tap                 | center           | <1                     |
| 38 | 414950    | 2026-01-31            | Main Building | Fountain With Bottle Filler | Aux Gym Hallway  | 1 of 1                   | Water Bottle Filler | center           | <1                     |
| 39 | 414951    | 2026-01-31            | Main Building | Fountain With Bottle Filler | Aux Gym Hallway  | 1 of 1                   | Water Fountain      | right            | <1                     |