

Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	Prior 1 st Draw Results (ppb)	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
314 Pelhamdale - Business Office									
No exceedances									
Prospect Hill Elementary School									
Kitchen 2-Bay	SK	App	16.0	4/8/2026	-	-	-	-	Remove fixture from service; Flush sampling recommended
Faculty Room Kitchenette	SK	App	8.0	4/8/2026	-	-	-	-	Remove fixture from service; Flush sampling recommended
Hutchinson Elementary School									
Kitchen Pot Filler by Stove	PF	App	15.0	4/8/2026	-	-	-	-	Remove fixture from service; Flush sampling recommended
Room 208	WF	App	6.0	4/8/2026	-	-	-	-	Remove fixture from service; Flush sampling recommended
Room 206	WF	App	23.0	4/8/2026	-	-	-	-	Remove fixture from service; Flush sampling recommended
Room 213	WF	App	33.0	4/8/2026	-	-	-	-	Remove fixture from service; Flush sampling recommended
Colonial Elementary School									
Waiting on results									
Siwanoy Elementary School									
Waiting on results									
Pelham Middle School									
Science Prep Room 266/262 Ice Machine - Water Dispenser	OS	App	79.0	4/7/2026	-	-	-	-	Remove fixture from service; Place a sign, no drinking
Room 278C Library Office Classroom	SK	App	11.0	4/7/2026	-	-	-	-	Remove fixture from service; Flush sampling recommended
Pelham Memorial High School									
Hall by Room 202	WF	App	6.0	4/7/2026	-	-	-	-	Remove fixture from service; Flush sampling recommended
Glover Field									
Boy's Locker Room Slop Sink	SS	App	7.0	4/7/2026	-	-	-	-	Remove fixture from service; Place a sign, no drinking
Exterior by Locker Rooms - Right	WF	App	7.0	4/7/2026	-	-	-	-	Remove fixture from service; Flush sampling recommended
Key									
WF-Water Fountain									
BF-Bottle Filler									
SK-Sink									
PF-Pot Filler									
SP-Spigot									
App-currently considered an applicable/potable source									