

## Laboratory Report

April 14, 2026

Casey Lee  
Enviroscience Consultants, Inc.  
2150 Smithtown Ave.  
Ronkonkoma, NY, 11779


Project: Pelham UFSD (Siwanoy Elementary School)  
Project Address: Siwanoy Elementary School  
Report ID: 260408006  
Sample IDs: 260408006-147 - 260408006-162

New York Environmental is a NELAC accredited laboratory. Attached reported results meet the requirements of the NELAC standard unless otherwise noted.

Samples' analytical results relate only to the parameters tested for the samples received in the condition received by the laboratory, as noted on the Chain of Custody. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



---

Li Tsang, Laboratory Director

Date Collected:	8-Apr-26
Date Received:	8-Apr-26
Date Analyzed:	9-Apr-26

Analytical Method:	EPA 200.9
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
260408006-147	1	Hall by 014 - WF; initial	0.001	<0.001	mg/L	
260408006-148	2	Hall by 014 - BF; initial	0.001	<0.001	mg/L	
260408006-149	3	OIS Teacher's Lounge Kitchenette - SK; initial	0.001	<0.001	mg/L	
260408006-150	4	OIS Teacher's Lounge Kitchenette - SPY; initial	0.001	0.001	mg/L	
260408006-151	5	Hall by 105 - WF; initial	0.001	<0.001	mg/L	
260408006-152	6	Hall by 105 - BF; initial	0.001	<0.001	mg/L	
260408006-153	7	Hall by 209 - WF; initial	0.001	<0.001	mg/L	
260408006-155	8	Hall by 209 - BF; initial	0.001	<0.001	mg/L	
260408006-156	9	Hall by 202 - WF; initial	0.001	<0.001	mg/L	
260408006-158	10	Hall by 202 - BF; initial	0.001	<0.001	mg/L	
260408006-159	11	Hall by Gym - WF; initial	0.001	<0.001	mg/L	
260408006-161	12	Hall by Gym - BF; initial	0.001	<0.001	mg/L	
260408006-162	13	110A Serving Area 2-Bay - SK; initial	0.001	0.005	mg/L	

**Comment(s):**

LOQ: Limit of Quantitation

CID: Client ID

