

Laboratory Report

April 10, 2026

Casey Lee
Enviroscience Consultants, Inc.
2150 Smithtown Ave.
Ronkonkoma, NY, 11779


Project: Pelham UFSD (Colonial School)
Project Address: Colonial School
Report ID: 260408004
Sample IDs: 260408004-125 - 260408004-133

New York Environmental is a NELAC accredited laboratory. Attached reported results meet the requirements of the NELAC standard unless otherwise noted.

Samples' analytical results relate only to the parameters tested for the samples received in the condition received by the laboratory, as noted on the Chain of Custody. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	8-Apr-26
Date Received:	8-Apr-26
Date Analyzed:	9-Apr-26

Analytical Method:	EPA 200.9
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
260408004-125	1	Teacher's Lounge Room 007 - SK; initial	0.001	0.002	mg/L	
260408004-126	2	Hall by Boy's Bathroom 006 - WF; initial	0.001	<0.001	mg/L	
260408004-127	3	Hall by Boy's Bathroom 006 - BF; initial	0.001	<0.001	mg/L	
260408004-128	4	Serving Room 2- Bay - SK; initial	0.001	<0.001	mg/L	
260408004-129	5	Hall by 107 - WF; initial	0.001	<0.001	mg/L	
260408004-130	6	Hall by 107 - BF; initial	0.001	<0.001	mg/L	
260408004-131	7	Hall by 207 - WF; initial	0.001	<0.001	mg/L	
260408004-132	8	Hall by 207 - BF; initial	0.001	<0.001	mg/L	
260408004-133	9	Nurse's Office - SK; initial	0.001	0.002	mg/L	

Comment(s):

LOQ: Limit of Quantitation
 CID: Client ID

