

**BID ADDENDUM NO. 5**

**OWNER:** EDGEMONT SCHOOL DISTRICT

**PROJECT NAME:** HIGH SCHOOL RESOURCE & BUILDING E RENOVATIONS  
& ATHLETIC FIELD RECONSTRUCTION

This Addendum is hereby included in and made a part of the Contract Documents, dated March 24, 2026 whether or not attached thereto.

All requirements of the original project specifications and drawings shall remain in force except as amended by this addendum.

DATE: April 16, 2026

This addendum consists of one (1) page.

***THE FOLLOWING ARE MODIFICATIONS, CLARIFICATIONS, DELETIONS OR ADDITIONS TO THE SPECIFICATIONS:***

**01 6190 – MATRIX OF BUILDING SYSTEM RESPONSIBILITY**

**REVISE** all references to “CAT 6 cable” to read “CAT 6A cable”.

**27 1000 – STRUCTURED CABLING FOR VOICE, DATA AND VIDEO SURVEILLANCE**

27 1000-3 2.3 A.1 **REVISE** “Category 6 UTP” to read “Category 6A UTP”.

**END OF BID ADDENDUM NO. 5**