ADDENDUM #2

To BID # 27001

TUSD Schools Roof Replacement Project

April 21, 2026

TO: ALL PROSEPECTIVE BIDDERS
FROM: Travis Unified School District

RE: Addendum #2

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents as noted below.

Questions and responses:

1. What thickness of insulation is required?

   Answer – Insulation thickness shall be replaced in kind to match the existing insulation thickness. For roofs that do not currently have insulation, new insulation shall be installed with a minimum thickness of 2 inches.

2. Is each school will be bid on separately?

   Answer – See Addendum 1 for change to Notice to Bidders, line 14. a.