



Sterling Technologies, LLC

317 NE 144th Street • Vancouver, WA 98685 • (360) 576-6331

LIMITED LEAD AND ASBESTOS SURVEY

Monticello Middle School
1225 28th Avenue
Longview, Washington



Prepared for:
Cody Brague
Facilities Manager

Survey Date: March 11, 2026

Surveyed by: Thomas Nadermann
Asbestos Certificate #: IRO-26-6998A; Expires 2/23/2027
Lead Risk Assessor Certificate #: 2062-Indv-R; Expires 10/23/2026
Email: thomas@sterling-llc.com

Report Date: March 18, 2026

1.0 INTRODUCTION

1.1 Property Description

Project Address:	1225 28 th Avenue; Longview, WA 98632
Name of Owner/Operator:	Longview School District
Owner/Operator Address:	1225 28 th Avenue; Longview, WA 98632
Owner/Operator Phone:	Cody Bague - 360-643-0238
Building Past Use:	School
Building Current Use:	School
Number of Buildings:	1
Number of Floors:	2
Year Built:	1980
Approx. Square Footage:	5000

The building surveyed is a school of concrete and steel frame construction. The exterior is finished with wood siding and brick in places. The interior floors are finished with floor tile, and the walls and ceiling are finished with wallboard. The HVAC, plumbing, electrical, and attic roof areas of the building were outside of the remediation scope of work and were not investigated.

1.2 Purpose

The purpose of the survey is to identify the presence and condition of accessible suspect asbestos-containing materials (ACM) that may be impacted during planned renovation activities due to water filter improvements. Asbestos may be present in materials not sampled, and additional sampling may be warranted in the event of future disturbances of suspect materials.

1.3 Sampling Results Summary

A total of 8 suspect ACM samples were collected of which none were greater than 1% asbestos.

A total of 4 suspect lead-in-paint samples were collected, none were over the 5,000 parts per million (ppm) HUD standard.

See Section 2.0 for details of analytical results.

1.4 Scope

Samples were collected of suspect asbestos-containing materials and lead coatings from areas potentially impacted by this specific project (exterior wall pillar repairs). This assessment does not include materials in areas not impacted by the scope of work or materials behind walls or above ceilings where not visible or hidden.

Services such as the interview of property management and maintenance personnel, tenants, review of prior records, regulatory records, evaluation of compliance, risk assessment, and the

development of abatement specifications are excluded from the scope of services, along with other activities not expressly identified herein. No demolition, destructive testing, or product research was performed to reveal material compositions.

The work is not intended as a specification for asbestos abatement or to support bidding for or completion of maintenance, abatement, removal, or replacement activities. Quantification of the exact quantities of materials is beyond the scope of this survey. Any quantities of ACM listed are estimates only and should be confirmed by the client.

Sterling Technologies, and their employees/representatives, bears no responsibility for the actual condition of the structure or safety of the site pertaining to asbestos and/or asbestos contamination regardless of the actions taken by the survey team or the client.

1.5 Reporting Limits

In Washington, materials with greater than one percent (1%) asbestos are regulated as asbestos-containing materials per WAC-296-62-077. Materials containing asbestos above 1% are regulated under OSHA and have specific training and handling requirements. In some cases, abatement of these materials is recommended. Building owners are required to identify ACMs in their buildings and to inform contractors of their locations prior to any remodeling, renovation, or demolition activities that could disturb these materials.

Lead-in-paint samples which exceed the 5,000 ppm HUD lead standard are considered lead-based paint. For lead-in-paint concentrations below 5,000 ppm and above 90 ppm, the OSHA implications of lead-in-air should be considered. Area monitoring of the project work area and personal monitoring of workers would apply; as well as the appropriate use of personal protective equipment by workers given the presence of this hazard.

Lead-in-dust is considered a hazard when equal to or exceeding 40 micrograms per square foot on floors, 250 micrograms per square foot on interior window sills, and 400 ppm in bare soil in children's play areas or 1200 ppm average for bare soil in the rest of the yard.

1.6 Asbestos Visual Evaluation

For this assessment, sampling was limited to material associated with the planned renovations. Building materials were inspected to identify and evaluate the condition of suspect ACM.

Classification

Asbestos-containing building materials are typically classified as surfacing, thermal systems insulation, or miscellaneous ACM.

- Surfacing – Material that is troweled-on, sprayed, or otherwise applied to surfaces. Examples include acoustical plaster on ceilings, fireproofing on structural members, or similar applications for acoustical, fireproofing, and other purposes.
- Thermal Systems Insulation – Materials applied to pipes, fittings, boilers, breeching, tanks, ducts, or other structural components to prevent heat loss or gain.
- Miscellaneous – All other ACM including taping mud, flooring, mastic, stucco, leveling compound, hard wall plasters, wall texturing as surfacing, etc.

Evaluation of Asbestos Condition

An evaluation of the condition of the asbestos-containing materials can be useful in deciding how to manage materials. The ACM most likely to release asbestos fibers are those which are friable. The definition of friable is any material, when dry, that is capable of being crumbled, pulverized, or reduced to powder by hand pressure. Non-friable sources of asbestos are materials containing cement or asphaltic binder which may become friable and release fibers if the sources are exposed to actions such as abrasion, drilling, cutting, fracturing, or hammering. Non-friable sources of asbestos do not typically pose a significant exposure risk if they remain in good condition and are not disturbed. During renovation or demolition activities or when subject to abrasion, non-friable sources may become friable and thus may pose an exposure risk.

Protocols have been used in the evaluation of the condition of materials. ACM is considered in “poor” condition when the binding of the material is losing its integrity as indicated by peeling, cracking, or crumbling of the material [OAR 340-248-0010(25)].

The condition of materials is based upon observations at the time of the survey and is independent of the friable or non-friable nature of the materials.

Asbestos Categorization

Asbestos air emissions are regulated by the U.S. EPA’s National Emission Standard for Hazardous Air Pollutants (NESHAP) Asbestos Standard 40 CFR, Subpart M. The regulations are classified into three categories:

- Category I Non-friable – ACM packings, gaskets, resilient floor coverings, Galbestos, and asphalt roofing products containing more than 1% asbestos by PLM.
- Category II Non-friable – Any ACM that is not Category I non-friable.
- Regulated Asbestos-Containing Materials (RACM) – Friable manufactured materials, Category I non-friable ACM that has become friable, or Category I non-friable ACM that will be or has been subjected to sanding, grinding, cutting, or abrading. RACM also includes Category II non-friable ACM that has a high probability of becoming or has become crumbled, pulverized, or reduced to powder by force.

1.7 Sampling and Laboratory Analysis

Bulk samples of suspected ACM and lead were collected for analysis by EPA accredited inspector staff provided by Sterling. The asbestos samples were analyzed by Cameron Zimmerman of Eurofins Built Environment Testing West LLC in Portland, Oregon. The lead samples were analyzed by the lab of Eurofins Built Environment Testing West LLC in Portland, OR.

The asbestos samples were analyzed using polarizing light microscopy (PLM) with dispersion staining in accordance with the methods described by the EPA and the National Institute of Standards and Technology. The lead samples were analyzed using flame atomic absorption spectrometry in accordance with the methods described by the EPA and the National Institute of Standards and Technology.

2.0 ANALYTICAL RESULTS

2.1 Asbestos

Federal and state regulations define ACM as any material containing more than 1% asbestos as determined using PLM. The collected bulk samples of suspected ACM and the analytical results are listed in the following table. The laboratory results and chain of custody are contained in Appendix B. Documentation of the laboratory results should be retained as a reference for future renovation activities.

Positive Asbestos Bulk Sample Results

Sample No.	Condition	Friable?	Sample Location	Quantity	Material Description	Asbestos %
None of the samples tested were positive for asbestos.						

Negative Asbestos Bulk Sample Results

Sample No.	Sample Location	Material Description	Asbestos %
MC-31126-5	Rm 155 Wall Pillar	Gray Texture	Non-Detect
		White Texture	Non-Detect
		Off-White Texture w/Red Paint	Non-Detect
MC-31126-6	Rm 155 Wall Pillar	Off-White Texture w/Paint	Non-Detect
MC31126-7	Rm 153 Wall Pillar	Off-White Texture w/Paint	Non-Detect
		White Powdery Material w/Paint	Non-Detect
		Green Texture	Non-Detect
MC-31126-8	Rm 153 Wall Pillar	Off-White Texture w/Paint	Non-Detect
		White Powdery Material w/Paint	Non-Detect
		Green Texture (Trace)	Non-Detect
MC-31126-9	Rm 153 Wall Pillar Grout	Tan Non-Fibrous Material	Non-Detect
		Gray Non-Fibrous Material	Non-Detect
		White Non-Fibrous Material	Non-Detect
MC-31126-10	Rm 153 Wall Pillar Grout	Tan Non-Fibrous Material	Non-Detect
		Gray Non-Fibrous Material	Non-Detect
		White Non-Fibrous Material	Non-Detect
MC-31126-11	Rm 155 Wall Pillar Grout	Tan Non-Fibrous Material	Non-Detect
		Gray Non-Fibrous Material	Non-Detect
MC-31126-12	Rm 155 Wall Pillar Grout	Tan Non-Fibrous Material	Non-Detect
		Gray Non-Fibrous Material	Non-Detect

2.2 Lead

Lead-in-paint samples which exceed the 5,000 ppm HUD lead standard are considered lead-based paint.

Lead-in-Paint Sampling Results

Sample No.	Location	Material Description	Result (ppm)
MC-31126-1	Wall Pillar, Room 153	Cream paint	ND
MC-31126-2	Wall Pillar, Room 153	Cream paint	ND
MC-31126-3	Wall Pillar, Room 155	Cream paint	ND
MC-31126-4	Wall Pillar, Room 155	Cream paint	ND

3.0 RECOMMENDED RESPONSE ACTION(S)

3.1 Asbestos

Any friable asbestos-containing materials that will be impacted by renovation/remediation activities must be properly abated (handled, removed, and disposed) by a licensed asbestos abatement contractor prior to any renovation/remediation activity. Non-friable material may be removed by a contractor or individual who is not a licensed asbestos abatement contractor if it maintains its non-friable condition. Notification, packaging, and disposal requirements still apply to non-friable material.

Any material(s) encountered not specifically mentioned in this report must be considered asbestos-containing material until sufficient sampling has been completed to determine the material(s) are non-asbestos.

3.2 Lead

Every effort was made to identify all suspect lead-based paint coated surfaces in this limited survey. As with any survey, there is always a chance that suspect lead-based paint coated surfaces might be encountered that were not obvious during the survey. Should suspect lead-based paint coated surfaces be identified, work must stop until these materials can be investigated and properly abated as necessary.

4.0 LIMITATIONS

This report applies only to the specific subject property, location, and area detailed above. While areas specified by the customer were surveyed and materials sampled, areas behind walls and/or covered by structural members, or materials requiring destructive means to access which could not be found with reasonable diligence were not sampled during the survey. There can be hidden crawl spaces and cavities that were not surveyed. Any areas not specified to be surveyed cannot be assumed to be free of asbestos as no survey was performed to determine the presence of asbestos-containing materials in these areas.

Within the limitations of scope, schedule, and budget, our services were executed in accordance with generally accepted practices in this area at the time this report was prepared.

No other hazardous materials/wastes were investigated. No other conditions, expressed or implied, should be understood.

5.0 ASBESTOS SURVEY REGULATORY COMPLIANCE

The intent of the asbestos survey is to comply with the State of Washington asbestos survey and report requirements. A complete copy of the asbestos survey report must be kept onsite at the facility during renovation or demolition, including during the asbestos abatement project. In addition, a copy of the asbestos survey report must be submitted to the Northwest Clean Air Agency upon request.

A complete copy of the asbestos survey report must be provided to the licensed asbestos abatement contractor involved during the renovation/remediation project. In the case of projects involving removal of nonfriable asbestos-containing material being completed by a contractor or individual who is not a licensed asbestos abatement contractor, a complete copy of the survey report must be provided to the company or individual(s) conducting the renovation/remediation project and must be kept onsite during the project.

6.0 RECORDKEEPING

Additional copies of this report are available from Sterling Technologies upon request.

Unless otherwise requested, samples will be retained for a period of 30 days, after which they will be discarded.

If you have any questions about these results or would like additional information, please feel free to call our office. Thank you for this opportunity to be of service.

Respectfully submitted,



Thomas Nadermann, M.S.
Principal
AHERA Inspector #155212

Photo Log



Classroom impacted by exterior wall



Water impacted beam interior




Plaster decay onto sill



Plaster cracks



Corrosion evidence from steel beam



Cracks and corrosión

APPENDIX A

Inspector's Certification

THIS IS TO CERTIFY THAT

THOMAS NADERMANN

HAS SUCCESSFULLY COMPLETED THE TRAINING COURSE

for

ONLINE AHERA ASBESTOS INSPECTOR REFRESHER

In accordance with TSCA Title II, Part 763, Subpart E, Appendix C of 40 CFR

Course Date: 02/23/2026

Course Location: Online

Certificate: IRO-26-6998A

For verification of the authenticity of this certificate contact:

Apex Companies, LLC, by and through its wholly owned subsidiary PBS Engineering and Environmental LLC (Apex)
4412 S Corbett Avenue
Portland, OR 97239
503.248.1939



CCB #5RA0615 4-Hr Training

4-Hour Online AHERA Inspector Refresher Training; AHERA is the Asbestos Hazard Emergency Response Act enacting Title II of Toxic Substance Control Act (TSCA)

Expiration Date: 02/23/2027

David Kahn
David Kahn, Instructor

State of Oregon
Oregon Health Authority

Thomas H. Nadermann

is certified by the Oregon Health Authority to conduct Lead-Based Paint Activities

Risk Assessor

Certification Number: 2062--Indv--R
Issuance Date: 10/23/2023
Expiration Date: 10/23/2026



APPENDIX B

Laboratory Results

Chain of Custody


Report for:

Thomas Nadermann
Sterling Technologies LLC
317 NE 144 Street
Vancouver, WA 98685

Regarding: Eurofins Built Environment Testing West, LLC
Project: Longview School District; Monticello Elementary
EML ID: 4452180

Approved by:

Dates of Analysis:
Asbestos PLM: 03-18-2026



Technical Manager
Ryan Talaski-Brown

Service SOPs: Asbestos PLM (EPA 40CFR App E to Sub E of Part 763 & EPA 600/R-93-116, EBET-PLM-SOP83921)
NVLAP Lab Code 200741-0

All samples were received in acceptable condition unless noted in the Report Comments portion in the body of the report. The results relate only to the samples as received and tested. The results include an inherent uncertainty of measurement associated with estimating percentages by polarized light microscopy. Measurement uncertainty data for sample results with >1% asbestos concentration can be provided when requested.

Eurofins Built Environment Testing West, LLC ("the Company"), a member of the Eurofins Built Environment Testing group of companies, shall have no liability to the client or the client's customer with respect to decisions or recommendations made, actions taken or courses of conduct implemented by either the client or the client's customer as a result of or based upon the Test Results. In no event shall the Company be liable to the client with respect to the Test Results except for the Company's own willful misconduct or gross negligence nor shall the Company be liable for incidental or consequential damages or lost profits or revenues to the fullest extent such liability may be disclaimed by law, even if the Company has been advised of the possibility of such damages, lost profits or lost revenues. In no event shall the Company's liability with respect to the Test Results exceed the amount paid to the Company by the client therefor.

Client: Sterling Technologies LLC
 C/O: Thomas Nadermann
 Re: Longview School District; Monticello Elementary

Date of Sampling: 03-11-2026
 Date of Receipt: 03-13-2026
 Date of Report: 03-18-2026

ASBESTOS PLM REPORT

Total Samples Submitted: 8
Total Samples Analyzed: 8
Total Samples with Layer Asbestos Content > 1%: 0

Location: MC-31126-5, Wall Pillar Rm 155 Texture

Lab ID-Version‡: 22363422-1

Sample Layers	Asbestos Content
Gray Texture	ND
White Texture	ND
Off-White Texture with Red Paint	ND
Sample Composite Homogeneity:	Moderate

Location: MC-31126-6, Wall Pillar Rm 155 Texture

Lab ID-Version‡: 22363423-1

Sample Layers	Asbestos Content
Off-White Texture with Paint	ND
Sample Composite Homogeneity:	Good

Location: MC-31126-7, Wall Pillar Rm 153 Texture

Lab ID-Version‡: 22363424-1

Sample Layers	Asbestos Content
Off-White Texture	ND
White Powdery Material with Paint	ND
Green Texture	ND
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

All components not quantified as asbestos content and non-asbestos content are considered to be non-fibrous matrix components. Matrix components may include, but are not limited to, gypsum, paint, silicate minerals, vinyl, binder, calcium carbonate, tar, and foam.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Sterling Technologies LLC
 C/O: Thomas Nadermann
 Re: Longview School District; Monticello Elementary

Date of Sampling: 03-11-2026
 Date of Receipt: 03-13-2026
 Date of Report: 03-18-2026

ASBESTOS PLM REPORT

Location: MC-31126-8, Wall Pillar Rm 153 Texture

Lab ID-Version‡: 22363425-1

Sample Layers	Asbestos Content
Off-White Texture with Paint	ND
White Powdery Material with Paint	ND
Green Texture (Trace)	ND
Sample Composite Homogeneity: Good	

Location: MC-31126-9, Wall Pillar Rm 153 Concrete Grout

Lab ID-Version‡: 22363426-1

Sample Layers	Asbestos Content
Tan Non-Fibrous Material	ND
Gray Non-Fibrous Material	ND
White Non-Fibrous Material	ND
Sample Composite Homogeneity: Good	

Location: MC-31126-10, Wall Pillar Rm 153 Concrete Grout

Lab ID-Version‡: 22363427-1

Sample Layers	Asbestos Content
Tan Non-Fibrous Material	ND
Gray Non-Fibrous Material	ND
White Non-Fibrous Material	ND
Sample Composite Homogeneity: Good	

Location: MC-31126-11, Wall Pillar Rm 155 Concrete Grout

Lab ID-Version‡: 22363428-1

Sample Layers	Asbestos Content
Tan Non-Fibrous Material	ND
Gray Non-Fibrous Material	ND
Sample Composite Homogeneity: Good	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

All components not quantified as asbestos content and non-asbestos content are considered to be non-fibrous matrix components. Matrix components may include, but are not limited to, gypsum, paint, silicate minerals, vinyl, binder, calcium carbonate, tar, and foam.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Sterling Technologies LLC
C/O: Thomas Nadermann
Re: Longview School District; Monticello Elementary

Date of Sampling: 03-11-2026
Date of Receipt: 03-13-2026
Date of Report: 03-18-2026

ASBESTOS PLM REPORT

Location: MC-31126-12, Wall Pillar Rm 155 Concrete Grout

Lab ID-Version‡: 22363429-1

Sample Layers	Asbestos Content
Gray Non-Fibrous Material	ND
White Non-Fibrous Material	ND
Sample Composite Homogeneity: Good	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

All components not quantified as asbestos content and non-asbestos content are considered to be non-fibrous matrix components. Matrix components may include, but are not limited to, gypsum, paint, silicate minerals, vinyl, binder, calcium carbonate, tar, and foam.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Eurofins Built Environment Testing West, LLC
4321 S. Corbett Ave. Suite A, Portland, OR 97239
(833) 465-5857 www.eurofinsus.com/Built


Client: Sterling Technologies LLC
C/O: Thomas Nadermann
Re: Longview School District; Monticello Elementary

Date of Sampling: 03-11-2026
Date of Receipt: 03-13-2026
Date of Report: 03-18-2026

ASBESTOS PLM REPORT

PROJECT ANALYST AND SIGNATORY REPORT

Project Analyst



Analyst: Cameron Zimmerman

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Report for:


Thomas Nadermann
Sterling Technologies LLC
317 NE 144 Street
Vancouver, WA 98685

Regarding: Eurofins Built Environment Testing West, LLC
Project: Longview School District; Monticello Elementary
EML ID: 4452180

Approved by:

Dates of Analysis:

Lead - Flame AA: 03-20-2026



Approved Signatory
Philip Newton

Service SOPs: Lead - Flame AA (EB-BC-S-8443)
AIHA LAP, LLC accredited service, Lab ID #178697

All samples were received in acceptable condition unless noted in the Report Comments portion in the body of the report. Due to the nature of the analyses performed, field blank correction of results is not applied. The results relate only to the samples as received and tested. Sample size, as it relates to Wipe samples only, is supplied by the client.

Eurofins Built Environment Testing West, LLC ("the Company"), a member of the Eurofins Built Environment Testing group of companies, shall have no liability to the client or the client's customer with respect to decisions or recommendations made, actions taken or courses of conduct implemented by either the client or the client's customer as a result of or based upon the Test Results. In no event shall the Company be liable to the client with respect to the Test Results except for the Company's own willful misconduct or gross negligence nor shall the Company be liable for incidental or consequential damages or lost profits or revenues to the fullest extent such liability may be disclaimed by law, even if the Company has been advised of the possibility of such damages, lost profits or lost revenues. In no event shall the Company's liability with respect to the Test Results exceed the amount paid to the Company by the client therefor.

Eurofins Built Environment Testing West, LLC's LabServe® reporting system includes automated fail-safes to ensure that all AIHA LAP, LLC quality requirements are met and notifications are added to reports when any quality steps remain pending.

Client: Sterling Technologies LLC
 C/O: Thomas Nadermann
 Re: Longview School District; Monticello Elementary

Date of Sampling: 03-11-2026
 Date of Receipt: 03-13-2026
 Date of Report: 03-20-2026

LEAD: FLAME ATOMIC ABSORPTION SPECTROMETRY

Location:	MC-31126-1: Wall Pillar Rm 153	MC-31126-2: Wall Pillar Rm 153	MC-31126-3: Wall Pillar Rm 155	MC-31126-4: Wall Pillar Rm 155
Comments (see below)	None	None	None	None
Lab ID-Version‡:	22397953-1	22397954-1	22397955-1	22397956-1
Analysis Date:	03/20/2026	03/20/2026	03/20/2026	03/20/2026
Sample type	Paint Chip sample	Paint Chip sample	Paint Chip sample	Paint Chip sample
Method*	NIOSH 7082 & EPA 7000B modified	NIOSH 7082 & EPA 7000B modified	NIOSH 7082 & EPA 7000B modified	NIOSH 7082 & EPA 7000B modified
† Method Reporting Limit	48 ppm	40 ppm	39 ppm	70 ppm
Sample size	0.2083 grams	0.2530 grams	0.2583 grams	0.1423 grams
§ Total Lead Result	180 ppm	99 ppm	160 ppm	< 70 ppm

Comments:

Sample results have not been corrected for blank values.

Bulk samples are not covered under the AIHA LAP, LLC service accreditation.

Wipe samples must meet ASTM E1792 criteria. Method Reporting Limits may not be valid for non-ASTM E1792 wipe samples.

Estimated accuracy is solely based on recovery data from internal laboratory control samples at the 95% confidence interval ($k \sim 2$) of the level of concern, derived from a 1,000-ppm certified lead reference.

*Sample preparation and analytical methods are based upon NIOSH 7082 and EPA 7000B.

† The Method Reporting Limit is the minimum concentration of Lead that the laboratory can confidently detect in the sample.

§ Total Lead Result has been rounded to two significant figures to reflect analytical precision.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Eurofins Built Environment Testing West, LLC
2841 Dow Avenue, Suite 300, Tustin, CA 92780
(833) 465-5857 www.eurofinsus.com/Built


Client: Sterling Technologies LLC
C/O: Thomas Nadermann
Re: Longview School District; Monticello Elementary

Date of Sampling: 03-11-2026
Date of Receipt: 03-13-2026
Date of Report: 03-20-2026

LEAD: FLAME ATOMIC ABSORPTION SPECTROMETRY

PROJECT ANALYST AND SIGNATORY REPORT

Project Analyst



Analyst: Alex Nguyen

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by AIHA LAP, LLC, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".