



2150 Smithtown Ave., Suite 3, Ronkonkoma, NY 11779
T: 631.580.3191 • F: 631.580.3195 • W: envirohealth.org

Mr. Christopher McCartney
Somers CSD
250 Route 202
Somers, NY 10589
Ph: 914-277-2400

Re: **Lead in Drinking Water Sampling & Analysis - 2026-2028**

Dear Mr. McCartney:

On April 9, 2026, Envirosience Consultants performed a limited sampling event at Somers Middle School, located at 250 US 202, Somers, NY 10589. Samples were collected from newly installed kitchen fixtures.

First-draw samples were collected in wide-mouth 250 milliliter containers and during the early morning, prior to any water sources being used. The samples were transported to New York Environmental Laboratory and were analyzed for lead concentration. The current limit for lead in drinking water is 5 parts per billion (ppb). Any locations that were above the limit were taken out of service as potable outlets. Signs were posted for handwashing & dishwashing only.

The following locations were above the limit:

Kitchen 3-Bay - Left: 8.0 ppb

Please see the attached Outlet Inventory tables and lab reports for detailed results at each location. These locations have satisfied the requirement for the 2026-2028 Lead in Drinking Water sampling period.

Should you have any questions, please feel free to contact me.

Sincerely,

Casey Lee
Lead in Drinking Water Coordinator

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-01	Kitchen 3-Bay - Left	SK	App	8.0	4/9/2026	3.0	<1.0	4/9/2026	Sign posted; Handwashing & dishwashing only
1001-02	Kitchen 3-Bay - Right	SK	App	5.0	4/9/2026	<1.0	<1.0	4/9/2026	-
1001-03	Kitchen Prep Sink	SK	App	5.0	4/9/2026	2.0	<1.0	4/9/2026	-

Laboratory Report

April 14, 2026

Casey Lee
Enviroscience Consultants, Inc.
2150 Smithtown Ave.
Ronkonkoma, NY, 11779


Project: Somers CSD (Somers Middle School)
Project Address: Somers Middle School
Report ID: 260409001
Sample IDs: 260409001-010 - 260409001-018

New York Environmental is a NELAC accredited laboratory. Attached reported results meet the requirements of the NELAC standard unless otherwise noted.

Samples' analytical results relate only to the parameters tested for the samples received in the condition received by the laboratory, as noted on the Chain of Custody. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	9-Apr-26
Date Received:	9-Apr-26
Date Analyzed:	10-Apr-26

Analytical Method:	EPA 200.9
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
260409001-010	1A	Kitchen 3-Bay - Left - SK; Initial	0.001	0.008	mg/L	H
260409001-011	1B	Kitchen 3-Bay - Left - SK; 15 sec Flush	0.001	0.003	mg/L	
260409001-012	1C	Kitchen 3-Bay - Left - SK; 60 sec Flush	0.001	<0.001	mg/L	
260409001-013	2A	Kitchen 3-Bay - Right - SK; Initial	0.001	0.005	mg/L	
260409001-014	2B	Kitchen 3-Bay - Right - SK; 15 sec Flush	0.001	<0.001	mg/L	
260409001-015	2C	Kitchen 3-Bay - Right - SK; 60 sec Flush	0.001	<0.001	mg/L	
260409001-016	3A	Kitchen Prep Sink - SK; Initial	0.001	0.005	mg/L	
260409001-017	3B	Kitchen Prep Sink - SK; 15 sec Flush	0.001	0.002	mg/L	
260409001-018	3C	Kitchen Prep Sink - SK; 60 sec Flush	0.001	<0.001	mg/L	

Comment(s):

LOQ: Limit of Quantitation

CID: Client ID

H: Sample result exceeds applicable regulatory limit.

