

January 30, 2026

Mr. Zachary Schoepflin
West Valley CSD
5359 School Street
West Valley, New York 14171

Re: Lead Testing in School Drinking Water

Dear Mr. Schoepflin:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for West Valley Central School District, including:

- **West Valley Central School – 5359 School Street, West Valley, NY**

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: *Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Sampling was performed on January 9, 2026. As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 15 sources of potable water in West Valley Central School have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion. To comply with NYS regulations, response actions by the district are required. Response actions are outlined in Section 1.3 (*Response Actions Required Under NYS Regulations*).

Thank you for the opportunity to be of service to West Valley Central School District.

Sincerely,
Stohl Environmental, LLC.



Michael Scinta
EPA Lead Risk Assessor

Lead Testing in School Drinking Water

Prepared for:

West Valley Central School District

Prepared by:



**3860 California Road
Orchard Park, New York 14127**

Conditions as of January 9, 2026

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports and Chain of Custody Documents
- 1.5. Laboratory Certifications

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by West Valley Central School District to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building:

- **West Valley Central School – 5359 School Street, West Valley, NY**

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within West Valley Central School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***3Ts for Reducing Lead in Drinking Water in Schools***, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Summary of Samples Collected at West Valley Central School:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
West Valley Central School	1/9/2026	67	52	15

**NYS Action Level is 5 parts per billion*

Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet type	Laboratory Analysis (in ppb)
221.1-06	Left Lavatory	Sink	5.5
221.1-14	C-103 Drinking Fountain	Drinking Fountain	5.3
221.1-15	C-104 Sink	Sink	13.3
221.1-17	C-107 Sink	Sink	8.6
221.1-22	C-106 Drinking Fountain	Drinking Fountain	5.4
221.1-23	B-102 Sink	Sink	6.4
221.1-25	B-101 Sink	Sink	32.1
221.1-27	B-108 Sink	Sink	12.2
221.1-28	B-108 Drinking Fountain	Drinking Fountain	10.0
221.1-31	B-106 Sink	Sink	19.6
221.1-32	B-106 Drinking Fountain	Drinking Fountain	26.7
221.1-42	A-111 Left	Sink	6.4
221.1-43	A-111 Left Near Window	Sink	5.4
221.1-56	A-210 Left	Sink	39.9
221.1-59	Girls Locker Room Drinking Fountain	Drinking Fountain	13.2

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration more than the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports and Chain of Custody Documents



January 26, 2026

Service Request No:R2600461

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: West Valley CSD

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory January 13, 2026
For your reference, these analyses have been assigned our service request number **R2600461**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Client: Stohl Environmental
Project: West Valley CSD
Sample Matrix: Drinking Water

Service Request: R2600461
Date Received: 01/13/2026

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 01/13/2026. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

Approved by

A handwritten signature in black ink, appearing to read 'Meghan Pedicini', is written over a horizontal line.

Date

01/26/2026



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 221.1-01		Lab ID: R2600461-001				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.2			1.0	ug/L	200.8
CLIENT ID: 221.1-02		Lab ID: R2600461-002				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.7			1.0	ug/L	200.8
CLIENT ID: 221.1-03		Lab ID: R2600461-003				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.5			1.0	ug/L	200.8
CLIENT ID: 221.1-04A		Lab ID: R2600461-004				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.5			1.0	ug/L	200.8
CLIENT ID: 221.1-04B		Lab ID: R2600461-005				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.2			1.0	ug/L	200.8
CLIENT ID: 221.1-06		Lab ID: R2600461-007				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.5			1.0	ug/L	200.8
CLIENT ID: 221.1-09		Lab ID: R2600461-010				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.6			1.0	ug/L	200.8
CLIENT ID: 221.1-10		Lab ID: R2600461-011				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.3			1.0	ug/L	200.8
CLIENT ID: 221.1-13		Lab ID: R2600461-014				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.1			1.0	ug/L	200.8
CLIENT ID: 221.1-14		Lab ID: R2600461-015				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.3			1.0	ug/L	200.8
CLIENT ID: 221.1-15		Lab ID: R2600461-016				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	13.3			1.0	ug/L	200.8
CLIENT ID: 221.1-16		Lab ID: R2600461-017				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.1			1.0	ug/L	200.8



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 221.1-17		Lab ID: R2600461-018				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	8.6			1.0	ug/L	200.8
CLIENT ID: 221.1-18		Lab ID: R2600461-019				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.8			1.0	ug/L	200.8
CLIENT ID: 221.1-20		Lab ID: R2600461-021				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.9			1.0	ug/L	200.8
CLIENT ID: 221.1-21		Lab ID: R2600461-022				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.5			1.0	ug/L	200.8
CLIENT ID: 221.1-22		Lab ID: R2600461-023				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.4			1.0	ug/L	200.8
CLIENT ID: 221.1-23		Lab ID: R2600461-024				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	6.4			1.0	ug/L	200.8
CLIENT ID: 221.1-24		Lab ID: R2600461-025				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.6			1.0	ug/L	200.8
CLIENT ID: 221.1-25		Lab ID: R2600461-026				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	32.1			1.0	ug/L	200.8
CLIENT ID: 221.1-26		Lab ID: R2600461-027				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.9			1.0	ug/L	200.8
CLIENT ID: 221.1-27		Lab ID: R2600461-028				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	12.2			1.0	ug/L	200.8
CLIENT ID: 221.1-28		Lab ID: R2600461-029				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	10.0			1.0	ug/L	200.8
CLIENT ID: 221.1-29		Lab ID: R2600461-030				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.9			1.0	ug/L	200.8



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 221.1-30			Lab ID: R2600461-031			
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.5			1.0	ug/L	200.8

CLIENT ID: 221.1-31			Lab ID: R2600461-032			
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	19.6			1.0	ug/L	200.8

CLIENT ID: 221.1-32			Lab ID: R2600461-033			
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	26.7			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1

Service Request:R2600461

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2600461-001	221.1-01	1/9/2026	
R2600461-002	221.1-02	1/9/2026	
R2600461-003	221.1-03	1/9/2026	
R2600461-004	221.1-04A	1/9/2026	
R2600461-005	221.1-04B	1/9/2026	
R2600461-006	221.1-05	1/9/2026	
R2600461-007	221.1-06	1/9/2026	
R2600461-008	221.1-07	1/9/2026	
R2600461-009	221.1-08	1/9/2026	
R2600461-010	221.1-09	1/9/2026	
R2600461-011	221.1-10	1/9/2026	
R2600461-012	221.1-11	1/9/2026	
R2600461-013	221.1-12	1/9/2026	
R2600461-014	221.1-13	1/9/2026	
R2600461-015	221.1-14	1/9/2026	
R2600461-016	221.1-15	1/9/2026	
R2600461-017	221.1-16	1/9/2026	
R2600461-018	221.1-17	1/9/2026	
R2600461-019	221.1-18	1/9/2026	
R2600461-020	221.1-19	1/9/2026	
R2600461-021	221.1-20	1/9/2026	
R2600461-022	221.1-21	1/9/2026	
R2600461-023	221.1-22	1/9/2026	
R2600461-024	221.1-23	1/9/2026	
R2600461-025	221.1-24	1/9/2026	
R2600461-026	221.1-25	1/9/2026	
R2600461-027	221.1-26	1/9/2026	
R2600461-028	221.1-27	1/9/2026	
R2600461-029	221.1-28	1/9/2026	
R2600461-030	221.1-29	1/9/2026	
R2600461-031	221.1-30	1/9/2026	
R2600461-032	221.1-31	1/9/2026	
R2600461-033	221.1-32	1/9/2026	
R2600461-034	221.1-33	1/9/2026	
R2600461-035	221.1-34	1/9/2026	
R2600461-036	221.1-35	1/9/2026	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-221.1

Client: West Valley CSD

Contact: Zachary Schoepflin

Building: West Valley Central School

Location: 5359 School St

LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
221.1-01	Back Wall Sink	Sink	5:10
221.1-02	Right Side Dishline Sink	Sink	5:11
221.1-03	Right Side Dishline Sprayer	Sprayer	5:13
221.1-04A	Cafe DF	DF	5:14
221.1-04B	Cafe DFB	DFB	5:16
221.1-05	C-100 Kitchenette Sink	Sink	5:17
221.1-06	Left Lav	Sink	5:19
221.1-07	Right Lav	Sink	5:20
221.1-08	C-101	Sink	5:22
221.1-09	C-109 Lav	Sink	5:23
221.1-10	C-109 Left	Sink	5:25
221.1-11	C-109 Right	Sink	5:26
221.1-12	C-102	Sink	5:28
221.1-13	C-103	Sink	5:29
221.1-14	C-103 DF	DF	5:31
221.1-15	C-104	Sink	5:32
221.1-16	C-104 DF	DF	5:34
221.1-17	C-107	Sink	5:35

Notes:

Please e-mail lab results to labs@stohlenv.com

☒ If checked, also e-mail results to:

mscinta@stohlenvironmental.com

Sampled By: Alexis Dellinger Print Name

Stohl Env: Alexis Dellinger

Date: 1/9/2026

Relinquished By: [Signature] Print Name

Stohl Env: Connor Crilly

Date: 1/13/26 8:45 AM

Received (Name / Lab): [Signature] ALS

Date: 1/13/26

Time: 1/13/26 8:53

Sample Login (Name / Lab):

Date:

Time:

Analysis (Name / Lab):

Date:

Time:

QA/QC Review (Name / Lab):

Date:

Time:

Archived / Released:

QA/QC InterLAB Use:

Date:

Time:

Page 1 of 4

R2600461

5

Stohl Environmental
West Valley CSD





Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name)

ALS

STOHL Job #

2023L-221.1

Client: West Valley CSD

Contact: Zachary Schoepflin

Building: West Valley Central School

Location: 5359 School St

LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
221.1-18	C-107 DF	DF	5:37
221.1-19	C-104	Sink	5:38
221.1-20	C-104 DF	DF	5:40
221.1-21	C-106	Sink	5:41
221.1-22	C-106 DF	DF	5:43
221.1-23	B-102	Sink	5:44
221.1-24	B-102 DF	DF	5:46
221.1-25	B-101	Sink	5:47
221.1-26	B-101 DF	DF	5:49
221.1-27	B-108	Sink	5:50
221.1-28	B-108 DF	DF	5:52
221.1-29	B-109	Sink	5:53
221.1-30	B-107	Sink	5:55
221.1-31	B-106	Sink	5:56
221.1-32	B-106 DF	DF	5:58
221.1-33	B-105	Sink	5:59
221.1-34	B-105 DF	DF	6:01
221.1-35	B-104	Sink	6:02

Notes:


Please e-mail lab results to labs@stohlenv.com.

mscinta@stohlenv.com

Sampled By: Alexis Dellinger Print Name

Stohl Env: Alexis Dellinger

Date: 1/9/2026

Relinquished By:  Print Name

Stohl Env: Connor Crilly

Date: 1/13/26 8:45 AM

Received (Name / Lab):  ALS

Date: 1/13/26

Time: 8:53

Sample Login (Name / Lab):

Date:

Time:

Analysis (Name / Lab):

Date:

Time:

QA/QC Review (Name / Lab):

Date:

Time:

Archived / Released: QA/QC InterLAB Use:

Date:

Time:



Cooler Receipt and Preservation Check Form

R2600461

5

Stohl Environmental
West Valley CSD



Project/Client Stohl

Folder Number _____

Cooler received on 11/3/26

by: RM

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>(N)</u>
2	Custody papers properly completed (ink, signed)?	Y <u>(N)</u>
3	Did all bottles arrive in good condition (unbroken)?	Y <u>(N)</u>
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>(N)</u>

5a	Did VOA vials have sig* bubbles?	Y N <u>(NA)</u>
5b	Sig* bubbles: Alk? Y N <u>(NA)</u> Sulfide? Y N <u>(NA)</u>	
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035set <u>(NA)</u>	

8. Temperature Readings Date: 11/3/26 Time: 9:00 ID: IR#11 IR#12 IR#13 From: Temp Blank Sample Bottle

Temp (°C)	<u>10.9</u>						
Within 0-6°C?	Y <u>(N)</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: No ice Ice melted Poorly Packed (described below) Same Day Rule

& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMO by RM on 11/3 at 9:00

5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 01/13/26 Time: 1110 by: cc

- | | |
|---|---------------------|
| 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? | YES <u>(NO)</u> |
| 10. Did all bottle labels and tags agree with custody papers? | YES <u>(NO)</u> |
| 11. Were correct containers used for the tests indicated? | <u>(YES)</u> NO |
| 12. Were 5035 vials acceptable (no extra labels, not leaking)? | YES NO <u>(N/A)</u> |
| 13. Were dissolved metals filtered in the field? | YES NO <u>(N/A)</u> |

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>202325</u>	HNO ₃		✓			<u>All</u>	<u>4ml</u>	<u>245078</u>	<u>All < 2</u>
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis.
Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 092225-2ADD

Explain all Discrepancies/ Other Comments:

9/10) No bottle Labels

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: cc

*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-221.1

Client: West Valley CSD

Contact: Zachary Schoepflin

Building: West Valley Central School

Location: 5359 School St

LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
221.1-01	Back Wall Sink	Sink	5:10
221.1-02	Right Side Dishline Sink	Sink	5:11
221.1-03	Right Side Dishline Sprayer	Sprayer	5:13
221.1-04A	Cafe DF	DF	5:14
221.1-04B	Cafe DFB	DFB	5:16
221.1-05	C-100 Kitchenette Sink	Sink	5:17
221.1-06	Left Lav	Sink	5:19
221.1-07	Right Lav	Sink	5:20
221.1-08	C-101	Sink	5:22
221.1-09	C-109 Lav	Sink	5:23
221.1-10	C-109 Left	Sink	5:25
221.1-11	C-109 Right	Sink	5:26
221.1-12	C-102	Sink	5:28
221.1-13	C-103	Sink	5:29
221.1-14	C-103 DF	DF	5:31
221.1-15	C-104	Sink	5:32
221.1-16	C-104 DF	DF	5:34
221.1-17	C-107	Sink	5:35

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

☒ If checked, also e-mail results to: mscinta@stohlenvironmental.com

Sampled By: Alexis Dellinger Print Name

Stohl Env: Alexis Dellinger

Date: 1/9/2026

Relinquished By: [Signature] Print Name

Stohl Env: Connor Crilly

Date: 1/13/26 8:45 AM

Received (Name / Lab): [Signature] ALS

Date: 1/13/26

Time: 1/13/26 8:53

Sample Login (Name / Lab):

Date:

Time:

Analysis (Name / Lab):

Date:

Time:

QA/QC Review (Name / Lab):

Date:

Time:

Archived / Released: QA/QC InterLAB Use:

Date:

Time:

Page 1 of 4

R2600461

5

Stohl Environmental
West Valley CSD





Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-221.1

Client: West Valley CSD

Contact: Zachary Schoepflin

Building: West Valley Central School

Location: 5359 School St

LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
221.1-18	C-107 DF	DF	5:37
221.1-19	C-104	Sink	5:38
221.1-20	C-104 DF	DF	5:40
221.1-21	C-106	Sink	5:41
221.1-22	C-106 DF	DF	5:43
221.1-23	B-102	Sink	5:44
221.1-24	B-102 DF	DF	5:46
221.1-25	B-101	Sink	5:47
221.1-26	B-101 DF	DF	5:49
221.1-27	B-108	Sink	5:50
221.1-28	B-108 DF	DF	5:52
221.1-29	B-109	Sink	5:53
221.1-30	B-107	Sink	5:55
221.1-31	B-106	Sink	5:56
221.1-32	B-106 DF	DF	5:58
221.1-33	B-105	Sink	5:59
221.1-34	B-105 DF	DF	6:01
221.1-35	B-104	Sink	6:02

Notes:

Please e-mail lab results to labs@stohlenvironmental.com.

mscinta@stohlenvironmental.com

Sampled By: Alexis Dellinger Print Name

Stohl Env: Alexis Dellinger

Date: 1/9/2026

Relinquished By: [Signature] Print Name

Stohl Env: Connor Crilly

Date: 1/13/26 8:45 AM

Received (Name / Lab): AM MMA ALS

Date: 1/13/26

Time: 8:53

Sample Login (Name / Lab): _____

Date: _____

Time: _____

Analysis (Name / Lab): _____

Date: _____

Time: _____

QA/QC Review (Name / Lab): _____

Date: _____

Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____

Date: _____

Time: _____



Cooler Receipt and Preservation Check Form

R2600461

5

Stohl Environmental
West Valley CSD



Project/Client Stohl

Folder Number _____

Cooler received on 11/3/26

by: RM

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>(N)</u>	5a	Did VOA vials have sig* bubbles?	Y N <u>(NA)</u>
2	Custody papers properly completed (ink, signed)?	<u>(Y)</u> N	5b	Sig* bubbles: Alk? Y N <u>(NA)</u> Sulfide? Y N <u>(NA)</u>	
3	Did all bottles arrive in good condition (unbroken)?	<u>(Y)</u> N	6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>(N)</u>	7	Soil VOA received as: Bulk Encore 5035set	<u>(NA)</u>

8. Temperature Readings Date: 11/3/26 Time: 9:00 ID: IR#11 IR#12 IR#13 From: Temp Blank Sample Bottle

Temp (°C)	<u>10.9</u>						
Within 0-6°C?	<u>Y (N)</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: No ice Ice melted Poorly Packed (described below) Same Day Rule

& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMO by RM on 11/3 at 9:00
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 01/13/26 Time: 1110 by: cc

9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES (NO)
10. Did all bottle labels and tags agree with custody papers? YES (NO)
11. Were correct containers used for the tests indicated? (YES) NO
12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO (N/A)
13. Were dissolved metals filtered in the field? YES NO (N/A)

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>202325</u>	HNO ₃		✓			<u>All</u>	<u>4ml</u>	<u>245078</u>	<u>All < 2</u>
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis.
Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 092225-2ADD

Explain all Discrepancies/ Other Comments:

9/10) No bottle Labels

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: cc

*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

U	Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.	+	Correlation coefficient for MSA is <0.995.
J	Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).	N	Inorganics- Matrix spike recovery was outside laboratory limits.
B	Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.	N	Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
E	Inorganics- Concentration is estimated due to the serial dilution was outside control limits.	S	Concentration has been determined using Method of Standard Additions (MSA).
E	Organics- Concentration has exceeded the calibration range for that specific analysis.	W	Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
D	Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.	P	Concentration >40% difference between the two GC columns.
*	Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.	C	Confirmed by GC/MS
H	Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.	Q	DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
#	Spike was diluted out.	X	See Case Narrative for discussion.
		MRL	Method Reporting Limit. Also known as:
		LOQ	Limit of Quantitation (LOQ) The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
		MDL	Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
		LOD	Limit of Detection. A value at or above the MDL which has been verified to be detectable.
		ND	Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1

Service Request: R2600461

Sample Name: 221.1-01
Lab Code: R2600461-001
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 221.1-02
Lab Code: R2600461-002
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 221.1-03
Lab Code: R2600461-003
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 221.1-04A
Lab Code: R2600461-004
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 221.1-04B
Lab Code: R2600461-005
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1

Service Request: R2600461

Sample Name: 221.1-05
Lab Code: R2600461-006
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 221.1-06
Lab Code: R2600461-007
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 221.1-07
Lab Code: R2600461-008
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 221.1-08
Lab Code: R2600461-009
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 221.1-09
Lab Code: R2600461-010
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1

Service Request: R2600461

Sample Name: 221.1-10
Lab Code: R2600461-011
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 221.1-11
Lab Code: R2600461-012
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 221.1-12
Lab Code: R2600461-013
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 221.1-13
Lab Code: R2600461-014
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 221.1-14
Lab Code: R2600461-015
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1

Service Request: R2600461

Sample Name: 221.1-15
Lab Code: R2600461-016
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 221.1-16
Lab Code: R2600461-017
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 221.1-17
Lab Code: R2600461-018
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 221.1-18
Lab Code: R2600461-019
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 221.1-19
Lab Code: R2600461-020
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1

Service Request: R2600461

Sample Name: 221.1-20
Lab Code: R2600461-021
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-21
Lab Code: R2600461-022
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-22
Lab Code: R2600461-023
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-23
Lab Code: R2600461-024
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-24
Lab Code: R2600461-025
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1

Service Request: R2600461

Sample Name: 221.1-25
Lab Code: R2600461-026
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-26
Lab Code: R2600461-027
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-27
Lab Code: R2600461-028
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-28
Lab Code: R2600461-029
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-29
Lab Code: R2600461-030
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1

Service Request: R2600461

Sample Name: 221.1-30
Lab Code: R2600461-031
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-31
Lab Code: R2600461-032
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-32
Lab Code: R2600461-033
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-33
Lab Code: R2600461-034
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-34
Lab Code: R2600461-035
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1

Service Request: R2600461

Sample Name: 221.1-35
Lab Code: R2600461-036
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-01
Lab Code: R2600461-001

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	01/16/26 19:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-02
Lab Code: R2600461-002

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.7	ug/L	1.0	1	01/16/26 19:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-03
Lab Code: R2600461-003

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.5	ug/L	1.0	1	01/16/26 19:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-04A
Lab Code: R2600461-004

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.5	ug/L	1.0	1	01/16/26 19:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-04B
Lab Code: R2600461-005

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	01/16/26 19:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-05
Lab Code: R2600461-006

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/16/26 19:23	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-06
Lab Code: R2600461-007

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.5	ug/L	1.0	1	01/16/26 19:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-07
Lab Code: R2600461-008

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/16/26 19:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-08
Lab Code: R2600461-009

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/16/26 19:31	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-09
Lab Code: R2600461-010

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.6	ug/L	1.0	1	01/16/26 19:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-10
Lab Code: R2600461-011

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	01/16/26 19:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-11
Lab Code: R2600461-012

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/16/26 19:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-12
Lab Code: R2600461-013

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/16/26 19:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-13
Lab Code: R2600461-014

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.1	ug/L	1.0	1	01/16/26 19:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-14
Lab Code: R2600461-015

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.3	ug/L	1.0	1	01/16/26 19:40	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-15
Lab Code: R2600461-016

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	13.3	ug/L	1.0	1	01/16/26 19:42	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-16
Lab Code: R2600461-017

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.1	ug/L	1.0	1	01/16/26 19:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-17
Lab Code: R2600461-018

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.6	ug/L	1.0	1	01/16/26 19:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-18
Lab Code: R2600461-019

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.8	ug/L	1.0	1	01/16/26 19:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-19
Lab Code: R2600461-020

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/16/26 19:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-20
Lab Code: R2600461-021

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.9	ug/L	1.0	1	01/20/26 18:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-21
Lab Code: R2600461-022

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.5	ug/L	1.0	1	01/23/26 12:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-22
Lab Code: R2600461-023

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.4	ug/L	1.0	1	01/20/26 18:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-23
Lab Code: R2600461-024

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.4	ug/L	1.0	1	01/20/26 18:16	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-24
Lab Code: R2600461-025

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.6	ug/L	1.0	1	01/20/26 18:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-25
Lab Code: R2600461-026

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	32.1	ug/L	1.0	1	01/20/26 18:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-26
Lab Code: R2600461-027

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.9	ug/L	1.0	1	01/20/26 18:23	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-27
Lab Code: R2600461-028

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	12.2	ug/L	1.0	1	01/20/26 18:24	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-28
Lab Code: R2600461-029

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	10.0	ug/L	1.0	1	01/20/26 18:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-29
Lab Code: R2600461-030

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.9	ug/L	1.0	1	01/20/26 18:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-30
Lab Code: R2600461-031

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.5	ug/L	1.0	1	01/20/26 18:31	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-31
Lab Code: R2600461-032

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	19.6	ug/L	1.0	1	01/20/26 18:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-32
Lab Code: R2600461-033

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	26.7	ug/L	1.0	1	01/20/26 18:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-33
Lab Code: R2600461-034

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 18:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-34
Lab Code: R2600461-035

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 18:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-35
Lab Code: R2600461-036

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 18:38	



QC Summary Forms

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2600461-MB1

Service Request: R2600461
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/16/26 19:10	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2600461-MB2

Service Request: R2600461
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 17:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2600461-MB3

Service Request: R2600461
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 18:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2600461-MB4

Service Request: R2600461
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/23/26 12:33	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26
Date Analyzed: 01/16/26

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 221.1-01
Lab Code: R2600461-001
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike		Result	Duplicate Matrix Spike		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.2	21.0	20.0	99	20.7	20.0	98	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26
Date Analyzed: 01/16/26

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 221.1-19
Lab Code: R2600461-020
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2600461-020MS		Result	Duplicate Matrix Spike R2600461-020DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	19.9	20.0	99	19.9	20.0	99	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26
Date Analyzed: 01/23/26

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 221.1-21
Lab Code: R2600461-022
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2600461-022MS		Result	Duplicate Matrix Spike R2600461-022DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	4.5	26.1	20.0	108	25.6	20.0	105	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26
Date Analyzed: 01/20/26

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 221.1-22
Lab Code: R2600461-023
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2600461-023MS		Result	Duplicate Matrix Spike R2600461-023DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	5.4	25.8	20.0	102	25.8	20.0	102	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water

Service Request: R2600461
Date Collected: 01/09/26
Date Received: 01/13/26
Date Analyzed: 01/20/26

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 221.1-23
Lab Code: R2600461-024
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2600461-024MS		Result	Duplicate Matrix Spike R2600461-024DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	6.4	27.3	20.0	104	26.9	20.0	102	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water

Service Request: R2600461

Date Analyzed: 01/16/26

Lab Control Sample Summary

Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample

R2600461-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.3	20.0	101	85-115

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water

Service Request: R2600461

Date Analyzed: 01/20/26

Lab Control Sample Summary

Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample

R2600461-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.5	20.0	103	85-115

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water

Service Request: R2600461

Date Analyzed: 01/20/26

Lab Control Sample Summary

Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample

R2600461-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.9	20.0	110	85-115

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water

Service Request: R2600461
Date Analyzed: 01/23/26

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2600461-LCS4

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.3	20.0	107	85-115



January 29, 2026

Service Request No:R2600462

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: West Valley CSD

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory January 13, 2026
For your reference, these analyses have been assigned our service request number **R2600462**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Client: Stohl Environmental
Project: West Valley CSD
Sample Matrix: Drinking Water

Service Request: R2600462
Date Received: 01/13/2026

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty one drinking water samples were received for analysis at ALS Environmental on 01/13/2026. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

Approved by

A handwritten signature in black ink, appearing to read "Meghan Pedicini".

Date

01/29/2026



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 221.1-42			Lab ID: R2600462-008			
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	6.4			1.0	ug/L	200.8

CLIENT ID: 221.1-43			Lab ID: R2600462-009			
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.4			1.0	ug/L	200.8

CLIENT ID: 221.1-53			Lab ID: R2600462-021			
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.7			1.0	ug/L	200.8

CLIENT ID: 221.1-56			Lab ID: R2600462-026			
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	39.9			1.0	ug/L	200.8

CLIENT ID: 221.1-57			Lab ID: R2600462-027			
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.4			1.0	ug/L	200.8

CLIENT ID: 221.1-59			Lab ID: R2600462-029			
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	13.2			1.0	ug/L	200.8

CLIENT ID: 221.1-61			Lab ID: R2600462-031			
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1

Service Request:R2600462

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2600462-001	221.1-36	1/9/2026	
R2600462-002	221.1-37	1/9/2026	
R2600462-003	221.1-38	1/9/2026	
R2600462-004	221.1-39A	1/9/2026	
R2600462-005	221.1-39B	1/9/2026	
R2600462-006	221.1-40	1/9/2026	
R2600462-007	221.1-41	1/9/2026	
R2600462-008	221.1-42	1/9/2026	
R2600462-009	221.1-43	1/9/2026	
R2600462-010	221.1-44	1/9/2026	
R2600462-011	221.1-45	1/9/2026	
R2600462-012	221.1-46	1/9/2026	
R2600462-013	221.1-47	1/9/2026	
R2600462-014	221.1-48	1/9/2026	
R2600462-015	221.1-49A	1/9/2026	
R2600462-016	221.1-49B	1/9/2026	
R2600462-017	221.1-50	1/9/2026	
R2600462-018	221.1-51	1/9/2026	
R2600462-019	221.1-52A	1/9/2026	
R2600462-020	221.1-52B	1/9/2026	
R2600462-021	221.1-53	1/9/2026	
R2600462-022	221.1-54A	1/9/2026	
R2600462-023	221.1-54B	1/9/2026	
R2600462-024	221.1-55A	1/9/2026	
R2600462-025	221.1-55B	1/9/2026	
R2600462-026	221.1-56	1/9/2026	
R2600462-027	221.1-57	1/9/2026	
R2600462-028	221.1-58	1/9/2026	
R2600462-029	221.1-59	1/9/2026	
R2600462-030	221.1-60	1/9/2026	
R2600462-031	221.1-61	1/9/2026	



Chain of Custody Document

Submitted to: (Lab Name) ALS

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

STOHL Job # 2023L-221.1

Client: West Valley CSD

Contact: Zachary Schoepflin

Building: West Valley Central School

Location: 5359 School St

LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
221.1-36	B-104 DF	DF	6:04
221.1-37	B-103	Sink	6:05
221.1-38	B-103 DF	DF	6:07
221.1-39A	DF Near A-106	DF	6:08
221.1-39B	DFB Near A-106	DFB	6:10
221.1-40	A-109 Near Fume Hood	Sink	6:11
221.1-41	A-109	Sink	6:13
221.1-42	A-111 Left	Sink	6:14
221.1-43	A-111 Left Near Window	Sink	6:16
221.1-44	A-111 Middle Near Window	Sink	6:17
221.1-45	A-111 Right Near Window	Sink	6:19
221.1-46	A-111 Near Fume Hood	Sink	6:20
221.1-47	A-123	Sink	6:22
221.1-48	A-123	Sink	6:23
221.1-49A	DF Near A-124	DF	6:25
221.1-49B	DFB Near A-124	DFB	6:26
221.1-50	A-127	Sink	6:28
221.1-51	A-127	Sink	6:29

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

mscinta@stohlenvironmental.com

Sampled By: Alexis Dellinger Print Name

Stohl Env: Alexis Dellinger

Date: 1/9/2026

Relinquished By: [Signature] Print Name

Stohl Env: Connor Crilly

Date: 1/8/26 8:45 AM

Received (Name / Lab): [Signature]

Date: 1/13/26

Time: 8:53

Sample Login (Name / Lab): _____

Date: _____

Time: _____

Analysis (Name / Lab): _____

Date: _____

Time: _____

QA/QC Review (Name / Lab): _____

Date: _____

Time: _____

Archived / Released: _____

QA/QC InterLAB Use: _____

Date: _____

Time: _____

Page 3 of 4

R2600462

5

Stohl Environmental
West Valley CSD





Chain of Custody Document

Submitted to: (Lab Name)

ALS

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

STOHL Job #

2023L-221.1

Client: West Valley CSD

Contact: Zachary Schoepflin

Building: West Valley Central School

Location: 5359 School St

LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
221.1-52A	DF Near Girls Locker Room	DF	6:31
221.1-52B	DFB Near Girls Locker Room	DFB	6:32
221.1-53	A-200	Sink	6:34
221.1-54A	DF Near A-217	DF	6:35
221.1-54B	DFB Near A-217	DFB	6:37
221.1-55A	DF Near A-123	DF	6:38
221.1-55B	DFB Near A-123	DFB	6:40
221.1-56	A-210 Left	Sink	6:41
221.1-57	A-210 Right	Sink	6:43
221.1-58	Faculty Sink	Sink	6:44
221.1-59	Girls Locker Room DF	DF	6:46
221.1-60	Boys Locker Room DF	DF	6:47
221.1-61	Bus Garage Lav	Sink	6:49

Notes:Please e-mail lab results to labs@stohlenv.commscinta@stohlenvironmental.com

Sampled By: Alexis Dellinger Print Name

Stohl Env: Alexis Dellinger

Date: 1/9/2026

Relinquished By: Print Name

Stohl Env: Connor Crilly

Date: 1/13/26 8:45 AM

Received (Name / Lab):

Date: 1/13/26

Time: 8:53

Sample Login (Name / Lab):

Date:

Time:

Analysis (Name / Lab):

Date:

Time:

QA/QC Review (Name / Lab):

Date:

Time:

Archived / Released:

QA/QC InterLAB Use:

Date:

Time:

Page

4

of

4



Cooler Receipt and Preservation Check Form

R2600462

5

Stohl Environmental
West Valley CSD



Project/Client Stohl

Folder Number _____

Cooler received on 11/3/26

by: RM

COURIER: ALS UPS FEDEX VELOCITY (CLIENT)

1	Were Custody seals on outside of cooler?	Y <u>(N)</u>
2	Custody papers properly completed (ink, signed)?	<u>(Y)</u> N
3	Did all bottles arrive in good condition (unbroken)?	<u>(Y)</u> N
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>(N)</u>

5a	Did VOA vials have sig* bubbles?	Y N <u>(NA)</u>
5b	Sig* bubbles: Alk? Y N <u>(NA)</u> Sulfide? Y N <u>(NA)</u>	
6	Where did the bottles originate?	<u>(ALS/ROC)</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035set <u>(NA)</u>	

8. Temperature Readings Date: 11/3/26 Time: 9:00 ID: (IR#11) IR#12 IR#13 From: Temp Blank (Sample Bottle)

Temp (°C)	<u>10.9</u>						
Within 0-6°C?	Y <u>(N)</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: No ice Ice melted Poorly Packed (described below) Same Day Rule

& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: S/MO by RM on 11/3 at 9:00

5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 01/13/26 Time: 1123 by: cc

- Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES (NO)
- Did all bottle labels and tags agree with custody papers? YES (NO)
- Were correct containers used for the tests indicated? (YES) NO
- Were 5035 vials acceptable (no extra labels, not leaking)? YES NO (N/A)
- Were dissolved metals filtered in the field? YES NO (N/A)

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥ 12		NaOH	<u>cc</u>	<u>01132026</u>						
≤ 2	<u>202325</u>	HNO ₃	<u>X</u>	<u>✓</u>			<u>A11</u>	<u>4ml</u>	<u>245078</u>	<u>A11 < 2</u>
≤ 2		H ₂ SO ₄								
< 4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 092225-2ADD, 092925-2ERG

Explain all Discrepancies/ Other Comments:

9/10) No bottle label

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: cc

*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Chain of Custody Document

Submitted to: (Lab Name) ALS

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

STOHL Job # 2023L-221.1

Client: West Valley CSD

Contact: Zachary Schoepflin

Building: West Valley Central School

Location: 5359 School St

LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
221.1-36	B-104 DF	DF	6:04
221.1-37	B-103	Sink	6:05
221.1-38	B-103 DF	DF	6:07
221.1-39A	DF Near A-106	DF	6:08
221.1-39B	DFB Near A-106	DFB	6:10
221.1-40	A-109 Near Fume Hood	Sink	6:11
221.1-41	A-109	Sink	6:13
221.1-42	A-111 Left	Sink	6:14
221.1-43	A-111 Left Near Window	Sink	6:16
221.1-44	A-111 Middle Near Window	Sink	6:17
221.1-45	A-111 Right Near Window	Sink	6:19
221.1-46	A-111 Near Fume Hood	Sink	6:20
221.1-47	A-123	Sink	6:22
221.1-48	A-123	Sink	6:23
221.1-49A	DF Near A-124	DF	6:25
221.1-49B	DFB Near A-124	DFB	6:26
221.1-50	A-127	Sink	6:28
221.1-51	A-127	Sink	6:29

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

mscinta@stohlenvironmental.com

Sampled By: Alexis Dellinger Print Name

Stohl Env: Alexis Dellinger

Date: 1/9/2026

Relinquished By: [Signature] Print Name

Stohl Env: Connor Crilly

Date: 1/8/26 8:45 AM

Received (Name / Lab): [Signature]

Date: 1/13/26

Time: 8:53

Sample Login (Name / Lab): _____

Date: _____

Time: _____

Analysis (Name / Lab): _____

Date: _____

Time: _____

QA/QC Review (Name / Lab): _____

Date: _____

Time: _____

Archived / Released: _____

QA/QC InterLAB Use: _____

Date: _____

Time: _____

Page 3 of 4

R2600462

5

Stohl Environmental
West Valley CSD





Chain of Custody Document

Submitted to: (Lab Name) ALS

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

STOHL Job # 2023L-221.1

Client: West Valley CSD

Contact: Zachary Schoepflin

Building: West Valley Central School

Location: 5359 School St

LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
221.1-52A	DF Near Girls Locker Room	DF	6:31
221.1-52B	DFB Near Girls Locker Room	DFB	6:32
221.1-53	A-200	Sink	6:34
221.1-54A	DF Near A-217	DF	6:35
221.1-54B	DFB Near A-217	DFB	6:37
221.1-55A	DF Near A-123	DF	6:38
221.1-55B	DFB Near A-123	DFB	6:40
221.1-56	A-210 Left	Sink	6:41
221.1-57	A-210 Right	Sink	6:43
221.1-58	Faculty Sink	Sink	6:44
221.1-59	Girls Locker Room DF	DF	6:46
221.1-60	Boys Locker Room DF	DF	6:47
221.1-61	Bus Garage Lav	Sink	6:49

Notes:

Please e-mail lab results to labs@stohlenv.com

mscinta@stohlenvironmental.com

Sampled By: Alexis Dellinger Print Name

Stohl Env: Alexis Dellinger

Date: 1/9/2026

Relinquished By: [Signature] Print Name

Stohl Env: Connor Crilly

Date: 1/13/26 8:45 AM

Received (Name / Lab): [Signature]

Date: 1/13/26

Time: 8:53

Sample Login (Name / Lab): _____

Date: _____

Time: _____

Analysis (Name / Lab): _____

Date: _____

Time: _____

QA/QC Review (Name / Lab): _____

Date: _____

Time: _____

Archived / Released: _____

QA/QC InterLAB Use: _____

Date: _____

Time: _____



Cooler Receipt and Preservation Check Form

R2600462

5

Stohl Environmental
West Valley CSD



Project/Client Stohl

Folder Number _____

Cooler received on 11/3/26

by: RM

COURIER: ALS UPS FEDEX VELOCITY (CLIENT)

1	Were Custody seals on outside of cooler?	Y <u>(N)</u>
2	Custody papers properly completed (ink, signed)?	<u>(Y)</u> N
3	Did all bottles arrive in good condition (unbroken)?	<u>(Y)</u> N
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>(N)</u>

5a	Did VOA vials have sig* bubbles?	Y N <u>(NA)</u>
5b	Sig* bubbles: Alk? Y N <u>(NA)</u> Sulfide? Y N <u>(NA)</u>	
6	Where did the bottles originate?	<u>(ALS/ROC)</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035set <u>(NA)</u>	

8. Temperature Readings Date: 11/3/26 Time: 9:00 ID: (IR#11) IR#12 IR#13 From: Temp Blank (Sample Bottle)

Temp (°C)	<u>10.9</u>						
Within 0-6°C?	Y <u>(N)</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: No ice Ice melted Poorly Packed (described below) Same Day Rule

& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: S/MO by RM on 11/3 at 9:00

5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 01/13/26 Time: 1123 by: cc

- Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES (NO)
- Did all bottle labels and tags agree with custody papers? YES (NO)
- Were correct containers used for the tests indicated? (YES) NO
- Were 5035 vials acceptable (no extra labels, not leaking)? YES NO (N/A)
- Were dissolved metals filtered in the field? YES NO (N/A)

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH	<u>cc</u>	<u>01132026</u>						
≤2	<u>202325</u>	HNO ₃	<u>X</u>	<u>✓</u>			<u>A11</u>	<u>4ml</u>	<u>245078</u>	<u>A11 < 2</u>
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 092225-2ADD, 092925-2ERG

Explain all Discrepancies/ Other Comments:

9/10) No bottle label

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: cc

*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

U	Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.	+	Correlation coefficient for MSA is <0.995.
J	Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).	N	Inorganics- Matrix spike recovery was outside laboratory limits.
B	Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.	N	Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
E	Inorganics- Concentration is estimated due to the serial dilution was outside control limits.	S	Concentration has been determined using Method of Standard Additions (MSA).
E	Organics- Concentration has exceeded the calibration range for that specific analysis.	W	Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
D	Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.	P	Concentration >40% difference between the two GC columns.
*	Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.	C	Confirmed by GC/MS
H	Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.	Q	DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
#	Spike was diluted out.	X	See Case Narrative for discussion.
		MRL	Method Reporting Limit. Also known as:
		LOQ	Limit of Quantitation (LOQ) The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
		MDL	Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
		LOD	Limit of Detection. A value at or above the MDL which has been verified to be detectable.
		ND	Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1

Service Request: R2600462

Sample Name: 221.1-36
Lab Code: R2600462-001
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-37
Lab Code: R2600462-002
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-38
Lab Code: R2600462-003
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-39A
Lab Code: R2600462-004
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-39B
Lab Code: R2600462-005
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1

Service Request: R2600462

Sample Name: 221.1-40
Lab Code: R2600462-006
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-41
Lab Code: R2600462-007
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-42
Lab Code: R2600462-008
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-43
Lab Code: R2600462-009
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-44
Lab Code: R2600462-010
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1

Service Request: R2600462

Sample Name: 221.1-45
Lab Code: R2600462-011
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-46
Lab Code: R2600462-012
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-47
Lab Code: R2600462-013
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-48
Lab Code: R2600462-014
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-49A
Lab Code: R2600462-015
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1

Service Request: R2600462

Sample Name: 221.1-49B
Lab Code: R2600462-016
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-50
Lab Code: R2600462-017
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-51
Lab Code: R2600462-018
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-52A
Lab Code: R2600462-019
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-52B
Lab Code: R2600462-020
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1

Service Request: R2600462

Sample Name: 221.1-53
Lab Code: R2600462-021
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-54A
Lab Code: R2600462-022
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-54B
Lab Code: R2600462-023
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-55A
Lab Code: R2600462-024
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-55B
Lab Code: R2600462-025
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1

Service Request: R2600462

Sample Name: 221.1-56
Lab Code: R2600462-026
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-57
Lab Code: R2600462-027
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-58
Lab Code: R2600462-028
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-59
Lab Code: R2600462-029
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

Sample Name: 221.1-60
Lab Code: R2600462-030
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1

Service Request: R2600462

Sample Name: 221.1-61
Lab Code: R2600462-031
Sample Matrix: Drinking Water

Date Collected: 01/9/26
Date Received: 01/13/26

Analysis Method
200.8

Extracted/Digested By

Analyzed By
DWINTER



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-36
Lab Code: R2600462-001

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 18:40	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-37
Lab Code: R2600462-002

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 18:41	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-38
Lab Code: R2600462-003

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 18:43	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-39A
Lab Code: R2600462-004

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 18:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-39B
Lab Code: R2600462-005

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 18:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-40
Lab Code: R2600462-006

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 18:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-41
Lab Code: R2600462-007

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 18:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-42
Lab Code: R2600462-008

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.4	ug/L	1.0	1	01/20/26 18:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-43
Lab Code: R2600462-009

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.4	ug/L	1.0	1	01/20/26 19:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-44
Lab Code: R2600462-010

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 19:06	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-45
Lab Code: R2600462-011

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 19:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-46
Lab Code: R2600462-012

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 19:09	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-47
Lab Code: R2600462-013

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 19:10	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-48
Lab Code: R2600462-014

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 19:12	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-49A
Lab Code: R2600462-015

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 19:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-49B
Lab Code: R2600462-016

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 19:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-50
Lab Code: R2600462-017

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 19:16	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-51
Lab Code: R2600462-018

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 19:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-52A
Lab Code: R2600462-019

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 19:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-52B
Lab Code: R2600462-020

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 19:23	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-53
Lab Code: R2600462-021

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.7	ug/L	1.0	1	01/20/26 19:24	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-54A
Lab Code: R2600462-022

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 19:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-54B
Lab Code: R2600462-023

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 19:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-55A
Lab Code: R2600462-024

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 19:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-55B
Lab Code: R2600462-025

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 19:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-56
Lab Code: R2600462-026

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	39.9	ug/L	1.0	1	01/20/26 19:31	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-57
Lab Code: R2600462-027

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.4	ug/L	1.0	1	01/20/26 19:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-58
Lab Code: R2600462-028

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/23/26 13:52	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-59
Lab Code: R2600462-029

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	13.2	ug/L	1.0	1	01/23/26 13:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-60
Lab Code: R2600462-030

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/23/26 14:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: 221.1-61
Lab Code: R2600462-031

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26 08:53
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	01/27/26 15:39	



QC Summary Forms

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2600462-MB1

Service Request: R2600462
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 18:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2600462-MB2

Service Request: R2600462
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/20/26 18:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2600462-MB3

Service Request: R2600462
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/23/26 13:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2600462-MB4

Service Request: R2600462
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/23/26 13:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2600462-MB5

Service Request: R2600462
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	01/27/26 15:36	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26
Date Analyzed: 01/20/26

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 221.1-41
Lab Code: R2600462-007
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2600462-007MS		Result	Duplicate Matrix Spike R2600462-007DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	20.4	20.0	102	20.0	20.0	100	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26
Date Analyzed: 01/20/26

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 221.1-42
Lab Code: R2600462-008
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Matrix Spike R2600462-008MS				Duplicate Matrix Spike R2600462-008DMS				RPD Limit
		Result	Spike Amount	% Rec	Result	Spike Amount	% Rec	% Rec Limits	RPD	
Lead, Total	6.4	26.2	20.0	99	26.4	20.0	100	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26
Date Analyzed: 01/20/26

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 221.1-57
Lab Code: R2600462-027
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike		Result	Duplicate Matrix Spike		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	3.4	24.7	20.0	106	23.6	20.0	101	70-130	4	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26
Date Analyzed: 01/23/26

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 221.1-59
Lab Code: R2600462-029
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result		Matrix Spike		Result	Duplicate Matrix Spike		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
			R2600462-029MS			R2600462-029DMS				
Lead, Total	13.2	33.8	20.0	103	29.4	20.0	81	70-130	14	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26
Date Analyzed: 01/23/26

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 221.1-60
Lab Code: R2600462-030
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike		Result	Duplicate Matrix Spike		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	20.8	20.0	104	20.3	20.0	102	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water

Service Request: R2600462
Date Collected: 01/09/26
Date Received: 01/13/26
Date Analyzed: 01/27/26

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 221.1-61
Lab Code: R2600462-031
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2600462-031MS		Result	Duplicate Matrix Spike R2600462-031DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.1	21.9	20.0	104	22.4	20.0	106	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water

Service Request: R2600462

Date Analyzed: 01/20/26

Lab Control Sample Summary

Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample

R2600462-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.9	20.0	110	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water

Service Request: R2600462
Date Analyzed: 01/20/26

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2600462-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.6	20.0	103	85-115

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water

Service Request: R2600462

Date Analyzed: 01/23/26

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample

R2600462-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.8	20.0	104	85-115

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water

Service Request: R2600462

Date Analyzed: 01/23/26

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample

R2600462-LCS4

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	19.9	20.0	100	85-115

Client: Stohl Environmental
Project: West Valley CSD/2023L-221.1
Sample Matrix: Drinking Water

Service Request: R2600462
Date Analyzed: 01/27/26

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2600462-LCS5

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.7	20.0	109	85-115

1.5 Laboratory Certifications

**NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER**



Expires 12:01 AM April 01, 2026
Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE
Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. CHRISTINE KUTZER
ALS ENVIRONMENTAL - ROCHESTER
1565 JEFFERSON ROAD BUILDING 300, SUITE 360
ROCHESTER, NY 14623

NY Lab Id No: 10145

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Bacteriology	
Coliform, Total / E. coli (Qualitative)	SM 20, 21-23 9223B (-04) (Colilert)
Dissolved Gases	
Acetylene	RSK-175
Ethane	RSK-175
Ethene (Ethylene)	RSK-175
Methane	RSK-175
Propane	RSK-175
Fuel Additives	
Methyl tert-butyl ether	EPA 524.2
Naphthalene	EPA 524.2
Metals I	
Arsenic, Total	EPA 200.8 Rev. 5.4
Barium, Total	EPA 200.8 Rev. 5.4
Cadmium, Total	EPA 200.8 Rev. 5.4
Chromium, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Iron, Total	EPA 200.7 Rev. 4.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Mercury, Total	EPA 245.1 Rev. 3.0
Selenium, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Zinc, Total	EPA 200.7 Rev. 4.4

Serial No.: 70111

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-5570 or by email to elap@health.ny.gov.

Page 1 of 5

