

CENTER GROVE COMMUNITY SCHOOL CORPORATION

www.centergrove.k12.in.us



April 23, 2026

Subject: Response to Indoor Air Quality Evaluation – Center Grove High School

Dear Mr. Clark,

Thank you for your letter dated April 21, 2026, regarding the indoor air quality evaluation conducted at Center Grove High School on April 13, 2026. We appreciate the thorough assessment and the guidance provided.

In response to the findings outlined in your report, we have taken and/or initiated the following actions:

Carbon Dioxide Levels

Our facilities team has inspected the HVAC systems serving the third-floor area by locker 3351. We have increased the outdoor air intake and will continue to monitor to ensure proper ventilation in adjacent classrooms.

Active Water Leak (Hallway by Room 520)

The identified leak has been addressed. Maintenance staff repaired the source of the intrusion within the required 48-hour window. Any remaining moisture-damage materials in the area are being assessed and will be replaced as necessary to prevent further issues.

Stained Ceiling Tiles

Following the correction of leaks, we have begun replacing stained ceiling tiles throughout the building. This will allow for better monitoring of any future water intrusion and ensure a clean and safe environment.

Additionally, we have reviewed humidity levels and confirmed that they remain within recommended guidelines. We will continue to monitor indoor environmental conditions to maintain a healthy setting for students and staff.

In compliance with 410 IAC 33-6-2, this report has been posted at Center Grove High School and on our website within the required timeframe and will remain posted for 14 days. This response will also be posted accordingly. The relevant webpage links are provided below:

<https://www.centergrove.k12.in.us/district/facilities/facility-testing>

CENTER GROVE COMMUNITY SCHOOL CORPORATION

www.centergrove.k12.in.us



We are committed to maintaining a safe and healthy environment for all students, staff, and visitors. Please feel free to contact us if you require additional information or wish to schedule a follow-up review.

Sincerely,

A handwritten signature in black ink, appearing to read "Dr. Taylor", is written over a large, stylized, light-colored mark that resembles a large "J" or a stylized "T".

Dr. Jason R. Taylor
Associate Superintendent
Center Grove Community School Corporation
4800 West Stones Crossing Road
Greenwood, IN 46143
(317) 881-9326