

RFP No. 25-26-001A Fire Science Building Upgrades

QUESTIONS AND RESPONSES

APRIL 27, 2026

1. **Please confirm the required number of proposal copies to be submitted for this project.**

Response: *Please submit one(1) original and two (2) proposal copies and one(1) electronic version (i.e. USB or CD).*

2. **Is there a requirement for a wet pipe fire sprinkler system?**

Response: *No. We will not provide a sprinkler system. We will just add smoke detectors to the new created areas and tie to the existing system.*

3. **Could you please clarify if we are permitted to use a comparable model from a different manufacturer, or if the specification must remain strictly with Trane?**

Response: *In Section 238126 Split System Air Conditioners, Trane is listed but so is Carrier, Lennox, York. The specification does not remain strictly with Trane.*