

Ann Arbor Public Schools
District Wide Investigation
Results Table 2025



ANN ARBOR PUBLIC SCHOOLS
Drinking Water Analysis
Project Number: AE250030

Site:	Abbot Elementary School							
Type of Sampling:	Investigative Initial First Draw (IFD) Lead							
Date of Sampling:	4/18/2025							
Sampler(s):	Brooklyn Bellhorn							
Sample #	Location	Fixture Type	MI Drinking Water Access Act 154 Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present? <i>Yes or No</i>	POU Filter Present? <i>Yes or No</i>	Filter Date/ Hydration Station Filter Indicator Color	Notes
Abbot-10	Room D-4, Stainless Glass Filler	Glass Filler	Zero	Non-Detect	No	Y	4/11/2025	
Abbot-19	Room C-10, Combination Sink, Glass Filler	Combination Sink Glass Filler	Zero	Non-Detect	No	Y	4/11/2025	



ANN ARBOR PUBLIC SCHOOLS
Drinking Water Analysis
Project Number: AE250030

Site:	Angell Elementary School							
Type of Sampling:	Investigative Initial First Draw (IFD) Lead							
Date of Sampling:	7/15/2025							
Sampler(s):	Alexander Gonzalez							
Sample #	Location	Fixture Type	MI Drinking Water Access Act 154 Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present? <i>Yes or No</i>	POU Filter Present? <i>Yes or No</i>	Filter Date/ Hydration Station Filter Indicator Color	Notes
Angell-05	Floor 1, Kitchen, 3-Compartment Sink, Add On Faucet, Far Right	Kitchen Faucet	Zero	7	Yes	Y	5/25/2025	
Angell-38	Floor 1, Staff Lounge, Combination Sink, Glass Filler	Combination Sink Glass Filler	Zero	2	Yes	Y	5/27/2025	
Angell-40	Floor 1, Cafeteria, Hydration Station, Bubbler	Hydration Station	Zero	Non-Detect	Yes	Y	Green	



ANN ARBOR PUBLIC SCHOOLS
Drinking Water Analysis
Project Number: AE250030

Site:	Angell Elementary School							
Type of Sampling:	Investigative Initial First Draw (IFD) Lead							
Date of Sampling:	8/22/2025							
Sampler(s):	Brooklyn Bellhorn							
Sample #	Location	Fixture Type	MI Drinking Water Access Act 154 Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present? <i>Yes or No</i>	POU Filter Present? <i>Yes or No</i>	Filter Date/ Hydration Station Filter Indicator Color	Notes
Angell-05	Floor 1, Kitchen, 3-Compartment Sink, Add On Faucet, Far Right	Kitchen Faucet	Zero	Non-Detect	Yes	Y	5/25/2025	
Angell-38	Floor 1, Staff Lounge, Combination Sink, Glass Filler	Combination Sink Glass Filler	Zero	2	Yes	Y	5/27/2025	



ANN ARBOR PUBLIC SCHOOLS
Drinking Water Analysis
Project Number: AE250030

Site:	Bach Elementary School							
Type of Sampling:	Investigative Initial First Draw (IFD) Lead							
Date of Sampling:	4/18/2025							
Sampler(s):	Brooklyn Bellhorn							
Sample #	Location	Fixture Type	MI Drinking Water Access Act 154 Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present? <i>Yes or No</i>	POU Filter Present? <i>Yes or No</i>	Filter Date/ Hydration Station Filter Indicator Color	Notes
Bach-22	Floor 1, Kitchen, 3-Compartment Sink, Far Left Faucet	Kitchen Faucet	Zero	Non-Detect	Yes	Y	4/11/2025	



ANN ARBOR PUBLIC SCHOOLS
Drinking Water Analysis
Project Number: AE250030

Site:	Bryant Elementary School							
Type of Sampling:	Investigative Initial First Draw (IFD) Lead							
Date of Sampling:	5/3/2025 & 5/10/2025							
Sampler(s):	Alex Gonzalez							
Sample #	Location	Fixture Type	MI Drinking Water Access Act 154 Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present? <i>Yes or No</i>	POU Filter Present? <i>Yes or No</i>	Filter Date/ Hydration Station Filter Indicator Color	Notes
Bryant-02	Teachers Lounge/Clinic, Combination Sink, Glass Filler	Combination Sink Glass Filler	Zero	Non-Detect	Yes	Y	4/18/2025	
Bryant-16	Room 216, Combination Sink, Glass Filler	Combination Sink Glass Filler	Zero	Non-Detect	Yes	Y	4/18/2025	
Bryant-17	Room 207, Combination Sink, Glass Filler	Combination Sink Glass Filler	Zero	Non-Detect	Yes	Y	4/18/2025	
Bryant-18	Room 205, Combination Sink, Glass Filler	Combination Sink Glass Filler	Zero	Non-Detect	Yes	Y	4/18/2025	



ANN ARBOR PUBLIC SCHOOLS
Drinking Water Analysis
Project Number: AE250030

Site:	Clague Middle School							
Type of Sampling:	Investigative Initial First Draw (IFD) Lead							
Date of Sampling:	04/18/2025							
Sampler(s):	Brooklyn Bellhorn							
Sample #	Location	Fixture Type	MI Drinking Water Access Act 154 Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present? <i>Yes or No</i>	POU Filter Present? <i>Yes or No</i>	Filter Date/ Hydration Station Filter Indicator Color	Notes
Clague-48	Floor 1, Clinic, Combination Sink, Glass Filler	Combination Sink	Zero	Non-Detect	No	Yes	4/11/2025	
Clague-46	Floor 1, Media Center Work Room, Faucet	Faucet	Zero	Non-Detect	Yes	No	None	



ANN ARBOR PUBLIC SCHOOLS
Drinking Water Analysis
Project Number: AE250030(A)

Site:	Freeman Environmental Center							
Type of Sampling:	Investigative Initial First Draw (IFD) Lead							
Date of Sampling:	4/18/2025							
Sampler(s):	Brooklyn Bellhorn							
Sample #	Location	Fixture Type	MI Drinking Water Access Act 154 Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present? <i>Yes or No</i>	POU Filter Present? <i>Yes or No</i>	Filter Date/ Hydration Station Filter Indicator Color	Notes
Freeman-02	Kitchen Sink, Faucet	Kitchen Sink	Zero	Non-Detect	Yes	Yes	4/11/2025	
Freeman-06	Studio, Room 14, Far West Sink of Set of Five, Faucet	Faucet	Zero	1	Yes	Yes	4/14/2025	



ANN ARBOR PUBLIC SCHOOLS
Drinking Water Analysis
Project Number: AE250030

Site:	Freeman Environmental Center							
Type of Sampling:	Investigative Initial First Draw (IFD) Lead							
Date of Sampling:	7/15/2025							
Sampler(s):	Alexander Gonzalez							
Sample #	Location	Fixture Type	MI Drinking Water Access Act 154 Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present? <i>Yes or No</i>	POU Filter Present? <i>Yes or No</i>	Filter Date/ Hydration Station Filter Indicator Color	Notes
Freeman-06	Studio, Room 14, Far West Sink of Set of Five, Faucet	Faucet	Zero	1	Yes	Yes	4/14/2025	



ANN ARBOR PUBLIC SCHOOLS
Drinking Water Analysis
Project Number: AE250030(A)

Site:	Freeman Environmental Center							
Type of Sampling:	Investigative Initial First Draw (IFD) Lead							
Date of Sampling:	8/22/2025							
Sampler(s):	Brooklyn Bellhorn							
Sample #	Location	Fixture Type	MI Drinking Water Access Act 154 Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present? <i>Yes or No</i>	POU Filter Present? <i>Yes or No</i>	Filter Date/ Hydration Station Filter Indicator Color	Notes
Freeman-06	Studio, Room 14, Far West Sink of Set of Five, Faucet	Faucet	Zero	1	Yes	Yes	4/14/2025	



ANN ARBOR PUBLIC SCHOOLS
Drinking Water Analysis
Project Number: AE250030

Site:	Huron High School							
Type of Sampling:	Investigative Initial First Draw (IFD) Lead							
Date of Sampling:	12/22/2025							
Sampler(s):	Aaron Hutka							
Sample #	Location	Fixture Type	MI Drinking Water Access Act 154 Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present? <i>Yes or No</i>	POU Filter Present? <i>Yes or No</i>	Filter Date/ Hydration Station Filter Indicator Color	Notes
Huron-25	Cafeteria, East , Outside Service Area, Single Hydration Station, Bubbler	Hydration Station	Zero	1	Yes	Yes	Green	
Huron-40	Floor 2, Northwest Wing, Room Between Room 2201 and Room 2200, Green House, 2-Compartment Sink, Faucet	Faucet	Zero	1	Yes	Yes	8/13/2025	



ANN ARBOR PUBLIC SCHOOLS
Drinking Water Analysis
Project Number: AE250030(A)

Site:	Logan Elementary School							
Type of Sampling:	Investigative Initial First Draw (IFD) Lead							
Date of Sampling:	4/18/2025 and 4/26/2025							
Sampler(s):	Brooklyn Bellhorn and Chris McCallum							
Sample #	Location	Fixture Type	MI Drinking Water Access Act 154 Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present? <i>Yes or No</i>	POU Filter Present? <i>Yes or No</i>	Filter Date/ Hydration Station Filter Indicator Color	Notes
Logan ES-33	Room 233, Combination Sink, Glass Filler	Glass Filler	Zero	Non-Detect	Yes	Yes	4/2/2024	
Logan ES-45	Room 250, Combination Sink, Glass Filler	Glass Filler	Zero	Non-Detect	Yes	Yes	4/11/2025	

*Non-Detect: Result was non detected at Reported Detection Limit of 1 ug/L



ANN ARBOR PUBLIC SCHOOLS
Drinking Water Analysis
Project Number: AE250030(A)

Site:	Pioneer High School							
Type of Sampling:	Investigative Initial First Draw (IFD) Lead							
Date of Sampling:	07/15/2025							
Sampler(s):	Brooklyn Bellhorn							
Sample #	Location	Fixture Type	MI Drinking Water Access Act 154 Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present? <i>Yes or No</i>	POU Filter Present? <i>Yes or No</i>	Filter Date/ Hydration Station Filter Indicator Color	Notes
Pioneer-77	Outbuilding, Room 123, East Concessions, 3-Comp Right Faucet	Kitchen sink	Zero	1	No	Yes	None	



ANN ARBOR PUBLIC SCHOOLS
Drinking Water Analysis
Project Number: AE250030(A)

Site:	Pioneer High School							
Type of Sampling:	Investigative Initial First Draw (IFD) Lead							
Date of Sampling:	08/22/2025							
Sampler(s):	Brooklyn Bellhorn							
Sample #	Location	Fixture Type	MI Drinking Water Access Act 154 Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present? <i>Yes or No</i>	POU Filter Present? <i>Yes or No</i>	Filter Date/ Hydration Station Filter Indicator Color	Notes
Pioneer-77	Outbuilding, Room 123, East Concessions, 3-Comp Right Faucet	Kitchen sink	Zero	Non-Detect	No	Yes	None	

*Non-Detect: Result was non detected at Reported Detection Limit of 1 ug/L



ANN ARBOR PUBLIC SCHOOLS
Drinking Water Analysis
Project Number: AE250030

Site:	Skyline High School							
Type of Sampling:	Initial First Draw (IFD) Lead							
Date of Sampling:	08/22/25							
Sampler(s):	Brooklyn Bellhorn							
Sample #	Location	Fixture Type	MI Drinking Water Access Act 154 Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present? <i>Yes or No</i>	POU Filter Present? <i>Yes or No</i>	Filter Date/ Hydration Station Filter Indicator Color	Notes
Skyline-20	Floor 1, Greenroom, Kitchen Faucet	Faucet	Zero	7	Yes	Yes	None	
Skyline-42	Floor 2, Kitchen, North Wall, 3-Compartment Sink, Single Add On Faucet, Far Left Faucet, Kitchen Faucet	Faucet	Zero	Non-Detect	Yes	Yes	7/22/2025	

*Non-Detect: Result was non detected at Reported Detection Limit of 1 ug/L



ANN ARBOR PUBLIC SCHOOLS
Drinking Water Analysis
Project Number: AE250030(A)

Site:	STEAM at Northside School							
Type of Sampling:	Investigative Initial First Draw (IFD) Lead							
Date of Sampling:	5/3/2025							
Sampler(s):	Garrett Pilachowski							
Sample #	Location	Fixture Type	MI Drinking Water Access Act 154 Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present? <i>Yes or No</i>	POU Filter Present? <i>Yes or No</i>	Filter Date/ Hydration Station Filter Indicator Color	Notes
STEAM - 48	First Floor, Room 302, Combination Sink, Glass Filler	Combination Sink Glass Filler	Zero	1	Yes	Yes	4/29/2025	

*Non-Detect: Result was non detected at Reported Detection Limit of 1 ug/L



ANN ARBOR PUBLIC SCHOOLS
Drinking Water Analysis
Project Number: AE250030(A)

Site:	STEAM at Northside School							
Type of Sampling:	Investigative Initial First Draw (IFD) Lead							
Date of Sampling:	8/22/2025							
Sampler(s):	Brooklyn Bellhorn							
Sample #	Location	Fixture Type	MI Drinking Water Access Act 154 Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present? <i>Yes or No</i>	POU Filter Present? <i>Yes or No</i>	Filter Date/ Hydration Station Filter Indicator Color	Notes
STEAM - 48	First Floor, Room 302, Combination Sink, Glass Filler	Combination Sink Glass Filler	Zero	3	Yes	Yes	7/9/2025	



ANN ARBOR PUBLIC SCHOOLS
Drinking Water Analysis
Project Number: AE250030(A)

Site:	Thurston Elementary School							
Type of Sampling:	Investigative Initial First Draw (IFD) Lead							
Date of Sampling:	05/03/2025							
Sampler(s):	Garrett Pilachowski							
Sample #	Location	Fixture Type	MI Drinking Water Access Act 154 Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present? <i>Yes or No</i>	POU Filter Present? <i>Yes or No</i>	Filter Date/ Hydration Station Filter Indicator Color	Notes
Thurston-09	Room 4, Combination Sink, Glass Filler	Combination Sink	Zero	Non-Detect	Yes	Yes	5/1/2025	