

Measure C Bond Office

May 1, 2026

To: All Bidders

From: Sandra Lovaas, Measure C Bond Manager
Pleasant Valley School District

Subject: Addendum 1, **Bid FB-26-16, Landscape Improvements, Las Colinas Middle School, 5750 Fieldcrest Dr, Camarillo, 93012**

This addendum is hereby made a part of the Contract Documents for **Bid FB-26-06, Parking Lot Pavement and ADA Pathway Replacement Project, Las Colinas Middle School** to the same extent as though it was originally included therein and takes precedence over the original documents.

Receipt of this addendum should be acknowledged on the Bid Form.

Answers the following submitted RFI:

As discussed at the job walk we were notified that the paving will be installed first. Would it be possible to request that the demo/removals and the planting of the 36" box trees be done first before the paving is complete? This will help mitigate any damage with using equipment on the new paving for the demo & tree planting. We can return after the paving to install the irrigation, planting and sod.

The District is not able to revise project schedule to allow demo/removals or planting of box trees prior to parking lot paving project. Landscape contractor will be responsible to protect in place all existing site conditions.

Revises Specification Section 32 01 90 Tree Removals and Pruning, 1.03 Qualifications
See Attachment



Pleasant Valley School District

600 Temple Avenue • Camarillo, CA 93010 • (805) 389-2100 (Office) • www.pleasantvalleysd.org
PVSD prepares 21st century learners who are responsible members of our global society.

ADDENDUM NO. 1

Date: April 28, 2026

Issued By: Jordan & Bain Landscape Architects, Inc.
459 North Ventura Avenue, Ventura, California 93001
(805) 642-3641 Phone; (805) 653-7874 Fax

Project: Las Colinas Middle School Landscape Renovation
Camarillo, California

Issued To: Pleasant Valley School District
For Review and Distribution

This Addendum forms a part of the Contract Documents and modifies the original Contract Documents as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Changes are indicated as Delta 1, dated April 28, 2026.

This Addendum consists of one (1) page.

A. Specifications

1. Section 32 01 90 Tree Removals and Pruning; 1.03 Qualifications – Tree Removal Contractor shall be either a C-61/D49 or a C-27 Landscape Contractor. General Engineering ‘A’ Contractors must hire either a C-61/D49 or C-27 as a Subcontractor to remove trees and stump grind stumps and roots to 12” below grade.