

**Districtwide Lead in Drinking Water
Sampling and Remediation Plan for 2026-2028 Compliance.**

Pelham UFSD

April 2026

Enviroscience Project #27674



2150 Smithtown Ave., Suite 3, Ronkonkoma, NY 11779

T: 631.580.3191 • **F:** 631.580.3195 • **W:** envirohealth.org

DISTRICTWIDE LEAD IN DRINKING WATER SAMPLING AND REMEDIATION PLAN

2026-2028

APRIL 2026

ENVIROSCIENCE PROJECT #27674

Prepared for: PELHAM UFSD
575 Colonial Avenue
Pelham, New York 10803

Prepared by: ENVIROSCIENCE CONSULTANTS, LLC
2150 Smithtown Avenue
Ronkonkoma, New York 11779
(631) 580-3191

Project Manager: 
Casey Lee

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>
1.0	Executive Summary
2.0	Sampling Methodology
3.0	Initial Results

Appendices

Appendix A	Colonial Elementary School
Appendix B	Hutchinson Elementary School
Appendix C	Prospect Hill Elementary School
Appendix D	Siwanoy Elementary School
Appendix E	Pelham Middle School
Appendix F	Pelham Memorial High School
Appendix G	Glover Field
Appendix H	Business Office – 314 Pelhamdale

1.0 EXECUTIVE SUMMARY

The Pelham UFSD has developed their Lead in Drinking Water Sampling and Remediation Plan for the 2026-2028 compliance period, as required by the New York State Department of Health (Public Health Law Sections 1370-a and 1110, Subpart 67-4 Lead Testing in School Drinking Water).

In accordance with the regulation, this Lead Remediation Plan is prepared to identify locations deemed as Applicable Drinking Water Sources and report first draw sample results, to mitigate locations where sample results exceed 5 parts per billion, to identify locations deemed as Non-Applicable Water Sources, communicate this designation to building occupants, and to develop strategies for monitoring locations deemed Non-Applicable Water Sources to ensure building occupants do not consume water from these locations.

The following locations within the Pelham UFSD buildings have been deemed Applicable Drinking Water Sources by the administration:

- 1) Water fountains and bottle filling stations;
- 2) Kitchen water faucets and pot fillers used in food preparation;
- 3) Ice machines
- 4) Home Economics classroom sinks
- 5) Kindergarten Bathroom sinks
- 6) Nurse's Office and Faculty Room sinks

First draw samples were collected from each of these locations within the district and analyzed by a New York State Department of Health ELAP certified laboratory. The chains of custody are available upon request. For results at or below 5 ppb, no further action is required until the 2029-2031 compliance period. For locations above 5 ppb, options include: second and third draw sample collection to determine source of lead, designation of the location as Non-Applicable Water Source, or permanent removal of the fixture from the location. In either case, the result was communicated by Enviroscience Consultants, and the fixture was shut off by the district immediately upon receipt of results.

The following locations within the Pelham UFSD buildings were deemed Non-Applicable Water Sources by the administration:

- 1) Science Laboratory sinks
- 2) Art Room sinks
- 3) Technical Classroom sinks
- 4) Other Classroom sinks
- 5) Student & Adult Bathroom sinks
- 6) Outside spigots not used for sports or gardening
- 7) Custodial Closet sinks
- 8) Mixed Valve sinks (or hot only)
- 9) Coach's Office and Locker Room Showers

In these cases, the Pelham UFSD staff have placed signs adjacent to the fixture to notify occupants that the water is not intended for consumption. To further support this protocol, the following management of the locations is required:

- 1) Science Laboratory sinks - communicate in writing with students that these locations are for science experiments and hand washing only, not for consumption. This is most easily accomplished by including this language in the laboratory safety paperwork distributed to students at the beginning of the school year. This program should be monitored by the respective science teachers, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 2) Art Room sinks - communicate in writing to students that these locations are for cleaning of art supplies and hand washing only, not for consumption. This is most easily accomplished by including this language in the course paperwork distributed to students at the beginning of the school year. This program should be monitored by the respective art teachers, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 3) Technical Classroom sinks - classrooms in this category often include wood shop or auto mechanics classrooms, where students are to hand wash after bathroom usage or activities as part of a regular hygiene program. This program should be monitored by teachers and staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.

- 4) Other Classroom sinks - classrooms in this category often include elementary classrooms, where students are to hand wash after bathroom usage or activities as part of a regular hygiene program. This program should be monitored by teachers and staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 5) Bathroom sinks - in intermediate buildings, signage should be sufficient for communicating the concept of hand washing only. In elementary schools, if signs are to be posted, then personal hygiene should be integrated into curriculum to ensure students understand bathroom sinks are for hand washing only, and not consumption. Further, show what the signage looks like in bathrooms, so they learn to recognize its meaning. This program should be monitored by teachers and staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 6) Outside spigots - all-weather signage and or a key operated fixture should be installed at each location. Further, spigots will have a special key maintained by the custodial staff to ensure that non-authorized persons do not fill sports coolers or use hoses for consumption. This program should be monitored by custodial staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 7) Custodial Closet sinks - these locations should be accessed by custodial personnel only and locked when not in use. Access to others should be restricted. This program should be monitored by custodial staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 8) Mixed Valve sinks (or hot only) – per Public Health Law Sections 1370-a and 1110, Subpart 67-4 Lead Testing in School Drinking Water mixed valve or hot water only sources are not required to be sampled. Signage is required for these sources. Signage should be sufficient for communicating the concept of hand washing only. In elementary schools, personal hygiene should be integrated into curriculum to ensure students understand bathroom sinks are for hand washing only, and not consumption. Further, show what the signage looks like so they learn to recognize its meaning. This

program should be monitored by teachers and staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.

- 9) Showers – Signs should be posted upon the entrance of the shower where easily seen. Further, an effort should be made to limit potential water damage. Staff should inspect the condition of signs regularly.

All locations deemed Non-Applicable, but do not have signs, should be taken offline until signs have been posted. Signs are suggested to have pictures that instruct for handwashing only, do not drink.

2.0 SAMPLING METHODOLOGY

In accordance with the regulation, Enviroscience Consultants, LLC performed initial water sampling at the Pelham UFSD buildings on April 7th & 8th, 2026. Samples were collected in wide-mouth 250 milliliter containers and were collected in the morning hours before the facilities opened. The water sources were not used for at least 8 hours and not more than 18 hours prior to sampling. Unique source numbers and designations were assigned to each source location. Unique sample identification numbers were assigned to each sample taken. The key to fixture type codes and source designations are shown below.

Code Key for Lead in Water					
Fixture Type Codes					
BF	Bottle Filler	SK	Sink	SS	Slop Sink
HB	Hose Bib	SL	Supply Line	V	Valve
IM	Ice Machine	SP	Spigot	WC	Water Cooler
OS	Other Source	SPY	Spray	WF	Water Fountain
PF	Pot Filler				
Source Designations					
App	Applicable	N/A	Non-Applicable		

3.0 INITIAL RESULTS

All water source locations in each of the school buildings were assessed. Water source locations identified as drinking water sources were considered Applicable, and first draw samples were collected. Water source locations identified as non-drinking water sources were considered Non-Applicable, and these locations were documented.

The results of the initial sampling and the use of signs warning against water use at Non-Applicable sources is documented in the School Water Outlet Inventory for each building.

All elevated locations should be taken off line until the remediation is completed. Any other drinking water sources in these buildings that were not functional at the time of initial sampling and have not been tested should be tested before returning to service. All locations deemed Non-Applicable, but do not have signs, should be taken offline until signs have been posted. Signs are suggested to have pictures that instruct for handwashing only, do not drink.

The following is a summary of results in parts per billion (ppb) of locations in the Pelham UFSD where first-draw sample results were found above 5 ppb:

Colonial Elementary School			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
No Exceedances			

Hutchinson Elementary School			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Kitchen Pot Filler by Stove	15.0 ppb	4/8/26	Removed from service; Pending remediation
Classroom 208 Bubbler Fountain	6.0 ppb	4/8/26	Removed from service; Pending remediation
Classroom 206 Bubbler Fountain	23.0 ppb	4/8/26	Removed from service; Pending remediation
Classroom 213 Bubbler Fountain	33.0 ppb	4/8/26	Removed from service; Pending remediation

Prospect Hill Elementary School

SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Kitchen 2-Bay Sink	16.0 ppb	4/8/26	Removed from service; Pending remediation
Faculty Room Kitchenette Sink	8.0 ppb	4/8/26	Removed from service; Pending remediation

Siwanoy Elementary School

SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
No Exceedances			

Pelham Middle School

SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Science Prep Room 266/262 Ice Machine Water Dispenser	79.0 ppb	4/7/26	Removed from service; Pending remediation
Room 278C Library Office Classroom Sink	11.0 ppb	4/7/26	Removed from service; Pending remediation

Pelham Memorial High School

SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Hall by Room 202 Water Fountain	6.0 ppb	4/7/26	Removed from service; Pending remediation

Glover Field			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Boy's Locker Room Slop Sink	7.0 ppb	4/7/26	Removed from service; Pending remediation
Exterior by Locker Rooms – Right Water Fountain	7.0 ppb	4/7/26	Removed from service; Pending remediation

Business Office – 314 Pelhamdale			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
No Exceedances			

Appendix A

Colonial Elementary School

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0001-01	Classroom 016	SK	N/A		4/8/2026				Mixed Valve; Sign
0002-01	Teacher's Lounge 007	SK	App	2.0	4/8/2026				-
0002-02	Teacher's Lounge 007	SP	N/A		4/8/2026				Removed from Service
0003-01	Boy's Bathroom 006	SK	N/A		4/8/2026				Mixed Valve; Sign
0004-01	Hall by Boy's Bathroom 006	WF	App	<1.0	4/8/2026				-
0004-02	Hall by Boy's Bathroom 006	BF	App	<1.0	4/8/2026				-
0005-01	Girl's Bathroom 005	SK	N/A		4/8/2026				Mixed Valve; Sign
0006-01	Serving Room 2-Bay	SK	App	<1.0	4/8/2026				-
0007-01	Art Room 002	SK	N/A		4/8/2026				Sign
1001-01	Classroom 103	SK	N/A		4/8/2026				Sign
1002-01	Classroom 104	SK	N/A		4/8/2026				Sign
1003-01	Classroom 105	SK	N/A		4/8/2026				Sign
1004-01	Classroom 107	SK	N/A		4/8/2026				Sign
1005-01	Principle's Office Bathroom	SK	N/A		4/8/2026				Mixed Valve; Sign
1006-01	Custodial Closet 018	SS	N/A		4/8/2026				Sign
1007-01	Hall by 107	WF	App	<1.0	4/8/2026				-
1007-02	Hall by 107	BF	App	<1.0	4/8/2026				-
2001-01	Hall by 207	WF	App	<1.0	4/8/2026				-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2001-02	Hall by 207	BF	App	<1.0	4/8/2026				-
2002-01	Nurse's Office	SK	App	2.0	4/8/2026				-
2003-01	Classroom 208	SK	N/A		4/8/2026				Sign
2004-01	Classroom 207	SK	N/A		4/8/2026				Sign
2005-01	Classroom 209	SK	N/A		4/8/2026				Sign
2006-01	Classroom 206	SK	N/A		4/8/2026				Sign
2007-01	Classroom 211	SK	N/A		4/8/2026				Sign
2008-01	Classroom 205	SK	N/A		4/8/2026				Sign
2009-01	Classroom 204	SK	N/A		4/8/2026				Sign
2010-01	Girl's Bathroom 210 - Left	SK	N/A		4/8/2026				Mixed Valve; Sign
2010-02	Girl's Bathroom 210 - Right	SK	N/A		4/8/2026				Sign
2011-01	Boy's Bathroom 201 - Left	SK	N/A		4/8/2026				Mixed Valve; Sign
2011-02	Boy's Bathroom 201 - Right	SK	N/A		4/8/2026				Mixed Valve; Sign

Laboratory Report

April 10, 2026

Casey Lee
Enviroscience Consultants, Inc.
2150 Smithtown Ave.
Ronkonkoma, NY, 11779


Project: Pelham UFSD (Colonial School)
Project Address: Colonial School
Report ID: 260408004
Sample IDs: 260408004-125 - 260408004-133

New York Environmental is a NELAC accredited laboratory. Attached reported results meet the requirements of the NELAC standard unless otherwise noted.

Samples' analytical results relate only to the parameters tested for the samples received in the condition received by the laboratory, as noted on the Chain of Custody. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	8-Apr-26
Date Received:	8-Apr-26
Date Analyzed:	9-Apr-26

Analytical Method:	EPA 200.9
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
260408004-125	1	Teacher's Lounge Room 007 - SK; initial	0.001	0.002	mg/L	
260408004-126	2	Hall by Boy's Bathroom 006 - WF; initial	0.001	<0.001	mg/L	
260408004-127	3	Hall by Boy's Bathroom 006 - BF; initial	0.001	<0.001	mg/L	
260408004-128	4	Serving Room 2- Bay - SK; initial	0.001	<0.001	mg/L	
260408004-129	5	Hall by 107 - WF; initial	0.001	<0.001	mg/L	
260408004-130	6	Hall by 107 - BF; initial	0.001	<0.001	mg/L	
260408004-131	7	Hall by 207 - WF; initial	0.001	<0.001	mg/L	
260408004-132	8	Hall by 207 - BF; initial	0.001	<0.001	mg/L	
260408004-133	9	Nurse's Office - SK; initial	0.001	0.002	mg/L	

Comment(s):

LOQ: Limit of Quantitation
 CID: Client ID



Appendix B

Hutchinson Elementary School

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-01	Kitchen Island 2-Bay	SK	App	<1.0	4/8/2026				-
1001-02	Kitchen Ice Machine	IM	App	<1.0	4/8/2026				-
1001-03	Kitchen Pot Filler by Stove	PF	App	15.0	4/8/2026				Removed from service; Pending remediation
1001-04	Kitchen Handwash	SK	N/A		4/8/2026				Sign
1002-01	Cafeteria	WF	App	<1.0	4/8/2026				-
1002-02	Cafeteria	BF	App	<1.0	4/8/2026				-
1003-01	All Gender Bathroom by Kitchen	SK	N/A		4/8/2026				Sign
0001-01	Ground Level Girl's Bathroom - Left	SK	N/A		4/8/2026				Mixed Valve; Sign
0001-02	Ground Level Girl's Bathroom - Right	SK	N/A		4/8/2026				Mixed Valve; Sign
0002-01	Ground Level Boy's Bathroom - Left	SK	N/A		4/8/2026				Mixed Valve; Sign
0002-02	Ground Level Boy's Bathroom - Right	SK	N/A		4/8/2026				Mixed Valve; Sign
0003-01	Ground Level Custodial Closet by Elevator	SS	N/A		4/8/2026				Sign
0004-01	Ground Level All Gender Bathroom	SK	N/A		4/8/2026				Sign
0005-01	Ground Level Hall by Bathrooms	WF	App	<1.0	4/8/2026				-
0005-02	Ground Level Hall by Bathrooms	BF	App	<1.0	4/8/2026				-
1004-01	All Gender Bathroom by Main Entrance	SK	N/A		4/8/2026				Sign
1005-01	Nurse's Office - by Entrance	SK	App	<1.0	4/8/2026				-
1005-02	Nurse's Office - by Fridge	SK	N/A		4/8/2026				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1005-03	Nurse's Office Bathroom	SK	App	<1.0	4/8/2026				-
1006-01	101E Work Room	SK	App	<1.0	4/8/2026				-
1006-02	101E Work Room Bathroom	SK	N/A		4/8/2026				Sign
1007-01	Classroom 103	SK	N/A		4/8/2026				Sign
1007-02	Classroom 103	WF	App	<1.0	4/8/2026				-
1008-01	Room 123 Library Commons	SK	App	1.0	4/8/2026				-
1009-01	Art Room 117 Trough - Left	SK	N/A		4/8/2026				Sign
1009-02	Art Room 117 Trough - Middle	SK	N/A		4/8/2026				Sign
1009-03	Art Room 117 Trough - Right	SK	N/A		4/8/2026				Sign
1010-01	Room 124 - Left	SK	N/A		4/8/2026				Sign
1010-02	Room 124 - Right	SK	N/A		4/8/2026				Sign
1011-01	Classroom 116	WF	App	<1.0	4/8/2026				-
1011-02	Classroom 116	SK	N/A		4/8/2026				Sign
1012-01	Classroom 113	WF	App	1.0	4/8/2026				-
1012-02	Classroom 113	SK	N/A		4/8/2026				Sign
1012-03	Classroom 113 Bathroom	SK	App	<1.0	4/8/2026				-
1013-01	Custodial Closet by 113	SS	N/A		4/8/2026				Sign
1014-01	All Gender Bathroom by 113	SK	N/A		4/8/2026				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1015-01	Classroom 111	WF	App	<1.0	4/8/2026				-
1015-02	Classroom 111	SK	N/A		4/8/2026				Sign
1015-03	Classroom 111 Bathroom	SK	App	<1.0	4/8/2026				-
1016-01	Classroom 110	WF	App	<1.0	4/8/2026				-
1016-02	Classroom 110	SK	N/A		4/8/2026				Sign
1016-03	Classroom 110 Bathroom	SK	App	<1.0	4/8/2026				-
1017-01	Classroom 109	WF	App	<1.0	4/8/2026				-
1017-02	Classroom 109	SK	N/A		4/8/2026				Sign
1018-01	Classroom 107	WF	App	<1.0	4/8/2026				-
1018-02	Classroom 107	SK	N/A		4/8/2026				Sign
1019-01	Classroom 106	WF	App	<1.0	4/8/2026				-
1019-02	Classroom 106	SK	N/A		4/8/2026				Sign
1020-01	Boy's Bathroom by 106 - Left	SK	N/A		4/8/2026				Mixed Valve; Sign
1020-02	Boy's Bathroom by 106 - Right	SK	N/A		4/8/2026				Mixed Valve; Sign
1021-01	Girl's Bathroom by 106 - Left	SK	N/A		4/8/2026				Mixed Valve; Sign
1021-02	Girl's Bathroom by 106 - Right	SK	N/A		4/8/2026				Mixed Valve; Sign
1022-01	Hall by 106	WF	App	<1.0	4/8/2026				-
1022-02	Hall by 106	BF	App	<1.0	4/8/2026				-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2001-01	Classroom 208	WF	App	6.0	4/8/2026				Removed from service; Pending remediation
2001-02	Classroom 208	SK	N/A		4/8/2026				Sign
2002-01	Classroom 210	WF	App	<1.0	4/8/2026				-
2002-02	Classroom 210	SK	N/A		4/8/2026				Sign
2003-01	Classroom 212	WF	App	4.0	4/8/2026				-
2003-02	Classroom 212	SK	N/A		4/8/2026				Sign
2004-01	Classroom 213	WF	App	33.0	4/8/2026				Removed from service; Pending remediation
2004-02	Classroom 213	SK	N/A		4/8/2026				Sign
2005-01	Classroom 235	WF	App	<1.0	4/8/2026				-
2005-02	Classroom 235	SK	N/A		4/8/2026				Sign
2006-01	Classroom 215	WF	App	2.0	4/8/2026				-
2006-02	Classroom 215	SK	N/A		4/8/2026				Sign
2007-01	Classroom 217	WF	App	<1.0	4/8/2026				-
2007-02	Classroom 217	SK	N/A		4/8/2026				Sign
2008-01	Classroom 219	WF	App	2.0	4/8/2026				-
2008-02	Classroom 219	SK	N/A		4/8/2026				Sign
2009-01	Staff Room 232 All Gender Bathroom	SK	N/A		4/8/2026				Sign
2009-02	Staff Room 232 Kitchenette	SK	App	1.0	4/8/2026				-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2009-03	Staff Room 232 Privacy Room	SK	App	4.0	4/8/2026				-
2010-01	Classroom 221	WF	App	<1.0	4/8/2026				-
2010-02	Classroom 221	SK	N/A		4/8/2026				Sign
2011-01	Classroom 222	WF	App	1.0	4/8/2026				-
2011-02	Classroom 222	SK	N/A		4/8/2026				Sign
2012-01	Girl's Bathroom by 222 - Left	SK	N/A		4/8/2026				Mixed Valve; Sign
2012-02	Girl's Bathroom by 222 - Right	SK	N/A		4/8/2026				Mixed Valve; Sign
2013-01	Boy's Bathroom by 222 - Left	SK	N/A		4/8/2026				Mixed Valve; Sign
2013-02	Boy's Bathroom by 222 - Right	SK	N/A		4/8/2026				Mixed Valve; Sign
2014-01	Hall by 222	WF	App	<1.0	4/8/2026				-
2014-02	Hall by 222	BF	App	<1.0	4/8/2026				-
2015-01	Classroom 201	WF	App	<1.0	4/8/2026				-
2015-02	Classroom 201	SK	N/A		4/8/2026				Sign
2016-01	Classroom 203	WF	App	<1.0	4/8/2026				-
2016-02	Classroom 203	SK	N/A		4/8/2026				Sign
2017-01	Classroom 204	WF	App	3.0	4/8/2026				-
2017-02	Classroom 204	SK	N/A		4/8/2026				Sign
2018-01	Classroom 206	WF	App	23.0	4/8/2026				Removed from service; Pending remediation

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2018-02	Classroom 206	SK	N/A		4/8/2026				Sign

Laboratory Report

April 10, 2026

Casey Lee
Enviroscience Consultants, Inc.
2150 Smithtown Ave.
Ronkonkoma, NY, 11779


Project: Pelham UFSD (Hutchinson Elementary School)
Project Address: Hutchinson Elementary School
Report ID: 260408009
Sample IDs: 260408009-257 - 260408009-298

New York Environmental is a NELAC accredited laboratory. Attached reported results meet the requirements of the NELAC standard unless otherwise noted.

Samples' analytical results relate only to the parameters tested for the samples received in the condition received by the laboratory, as noted on the Chain of Custody. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	8-Apr-26
Date Received:	8-Apr-26
Date Analyzed:	9-Apr-26

Analytical Method:	EPA 200.9
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
260408009-257	1	Kitchen Island 2-Bay - SK; initial	0.001	<0.001	mg/L	
260408009-258	2	Kitchen Ice Machine - IM; initial	0.001	<0.001	mg/L	
260408009-259	3	Kitchen Pot Filler by Stove - PF; initial	0.001	0.015	mg/L	H
260408009-260	4	Cafeteria - WF; initial	0.001	<0.001	mg/L	
260408009-261	5	Cafeteria - BF; initial	0.001	<0.001	mg/L	
260408009-262	6	Hall by Bathrooms - WF; initial	0.001	<0.001	mg/L	
260408009-263	7	Hall by Bathrooms - BF; initial	0.001	<0.001	mg/L	
260408009-264	8	Nurse's office by Entrance - SK; initial	0.001	<0.001	mg/L	
260408009-265	9	Nurse's Bathroom - SK; initial	0.001	<0.001	mg/L	
260408009-266	10	101E Work Room - SK; initial	0.001	<0.001	mg/L	
260408009-267	11	Room 103 - WF; initial	0.001	<0.001	mg/L	
260408009-268	12	Room 123 Library Commons - SK; initial	0.001	0.001	mg/L	
260408009-269	13	Room 116 - WF; initial	0.001	<0.001	mg/L	
260408009-270	14	Room 113 - WF; initial	0.001	0.001	mg/L	
260408009-271	15	Room 111 - WF; initial	0.001	<0.001	mg/L	
260408009-272	16	Room 110 - WF; initial	0.001	<0.001	mg/L	
260408009-273	17	Room 109 - WF; initial	0.001	<0.001	mg/L	
260408009-274	18	Room 110 Bathroom - SK; initial	0.001	<0.001	mg/L	
260408009-275	19	Room 111 Bathroom - SK; initial	0.001	<0.001	mg/L	
260408009-276	20	Room 113 Bathroom - SK; initial	0.001	<0.001	mg/L	
260408009-277	21	Room 107 - WF; initial	0.001	<0.001	mg/L	
260408009-278	22	Room 106 - WF; initial	0.001	<0.001	mg/L	
260408009-279	23	Hall by 106 - WF; initial	0.001	<0.001	mg/L	
260408009-280	24	Hall by 106 - BF; initial	0.001	<0.001	mg/L	
260408009-281	25	Room 208 - WF; initial	0.001	0.006	mg/L	H
260408009-282	26	Room 210 - WF; initial	0.001	<0.001	mg/L	
260408009-283	27	Room 212 - WF; initial	0.001	0.004	mg/L	
260408009-284	28	Room 235 - WF; initial	0.001	<0.001	mg/L	
260408009-285	29	Room 215 - WF; initial	0.001	0.002	mg/L	
260408009-286	30	Room 217 - WF; initial	0.001	<0.001	mg/L	
260408009-287	31	Room 219 - WF; initial	0.001	0.002	mg/L	
260408009-288	32	Room 232 Staff Room Kitchenette - SK; initial	0.001	0.001	mg/L	
260408009-289	33	Room 232 Additional Room - SK; initial	0.001	0.004	mg/L	
260408009-290	34	Room 121 - WF; initial	0.001	<0.001	mg/L	



Date Collected:	8-Apr-26
Date Received:	8-Apr-26
Date Analyzed:	9-Apr-26

Analytical Method:	EPA 200.9
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
260408009-291	35	Room 222 - WF; initial	0.001	0.001	mg/L	
260408009-292	36	Hall by 222 - WF; initial	0.001	<0.001	mg/L	
260408009-293	37	Hall by 222 - BF; initial	0.001	<0.001	mg/L	
260408009-294	38	Room 201 - WF; initial	0.001	<0.001	mg/L	
260408009-295	39	Room 203 - WF; initial	0.001	<0.001	mg/L	
260408009-296	40	Room 204 - WF; initial	0.001	0.003	mg/L	
260408009-297	41	Room 206 - WF; initial	0.001	0.023	mg/L	H
260408009-298	42	Room 213 - WF; initial	0.001	0.033	mg/L	H

Comment(s):

LOQ: Limit of Quantitation

CID: Client ID

H: Sample result exceeds applicable regulatory limit.



Appendix C

Prospect Hill Elementary School

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0001-01	Kitchen 2-Bay	SK	App	16.0	4/8/2026				Removed from service; Pending remediation
0002-01	Art Room	SK	N/A		4/8/2026				Sign
0003-01	Girl's Bathroom by Art Room - Left	SK	N/A		4/8/2026				Sign
0003-02	Girl's Bathroom by Art Room - Right	SK	N/A		4/8/2026				Mixed Valve; Sign
0004-01	Custodial Office 008	SS	N/A		4/8/2026				Mixed Valve; Sign
0005-01	Hall by Room 005	WF	App	<1.0	4/8/2026				-
0005-02	Hall by Room 005	BF	App	<1.0	4/8/2026				-
0006-01	Standpipe Room All Gender Bathroom	SK	N/A		4/8/2026				Sign
0007-01	Boy's Bathroom by 005 - Left	SK	N/A		4/8/2026				Sign
0007-02	Boy's Bathroom by 005 - Right	SK	N/A		4/8/2026				Sign
1001-01	All Gender Bathroom by 1st Floor Elevator	SK	N/A		4/8/2026				Mixed Valve; Sign
1002-01	Hall by Main Office	WF	App	<1.0	4/8/2026				-
1002-02	Hall by Main Office	BF	App	<1.0	4/8/2026				-
1003-01	Faculty Room Kitchenette	SK	App	8.0	4/8/2026				Removed from service; Pending remediation
1003-02	Faculty Room Bathroom	SK	N/A		4/8/2026				Mixed Valve; Sign
1004-01	Boy's Bathroom by 102 - Left	SK	N/A		4/8/2026				Mixed Valve; Sign
1004-02	Boy's Bathroom by 102 - Right	SK	N/A		4/8/2026				Mixed Valve; Sign
1005-01	Girl's Bathroom by 106 - Left	SK	N/A		4/8/2026				Mixed Valve; Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1005-02	Girl's Bathroom by 106 - Right	SK	N/A		4/8/2026				Mixed Valve; Sign
1006-01	Custodial Closet 108	SS	N/A		4/8/2026				Sign
1007-01	Hall by 119 - Left	WF	App	<1.0	4/8/2026				-
1007-02	Hall by 119 - Right	WF	App	<1.0	4/8/2026				-
1007-03	Hall by 119	BF	App	<1.0	4/8/2026				-
2001-01	Hall by 202	WF	App	<1.0	4/8/2026				-
2001-02	Hall by 202	BF	App	<1.0	4/8/2026				-
2002-01	Boy's Bathroom by 205 - Left	SK	N/A		4/8/2026				Mixed Valve; Sign
2002-02	Boy's Bathroom by 205 - Right	SK	N/A		4/8/2026				Mixed Valve; Sign
2003-01	Girl's Bathroom by 205 - Left	SK	N/A		4/8/2026				Mixed Valve; Sign
2003-02	Girl's Bathroom by 205 - Right	SK	N/A		4/8/2026				Mixed Valve; Sign

Laboratory Report

April 10, 2026

Casey Lee
Enviroscience Consultants, Inc.
2150 Smithtown Ave.
Ronkonkoma, NY, 11779

Project: Pelham UFSD (Prospect Hill Elementary School)
Project Address: Prospect Hill Elementary School
Report ID: 260408005
Sample IDs: 260408005-134 - 260408005-144

New York Environmental is a NELAC accredited laboratory. Attached reported results meet the requirements of the NELAC standard unless otherwise noted.

Samples' analytical results relate only to the parameters tested for the samples received in the condition received by the laboratory, as noted on the Chain of Custody. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	8-Apr-26
Date Received:	8-Apr-26
Date Analyzed:	9-Apr-26

Analytical Method:	EPA 200.9
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
260408005-134	1	Kitchen 2 - Bay - SK; initial	0.001	0.016	mg/L	H
260408005-135	2	Hall by 005 - WF; initial	0.001	<0.001	mg/L	
260408005-136	3	Hall by 005 - BF; initial	0.001	<0.001	mg/L	
260408005-137	4	Hall by Main office - WF; initial	0.001	<0.001	mg/L	
260408005-138	5	Hall by Main office - BF; initial	0.001	<0.001	mg/L	
260408005-139	6	Faculty Room Kitchenette - SK; initial	0.001	0.008	mg/L	H
260408005-140	7	Hall by 119-Left - WF; initial	0.001	<0.001	mg/L	
260408005-141	8	Hall by 119-Right - WF; initial	0.001	<0.001	mg/L	
260408005-142	9	Hall by 119 - BF; initial	0.001	<0.001	mg/L	
260408005-143	10	Hall by 202 - WF; initial	0.001	<0.001	mg/L	
260408005-144	11	Hall by 202 - BF; initial	0.001	<0.001	mg/L	

Comment(s):

LOQ: Limit of Quantitation

CID: Client ID

H: Sample result exceeds applicable regulatory limit.



Appendix D

Siwanoy Elementary School

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0001-01	Hall by 014	WF	App	<1.0	4/8/2026				-
0001-02	Hall by 014	BF	App	<1.0	4/8/2026				-
0002-01	Classroom 014	SK	N/A		4/8/2026				Sign
0003-01	015 Teacher's Lounge Kitchenette	SK	App	<1.0	4/8/2026				-
0003-02	015 Teacher's Lounge Kitchenette	SPY	App	1.0	4/8/2026				-
0004-01	Classroom 002	SK	N/A		4/8/2026				Sign
0005-01	All Gender Bathroom by 007	SK	N/A		4/8/2026				Mixed Valve; Sign
0006-01	Nurse's Office	SK	N/A		4/8/2026				Mixed Valve; Sign
1001-01	Hall by 105	WF	App	<1.0	4/8/2026				-
1001-02	Hall by 105	BF	App	<1.0	4/8/2026				-
1002-01	Classroom 105	SK	N/A		4/8/2026				Sign
1003-01	Classroom 104	SK	N/A		4/8/2026				Sign
1004-01	Classroom 103	SK	N/A		4/8/2026				Sign
1005-01	Classroom 102	SK	N/A		4/8/2026				Sign
1006-01	Hall by Gym	WF	App	<1.0	4/8/2026				-
1006-02	Hall by Gym	BF	App	<1.0	4/8/2026				-
1007-01	Serving Room 110A 2-Bay	SK	App	5.0	4/8/2026				-
1008-01	Classroom 101	SK	N/A		4/8/2026				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1009-01	Boy's Bathroom 107 - Left	SK	N/A		4/8/2026				Mixed Valve; Sign
1009-02	Boy's Bathroom 107 - Middle	SK	N/A		4/8/2026				Mixed Valve; Sign
1009-03	Boy's Bathroom 107 - Right	SK	N/A		4/8/2026				Sign
1010-01	Classroom 108	SK	N/A		4/8/2026				Sign
1011-01	Classroom 109	SK	N/A		4/8/2026				Sign
2001-01	Hall by 209	WF	App	<1.0	4/8/2026				-
2001-02	Hall by 209	BF	App	<1.0	4/8/2026				-
2002-01	Girl's Bathroom 209 - Left	SK	N/A		4/8/2026				Mixed Valve; Sign
2002-02	Girl's Bathroom 209 - Middle	SK	N/A		4/8/2026				Mixed Valve; Sign
2002-03	Girl's Bathroom 209 - Right	SK	N/A		4/8/2026				Mixed Valve; Sign
2003-01	Classroom 210	SK	N/A		4/8/2026				Sign
2004-01	Classroom 211	SK	N/A		4/8/2026				Sign
2005-01	Classroom 206	SK	N/A		4/8/2026				Sign
2006-01	Classroom 205	SK	N/A		4/8/2026				Sign
2007-01	Classroom 203	SK	N/A		4/8/2026				Sign
2008-01	Hall by 202	WF	App	<1.0	4/8/2026				-
2008-02	Hall by 202	BF	App	<1.0	4/8/2026				-
2009-01	Classroom 202	SK	N/A		4/8/2026				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2010-01	Classroom 207	SK	N/A		4/8/2026				Sign

Laboratory Report

April 14, 2026

Casey Lee
Enviroscience Consultants, Inc.
2150 Smithtown Ave.
Ronkonkoma, NY, 11779


Project: Pelham UFSD (Siwanoy Elementary School)
Project Address: Siwanoy Elementary School
Report ID: 260408006
Sample IDs: 260408006-147 - 260408006-162

New York Environmental is a NELAC accredited laboratory. Attached reported results meet the requirements of the NELAC standard unless otherwise noted.

Samples' analytical results relate only to the parameters tested for the samples received in the condition received by the laboratory, as noted on the Chain of Custody. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	8-Apr-26
Date Received:	8-Apr-26
Date Analyzed:	9-Apr-26

Analytical Method:	EPA 200.9
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
260408006-147	1	Hall by 014 - WF; initial	0.001	<0.001	mg/L	
260408006-148	2	Hall by 014 - BF; initial	0.001	<0.001	mg/L	
260408006-149	3	OIS Teacher's Lounge Kitchenette - SK; initial	0.001	<0.001	mg/L	
260408006-150	4	OIS Teacher's Lounge Kitchenette - SPY; initial	0.001	0.001	mg/L	
260408006-151	5	Hall by 105 - WF; initial	0.001	<0.001	mg/L	
260408006-152	6	Hall by 105 - BF; initial	0.001	<0.001	mg/L	
260408006-153	7	Hall by 209 - WF; initial	0.001	<0.001	mg/L	
260408006-155	8	Hall by 209 - BF; initial	0.001	<0.001	mg/L	
260408006-156	9	Hall by 202 - WF; initial	0.001	<0.001	mg/L	
260408006-158	10	Hall by 202 - BF; initial	0.001	<0.001	mg/L	
260408006-159	11	Hall by Gym - WF; initial	0.001	<0.001	mg/L	
260408006-161	12	Hall by Gym - BF; initial	0.001	<0.001	mg/L	
260408006-162	13	110A Serving Area 2-Bay - SK; initial	0.001	0.005	mg/L	

Comment(s):

LOQ: Limit of Quantitation

CID: Client ID



Appendix E

Pelham Middle School

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0001-01	070 Girl's Locker Room Bathroom - Left	SK	N/A		4/7/2026				Sign
0001-02	070 Girl's Locker Room Bathroom - Middle	SK	N/A		4/7/2026				Sign
0001-03	070 Girl's Locker Room Bathroom - Right	SK	N/A		4/7/2026				Sign
0001-04	070 Girl's Locker Room Showers @A	SPY	N/A		4/7/2026				Sign
0001-05	070 Girl's Locker Room Showers @B	SPY	N/A		4/7/2026				Sign
0001-06	070 Girl's Locker Room Showers @C	SPY	N/A		4/7/2026				Sign
0001-07	070 Girl's Locker Room Showers @D	SPY	N/A		4/7/2026				Sign
0001-08	070 Girl's Locker Room	WF	App	<1.0	4/7/2026				-
0001-09	070 Girl's Locker Room - Coach's Room	SK	N/A		4/7/2026				Sign
0001-10	070 Girl's Locker Room - Coach's Room Shower	SPY	N/A		4/7/2026				Sign
0002-01	072 Boy's Locker Room	WF	App	<1.0	4/7/2026				-
0002-02	072 Boy's Locker Room Bathroom - Left	SK	N/A		4/7/2026				Sign
0002-03	072 Boy's Locker Room Bathroom - Middle	SK	N/A		4/7/2026				Sign
0002-04	072 Boy's Locker Room Bathroom - Right	SK	N/A		4/7/2026				Sign
0002-05	072 Boy's Locker Room Showers @A	SPY	N/A		4/7/2026				Sign
0002-06	072 Boy's Locker Room Showers @B	SPY	N/A		4/7/2026				Sign
0002-07	072 Boy's Locker Room Showers @C	SPY	N/A		4/7/2026				Sign
0002-08	072 Boy's Locker Room Showers @D	SPY	N/A		4/7/2026				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0002-09	072 Boy's Locker Room Showers @E	SPY	N/A		4/7/2026				Sign
0002-10	072 Boy's Locker Room Showers @F	SPY	N/A		4/7/2026				Sign
0002-11	072 Boy's Locker Room - Coach's Room	SK	N/A		4/7/2026				Sign
0002-12	072 Boy's Locker Room - Coach's Room Shower	SPY	N/A		4/7/2026				Sign
0003-01	Men's Bathroom by Gym - Left	SK	N/A		4/7/2026				Sign
0003-02	Men's Bathroom by Gym - Middle	SK	N/A		4/7/2026				Sign
0003-03	Men's Bathroom by Gym - Right	SK	N/A		4/7/2026				Sign
0004-01	Lobby by Gym - Left	WF	App	<1.0	4/7/2026				-
0004-02	Lobby by Gym - Right	WF	App	<1.0	4/7/2026				-
0005-01	Women's Bathroom by Gym @A	SK	N/A		4/7/2026				Mixed Valve; Sign
0005-02	Women's Bathroom by Gym @B	SK	N/A		4/7/2026				Mixed Valve; Sign
0005-03	Women's Bathroom by Gym @C	SK	N/A		4/7/2026				Sign
0005-04	Women's Bathroom by Gym @D	SK	N/A		4/7/2026				Sign
0005-05	Women's Bathroom by Gym @E	SK	N/A		4/7/2026				Mixed Valve; Sign
0006-01	061 Main Office All Gender Bathroom - Left	SK	N/A		4/7/2026				Sign
0006-02	061 Main Office All Gender Bathroom - Right	SK	N/A		4/7/2026				Sign
0006-03	061 Main Office Faculty Kitchenette	SK	App	<1.0	4/7/2026				-
0007-01	064 Nurse's Office	SK	App	<1.0	4/7/2026				-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0007-02	064 Nurse's Office	IM	App	<1.0	4/7/2026				-
0007-03	064 Nurse's Office Bathroom	SK	N/A		4/7/2026				Mixed Valve; Sign
1001-01	Science Room 162 Counter - Left	SK	N/A		4/7/2026				Sign
1001-02	Science Room 162 Counter - Right	SK	N/A		4/7/2026				Sign
1002-01	Girl's Bathroom by 162 - Left	SK	N/A		4/7/2026				Sign
1002-02	Girl's Bathroom by 162 - Middle	SK	N/A		4/7/2026				Mixed Valve; Sign
1002-03	Girl's Bathroom by 162 - Right	SK	N/A		4/7/2026				Sign
1003-01	Hall by 162 - Left	WF	App	<1.0	4/7/2026				-
1003-02	Hall by 162 - Right	WF	App	<1.0	4/7/2026				-
1004-01	Boy's Bathroom by 162 - Left	SK	N/A		4/7/2026				Sign
1004-02	Boy's Bathroom by 162 - Middle	SK	N/A		4/7/2026				Mixed Valve; Sign
1004-03	Boy's Bathroom by 162 - Right	SK	N/A		4/7/2026				Mixed Valve; Sign
1005-01	Science Room 166 Counter - Left	SK	App	2.0	4/7/2026				-
1005-02	Science Room 166 Counter - Right	SK	App	<1.0	4/7/2026				-
1006-01	Science Prep Room 166/162	SK	App	1.0	4/7/2026				-
1006-02	Science Prep Room 166/162	IM	N/A		4/7/2026				Non-functional; Sampling required before returning to service
2001-01	Girl's Bathroom by 264 - Left	SK	N/A		4/7/2026				Mixed Valve; Sign
2001-02	Girl's Bathroom by 264 - Middle	SK	N/A		4/7/2026				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2001-03	Girl's Bathroom by 264 - Right	SK	N/A		4/7/2026				Sign
2002-01	Hall by 264 - Left	WF	App	<1.0	4/7/2026				-
2002-02	Hall by 264 - Right	WF	App	<1.0	4/7/2026				-
2003-01	Boy's Bathroom by 264 - Left	SK	N/A		4/7/2026				Sign
2003-02	Boy's Bathroom by 264 - Middle	SK	N/A		4/7/2026				Sign
2003-03	Boy's Bathroom by 264 - Right	SK	N/A		4/7/2026				Mixed Valve; Sign
2004-01	Science Room 266 Counter - Left	SK	N/A		4/7/2026				Sign
2004-02	Science Room 266 Counter - Right	SK	N/A		4/7/2026				Sign
2005-01	Science Prep Room 266/262	SK	N/A		4/7/2026				Sign
2005-02	Science Prep Room 266/262 Ice Machine	IM	App	<1.0	4/7/2026				-
2005-03	Science Prep Room 266/262 Ice Machine Water Dispenser	OS	App	79.0	4/7/2026				Removed from service; Pending remediation
2006-01	Science Room 262 Counter - Left	SK	N/A		4/7/2026				Sign
2006-02	Science Room 262 Counter - Right	SK	N/A		4/7/2026				Sign
2007-01	Room 273 Faculty Office Kitchenette	SK	App	1.0	4/7/2026				-
2007-02	Room 273 Faculty Office Bathroom - Left	SK	N/A		4/7/2026				Mixed Valve; Sign
2007-03	Room 273 Faculty Office Bathroom - Right	SK	N/A		4/7/2026				Mixed Valve; Sign
2008-01	Room 278C Library Office Classroom	SK	App	11.0	4/7/2026				Removed from service; Pending remediation

Laboratory Report

April 10, 2026

Casey Lee
Enviroscience Consultants, Inc.
2150 Smithtown Ave.
Ronkonkoma, NY, 11779

Project: Pelham UFSD (Pelham Middle School)
Project Address: Pelham Middle School
Report ID: 260408008
Sample IDs: 260408008-239 - 260408008-256

New York Environmental is a NELAC accredited laboratory. Attached reported results meet the requirements of the NELAC standard unless otherwise noted.

Samples' analytical results relate only to the parameters tested for the samples received in the condition received by the laboratory, as noted on the Chain of Custody. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	7-Apr-26
Date Received:	8-Apr-26
Date Analyzed:	9-Apr-26

Analytical Method:	EPA 200.9
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
260408008-239	1	070 Girl's Locker Room - WF; initial	0.001	<0.001	mg/L	
260408008-240	2	072 Boy's Locker Room - WF; initial	0.001	<0.001	mg/L	
260408008-241	3	Lobby by Gym - Left - WF; initial	0.001	<0.001	mg/L	
260408008-242	4	Lobby by Gym - Right - WF; initial	0.001	<0.001	mg/L	
260408008-243	5	061 Main Office Faculty Kitchenette - SK; initial	0.001	<0.001	mg/L	
260408008-244	6	064 Nurse's Office - SK; initial	0.001	<0.001	mg/L	
260408008-245	7	064 Nurse's Office - IM; initial	0.001	<0.001	mg/L	
260408008-246	8	Hall by Room 162 - Left - WF; initial	0.001	<0.001	mg/L	
260408008-247	9	Hall by Room 162 - Right - WF; initial	0.001	<0.001	mg/L	
260408008-248	10	Science Room 166 Counter - Right - SK; initial	0.001	<0.001	mg/L	
260408008-249	11	Science Room 166 Counter - Left - SK; initial	0.001	0.002	mg/L	
260408008-250	12	Science Prep Room 166/162 - SK; initial	0.001	0.001	mg/L	
260408008-251	13	Hall by Room 264 - Left - WF; initial	0.001	<0.001	mg/L	
260408008-252	14	Hall by Room 264 - Right - WF; initial	0.001	<0.001	mg/L	
260408008-253	15	Science Prep Room 266/262 Ice Machine - IM; initial	0.001	<0.001	mg/L	
260408008-254	16	Science Prep Room 266/262 Ice Machine Water Dispenser - OS; initial	0.001	0.079	mg/L	H
260408008-255	17	Room 273 Faculty Office Kitchenette - SK; initial	0.001	0.001	mg/L	
260408008-256	18	Room 278C Library Office Classroom - SK; initial	0.001	0.011	mg/L	H

Comment(s):

LOQ: Limit of Quantitation

CID: Client ID

H: Sample result exceeds applicable regulatory limit.



Appendix F

Pelham Memorial High School

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0001-01	Hall by 012	WF	App	<1.0	4/7/2026				-
0001-02	Hall by 012	BF	App	<1.0	4/7/2026				-
0002-01	Kitchen Island	SK	App	<1.0	4/7/2026				-
0002-02	Kitchen Pot Filler by Stove	PF	App	1.0	4/7/2026				-
0002-03	Kitchen Handwash by Freezers	SK	N/A		4/7/2026				Sign
0002-04	Kitchen 3-Bay Dishwash - Left	SK	N/A		4/7/2026				Sign
0002-05	Kitchen 3-Bay Dishwash - Middle	SK	N/A		4/7/2026				Sign
0002-06	Kitchen 3-Bay Dishwash - Right	SK	N/A		4/7/2026				Sign
0002-07	Kitchen Slop Sink	SS	N/A		4/7/2026				Sign
0002-08	Kitchen Ice Machine	IM	App	<1.0	4/7/2026				-
0003-01	Snack Stand Coffee Filler	PF	N/A		4/7/2026				Non-functional; Sampling required before returning to service
0004-01	Café A	WF	App	<1.0	4/7/2026				-
0004-02	Café A	BF	App	<1.0	4/7/2026				-
0005-01	Girl's Locker Room Bathroom - Left	SK	N/A		4/7/2026				Sign
0005-02	Girl's Locker Room Bathroom - Middle	SK	N/A		4/7/2026				Sign
0005-03	Girl's Locker Room Bathroom - Right	SK	N/A		4/7/2026				Sign
0005-04	Girl's Locker Room Showers - Left	SPY	N/A		4/7/2026				Sign
0005-05	Girl's Locker Room Showers - Right	SPY	N/A		4/7/2026				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0005-06	Girl's Locker Room	WF	App	<1.0	4/7/2026				-
0005-07	Girl's Locker Room	BF	App	<1.0	4/7/2026				-
0006-01	Boy's Locker Room	WF	App	<1.0	4/7/2026				-
0006-02	Boy's Locker Room	BF	App	<1.0	4/7/2026				-
0006-03	Boy's Locker Room Showers - Left	SPY	N/A		4/7/2026				Sign
0006-04	Boy's Locker Room Showers - Middle	SPY	N/A		4/7/2026				Sign
0006-05	Boy's Locker Room Showers - Right	SPY	N/A		4/7/2026				Sign
0006-06	Boy's Locker Room Bathroom - Left	SK	N/A		4/7/2026				Sign
0006-07	Boy's Locker Room Bathroom - Middle	SK	N/A		4/7/2026				Sign
0006-08	Boy's Locker Room Bathroom - Right	SK	N/A		4/7/2026				Sign
0007-01	Boy's Coach's Room	SK	N/A		4/7/2026				Sign
0007-02	Boy's Coach's Room Shower	SPY	N/A		4/7/2026				Sign
0008-01	Girl's Coach's Room	SK	N/A		4/7/2026				Sign
0009-01	Weight Room	WF	App	<1.0	4/7/2026				-
0009-02	Weight Room	BF	App	<1.0	4/7/2026				-
0010-01	Art Room 012 Trough - Left	SK	N/A		4/7/2026				Sign
0010-02	Art Room 012 Trough - Middle	SK	N/A		4/7/2026				Sign
0010-03	Art Room 012 Trough - Right	SK	N/A		4/7/2026				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0010-04	Art Room 012 Counter	SK	N/A		4/7/2026				Sign
0011-01	Girl's Bathroom 014 - Left	SK	N/A		4/7/2026				Sign
0011-02	Girl's Bathroom 014 - Right	SK	N/A		4/7/2026				Sign
0012-01	Art Room 013 Trough - Left	SK	N/A		4/7/2026				Sign
0012-02	Art Room 013 Trough - Middle	SK	N/A		4/7/2026				Sign
0012-03	Art Room 013 Trough - Right	SK	N/A		4/7/2026				Sign
0012-04	Art Room 013 Counter	SK	N/A		4/7/2026				Sign
0013-01	Art Room 032 Trough - Left	SK	N/A		4/7/2026				Sign
0013-02	Art Room 032 Trough - Middle	SK	N/A		4/7/2026				Sign
0013-03	Art Room 032 Trough - Right	SK	N/A		4/7/2026				Sign
0014-01	Room 033 Bridge Academy Office Kitchenette	SK	App	1.0	4/7/2026				-
0014-02	Room 033 Bridge Academy Office Kitchenette	SP	App	1.0	4/7/2026				-
0015-01	All Gender Bathroom by Room 036	SK	N/A		4/7/2026				Mixed Valve; Sign
0016-01	002 Custodial Office	SK	N/A		4/7/2026				Sign
0016-02	002 Custodial Office Bathroom	SS	N/A		4/7/2026				Sign
0016-03	002 Custodial Office Kitchenette	SK	App	2.0	4/7/2026				-
0016-04	002 Custodial Office Kitchenette	SP	App	<1.0	4/7/2026				-
0016-05	002 Custodial Office Kitchenette	WC	App	<1.0	4/7/2026				-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0017-01	Nurse's Office	SK	N/A		4/7/2026				Mixed Valve; Sign
0017-02	Nurse's Office	SP	App	3.0	4/7/2026				-
0017-03	Nurse's Office Bathroom	SK	N/A		4/7/2026				Mixed Valve; Sign
0018-01	Hall by Fitness Office	WF	App	2.0	4/7/2026				-
0018-02	Hall by Fitness Office	BF	App	2.0	4/7/2026				-
0019-01	Room 011F Classroom	SK	N/A		4/7/2026				Sign
0020-01	Room 011D - Life Skills	SK	App	1.0	4/7/2026				-
1001-01	Hall by Guidance Office	WF	App	<1.0	4/7/2026				-
1001-02	Hall by Guidance Office	BF	App	<1.0	4/7/2026				-
1002-01	Room 105A Librarian's Office	SK	App	2.0	4/7/2026				-
1003-01	Counseling Office All Gender Bathroom - Left	SK	N/A		4/7/2026				Mixed Valve; Sign
1003-02	Counseling Office All Gender Bathroom - Right	SK	N/A		4/7/2026				Mixed Valve; Sign
1004-01	Room 139 Conference Room All Gender Bathroom	SK	N/A		4/7/2026				Sign
1005-01	Girl's Bathroom 131 - Left	SK	N/A		4/7/2026				Mixed Valve; Sign
1005-02	Girl's Bathroom 131 - Middle	SK	N/A		4/7/2026				Mixed Valve; Sign
1005-03	Girl's Bathroom 131 - Right	SK	N/A		4/7/2026				Mixed Valve; Sign
1006-01	Boy's Bathroom 130 - Left	SK	N/A		4/7/2026				Mixed Valve; Sign
1006-02	Boy's Bathroom 130 - Middle	SK	N/A		4/7/2026				Mixed Valve; Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1006-03	Boy's Bathroom 130 - Right	SK	N/A		4/7/2026				Mixed Valve; Sign
1007-01	Hall by 124	WF	App	<1.0	4/7/2026				-
1007-02	Hall by 124	BF	App	<1.0	4/7/2026				-
1008-01	Art Room 117 - Left	SK	N/A		4/7/2026				Sign
1008-02	Art Room 117 - Right	SK	N/A		4/7/2026				Sign
1009-01	Boy's Bathroom 115 - Left	SK	N/A		4/7/2026				Mixed Valve; Sign
1009-02	Boy's Bathroom 115 - Right	SK	N/A		4/7/2026				Sign
1010-01	Hall by 113A	WF	App	<1.0	4/7/2026				-
1010-02	Hall by 113A	BF	App	<1.0	4/7/2026				-
1011-01	Girl's Bathroom 106 - Left	SK	N/A		4/7/2026				Sign
1011-02	Girl's Bathroom 106 - Right	SK	N/A		4/7/2026				Mixed Valve; Sign
2001-01	Room 204 Office All Gender Bathroom	SK	N/A		4/7/2026				Mixed Valve; Sign
2002-01	Hall by 202	WF	App	6.0	4/7/2026				Removed from service; Pending remediation
2003-01	Room 239 All Gender Bathroom	SK	N/A		4/7/2026				Mixed Valve; Sign
2004-01	Girl's Bathroom 232 - Left	SK	N/A		4/7/2026				Sign
2004-02	Girl's Bathroom 232 - Middle	SK	N/A		4/7/2026				Sign
2004-03	Girl's Bathroom 232 - Right	SK	N/A		4/7/2026				Mixed Valve; Sign
2005-01	Boy's Bathroom 231 - Left	SK	N/A		4/7/2026				Mixed Valve; Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2005-02	Boy's Bathroom 231 - Middle	SK	N/A		4/7/2026				Mixed Valve; Sign
2005-03	Boy's Bathroom 231 - Right	SK	N/A		4/7/2026				Mixed Valve; Sign
2006-01	Custodial Closet by 231	SS	N/A		4/7/2026				Sign
2007-01	Hall by 224	WF	App	<1.0	4/7/2026				-
2007-02	Hall by 224	BF	App	<1.0	4/7/2026				-
2008-01	All Gender Staff Bathroom by 224 - Left	SK	N/A		4/7/2026				Mixed Valve; Sign
2009-01	All Gender Staff Bathroom by 224 - Right	SK	N/A		4/7/2026				Mixed Valve; Sign
2010-01	Boy's Bathroom 215 - Left	SK	N/A		4/7/2026				Mixed Valve; Sign
2010-02	Boy's Bathroom 215 - Right	SK	N/A		4/7/2026				Mixed Valve; Sign
2011-01	Hall by 216A	WF	App	<1.0	4/7/2026				-
2011-02	Hall by 216A	BF	App	<1.0	4/7/2026				-
2012-01	Girl's Bathroom 209 - Left	SK	N/A		4/7/2026				Mixed Valve; Sign
2012-02	Girl's Bathroom 209 - Right	SK	N/A		4/7/2026				Mixed Valve; Sign
2013-01	Hall by 207	WF	App	<1.0	4/7/2026				-
2013-02	Hall by 207	BF	App	<1.0	4/7/2026				-
2014-01	Science Room 251 Counter - Left	SK	N/A		4/7/2026				Sign
2014-02	Science Room 251 Counter - Middle	SK	N/A		4/7/2026				Sign
2014-03	Science Room 251 Counter - Right	SK	N/A		4/7/2026				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2014-04	Science Room 251 Teacher's Station	SK	N/A		4/7/2026				Sign
2014-05	Science Room 251 Table @A	SK	N/A		4/7/2026				Sign
2014-06	Science Room 251 Table @B	SK	N/A		4/7/2026				Sign
2014-07	Science Room 251 Table @C	SK	N/A		4/7/2026				Sign
2014-08	Science Room 251 Table @D	SK	N/A		4/7/2026				Sign
2014-09	Science Room 251 Vent Hood	SK	N/A		4/7/2026				Sign
2015-01	Science Room 250 Counter - Left	SK	N/A		4/7/2026				Sign
2015-02	Science Room 250 Counter - Right	SK	N/A		4/7/2026				Sign
2015-03	Science Room 250 Teacher's Station	SK	N/A		4/7/2026				Sign
2015-04	Science Room 250 Table @A	SK	N/A		4/7/2026				Sign
2015-05	Science Room 250 Table @B	SK	N/A		4/7/2026				Sign
2015-06	Science Room 250 Table @C	SK	N/A		4/7/2026				Sign
2015-07	Science Room 250 Table @D	SK	N/A		4/7/2026				Sign
2016-01	Science Room 252 Counter	SK	N/A		4/7/2026				Sign
2016-02	Science Room 252 Teacher's Station	SK	N/A		4/7/2026				Sign
2016-03	Science Room 252 Table @A	SK	N/A		4/7/2026				Sign
2016-04	Science Room 252 Table @B	SK	N/A		4/7/2026				Sign
2016-05	Science Room 252 Table @C	SK	N/A		4/7/2026				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2016-06	Science Room 252 Table @D	SK	N/A		4/7/2026				Sign
2017-01	Science Room 253 Counter - Left	SK	N/A		4/7/2026				Sign
2017-02	Science Room 253 Counter - Right	SK	N/A		4/7/2026				Sign
2017-03	Science Room 253 Teacher's Station	SK	N/A		4/7/2026				Sign
2017-04	Science Room 253 Table @A	SK	N/A		4/7/2026				Sign
2017-05	Science Room 253 Table @B	SK	N/A		4/7/2026				Sign
2017-06	Science Room 253 Table @C	SK	N/A		4/7/2026				Sign
2017-07	Science Room 253 Table @D	SK	N/A		4/7/2026				Sign
2017-08	Science Room 253 Table @E	SK	N/A		4/7/2026				Sign
2018-01	Science Room 254 Counter	SK	N/A		4/7/2026				Sign
2018-02	Science Room 254 Teacher's Station	SK	N/A		4/7/2026				Sign
2018-03	Science Room 254 Table @A	SK	N/A		4/7/2026				Sign
2018-04	Science Room 254 Table @B	SK	N/A		4/7/2026				Sign
2018-05	Science Room 254 Table @C	SK	N/A		4/7/2026				Sign
2018-06	Science Room 254 Table @D	SK	N/A		4/7/2026				Sign
2018-07	Science Room 254 Table @E	SK	N/A		4/7/2026				Sign
2019-01	Science Room 255 Counter - Left	SK	N/A		4/7/2026				Sign
2019-02	Science Room 255 Counter - Right	SK	N/A		4/7/2026				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2019-03	Science Room 255 Teacher's Station	SK	N/A		4/7/2026				Sign
2019-04	Science Room 255 Table @A	SK	N/A		4/7/2026				Sign
2019-05	Science Room 255 Table @B	SK	N/A		4/7/2026				Sign
2019-06	Science Room 255 Table @C	SK	N/A		4/7/2026				Sign
2019-07	Science Room 255 Table @D	SK	N/A		4/7/2026				Sign
2020-01	Hall by 255	WF	App	<1.0	4/7/2026				-
2020-02	Hall by 255	BF	App	<1.0	4/7/2026				-
1012-01	8th Grade Wing - All Gender Bathroom by 156 - Left	SK	N/A		4/7/2026				Mixed Valve; Sign
1012-02	8th Grade Wing - All Gender Bathroom by 156 - Right	SK	N/A		4/7/2026				Mixed Valve; Sign
1013-01	8th Grade Wing - Hall by 153C	WF	App	<1.0	4/7/2026				-
1013-02	8th Grade Wing - Hall by 153C	BF	App	<1.0	4/7/2026				-
1014-01	8th Grade Wing - Faculty Room 153C	SK	App	2.0	4/7/2026				-
1015-01	8th Grade Wing - Science Room 154 Counter - Left	SK	N/A		4/7/2026				Sign
1015-02	8th Grade Wing - Science Room 154 Counter - Middle	SK	N/A		4/7/2026				Sign
1015-03	8th Grade Wing - Science Room 154 Counter - Right	SK	N/A		4/7/2026				Sign
1016-01	8th Grade Wing - Science 154/156 Prep Room	SK	N/A		4/7/2026				Sign
1017-01	8th Grade Wing - Science Room 156 Counter - Left	SK	N/A		4/7/2026				Sign
1017-02	8th Grade Wing - Science Room 156 Counter - Middle	SK	N/A		4/7/2026				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1017-03	8th Grade Wing - Science Room 156 Counter - Right	SK	N/A		4/7/2026				Sign
0021-01	8th Grade Wing - All Gender Bathroom by 053 - Left	SK	N/A		4/7/2026				Mixed Valve; Sign
0021-02	8th Grade Wing - All Gender Bathroom by 053 - Right	SK	N/A		4/7/2026				Mixed Valve; Sign
0022-02	8th Grade Wing - Band Room 053	SK	App	<1.0	4/7/2026				-
0023-01	8th Grade Wing - Hall by Band Room	WF	App	<1.0	4/7/2026				-
0023-02	8th Grade Wing - Hall by Band Room	BF	App	<1.0	4/7/2026				-
0024-01	8th Grade Wing - Art Room 056 - Left	SS	N/A		4/7/2026				Sign
0024-02	8th Grade Wing - Art Room 056 - Right	SS	N/A		4/7/2026				Sign
0025-01	8th Grade Wing - Staff All Gender Bathroom by Band Room	SK	N/A		4/7/2026				Mixed Valve; Sign

Laboratory Report

April 10, 2026

Casey Lee
Enviroscience Consultants, Inc.
2150 Smithtown Ave.
Ronkonkoma, NY, 11779


Project: Pelham UFSD (Pelham Memorial High School)
Project Address: Pelham Memorial High School
Report ID: 260408010
Sample IDs: 260408010-299 - 260408010-342

New York Environmental is a NELAC accredited laboratory. Attached reported results meet the requirements of the NELAC standard unless otherwise noted.

Samples' analytical results relate only to the parameters tested for the samples received in the condition received by the laboratory, as noted on the Chain of Custody. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	7-Apr-26
Date Received:	8-Apr-26
Date Analyzed:	9-Apr-26

Analytical Method:	EPA 200.9
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
260408010-299	1	Hall by 012 - WF; initial	0.001	<0.001	mg/L	
260408010-300	2	Hall by 012 - BF; initial	0.001	<0.001	mg/L	
260408010-301	3	Kitchen Island - SK; initial	0.001	<0.001	mg/L	
260408010-302	4	Kitchen Pot Filler by Stove - PF; initial	0.001	0.001	mg/L	
260408010-303	5	Kitchen Ice Machine - IM; initial	0.001	<0.001	mg/L	
260408010-304	6	Café A - WF; initial	0.001	<0.001	mg/L	
260408010-305	7	Café A - BF; initial	0.001	<0.001	mg/L	
260408010-306	8	Girl's Locker Room - WF; initial	0.001	<0.001	mg/L	
260408010-307	9	Girl's Locker Room - BF; initial	0.001	<0.001	mg/L	
260408010-308	10	Boy's Locker Room - WF; initial	0.001	<0.001	mg/L	
260408010-309	11	Boy's Locker Room - BF; initial	0.001	<0.001	mg/L	
260408010-310	12	Weight Room - WF; initial	0.001	<0.001	mg/L	
260408010-311	13	Weight Room - BF; initial	0.001	<0.001	mg/L	
260408010-312	14	Room 033 Bridge Academy Office Kitchenette - SK; initial	0.001	0.001	mg/L	
260408010-313	15	Room 033 Bridge Academy Office Kitchenette - SP; initial	0.001	0.001	mg/L	
260408010-314	16	002 Custodial Office Kitchenette - SK; initial	0.001	0.002	mg/L	
260408010-315	17	002 Custodial Office Kitchenette - SP; initial	0.001	<0.001	mg/L	
260408010-316	18	002 Custodial Office Kitchenette - WC; initial	0.001	<0.001	mg/L	
260408010-317	19	Nurse's Office - SP; initial	0.001	0.003	mg/L	
260408010-318	20	Hall by Fitness Office - WF; initial	0.001	0.002	mg/L	
260408010-319	21	Hall by Fitness Office - BF; initial	0.001	0.002	mg/L	
260408010-320	22	Room 011D - Life Skills - SK; initial	0.001	0.001	mg/L	
260408010-321	23	Hall by Guidance Office - WF; initial	0.001	<0.001	mg/L	
260408010-322	24	Hall by Guidance Office - BF; initial	0.001	<0.001	mg/L	
260408010-323	25	Room 105A Librarian's Office - SK; initial	0.001	0.002	mg/L	
260408010-324	26	Hall by Room 124 - WF; initial	0.001	<0.001	mg/L	
260408010-325	27	Hall by Room 124 - BF; initial	0.001	<0.001	mg/L	
260408010-326	28	Hall by Room 113A - WF; initial	0.001	<0.001	mg/L	
260408010-327	29	Hall by Room 113A - BF; initial	0.001	<0.001	mg/L	
260408010-328	30	Hall by Room 202 - WF; initial	0.001	0.006	mg/L	H
260408010-329	31	Hall by Room 224 - WF; initial	0.001	<0.001	mg/L	
260408010-330	32	Hall by Room 224 - BF; initial	0.001	<0.001	mg/L	
260408010-331	33	Hall by Room 216A - WF; initial	0.001	<0.001	mg/L	
260408010-332	34	Hall by Room 216A - BF; initial	0.001	<0.001	mg/L	



Date Collected:	7-Apr-26
Date Received:	8-Apr-26
Date Analyzed:	9-Apr-26

Analytical Method:	EPA 200.9
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
260408010-333	35	Hall by Room 207 - WF; initial	0.001	<0.001	mg/L	
260408010-334	36	Hall by Room 207 - BF; initial	0.001	<0.001	mg/L	
260408010-335	37	Hall by Room 255 - WF; initial	0.001	<0.001	mg/L	
260408010-336	38	Hall by Room 255 - BF; initial	0.001	<0.001	mg/L	
260408010-337	39	8th Grade Wing - Hall by Room 153C - WF; initial	0.001	<0.001	mg/L	
260408010-338	40	8th Grade Wing - Hall by Room 153C - BF; initial	0.001	<0.001	mg/L	
260408010-339	41	8th Grade Wing - Faculty Room 153C - SK; initial	0.001	0.002	mg/L	
260408010-340	42	8th Grade Wing - Band Room 053 - SK; initial	0.001	<0.001	mg/L	
260408010-341	43	8th Grade Wing - Hall by Band Room - WF; initial	0.001	<0.001	mg/L	
260408010-342	44	8th Grade Wing - Hall by Band Room - BF; initial	0.001	<0.001	mg/L	

Comment(s):

LOQ: Limit of Quantitation

CID: Client ID

H: Sample result exceeds applicable regulatory limit.



Appendix G

Glover Field

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0001-01	Girl's Locker Room	WF	App	<1.0	4/7/2026				-
0001-02	Girl's Locker Room	BF	App	<1.0	4/7/2026				-
0001-03	Girl's Locker Room Bathroom - Left	SK	N/A		4/7/2026				Sign
0001-04	Girl's Locker Room Bathroom - Right	SK	N/A		4/7/2026				Mixed Valve; Sign
0001-05	Girl's Locker Room Showers @A	SPY	N/A		4/7/2026				Sign
0001-06	Girl's Locker Room Showers @B	SPY	N/A		4/7/2026				Sign
0001-07	Girl's Locker Room Showers @C	SPY	N/A		4/7/2026				Sign
0001-08	Girl's Locker Room Showers @D	SPY	N/A		4/7/2026				Sign
0001-09	Girl's Locker Room Showers @E	SPY	N/A		4/7/2026				Sign
0001-10	Girl's Locker Room Showers @F	SPY	N/A		4/7/2026				Sign
0001-11	Girl's Locker Room Showers @G	SPY	N/A		4/7/2026				Sign
0001-12	Girl's Locker Room Showers @H	SPY	N/A		4/7/2026				Sign
0002-01	Boy's Locker Room	WF	App	<1.0	4/7/2026				-
0002-02	Boy's Locker Room	BF	App	<1.0	4/7/2026				-
0002-03	Boy's Locker Room Bathroom - Left	SK	N/A		4/7/2026				Mixed Valve; Sign
0002-04	Boy's Locker Room Bathroom - Right	SK	N/A		4/7/2026				Sign
0002-05	Boy's Locker Room Showers @A	SPY	N/A		4/7/2026				Sign
0002-06	Boy's Locker Room Showers @B	SPY	N/A		4/7/2026				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0002-07	Boy's Locker Room Showers @C	SPY	N/A		4/7/2026				Sign
0002-08	Boy's Locker Room Showers @D	SPY	N/A		4/7/2026				Sign
0002-09	Boy's Locker Room Showers @E	SPY	N/A		4/7/2026				Sign
0002-10	Boy's Locker Room Showers @F	SPY	N/A		4/7/2026				Sign
0002-11	Boy's Locker Room Showers @G	SPY	N/A		4/7/2026				Sign
0002-12	Boy's Locker Room Showers @H	SPY	N/A		4/7/2026				Sign
0002-13	Boy's Locker Room Slop Sink	SS	App	7.0	4/7/2026				Removed from Service
0002-14	Boy's Locker Room Ice Machine	IM	App	<1.0	4/7/2026				-
0002-15	Boy's Locker Room Handwash	SK	N/A		4/7/2026				Sign
Exterior	Locker Room Building Exterior	SP	App	3.0	4/7/2026				-
Exterior	Exterior by Locker Room - Left	WF	App	2.0	4/7/2026				-
Exterior	Exterior by Locker Room - Right	WF	App	7.0	4/7/2026				Removed from service; Pending remediation
Exterior	Exterior by Tennis Courts	WF	App	<1.0	4/7/2026				-
Exterior	Exterior by Tennis Courts	BF	App	4.0	4/7/2026				-

Laboratory Report

April 10, 2026

Casey Lee
Enviroscience Consultants, Inc.
2150 Smithtown Ave.
Ronkonkoma, NY, 11779


Project: Pelham UFSD (Glover Field)
Project Address: Glover Field
Report ID: 260408007
Sample IDs: 260408007-228 - 260408007-238

New York Environmental is a NELAC accredited laboratory. Attached reported results meet the requirements of the NELAC standard unless otherwise noted.

Samples' analytical results relate only to the parameters tested for the samples received in the condition received by the laboratory, as noted on the Chain of Custody. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	7-Apr-26
Date Received:	8-Apr-26
Date Analyzed:	9-Apr-26

Analytical Method:	EPA 200.9
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
260408007-228	1	Girl's Locker Room - WF; initial	0.001	<0.001	mg/L	
260408007-229	2	Girl's Locker Room - BF; initial	0.001	<0.001	mg/L	
260408007-230	3	Boy's Locker Room - WF; initial	0.001	<0.001	mg/L	
260408007-231	4	Boy's Locker Room - BF; initial	0.001	<0.001	mg/L	
260408007-232	5	Boy's Locker Room Slop Sink - SS; initial	0.001	0.007	mg/L	H
260408007-233	6	Locker Room Building Exterior - SP; initial	0.001	0.003	mg/L	
260408007-234	7	Exterior by Locker Room - Left - WF; initial	0.001	0.002	mg/L	
260408007-235	8	Exterior by Locker Room - Right - WF; initial	0.001	0.007	mg/L	H
260408007-236	9	Exterior by Tennis Courts - WF; initial	0.001	<0.001	mg/L	
260408007-237	10	Exterior by Tennis Courts - BF; initial	0.001	0.004	mg/L	
260408007-238	11	Boy's Locker Room Ice Machine - IM; initial	0.001	<0.001	mg/L	

Comment(s):

LOQ: Limit of Quantitation

CID: Client ID

H: Sample result exceeds applicable regulatory limit.



Appendix H

Business Office – 314 Pelhamdale

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-01	1st Floor All Gender Bathroom	SK	N/A		4/8/2026				Mixed Valve; Sign
1002-01	Main Room	WF	App	<1.0	4/8/2026				-
1002-02	Main Room	BF	App	<1.0	4/8/2026				-
1003-01	Kitchen	SK	App	<1.0	4/8/2026				-
2001-01	2nd Floor All Gender Bathroom	SK	N/A		4/8/2026				Sign
2002-01	Facility Director's Office Bathroom	SK	N/A		4/8/2026				Sign
3001-01	3rd Floor All Gender Bathroom	SK	N/A		4/8/2026				Sign

Laboratory Report

April 10, 2026

Casey Lee
Enviroscience Consultants, Inc.
2150 Smithtown Ave.
Ronkonkoma, NY, 11779


Project: Pelham UFSD (314 Pelhamdale - Business Office)
Project Address: 314 Pelhamdale - Business Office
Report ID: 260408003
Sample IDs: 260408003-078 - 260408003-081

New York Environmental is a NELAC accredited laboratory. Attached reported results meet the requirements of the NELAC standard unless otherwise noted.

Samples' analytical results relate only to the parameters tested for the samples received in the condition received by the laboratory, as noted on the Chain of Custody. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

NYE Report #: 260408003

Date Collected:	8-Apr-26
Date Received:	8-Apr-26
Date Analyzed:	9-Apr-26

Analytical Method:	EPA 200.9
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
260408003-078	1	Main Room - WF; initial	0.001	<0.001	mg/L	
260408003-080	2	Main Room - BF; initial	0.001	<0.001	mg/L	
260408003-081	3	Kitchen - SK; initial	0.001	<0.001	mg/L	

Comment(s):

LOQ: Limit of Quantitation

CID: Client ID

