

Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

April 07, 2026

Batch #: 040726-2

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1900 Morningside Dr Bldg. - City High
School
Iowa City IA 52245

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

The Results are as follows:

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SNF027	SST	1303	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	2.1
SNK501	SST	1104	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.9
SNL313	SST	1701	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	1.5
SNL341	SST	1207B	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	<LLD
SNL380	SST	1801 GYM	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	<LLD
SNL409	SST	1207A	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	<LLD
SNL424	SST	1110	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	1.1
SNL447	SST	1102B1	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.6
SNL460	SST	1311	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	4.7
SNL467	SST	408	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.8
SNL469	SST	1810	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	2.6
SNL471	SST	1701	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	1.3
SNL477	SST	1210	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.4
SNL492	SST	1209	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.5
SNL575	SST	1107	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.7
SNL577	SST	1111	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.7
SNL581	SST	012 WRESTLING	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.7
SNL731	SST	401	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.6
SNL744	SST	1810A	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	4.0
SNM720	SST	1813	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	8.6
SNN844	SST	1106	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	1.3
SNU202	SST	1810	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	2.7
SNU292	SST	1705	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	1.4
SNU319	SST	1305	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	3.3
SNU462	SST	1701	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	1.0
SNU469	SST	1202B	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	<LLD
SNU488	SST	1102	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	1.1
SNU501	SST	1314	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	2.0
SNU524	SST	1101	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.7
SNU566	SST	1208	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	<LLD
SNU661	SST	031	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	<LLD
SNU749	SST	1313	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	2.1
SNU804	SST	1801 GYM	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.7
SNW993	SST	1801 GYM	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	<LLD
SNX006	SST	1202A	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.6
SNX032	SST	1108	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	1.0

Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

April 07, 2026

Batch #: 040726-2

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1900 Morningside Dr Bldg. - City High
School
Iowa City IA 52245

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SNX039	SST	031	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	<LLD
SNX059	SST	1402 SECOND FLOOR	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.5
SNX063	SST	1801 GYM	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.5
SNX080	SST	2703 SECOND FLOOR	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	1.1
SNX092	SST	1203	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	<LLD
SNX095	SST	1112	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	1.2
SNX104	SST	1801 GYM	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.6
SNX105	SST	1107	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.5
SNX171	SST	1814	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	3.4
SNX176	SST	1204	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	<LLD
SNX240	SST	1211	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.6
SNX269	SST	031	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	<LLD
SOA606	SST	1110d	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	1.1
SOV212	SST	1304	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	3.0
SOV275	SST	1407 SECOND FLOOR	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	1.0
SOV283	SST	1703	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	1.7
SOV312	SST	1114	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	1.8
SOV737	SST	400	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.7
SOV761	SST	1212	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	1.2
SOV803	SST	031	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	<LLD
SOV808	SST	1213	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	<LLD
SOV812	SST	1316	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	2.4
SOV818	SST	1808b	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	2.3
SOV837	SST	023	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.7
SOV844	SST	010 BREAK ROOM	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	<LLD
SOV879	SST	031	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	<LLD
SOV902	SST	406	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.5
SOV910	SST	1808c	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	2.1
SOV962	SST	1514 SECOND FLOOR	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	1.0
SOV970	SST	010 BREAK ROOM	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	1.3
SOV994	SST	1312	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	4.1
SOW004	SST	1202D	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	<LLD
SOW021	SST	1113	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.7
SOW067	SST	2702 SECOND FLOOR	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.7
SOW075	SST	1801 GYM	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.7
SOW078	SST	031	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.5
SOW142	SST	1205	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	<LLD
SOW174	SST	1201	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.9
SOW183	SST	1801D OFFICE	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	3.7

Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

April 07, 2026

Batch #: 040726-2

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1900 Morningside Dr Bldg. - City High
School
Iowa City IA 52245

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SOW199	SST	1701 SECOND FLOOR	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.7
SOW250	SST	012 WRESTLING	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.9
SOW284	SST	1110b	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	1.0
SOW309	SST	022	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.9
SOW360	SST	1810A	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	4.1
SOW368	SST	1310	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	3.7
SOW383	SST	1207	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	<LLD
SOW457	SST	012 WRESTLING	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	1.2
SOW477	SST	1808	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	2.1
SOW629	SST	1214	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	<LLD
SPL044	SST	1202C	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.7
SPL094	SST	1507 SECOND FLOOR	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	1.2
SOV361	SST	1114a	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	1.6
SOW351	SST	1114a	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	1.9
Average Radon Concentration in:			1114a				1.7 pCi/L
SMV427	SST	009 KITCHEN OFFICE	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.5
SNU494	SST	009 KITCHEN OFFICE	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.7
Average Radon Concentration in:			009 KITCHEN OFFICE				0.6 pCi/L
SNL319	SST	021	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.8
SNL405	SST	021	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.8
Average Radon Concentration in:			021				0.8 pCi/L
SNL579	SST	403	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	1.1
SOW063	SST	403	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	1.1
Average Radon Concentration in:			403				1.1 pCi/L
SNL560	SST	1109	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.7
SOW472	SST	1109	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.5
Average Radon Concentration in:			1109				0.6 pCi/L
SNX053	SST	1211a	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	<LLD
SNX184	SST	1211a	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	<LLD
Average Radon Concentration in:			1211a				<LLD pCi/L
SOV901	SST	1105	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.5
SOW339	SST	1105	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	<LLD
Average Radon Concentration in:			1105				0.5 pCi/L

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

April 07, 2026

Batch #: 040726-2

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1900 Morningside Dr Bldg. - City High
School
Iowa City IA 52245

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SNL331	SST	1307	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	2.6
SNU713	SST	1307	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	3.0
Average Radon Concentration in:			1307		2.8 pCi/L		
SOV323	SST	1315	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	2.6
SOV814	SST	1315	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	2.8
Average Radon Concentration in:			1315		2.7 pCi/L		
SNX089	SST	1809	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	4.1
SOW286	SST	1809	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	3.8
Average Radon Concentration in:			1809		3.9 pCi/L		
SNL310	SST	1816	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	3.4
SNL508	SST	1816	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	3.3
Average Radon Concentration in:			1816		3.3 pCi/L		
SNU349	SST	106 UPPER COMMONS	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.7
SNU624	SST	106 UPPER COMMONS	23-Mar-2026	12:45 PM	26-Mar-2026	10:45 AM	0.5
Average Radon Concentration in:			106 UPPER COMMONS		0.6 pCi/L		

Deployed By: Sam Becker RNTST10096

Retrieved By: Sam Becker RNTST10096

Analyzed By: Sam Becker RNTST10096

Reader S/N: E1549 Reader Calibration Due: 10/24/2026

Conditions: Requirements for Closed-Building Met

Weather: No Abnormal Weather Conditions

Vents: Open / Fan Auto

Mitigation: No System Installed

Note: <LLD = Less than the Lower Limit of Detection (LLD) of the Radon Detector.

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: _____ Date: _____

Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

April 14, 2026

Batch #: 040826-2

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
3100 E Washington St Bldg.- LEMME
ELEMENTARY SCHOOL
Iowa City IA 52245

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

The Results are as follows:

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SOW509	SST	RECEPTION 134	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	1.7
SOA644	SST	134A	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	4.8
SOV962	SST	134B	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	1.9
SNL559	SST	134D	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	3.7
SNX022	SST	133	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	1.5
SOW396	SST	134F	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	1.5
SPL057	SST	125	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	2.7
SNX268	SST	126	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	3.2
SNL489	SST	131	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	2.0
SNU669	SST	127	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	3.7
SOW051	SST	130	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	1.7
SNL548	SST	129	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	2.9
SNX008	SST	128	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	1.8
SOV876	SST	128	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	2.4
SOW234	SST	124	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	2.2
SPL035	SST	101	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	2.6
SNU462	SST	117	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	0.8
SOV895	SST	117A	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	1.7
SOW125	SST	103	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	0.9
SNU499	SST	102	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	2.6
SOW199	SST	105	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	3.2
SOV235	SST	104	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	0.5
SOV789	SST	106	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	0.7
SNU504	SST	107	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	0.6
SNX029	SST	109	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	0.7
SNL562	SST	108	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	1.4
SOV869	SST	110	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	0.5
SOV853	SST	112	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	0.8
SNU553	SST	113	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	<LLD
SOP140	SST	115	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	0.5
SNK456	SST	113	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	0.4
SNX161	SST	139	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	1.6
SOW173	SST	143	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	1.9
SNU484	SST	111	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	1.1
SNU633	SST	144	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	3.9
SNL590	SST	135A	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	1.9

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

April 14, 2026

Batch #: 040826-2

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
3100 E Washington St Bldg.- LEMME
ELEMENTARY SCHOOL
Iowa City IA 52245

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SOA602	SST	134C	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	2.9
SNX039	SST	134C	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	1.1
Average Radon Concentration in:				134C		2.0 pCi/L	
SOV886	SST	132	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	0.7
SNX254	SST	132	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	0.8
Average Radon Concentration in:				132		0.7 pCi/L	
SOV729	SST	123	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	3.3
SOW481	SST	123	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	4.6
Average Radon Concentration in:				123		3.9 pCi/L	
SOV734	SST	117	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	1.0
SNL335	SST	117	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	0.8
Average Radon Concentration in:				117		0.9 pCi/L	
SNU324	SST	140	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	1.6
SNL305	SST	140	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	1.2
Average Radon Concentration in:				140		1.4 pCi/L	
SNL673	SST	145	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	2.6
SNU735	SST	145	30-Mar-2026	2:05 PM	02-Apr-2026	1:00 PM	2.1
Average Radon Concentration in:				145		2.4 pCi/L	
Deployed By:	Sam Becker	RNTST10096					
Retrieved By:	Sam Becker	RNTST10096					
Analyzed By:	Sam Becker	RNTST10096					
Reader S/N:	E1549	Reader Calibration Due: 10/24/2026					

Note: <LLD = Less than the Lower Limit of Detection (LLD) of the Radon Detector.

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.

Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

April 14, 2026

Batch #: 040926-2

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1507 8th St Bldg.- NORTHWEST
MIDDLE SCHOOL
Coralville IA 52241

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

The Results are as follows:

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SNX080	SST	142	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.1
SNN844	SST	141	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.1
SNL575	SST	140	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.8
SOW021	SST	139	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.0
SNL341	SST	144	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.4
SNX006	SST	144A	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.5
SNU749	SST	144B	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.0
SOW457	SST	150	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.0
SNU494	SST	150A	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.0
SOW309	SST	145	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	2.0
SOV970	SST	232B	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.7
SNU349	SST	232A	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	<LLD
SMV427	SST	229	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.3
SNX092	SST	228	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.4
SNL313	SST	227	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.5
SOV312	SST	226	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.8
SNL331	SST	225	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.8
SOW383	SST	224	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.0
SNX059	SST	222	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.6
SNL577	SST	221	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.0
SOW078	SST	220	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	3.2
SOW068	SST	219	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	2.3
SOV902	SST	2420	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	2.5
SOV901	SST	242	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.0
SNU292	SST	242	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.6
SPL044	SST	242	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.8
SOW183	SST	242H	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.8
SOW075	SST	242I	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.6
SNL508	SST	242M	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.1
SNX171	SST	242B	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.4
SNU202	SST	285	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	<LLD
SOA606	SST	286	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.5
SNU488	SST	287	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	2.4
SNM720	SST	288A	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	2.1
SNW993	SST	272	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.5
SNX228	SST	270	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	<LLD

Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

April 14, 2026

Batch #: 040926-2

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1507 8th St Bldg.- NORTHWEST
MIDDLE SCHOOL
Coralville IA 52241

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SOW339	SST	269	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	<LLD
SNX032	SST	273	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.7
SNL553	SST	102	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.5
SOV236	SST	102A	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	4.9
SNX005	SST	102B	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.2
SOV992	SST	102C	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.3
SPL090	SST	103	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.3
SNU558	SST	103B	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.5
SOW412	SST	111	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.5
SOV744	SST	111	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.0
SNX136	SST	164	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	2.0
SNL322	SST	117B	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.9
SOV879	SST	118	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.3
SNU624	SST	118D	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.8
SNX062	SST	118A	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	2.8
SOW250	SST	118B	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.7
SNL731	SST	122	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	<LLD
SNU533	SST	123	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	2.1
SOV227	SST	163E	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	2.5
SOV844	SST	125	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	<LLD
SNL467	SST	156	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	<LLD
SPL094	SST	126	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.4
SNL581	SST	129A	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.5
SNU566	SST	154	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.5
SOV361	SST	151A	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.0
SNL492	SST	151B	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.0
SNX240	SST	151C	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.7
SOV814	SST	151F	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	2.3
SNL310	SST	274	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	<LLD
SNL469	SST	268	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	<LLD
SOW065	SST	267	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.8
SNU524	SST	265	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	<LLD
SNM776	SST	264	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	
SOV910	SST	263	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.8
SNL424	SST	262	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	<LLD
SNU713	SST	261	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.5
SNX250	SST	259	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	<LLD
SOW058	SST	256	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.5
SNU562	SST	255	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.1

Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

April 14, 2026

Batch #: 040926-2

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1507 8th St Bldg.- NORTHWEST
MIDDLE SCHOOL
Coralville IA 52241

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SNU590	SST	254	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.7
SNT780	SST	253	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.6
SNL357	SST	252	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	<LLD
SNL458	SST	251	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	<LLD
SOW008	SST	250	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.0
SOV811	SST	218	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.0
SOW009	SST	217	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.0
SOW004	SST	2216	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.8
SNL744	SST	242F	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.8
SNX063	SST	242E	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.0
SOV818	SST	242D	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.0
SNL380	SST	215	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.3
SNX176	SST	214	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.9
SOW174	SST	242C	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.4
SNF027	SST	242A	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.6
SOW477	SST	2428	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.8
SNU319	SST	2420	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.1
SOV808	SST	234	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.0
SOV761	SST	210	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	2.5
SNU469	SST	208	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.3
SNX104	SST	207	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.4
SNL471	SST	206	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.2
SOV283	SST	205	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.5
SOV803	SST	204	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.6
SNL579	SST	203	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.4
SNL490	SST	202	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	2.0
SOV737	SST	201	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.4
SOW067	SST	282	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.2
SOW472	SST	282A	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	4.0
SOW351	SST	282B	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.0
SNX276	SST	282E	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.0
SNX097	SST	280	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.7
SOV299	SST	278	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.4
SNX229	SST	283	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	<LLD
SNL383	SST	284	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.7
SOV828	SST	102D	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.2
SNX120	SST	102D	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.6

Average Radon Concentration in:

102D

1.4 pCi/L

Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

April 14, 2026

Batch #: 040926-2

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1507 8th St Bldg.- NORTHWEST
MIDDLE SCHOOL
Coralville IA 52241

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SNX095	SST	266	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	<LLD
SNK501	SST	266	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.8
Average Radon Concentration in:			266		0.6 pCi/L		
SOA024	SST	260	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.7
SNU555	SST	260	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.5
Average Radon Concentration in:			260		0.6 pCi/L		
SOW629	SST	241	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.4
SOV994	SST	241	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.9
Average Radon Concentration in:			241		0.7 pCi/L		
SOW360	SST	209	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.5
SOV812	SST	209	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.5
Average Radon Concentration in:			209		1.5 pCi/L		
SOW284	SST	282C	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.8
SNL405	SST	282C	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.0
Average Radon Concentration in:			282C		0.9 pCi/L		
SNL385	SST	166A	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	9.8
SOV381	SST	166A	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	10.5
Average Radon Concentration in:			166A		10.1 pCi/L		
SOV891	SST	117	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	2.5
SNU737	SST	117	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.2
Average Radon Concentration in:			117		1.8 pCi/L		
SNU603	SST	155	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.8
SOV275	SST	155	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.6
Average Radon Concentration in:			155		1.2 pCi/L		
SNL447	SST	138	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.3
SNX105	SST	138	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.4
Average Radon Concentration in:			138		1.3 pCi/L		
SNU501	SST	146	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.3
SOV212	SST	146	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.0
Average Radon Concentration in:			146		1.1 pCi/L		

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

April 14, 2026

Batch #: 040926-2

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1507 8th St Bldg.- NORTHWEST
MIDDLE SCHOOL
Coralville IA 52241

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SOW063	SST	223	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	1.0
SNL319	SST	223	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.7
Average Radon Concentration in:			223		0.8 pCi/L		
SOW286	SST	242K	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.8
SNU804	SST	242K	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	0.6
Average Radon Concentration in:			242K		0.7 pCi/L		
SNX184	SST	288	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	2.4
SNL477	SST	288	30-Mar-2026	9:50 AM	02-Apr-2026	3:10 AM	2.4
Average Radon Concentration in:			288		2.4 pCi/L		

Deployed By: Sam Becker RNTST10096

Retrieved By: Sam Becker RNTST10096

Analyzed By: Sam Becker RNTST10096

Reader S/N: E1549

Reader Calibration Due: 10/24/2026

Note: <LLD = Less than the Lower Limit of Detection (LLD) of the Radon Detector.

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: _____ Date: _____

Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

April 14, 2026

Batch #: 040826-1

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1400 Grissel Pl Bldg.- SHIMEK
ELEMENTARY SCHOOL
Iowa City IA 52245

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

The Results are as follows:

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SOV298	SST	100	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	1.6
SNK478	SST	100B	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	1.7
SNM817	SST	100C	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	1.7
SNX054	SST	100D	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	1.2
SNX116	SST	102	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	0.6
SOV872	SST	102	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	0.6
SNL491	SST	104	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	<LLD
SNT758	SST	104	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	<LLD
SNU515	SST	104a	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	1.1
SNX199	SST	106	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	1.6
SOA200	SST	140	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	2.3
SNL705	SST	138	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	1.9
SNN982	SST	136	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	2.4
SNL397	SST	132	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	2.1
SOV750	SST	130	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	7.0
SNL574	SST	126	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	0.8
SOV751	SST	126	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	0.9
SNL468	SST	126A	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	2.3
SNL379	SST	126C	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	0.7
SNL476	SST	126D	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	<LLD
SNN815	SST	129	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	1.1
SNX000	SST	127	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	2.0
SOW073	SST	133	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	1.7
SOV896	SST	123	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	0.6
SNL465	SST	117	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	0.8
SOW288	SST	115	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	1.2
SOV889	SST	121	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	1.2
SPL015	SST	116	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	0.9
SOV975	SST	105	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	0.8
SNX256	SST	110	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	2.4
SNX099	SST	108	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	1.3
SNL488	SST	100A	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	1.3
SOV871	SST	100A	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	1.2

Average Radon Concentration in:

100A

1.3 pCi/L

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

April 14, 2026

Batch #: 040826-1

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1400 Grissel Pl Bldg.- SHIMEK
ELEMENTARY SCHOOL
Iowa City IA 52245

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SPL049	SST	134	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	2.2
SNL329	SST	134	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	1.7
Average Radon Concentration in:			134		2.0 pCi/L		
SNL592	SST	131	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	0.9
SNX130	SST	131	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	1.0
Average Radon Concentration in:			131		0.9 pCi/L		
SNU569	SST	119	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	0.5
SNL306	SST	119	30-Mar-2026	8:50 AM	02-Apr-2026	12:20 PM	0.5
Average Radon Concentration in:			119		0.5 pCi/L		

Deployed By: Sam Becker RNTST10096

Retrieved By: Sam Becker RNTST10096

Analyzed By: Sam Becker RNTST10096

Reader S/N: E1549

Reader Calibration Due: 10/24/2026

Note: <LLD = Less than the Lower Limit of Detection (LLD) of the Radon Detector.

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: _____ Date: _____

Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

April 14, 2026

Batch #: 040926-1

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
3850 Rohret Rd Bldg.- WEBER
ELEMENTARY SCHOOL
Iowa City IA 52246

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

The Results are as follows:

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SML597	SST	202	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	1.8
SNE905	SST	112	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	<LLD
SNK538	SST	110E	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	1.1
SNL378	SST	513	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	<LLD
SNL456	SST	102	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	0.6
SNL503	SST	406	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	1.0
SNL546	SST	507	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	0.7
SNL561	SST	410	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	0.8
SNL578	SST	131 RECEPTION	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	2.3
SNL607	SST	305	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	0.7
SNT909	SST	408	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	<LLD
SNU490	SST	112	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	1.0
SNU510	SST	115 BAND	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	2.7
SNU547	SST	523 GYM	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	0.8
SNU574	SST	110	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	1.1
SNU614	SST	525	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	0.4
SNU630	SST	207	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	3.2
SNU772	SST	519	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	<LLD
SNX012	SST	105	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	0.5
SNX013	SST	504	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	0.4
SNX031	SST	208	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	1.9
SNX070	SST	510	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	0.7
SNX089	SST	301	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	1.6
SNX091	SST	206 *	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	1.7
SNX113	SST	110 D/C	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	0.6
SNX121	SST	113 ART	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	<LLD
SNX157	SST	136	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	1.1
SNX185	SST	134 NURSE	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	1.0
SNX191	SST	310	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	1.0
SNX221	SST	523 GYM	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	<LLD
SOP403	SST	509	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	0.8
SOV265	SST	401	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	<LLD
SOV271	SST	205	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	3.1
SOV284	SST	508	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	1.0
SOV323	SST	204	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	1.8
SOV771	SST	110	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	0.8

Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

April 14, 2026

Batch #: 040926-1

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
3850 Rohret Rd Bldg.- WEBER
ELEMENTARY SCHOOL
Iowa City IA 52246

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SOV786	SST	404	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	0.5
SOV799	SST	511	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	<LLD
SOV806	SST	135	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	0.8
SOV884	SST	407	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	0.9
SOV908	SST	117 MUSIC	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	<LLD
SOV965	SST	405	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	0.9
SOW043	SST	306	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	<LLD
SOW056	SST	210	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	1.5
SOW062	SST	515	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	0.6
SOW095	SST	506	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	1.0
SOW489	SST	307	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	1.0
SPK858	SST	309	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	2.9
SPK861	SST	401	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	1.9
SPL060	SST	521	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	<LLD
SNL401	SST	132 PRINCIPAL	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	2.5
SNU661	SST	132 PRINCIPAL	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	0.7
Average Radon Concentration in:			132 PRINCIPAL				1.6 pCi/L
SOV759	SST	209	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	<LLD
SOW519	SST	209	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	3.0
Average Radon Concentration in:			209				1.7 pCi/L
SOW170	SST	308	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	1.5
SPK866	SST	308	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	1.3
Average Radon Concentration in:			308				1.4 pCi/L
SOV349	SST	409	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	1.1
SOV980	SST	409	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	1.0
Average Radon Concentration in:			409				1.0 pCi/L
SNM865	SST	505	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	0.9
SNX283	SST	505	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	0.9
Average Radon Concentration in:			505				0.9 pCi/L
SNU800	SST	517	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	<LLD
SNX048	SST	517	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	<LLD
Average Radon Concentration in:			517				<LLD pCi/L
SNT742	SST	107 WORK ROOM	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	0.7
SOW066	SST	107 WORK ROOM	30-Mar-2026	12:40 AM	02-Apr-2026	2:10 AM	<LLD
Average Radon Concentration in:			107 WORK ROOM				0.5 pCi/L

Shive-Hattery

2839 Northgate Drive
Iowa City IA 52445
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)
<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

April 14, 2026

Batch #: 040926-1

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
3850 Rohret Rd Bldg.- WEBER
ELEMENTARY SCHOOL
Iowa City IA 52246

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SNL556	SST	121/119 CUSTODIAN	30-Mar-2026 12:40 AM	02-Apr-2026 2:10 AM	1.0
SOV339	SST	121/119 CUSTODIAN	30-Mar-2026 12:40 AM	02-Apr-2026 2:10 AM	1.3
Average Radon Concentration in:			121/119 CUSTODIAN		1.1 pCi/L

Deployed By: Sam Becker RNTST10096

Retrieved By: Sam Becker RNTST10096

Analyzed By: Sam Becker RNTST10096

Reader S/N: E1549

Reader Calibration Due: 10/24/2026

Note: <LLD = Less than the Lower Limit of Detection (LLD) of the Radon Detector.

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: _____ Date: _____

Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

April 17, 2026

Batch #: 041726-3

Customer:

Iowa City Community School District
1155 S. Riverside Drive
Iowa City IA 52246

Test Site:

Jarod Tylee
1137 S. Riverside Drive Bldg.- Physical
Plant
Iowa City IA 52246

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

The Results are as follows:

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SNL378	SST	RECEPTION 42	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	2.6
SNL561	SST	DIRECTOR 43	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	2.1
SNT742	SST	CONSTRUCTION PROJECTS MANAGER	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	2.5
SNU522	SST	OFFICE 38	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	2.0
SNU574	SST	PLUMBING SHOP	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	1.2
SNU614	SST	PLAN ROOM	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	1.0
SNU630	SST	LOGISTICS AND WAREHOUSE	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	1.6
SNX012	SST	PURCHASE 39	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	2.4
SNX013	SST	TRAINING ROOM	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	1.5
SNX157	SST	CONFERENCE ROOM	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	1.4
SNX191	SST	CONSTRUCTION PROJECTS MANAGER	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	1.8
SNX221	SST	MECHANIC OFFICE	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	1.9
SNX283	SST	KEYSHOP	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	1.4
SOP403	SST	HEALTH AND SAFETY OFFICE	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	1.9
SOV265	SST	GROUNDWORKS MANAGER	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	1.8
SOV323	SST	CUSTODIAL MANAGER	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	2.0
SOV349	SST	111	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	1.6
SOV759	SST	DAY SUBS	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	1.3
SOV771	SST	ASSISTANT FACILITY DIRECTOR	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	1.8
SOV965	SST	ELECTRICAL SHOP	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	1.3
SOW043	SST	HVAC SHOP	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	2.0
SOW056	SST	CABINET SHOP OFFICE	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	1.1
SOW062	SST	DIRECTORS OFFICE	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	1.8
SOW066	SST	107 GROUNDS	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	0.6
SOW095	SST	114 FOOD WAREHOUSE OFFICE	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	0.6
SOW170	SST	BREAKROOM	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	2.1
SPL097	SST	WORK ROOM 37	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	2.6

Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / sbecker@shive-hattery.com

Radon Test Report

April 17, 2026

Batch #: 041726-3

Customer:

Iowa City Community School District

1155 S. Riverside Drive

Iowa City IA 52246

Test Site:

Jarod Tylee

1137 S. Riverside Drive Bldg.- Physical
Plant

Iowa City IA 52246

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SNX185	SST	FRONT OFFICE	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	1.6
SOV980	SST	FRONT OFFICE	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	1.8
Average Radon Concentration in:			FRONT OFFICE				1.7 pCi/L
SNX113	SST	INFO SYSTEMS SPECIALIST	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	2.5
SOV908	SST	INFO SYSTEMS SPECIALIST	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	1.8
Average Radon Concentration in:			INFO SYSTEMS SPECIALIST				2.2 pCi/L
SNL518	SST	MEETING 44	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	2.6
SNT909	SST	MEETING 44	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	3.6
Average Radon Concentration in:			MEETING 44				3.1 pCi/L
SNL401	SST	108 BREAKROOM	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	1.4
SNX233	SST	108 BREAKROOM	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	1.1
Average Radon Concentration in:			108 BREAKROOM				1.3 pCi/L
SNU661	SST	BREAK ROOM	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	1.1
SOV837	SST	BREAK ROOM	07-Apr-2026	9:36 AM	09-Apr-2026	10:30 AM	0.8
Average Radon Concentration in:			BREAK ROOM				1.0 pCi/L
Deployed By:	Sam Becker	RNTST10096					
Retrieved By:	Sam Becker	RNTST10096					
Analyzed By:	Sam Becker	RNTST10096					
Reader S/N:	E1549	Reader Calibration Due: 10/24/2026					

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.