



**Business Services
Contracts Office**

5735 47th Avenue • Sacramento, CA 95824
(916) 643-2464

*Lisa Grant-Dawson, Interim Chief Business Officer
Robert Aldama, Purchasing Manager II*

ADDENDUM NO. 1

Date: May 6, 2026

Issued by: Sacramento City Unified School District

**Project: Project #: 26-060426
Recoating Gym and Dance Flooring**

This addenda shall supersede the original Information, attachments, and specifications regarding Project No. 26-043026 where it adds to, deletes from, clarifies or otherwise modifies them. All other conditions and any previous addenda shall remain unchanged.

Part A – Bidding and Contract Requirements

AD1.01 QUESTIONS

In reviewing the Scope of work I noticed it requires one coat of sealer and one coat of finish.

AD1.01 ANSWER

Refer to the Project Manual.

AD1.02 QUESTION

Hillyard Court Guard sealer is not a recommended practice to use under Diamond 1K. Diamond 1K is designed to be used as two coats.

AD1.02 ANSWER

If you use Hillyard court Guard, this should partner with Trophy H20 and the cross linker. If you use Diamond1K, this needs to be done with 2 coats of Diamond to be equivalent or better than the Spec.

AD1.03 QUESTION

Hillyard Trophy H20 gym finish on top of Courtguard is fine but a significant cost increase in Courtguard/Trophy H20 compared to two coats of Diamond 1K.

Project No: 26-060426
Recoating Gym and Dance Flooring at Multiple Sites
ADDENDUM NO. 1

AD1.03 ANSWER

Refer to the Project Manual.

AD1.04 QUESTION

Can we quote two coats of Diamond 1K?

AD1.04 ANSWER

Yes

AD1.05 QUESTION

Please see the attached Substitution Request for Bid No> 26-06026, Recoating Gym and Dance Flooring.

Specified Product: Hillyard Court Guard Seal
Hillyard Diamond 1K Finish
Hillyard Trophy H20 Finish

Substitution: GameTime Coatings Hybild Sealer : Equal and/or better
GameTime Coatings 1K Finish: equal and/or better
GameTime Coatings Xcel Finish: equal and or better

Product Data Sheets and SDS Attached

***Note- All material is made in Little Rock, AR and ships locally from our Sacramento based distribution center**

AD1.05 ANSWER

Substitution request is not approved. Please provide bid quote based on the 3 options provided

AD1.06 SCOPE OF WORK

Luther Burbank High School and small gym at Hiram Johnson HS scope has been removed from 26-06426 project.

Project No: 26-060426
Recoating Gym and Dance Flooring at Multiple Sites
ADDENDUM NO. 1

Attachments –
Revised Scope of Work

END OF ADDENDUM NO. 1

Acknowledgement of this Addendum will be required at time of bid: