



Adopted 10/29/2025

Updated 2/9/2026

College Place Middle School

Action Plan: Lead in Drinking Water

School Information

School Name(s): College Place Middle School

School District: Edmonds School District

County: Snohomish

Sampling and Testing Information

School Name	Sampling Date	Date Test Results Received	Sampling and Testing Provider
College Place MS	10/2/2025	10/28/2025	Washington State Dept of Health
College Place MS	12/8/2025	12/31/2025	Washington State Dept of Health

Testing Requirements

[RCW 28A.210.410](#) and [RCW 43.70.830](#) require all drinking water outlets in public schools built, or with all plumbing replaced, before 2016 be tested for lead at least once between July 1, 2014, and June 30, 2026. Retesting shall occur at least once every five years thereafter. Drinking water sampling and testing must be done in partnership with DOH or contracted through an [accredited lab](#).

Action Plan Requirements

If test results reveal elevated lead levels above 5 parts per billion (ppb) at any outlet used for drinking or cooking, an action plan must be developed. If your school has an existing action plan, you have the option of updating the existing plan to meet the following requirements instead of creating a new one.

Per [RCW 28A.210.410](#), a school's action plan must meet the following requirements:

- The action plan shall be developed in consultation with DOH or your local health jurisdiction and in accordance with [DOH's technical guidance](#).
- Consult with the Office of the Superintendent of Public Instruction (OSPI) when seeking funding for remediation activities. The OSPI [Lead in Water Remediation Grant](#) is a potential source of funding.
- Before the action plan is officially adopted, it must be shared publicly with opportunity for public comment.
- For testing that occurred after July 25, 2021, the deadline for adopting the action plan is six months after receiving elevated lead test results.
- The action plan must include:
 - 1) **Mitigation measures** implemented since receiving elevated lead test results.
 - 2) A schedule of **remediation activities** that adhere to the [technical guidance](#). The schedule may be based on the availability of state or federal funding for remediation activities.
 - 3) A plan for **post-remediation sampling and testing** to confirm remediation activities have reduced lead concentrations at drinking water outlets to 5 or fewer ppb.

Action Plan

Mitigation Measures

Mitigation measures are immediate (temporary or permanent) actions, such as shutting off an outlet or marking as “hand wash only,” to stop access to drinking water with elevated lead concentrations. Outlets with lead concentrations exceeding 15 ppb must be shut off immediately upon receiving test results in accordance with the [technical guidance](#).

1st Remediation Results - Not all remediations were complete, so not all locations were tested this round.

College Place MS has identified 4 drinking water outlets with elevated lead levels requiring mitigation. **Mitigation measures** have been implemented as follows:

	Sample Collection Date	Sample ID	School Name Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure (Indicate temporary or permanent)	Date Implemented
1)	12/8/2025	413220	College Place MS	Sink Fixture	17	Water shut off, temporary water stations provided as needed	Nov 2025
2)	12/8/2025	413227	College Place MS	Water Fountain	17	Water shut off, temporary water stations provided as needed	Nov 2025
3)	12/8/2025	413221	College Place MS	Sink Fixture	10	Water shut off, temporary water stations provided as needed	Nov 2025
4)	12/8/2025	413219	College Place MS	Sink Fixture	6	Water shut off, temporary water stations provided as needed	Nov 2025

Initial Results

College Place MS has identified 21 drinking water outlets with elevated lead levels requiring mitigation. **Mitigation measures** have been implemented as follows:

	Sample Collection Date	Sample ID	School Name Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure (Indicate temporary or permanent)	Date Implemented
1)	10/2/2025	412125	College Place MS	Sink Fixture	23	Water shut off, temporary water stations provided as needed	Nov 2025
2)	10/2/2025	412117	College Place MS	Sink Fixture	22	Water shut off, temporary water stations provided as needed	Nov 2025
3)	10/2/2025	412094	College Place MS	Sink Fixture	18	Water shut off, temporary water stations provided as needed	Nov 2025
4)	10/2/2025	412107	College Place MS	Water Fountain	18	Water shut off, temporary water stations provided as needed	Nov 2025
5)	10/2/2025	412115	College Place MS	Sink Fixture	16	Water shut off, temporary water stations provided as needed	Nov 2025
6)	10/2/2025	412127	College Place MS	Sink Fixture	15	Water shut off, temporary water stations provided as needed	Nov 2025
7)	10/2/2025	412093	College Place MS	Sink Fixture	12	Water shut off, temporary water stations provided as needed	Nov 2025
8)	10/2/2025	412108	College Place MS	Sink Fixture	12	Water shut off, temporary water stations provided as needed	Nov 2025

9)	10/2/2025	412112	College Place MS	Sink Fixture	12	Water shut off, temporary water stations provided as needed	Nov 2025
10)	10/2/2025	412106	College Place MS	Sink Fixture	11	Water shut off, temporary water stations provided as needed	Nov 2025
11)	10/2/2025	412116	College Place MS	Water Fountain	11	Water shut off, temporary water stations provided as needed	Nov 2025
12)	10/2/2025	412111	College Place MS	Sink Fixture	10	Water shut off, temporary water stations provided as needed	Nov 2025
13)	10/2/2025	412097	College Place MS	Sink Fixture	9	Water shut off, temporary water stations provided as needed	Nov 2025
14)	10/2/2025	412110	College Place MS	Water Fountain	9	Water shut off, temporary water stations provided as needed	Nov 2025
15)	10/2/2025	412126	College Place MS	Sink Fixture	9	Water shut off, temporary water stations provided as needed	Nov 2025
16)	10/2/2025	412098	College Place MS	Sink Fixture	8	Water shut off, temporary water stations provided as needed	Nov 2025
17)	10/2/2025	412090	College Place MS	Sink Fixture	7	Water shut off, temporary water stations provided as needed	Nov 2025
18)	10/2/2025	412113	College Place MS	Water Fountain	7	Water shut off, temporary water stations provided as needed	Nov 2025
19)	10/2/2025	412121	College Place MS	Water Fountain	7	Water shut off, temporary water stations provided as needed	Nov 2025

20)	10/2/2025	412092	College Place MS	Sink Fixture	6	Water shut off, temporary water stations provided as needed	Nov 2025
21)	10/2/2025	412103	College Place MS	Water Fountain	6	Water shut off, temporary water stations provided as needed	Nov 2025

Remediation Schedule

Remediation activities are short-term or permanent control measures to reduce lead concentrations in drinking water to 5 ppb or less. Per RCW 28A.210.410, outlets that have elevated lead levels (above 5 ppb) must be identified, remediated (if not permanently mitigated), and retested. Refer to the [technical guidance](#) for remediation options.

1st Remediation Results - Not all remediations were complete, so not all locations were tested this round.

College Place MS has identified 4 drinking water outlets with elevated lead levels requiring remediation. (Outlets listed in the previous table with **temporary** mitigation measures are repeated in the table below.) **Remediation activities** have been or will be implemented as follows:

	Sample Collection Date	Sample ID	School Name Building Name	Fixture Information	Lead Test Result (ppb)	Remediation Activity	Date Implemented
1)	12/8/2025	413220	College Place MS	Sink Fixture	17	Additional repairs, conditioning, and retesting	Jan/Feb 2026
2)	12/8/2025	413227	College Place MS	Water Fountain	17	Additional repairs, conditioning, and retesting	Jan/Feb 2026
3)	12/8/2025	413221	College Place MS	Sink Fixture	10	Additional repairs, conditioning, and retesting	Jan/Feb 2026
4)	12/8/2025	413219	College Place MS	Sink Fixture	6	Posted "Hand Wash Only" Signage	Jan/Feb 2026

Initial Results

College Place MS has identified 12 drinking water outlets with elevated lead levels requiring remediation. (Outlets listed in the previous table with **temporary** mitigation measures are repeated in the table below.) **Remediation activities** have been or will be implemented as follows:

	Sample Collection Date	Sample ID	School Name Building Name	Fixture Information	Lead Test Result (ppb)	Remediation Activity	Planned or Completed Implementation Date
1)	10/2/2025	412125	College Place MS	Sink Fixture	23	Posted “Hand Wash Only” Signage	Nov 2025
2)	10/2/2025	412117	College Place MS	Sink Fixture	22	Posted “Hand Wash Only” Signage	Nov 2025
3)	10/2/2025	412094	College Place MS	Sink Fixture	18	Install water filter	Nov 2025
4)	10/2/2025	412107	College Place MS	Water Fountain	18	Install water filter	Nov 2025
5)	10/2/2025	412115	College Place MS	Sink Fixture	16	Install water filter	Nov 2025
6)	10/2/2025	412127	College Place MS	Sink Fixture	15	Install water filter	Nov 2025
7)	10/2/2025	412093	College Place MS	Sink Fixture	12	Install water filter	Nov 2025
8)	10/2/2025	412108	College Place MS	Sink Fixture	12	Install water filter	Nov 2025
9)	10/2/2025	412112	College Place MS	Sink Fixture	12	Posted “Hand Wash Only” Signage	Nov 2025
10)	10/2/2025	412106	College Place MS	Sink Fixture	11	Install water filter	Nov 2025
11)	10/2/2025	412116	College Place MS	Water Fountain	11	Install water filter	Nov 2025
12)	10/2/2025	412111	College Place MS	Sink Fixture	10	Install water filter	Nov 2025
13)	10/2/2025	412097	College Place MS	Sink Fixture	9	Posted “Hand Wash Only” Signage	Nov 2025

14)	10/2/2025	412110	College Place MS	Water Fountain	9	Exterior fountain, water shut off for cold weather	Nov 2025
15)	10/2/2025	412126	College Place MS	Sink Fixture	9	Install water filter	Nov 2025
16)	10/2/2025	412098	College Place MS	Sink Fixture	8	Posted "Hand Wash Only" Signage	Nov 2025
17)	10/2/2025	412090	College Place MS	Sink Fixture	7	Install water filter	Nov 2025
18)	10/2/2025	412113	College Place MS	Water Fountain	7	Fixture turned off or removed	Nov 2025
19)	10/2/2025	412121	College Place MS	Water Fountain	7	Install water filter	Nov 2025
20)	10/2/2025	412092	College Place MS	Sink Fixture	6	Install water filter	Nov 2025
21)	10/2/2025	412103	College Place MS	Water Fountain	6	Install water filter	Nov 2025

Post-Remediation Testing

School Name	Planned Post-Remediation Testing
College Place MS	12 outlets were sampled and retested by: Washington State Dept of Health On Dec 8, 2026
College Place MS	6 outlets will be sampled and retested by: Washington State Dept of Health Sampling is scheduled for: Feb 19, 2026