April 10, 2026

To: All Bidders

From: Sandra Lovaas, Measure C Bond Manager
Pleasant Valley School District

Subject: **Bid FB-26-13, Landscape Improvements, Play Field Renovation, University Preparatory Charter School at CSUCI, 1099 Bedford Dr., Camarillo, 93010**

This addendum is hereby made a part of the Contract Documents for **Bid FB-26-13, Landscape Improvements, Play Field Renovation, University Preparatory Charter School at CSUCI, 1099 Bedford Dr., Camarillo, 93010,** to the same extent as though it was originally included therein and takes precedence over the original documents.

Receipt of this addendum should be acknowledged on the Bid Form.

1. This addendum answers the following submitted contractor RFI
   RFI 1: Refer to keynote N on sheet L2.3, please confirm existing remote control valve per note N shall be removed only and not replaced with new remote control valve, since plan L2.1 show symbol of new remote control valve at that location.
   Remote control valves identified with Keynote N shall have the old valve removed, line capped, wires within valve box for future use. No new remote control valve is needed on these locations.